

CO₂ Capture Facility at Kårstø, Norway Front-End Engineering and Design (FEED) Study Report

320-CCC FEED Study



Submitted by

Bechtel Overseas Corporation



13 January 2009, Revision 1 Redacted for Distribution as per Gassnova Instructions 3 April 2019 25474-000-30R-G04G-00001 10112936-PB-G-DOC-0005

© 2009 Bechtel Power Corporation. All rights reserved. Bechtel Confidential. Contains information that is confidential and proprietary to Bechtel **Content** and may not be used, reproduced, or disclosed in any format without Bechtel's prior written permission. This document is prepared exclusively for Gassnova in connection with FEED for the CO₂ Capture Facility at Kårstø, Norway and is not to be relied upon by others or used in connection with any other project.

Contents

Contents ____

1.0 Executive Summary

2.0 Study Approach

- 2.1 Project Team Organization
- 2.2 Work Process and Tools
- 2.3 HSE Philosophy
- 2.4 Occupational Health Approach
- 2.5 Risk Management

3.0 Tie-In to Existing CCPP

- 3.1 Existing Stack Demolition and/or Modification
- 3.2 Alternate Stack Study (If required)
- 3.3 Emissions Dispersion for Modified/New CCPP Stack
- 3.4 Flue Gas Ductwork to CCC Plant
- 3.5 Conclusions and Recommendations

4.0 Flue Gas Cooling

- 4.1 Cooling Alternatives
- 4.2 Cooling Equipment Selection and Layout
- 4.3 Cooling Performance
- 4.4 Conclusions and Recommendations
- 5.0 CCC Plant Process Design
 - 5.1 Design Basis
 - 5.2 Process Overview
 - 5.3 Process and Equipment Alternatives
 - 5.4 HSE Considerations for Design
 - 5.5 Hazards and Safety Analysis
 - 5.6 Equipment Selections
 - 5.7 Plant Layout
 - 5.8 Process Performance and Optimization
 - 5.9 Process Cooling
 - 5.10 Steam, Water, and Chemical Requirements
 - 5.11 Exhaust, Emissions, and Waste
 - 5.12 Conclusions and Recommendations

6.0 CO₂ Drying and Compression

- 6.1 Drying
- 6.2 Compressor and Cooling
- 6.3 Compressor Driver
- 6.4 Drying and Compression Performance
- 6.5 Liquids Storage and Handling
- 6.6 Waste Discharges
- 6.7 Conclusions and Recommendations

7.0 Mechanical Utility Systems

- 7.1 Utilities—Consumptions and Equipment Handling
- 7.2 Steam and Condensate
- 7.3 Cooling
- 7.4 Potable Water
- 7.5 Fire Protection Systems
- 7.6 Fuel Gas
- 7.7 Compressed Air
- 7.8 Inerting Gases
- 7.9 Desalination
- 7.10 Waste Collection and Drains
- 7.11 Wastewater Treatment
- 7.12 Piping and Insulation
- 7.13 External Utility and Piping Interfaces

8.0 CCC Plant Electrical Distribution System

- 8.1 General
- 8.2 Switchgear
- 8.3 Transformers
- 8.4 Power Factor Correction
- 8.5 Electrical Loads Summary
- 8.6 System Studies
- 8.7 Emergency and UPS Power
- 8.8 Hazardous Areas Classification
- 8.9 Cable and Raceway
- 8.10 Earthing and Lightning Protection
- 8.11 Lighting
- 8.12 External Electrical Interfaces

9.0 Automation Systems

- 9.1 Overall Control Systems Architecture
- 9.2 Controls Philosophy and Approach (Human Factors)
- 9.3 Plant Communication Systems
- 9.4 Safety and Shutdown Analysis and Provisions
- 9.5 Safety and Automation System
- 9.6 Gas and Emissions Monitoring and Metering
- 9.7 Startup and Shutdown Considerations
- 9.8 Primary Control System and Equipment
- 9.9 Central Control Room Layout
- 9.10 Local Equipment/Instrument Room Layouts
- 9.11 Packaged Equipment Controls Interface
- 9.12 Field Instruments and Devices
- 9.13 External Controls Systems Interfaces

10.0 Civil, Structural, and Architectural Features

- 10.1 Civil/ Structural Design Criteria
- 10.2 Foundations and Geotechnical Features
- 10.3 Underground Utilities Considerations
- 10.4 Structural Materials Selections
- 10.5 Buildings and Enclosures Design Criteria
- 10.6 Building and Enclosure Layouts

- 10.7 Building Architectural Features
- 10.8 Building HVAC, Utilities, and Services
- 10.9 Access, Paving, and Landscaping
- 10.10 Painting and Coating Requirements

11.0 Overall Facility Performance

- 11.1 CCC Plant Reliability/Availability/Maintainability Analysis
- 11.2 Emissions
- 11.3 Noise
- 11.4 Guarantees on Key Parameters

12.0 Materials Technology

- 12.1 Corrosion Evaluations
- 12.2 Durability Report

13.0 Occupational Health and Safety

- 13.1 Occupational Health Assessment
- 13.2 Fire and Explosion Strategy
- 13.3 Escape, Evacuation, and Rescue Strategy
- 13.4 Observations and Recommendations

14.0 Operations and Maintenance

- 14.1 Operations Philosophy
- 14.2 Operations Training and Staffing
- 14.3 Operations Particular Requirements
- 14.4 Maintenance Philosophy
- 14.5 Maintenance Training and Staffing
- 14.6 Maintenance Program Overview
- 14.7 Spare Parts
- 14.8 Consumables

15.0 Cost Estimate

- 15.1 CAPEX Estimate
- 15.2 OPEX Estimate
- 15.3 Input to CO₂ Capture Cost Estimate

16.0 Construction, Commissioning, and Execution

- 16.1 Construction Approach and Overview
- 16.2 Constructability Reviews
- 16.3 Commissioning Approach
- 16.4 Schedule Overview (Level II with Storyboard)
- 16.5 Schedule Assumptions and Risks
- 16.6 owner Milestones (Required by Schedule)

17.0 Optional Functionalities

- 18.0 References
 - 18.1 Attached Documents
 - 18.2 Supplementary Lists

1.0-Executive Summary

1.0 Executive Summary_____

1.1 General Description_____

This report includes work performed by Bechtel Overseas Corporation in executing the front-end engineering and design (FEED) study for the Kårstø CO₂ Carbon Capture and Compression (CCC) Plant Project in Norway. Work was performed per the conditions of the contract number 10112936-FI-B-CON-0014.

The FEED study includes the design of the CCC Plant and \pm 20% Capital and Operating cost estimates.

1.2 Base Case _____

The base case comprised an open-art MEA design arrangement with split flow. The performance and cost data for this approach is summarized below.

	Base Case: Open-art MEA with split flow
Capture rate	85.3%
LP steam	198.4
required	
(tons/hr)	
Electricity	32MW
requirements	
(MW/hr)	
Capital Cost	NOK 2.24billion
(excluding	
contingency)	
Operating	NOK 388million
cost (yearly	
avg)	
NPV of cost	199NOK/t
per tonne of	
CO2 Capture	

1.3 Risk___

Project Risks were evaluated as part of the FEED study and summarized in the Risk Management document. All aspects of project risk including technical, operations, schedule, environmental, construction and financial were considered. The top 10 risks are outlined below.

		Description of Risk	Risk	
ID	Risk	and Impact	score	Mitigation Measure
CC3	Hours of operation of Power Plant	If CCPP plant runs for less than 8000 hours it will have major impact on CO2 capture cost	16	Consider range when evaluating CO2 capture cost. Consider Monte- Carlo simulation
OP4	Energy Costs	Electricity is the largest operating costs element and cost may change significantly over the 25 year life.	12	Consider range when evaluating CO2 capture costs as part of investment decision. Consider long term agreement with Naturkraft
SC10	Environmental permit delays	Environmental agencies appear to be unsure of acceptable emissions limits to atmosphere. There is a risk that they may impose extra conditions that delay approval	12	Coordinate with Gassnova and environmental agencies prior to EPC to ensure that appropriate contingency is included in the EPC schedule.
CO2	Other major construction activity at the Kårstø site	There is a risk that other major construction activity will be undertaken at the Kårstø site at the same time as the CO2 project. This will impact the use of the module jetty, labor availability and nearby fabrication facility availability	12	Work with Gassnova to determine risk and then develop mitigation plan options (including early agreements with fabrication shops for shop access)
SC1	Long lead items	Lead time for compressor and columns could impact overall EPC schedule	12	Design prior to NTP. Early procurement negotiation with vendors
NT2	Scale-up issue with liquid distribution in columns	Concerns with liquid distribution	12	Use of circular columns. Vendor performed engineering of distributors during FEED study. Further studies should be undertaken in EPC for final design.

		Description of Risk	Risk	
ID	Risk	and Impact	score	Mitigation Measure
PE8	Licensing process	The schedule for the licensing process for a relatively new technology has to be clarified. This applies to the CCC plant and possibly also to the pipeline and storage scope	12	We believe Gassnova is already addressing this issue with the appropriate authorities.
PR1	Delay in supplying forgings for compressor	Large demand for forgings in current market. Forging work is often subcontracted out by compressor vendors. Delay in supply would have major impact on project schedule	12	Detailed investigation of forging capability/availability. Address risk in project schedule.
PR9	World wide economic issues	Risk of supplier or sub-supplier bankruptcy	12	Check supplier's financials prior to award per standard procedures. Require sub-supplier list with bids per procedures. Assign equipment title to Gassnova.
CT12	Inexperience of CCC plant operators	Concern that there is limited availability of operators with CCC or equivalent experience. Could impact to schedule, cost and safety	12	Provide plant operator training, simulators and experienced shift operators. Investigate the availability of the Statoil Hydro training facility. Process Engineering consultants on site for first 18 months of commercial operation.

1.4 Open Issues _____

The following is a brief description of the open issues at the time of issue of the FEED report



1.4.2 Least Cost Versus Hours Run per Year_

The operating costs and Cost of Carbon Capture calculation have been based on the assumption of maximum operation of the Naturkraft combined cycle power plant (CCPP) as outlined in the contract documents. Based on data from the last year, it appears unlikely that the CCPP will operate at these maximum conditions. Any significant reduction in power plant operation will have a significant impact on the financial model. We believe that it would be prudent to run other operating cost and Cost of carbon capture calculations to reflect various scenarios of CCPP operation.

1.4.3 Option to Use Existing Cooling Water Intake at Kårstø_____

The cooling water demand of for the power plant will be reduced during operation of the CCC Plant (less condenser duty at STG). We believe the option to use some of this 'saved' cooling water for the CCC Plant should be evaluated.

1.5 Conclusions _____

The conclusions for the Engineering, Procurement and Construction scope of the project are outlined below together with a summary of the financial conclusions and an overall conclusion of the findings of the FEED study

1.5.1 Engineering Conclusions_

- For the Kårstø case of relatively low concentrations of CO2 in the flue gas stream, the use of relatively high flue gas temperatures in the absorber is economical.
- Use of MEA @ 35% to 40% concentration is viable with use of 100% stainless steel materials of construction.
- The use of two absorbers of known industry size and geometry reduces the risk of poor flow distribution in the columns
- Use of stainless steel materials for the amine circuit allows greater flexibility in future use and solvent selection.

- There are several additional design options (optional functionalities) that could reduce project risk and save capital and operating costs. These are described in section 17 of the report.
- Successful initial operations will require significant intellectual investment.

1.5.2 Procurement Conclusions

- Use of two absorbers of maximum 12m diameter allows for maximum pre-assembly in the fabrication shops and also allows for shipping in one piece.
- Significant cost savings can be realized through competitive purchase in the world wide market, especially when maintaining flexibility in suppliers to optimize exchange rate fluctuations.
- Release of engineering prior to financial close can reduce the schedule risk by allowing immediate issue of request for bids for long lead items

1.5.3 Construction Conclusion

• Adjusting the schedule to allow modularization in low cost centers can save large amounts of labor costs with the added benefit of significantly reducing the amount of site labor.

1.5.4 Financial

- Price of electricity will, as expected, have the major impact on operating costs and costs of carbon capture. It appears that the price of electricity used in the contract model included allowances for transmission costs. If this is the case, we recommend that they be excluded from the pricing used to calculate operating costs.
- Any reduction in operating hours for the Naturkraft plant will skew economic model towards less capital cost intensive options

1.5.5 Overall FEED Study Conclusions _____

The generic open-art MEA design utilizing 2 absorbers and stainless steel materials for the amine system, appear to be a viable solution for the Kårstø Project at this time for the following main reasons:

- The environmental cleanup targets and the production capacity have been achieved with the proposed design.
- MEA appears to be efficient at removing low concentrations of CO2 in high temperature absorbers

- The use of two absorbers of 12m or less in diameter maximizes offsite fabrication and significantly reduces risks associated with poor flow distribution.
- Use of stainless steel materials for the amine system minimize the need for inhibitors and provides increased flexibility for use of new amines or other solvents as they are developed over the life of the project.



1.6 3D Model Aerial Views and Videos .

Attached are the following 3D renderings:

- Aerial from the Northeast
- Aerial from the North
- Aerial from the South
- Plant Layout Aerial View
- Plant Overhead View
- CCPP HRSG Stack Tie-in Design

Included on the compact disk (CD) enclosed with the Study Report are two video files providing a means of viewing the 3D CAD model using commercially available software:

- The AVI file plays like a movie in Microsoft Windows Media Player or other commercially available player software.
- The Navisworks NWD file uses Autodesk Navisworks Freedom software available as freeware from http://usa.autodesk.com/adsk/servlet/mform?siteID=123112&id=11091608. The Navisworks file permits the user to navigate the file.



Karsto Carbon Capture and Compression (CCC) Plant 3D Rendering Viewed from the Northeast









Copyright Bechtel Corporation 2008. All Rights Reserved.





O Copyright Bechtel Corporation 2008. All Rights Reserved.

Karsto CCC Plant Arrangement Aerial View - from the South



CONFIDENTIAL

CCC TEED STUDY Appendix 2.31

Karsto CCC Plant by Bechtel Plant Layout Aerial View



Karsto CCC Plant by Bechtel Plant Overhead View



© Copyright Bechtel Corporation 2008. All Rights Reserved.

-2

by Bechtel CCPP HRSG Stack Tie-m Design ale I 11 1 © Copyright Bechtel Corporation 2008. All Rights Reserved.

10

HHHH



2.0-Study Approach

2.0 Study Approach

Bechtel's project execution approach is based on a philosophy that has demonstrated repeated success. This philosophy includes the following concepts:

- Never compromise on safety goals and quality
- Stay aligned with the Owner's and other project stakeholders' goals
- Use a cost-effective standard approach
- Modify the project approach to suit customer- and project-specific conditions
- Always maintain control of areas affecting schedule and performance targets
- Use designs that support customer objectives

These concepts form the foundation of Bechtel's project approach, which reflects how we accomplish our work. We focus on a seamless approach to executing the work that minimizes the interface complexity between each function in our work process. To help streamline and control execution, we perform more of the detailed work than other engineering, procurement, and construction (EPC) contractors. We find that by performing the work ourselves, we control the outcome with greater certainty. This improved certainty is achieved by optimizing our work process by individual function and then integrating functions into a coherent overall plan.

The key features of our execution approach are as follows:

- **Project Management** is carried out using a dedicated project team organization. All of the functions necessary to execute a project (Engineering, Procurement, Construction, Project Controls, and Startup) assign individuals to the project team on a full-time basis. This team sits together in our Frederick, Maryland, office and is typically located near other projects using similar technologies. Key members of the execution team are strategically assigned to the project during the development phase to facilitate a seamless transition from development to execution. Details of how our project team is structured are provided later in this section.
- **Engineering** is performed at our Center of Excellence for Power in Frederick and can be supported by our New Delhi, India, office. In Frederick, we control the critical aspects of plant performance guarantees by executing all performance cycle and critical design selection activities under the auspices of our senior specialists. In New Delhi, part of the production engineering for foundations,

structural steel, piping, electrical, and control systems designs can be carried out.

- **Procurement** is managed from our Frederick office. We source all major equipment and critical materials from proven suppliers. Our global buying power enables us to secure better pricing, terms, deliveries, and support than can be secured by most other EPC contractors. Noncritical materials are sourced from low-cost, qualified suppliers, provided they meet the project's specification requirements.
- Contract Administration, consisting of prime contract and subcontract services, is performed by our Contracts department. Major subcontract packages are formed in the home office and transferred to the subcontract administrator at the site during the execution of the work. Contracts works closely with Engineering and Construction to assign the subcontracted work in accordance with the Project Execution Plan. Subcontractors are sourced and prequalified based on our global experience and resources and to leverage customer experience as well. However, we strive to maximize local content by using local subcontractors with the appropriate capabilities.
- **Construction** and overall site management execution are Bechtel's responsibility. Bechtel's cornerstone is the ability to execute challenging projects safely, on time, and within budget, with exceptional quality. The key to this ability is a dedicated, integrated project team supporting the construction and startup efforts.

Bechtel's Construction organization consists of a senior site management team supported by qualified, experienced field engineering; craft supervision; subcontract management; cost and scheduling; procurement; security; and environmental, safety & health organizations.

Bechtel's approach to our work is to have an experienced staff that provides overall management and direction to the direct-hire craft and specialty subcontractor construction workforce. Bechtel provides detailed work scopes, specifications, and drawings for all onsite subcontractors. Bechtel also provides quality assurance, technical support/oversight, and overall schedule management for all site work.

• **Project Controls** incorporates proven and effective project cost and schedule management systems and procedures for each project phase. The project controls model developed by Bechtel features tools designed to promote schedule-driven execution without compromising safety or quality.

• **Startup and Training** are performed directly by experienced Bechtel personnel using proven practices and tools. We integrate the Startup organization into the project early and incorporate its critical input into the design and schedule. A team of technical experts from our Center of Excellence provides oversight and support.

2.1 Project Team Organization _____

Bechtel assigns a dedicated team to execute projects. The team is led by a project director (PD)/project manager (PM), who provides operational oversight. The PD/PM also provides continuity and technical expertise between other Bechtel fossil-fueled projects and the specific project and liaises with senior management.

The PD/PM manages the day-to-day details of project execution and interfaces with the Owner. The dedicated project team reports to the PD/PM for all matters associated with the project and for day-to-day direction. Functional departments provide technical and quality oversight of the work being performed by the team, as well as staffing and personnel support. Members of the project team are located in a common area to facilitate cross-discipline coordination and design optimization.

To manage the effort, responsibilities are broken down as follows:

- Project engineering manager (PEM)/project engineer (PE) for design engineering
- Project procurement manager (PPM) for procurement of equipment and materials
- Project controls manager (PCM) for planning, scheduling, and cost support
- Site manager (SM) for all field activities
- Project startup manager (PSUM) for startup and commissioning of the new plant
- Project Quality Assurance manager (PQAM) for independent oversight of quality processes and procedures

This project management team interfaces regularly during project execution to:

- Establish short-term project goals/objectives
- Establish overall project priorities
- Coordinate design and constructability

- Address resource needs and organizational modifications
- Resolve critical project issues as required
- Address off-project coordination issues
- Optimize project communications

As project conditions dictate, the project team is augmented by additional Bechtel personnel or expertise provided by the functional departments.

We have used this team approach to successfully complete large, complex projects. Team members are selected based on their relevant experience and skills, including not only technical skills, but also administrative and leadership capabilities. The team approach also provides high visibility to both the Owner and Bechtel senior management. A project with full EPC scope includes the following team members.

Project Director/Project Manager—The PD/PM has the primary responsibility of delivering the project in accordance with the contract. In doing so, the PD/PM provides overall coordination of the various Bechtel entities involved in the project. This individual is the principal contact with the Owner for daily detailed interfaces. The PD/PM has a significant leadership role in addition to responsibility for delivering the project "as-sold." The PD/PM manages the relationships among the functional department managers, the engineering chiefs, and other contributing organizations.

Initially, this individual spends a significant amount of time in the Frederick office, where the design and procurement efforts take place. A critical responsibility is to manage the scope, schedule, and interface coordination among Engineering, Procurement, Construction, Startup, and Project Controls. The PD/PM also coordinates with the Owner in areas such as scope, technical content, project progress, quality, schedule, preoperational testing, and startup. As part of this activity, the PD/PM reviews and approves bid evaluations and major contracts and purchase orders. He/she continually works to facilitate positive relationships among the team members and with the Owner.

As the center of activities shifts to the construction site, the PD/PM and certain key team members spend an increasing amount of time at the jobsite to more directly coordinate field activities, thereby providing continuity of management direction. Typically, the PD/PM's jobsite effort approaches full time as activities shift from construction to startup. In any event, the PD/PM spends whatever time is required at the jobsite to ensure that Bechtel fulfills its obligations to the Owner.

Site Manager—Working as part of the project management team and reporting to the PD/PM, the SM leads the field construction and startup teams in building a quality facility that conforms to the contract scope of work and meets the design document requirements.

Overall responsibility rests with the SM to keep field construction activities on track and meet schedule requirements while maintaining quality and a Zero Accidents workplace. The SM apprises the PD/PM of any adverse trends and recommends corrective action(s) to eliminate or minimize any quality or schedule impacts. In addition, the SM has overall responsibility for industrial labor relations, workforce training, and community relations. At the start of the project, the SM spends considerable time in the Frederick office working with Engineering, Procurement, and Project Controls to optimize the detailed construction plan.

Project Engineering Manager/Project Engineer—The PEM/PE is responsible for the project's design engineering aspects. As the design team leader, the PEM/PE ensures that design deliverables are accomplished on schedule. In addition, he/she makes certain that the design is in accordance with the engineering scope agreed to with the Owner and conforms to applicable codes and standards, or as otherwise accepted by the Owner. The PEM/PE also focuses on integrating the scopes of work being performed by equipment suppliers with that being executed by Bechtel.

Project Procurement Manager—The PPM and his/her procurement team in Frederick purchase most equipment, materials, and services required for the project. The PPM is responsible for purchasing these items in accordance with the specifications and for managing assigned purchase orders. The PPM's principal function is to ensure that material, equipment, and services meet project quality and schedule requirements.

Project Controls Manager—The PCM is responsible for all scheduling and cost control tools. The PCM's principal function is to prepare and monitor the detailed schedules, estimates, budgets, and trends necessary to control the project. These key project controls tools are developed in the Frederick office and rolled out to members of the project team. These same tools are used by Construction. The PCM is responsible for integrating the project's scheduling and cost tools.

Project Startup Manager—The PSUM is assigned before mobilization and initially works in the Frederick office to assist in developing the detailed intermediate level schedule and establishing the project's startup execution plan. Once relocated to the jobsite, the PSUM is responsible for all equipment and system testing and checkout to ensure efficient and successful facility operation. The PSUM acts as the jobsite single point of contact with the Owner's operations personnel for the operations support required during startup and commissioning. He/she coordinates any required system outages and safety lockout and tagout activities. The PSUM also plans and manages all aspects of tie-ins and/or outages during the project's startup and commissioning phases. The PSUM reports to the SM and receives technical direction from the manager of Startup and Operating Services in Frederick.

Project Quality Assurance Manager—A PQAM is assigned as the coordinator/focal point for QA issues. The PQAM interfaces internally with project management and externally with the Owner on quality issues, and helps in their resolution.

At the outset of a project, the PQAM prepares a project-specific project quality plan (PQP) customized to meet contract requirements. The PQP is supported by the Bechtel Quality Management System and identifies the applicable procedures, instructions, and manuals to be implemented. The PQAM oversees, assesses, and reports the effectiveness of PQP implementation through internal and external quality audit/surveillance and reviews. Furthermore, the PQAM monitors project performance via reviews of quality-related reports, such as supplier surveillance inspection reports, project deficiencies reports, and site audit reports.

The one exception to the integrated EPC approach is the PQAM, who coordinates with the PD/PM but reports directly to Bechtel's manager of Quality Services. This arrangement ensures independent oversight of all matters pertaining to quality processes and procedures.

2.2 Work Process and Tools _____

2.2.1 Engineering ____

The approach outlined in this section forms the foundation that Bechtel uses to manage our engineering efforts on projects and studies. As project development progresses, we work with our customers to adjust this approach to address the project's specific requirements.

Design processes define the methods that Bechtel Engineering uses to prepare, review, approve, and control drawings and system descriptions. Our key processes are discussed in the following paragraphs.

iCOMET®—Bechtel uses iCOMET, our proprietary conceptual modeling and estimating tool, during the scope development and optimization

phase. With iCOMET as the base, Bechtel transitions to 3D computeraided drafting and design (CADD) as the controlling tool for the detailed design and construction phases to effectively coordinate among engineering disciplines, the construction team, clients, and equipment suppliers. This tool also significantly improves the engineering schedule and provides a superior design.

3D CADD—Exclusive use of 3D CADD to capture engineering data electronically has been Bechtel's standard practice for over a decade. Examples of tasks performed using 3D CADD include:

- Identify and resolve interference issues
- Develop accurate material takeoffs
- Provide composites for the project and the Owner
- Control construction materials and quantities
- Provide the client with a clear understanding of design concepts and perspectives
- Confirm dimensions to eliminate errors or rework
- Determine resource loading requirements for schedule input
- Permit designers and owners to view allocated maintenance access ways
- Allow Construction to plan construction activities

Bechtel's modeling work process uses the 3D model, an intelligent database viewed using Microstation. The 3D model is also integrated into our procurement work process, project controls activities, and the tools used by Construction. The model contains most Bechtel-designed commodities, as well as vendor-supplied packages for both aboveground and underground components. The vendor-supplied packages are included in the model to streamline construction and to identify/resolve any physical problems between suppliers before construction. A Microstation CADD terminal can be provided at any location for viewing the model during project execution.

Drawing Holds—When details of a pending drawing or system description change have not been finalized, but the document must be issued for other purposes, the area of the drawing not finalized is clearly identified as HOLD.

Checking—Drawings and calculations are independently checked by an individual qualified to have originated the drawing or system description; sketches and preliminary design drawings issued off project may be excluded from checking. The checker follows Bechtel's standard checking practices.

Coordination—Drawings are coordinated within the engineering disciplines using Bechtel standard guidelines.

Reviews and Approvals—Review and/or approval are the responsibility of the chief engineer, engineering group supervisor (EGS), and PE.

Drawing Change Notice—The drawing change notice (DCN) provides a means of documenting changes to design drawings without the immediate need to revise the drawings.

Incorporating Change Documents—Outstanding change documents (DCNs, field change requests [FCRs], field change notices [FCNs]) must be incorporated into associated drawings, by drawing revision

Register—Issued revisions of drawings (including sketches), DCNs, and system descriptions are recorded in $InfoWorks^{TM}$, Bechtel's proprietary document controls system maintained by Project Administration.

Design Document Submittals—As engineering designs are developed, Bechtel submits to the Owner those design drawings identified in the contract as requiring Owner's review or approval.

ProjectWorks®—Bechtel has developed *ProjectWorks*, a comprehensive suite of proprietary engineering and equipment management tools, to track characteristic quantities, deliverables, and status over the life of a project. *ProjectWorks* encompasses more than 30 automation tools, or Bechtel Standard Application Programs, that can be used selectively to support the execution of fixed price projects. The objectives of *ProjectWorks* are to reduce the total installed cost (TIC), shorten project schedules, and support globalization by establishing electronic data linkages and integration among offices, jobsites, customers, vendors, and suppliers at different geographic locations. Engineering uses the following *ProjectWorks* components:

- PDS-IPID This module of Intergraph's Plant Design System (PDS)
 2D suite of intelligent schematic tools enables rule-driven P&ID drafting using a consistent symbology set and allows data to be extracted from the P&IDs to facilitate downstream design activities such as construction planning, materials management, equipment list management, and piping design.
- iCOMET®—Bechtel's proprietary suite of software tools is designed for the rapid creation of conceptual, intelligent 3D models for the submittal estimate and the early stages of project execution.
- 3D CADD Model (3DM[™]) This is Bechtel's three-dimensional computer modeling system developed for use on engineering and construction projects. The system allows the individual discipline
designers and engineers to easily create 3D computer models in support of their design activities.

- *PipeWorks*TM—This is Bechtel's engineering and procurement application, which is designed to manage bulk quantities out of the 3D modeling system.
- SETROUTE®—This is Bechtel's electrical cable, raceway, equipment, and wiring database tracking and installation system.
- INSPEC[™] This Bechtel engineering database and application develops and maintains the project instrument index and I/O list, and works with the intelligent P&ID (IPID) and 3DM databases.
- *TEAMWorks*[™]—This is Bechtel's construction application for tracking mechanical and electrical equipment, piping lines, spooled pipe, bulk pipe, field welds, instruments, valves, receiving information, and installation status dates
- DataBroker[™]—This Bechtel engineering application is designed to manage the electronic data exchanges among the different *ProjectWorks* applications.

Other Engineering Tools—These include:

- CAESAR II pipe stress analysis
- ETAP short-circuit, load flow, voltage drop, motor starting, cable ampacity derating in duct bank, and cable pulling
- Multiground+ ground grid design calculation
- FAPPS structural beam analysis calculations for pipe supports
- InRoads civil engineering site and highway design
- Founds foundation design

2.2.2 Procurement

The automated and integrated processes of Bechtel's industry-leading Bechtel Procurement System (BPS) allow us to manage equipment and materials on a real-time basis throughout all project phases, from design to operation.

The PPM dedicated to the project team plans, organizes, staffs, and manages procurement activities. The PPM develops a procurement plan for purchasing equipment and engineered bulk materials. The procurement plan is consistent with the overall project milestone summary schedule (MSS).

Bechtel prepares a material assignment schedule (MAS) for every project. The MAS identifies permanent plant equipment, materials, and services and captures the overall procurement plan, including items subject to shop surveillance and shop expediting per the supplier quality surveillance plan.

Bechtel prepares a supplier quality surveillance plan, designating the equipment and the specific surveillance inspection points we intend to make. Customer-specific quality, inspection, and shop testing requirements are considered and incorporated during plan development.

2.2.3 Construction __

Bechtel plans, organizes, and controls all aspects of the construction process and provides all labor, supplies, materials, equipment, tools, and transportation required to perform the work.

Bechtel assigns the SM, project field engineer (PFE), and construction coordinator (CC) at the very outset of the project and may also assign the project field superintendent (PFS) and a PSUM at this time. These individuals are assigned at this early stage to make sure that the complex factors involved in building and testing the facility are taken into account during the project's design and procurement phases. During the several months these team members spend in the office before site mobilization, they:

- Make sure that construction input is integrated into schedules across all functions
- Review the commodity design for constructability and ease of procurement
- Help decide what part of the work is provided to specialty subcontractors
- Plan for the appropriate start of temporary facilities leading to site mobilization

The pre-mobilization period also finds the construction team making decisions on approaches for site access, equipment delivery, traffic and logisitics (T&L), equipment modularization site storage, and similar construction needs. For example, early in the project, opportunities to modularize selected components are evaluated in terms of benefits that could be realized by maximizing offsite shop fabrication/preassembly. Modularizing certain components off site can:

- Decrease onsite craft population
- Reduce time spent in potentially hazardous work situations because less time is required in elevated work locations and congested areas

- Improve schedule performance
- Potentially reduce site cost for support services due to reduced need for cranes and other indirect activities
- Provide greater ability to maintain work product quality

Labor is by far the single largest risk in executing a major project. It is the largest element of project cost and is subject to the most variability. Therefore, Bechtel establishes project labor and industrial relationship management programs to effectively manage the labor forces. Our oversight effort includes recruiting and training the craft worker population while maintaining strong working relationships at all levels of labor leadership.

For each large project, we prepare an Industrial Relations Plan. To begin this process, experienced Bechtel professionals perform a comprehensive labor assessment by researching the local labor market at the project site and surrounding areas. Once we have established craft availability and the effect of competing projects on the workforce, we are in a position to determine the appropriate steps to take to recruit and retain the needed craft workers in accordance with the project's staffing schedule.

Bechtel staffs large projects with a full-time labor relations professional. Should any labor-related issues affect the project, we immediately notify the customer.

Bechtel typically provides a comprehensive Site Security Plan, as well as a site-specific Construction Environmental Control Plan (CEMP), before project mobilization. Both plans carry through to substantial completion.

The detailed procedures and responsibilities in Bechtel's CEMP constitute a comprehensive program for managing environmental compliance during construction. The CEMP also addresses the process for monitoring jobsite activities during construction to maintain conformance with the contract, applicable permits, and applicable laws. Additional CEMP activities include:

- Development of an environmental compliance matrix
- Emergency response training
- Environmental monitoring

We designate an onsite Bechtel representative to monitor construction and startup activities for conformance to the CEMP, applicable permits, and applicable laws.

2.2.4 Project Controls

Bechtel's Project Controls department is responsible for estimating, scheduling, cost control, and management reporting functions. Our Project Controls organization implements and administers proven and effective estimating, cost, and schedule management systems and procedures for each project phase. The estimating, schedule control, cost control, and management reporting systems and procedures used on the project conform to corporate standards and are specifically tailored for the project's needs.

A project estimator is assigned to the project to direct and coordinate the overall estimating effort. Under the project estimator's direction, the estimating team prepares a cost estimate based on the client's Request for Proposal (RFP), company standards, and current market trends. The group uses Bechtel's in-house-developed estimating tools—Estimating Process Integration and Control (EPIC) and Bechtel Intelligence Database (BID).

EPIC allows work process integration across functional departments such as Engineering, Procurement, and Estimating. EPIC also allows development of detailed estimates with the capability to summarize the capital expenditures (CAPEX) estimate at various levels to facilitate review and comparison. BID captures technical and commercial information from both historical and current projects and contains technical parameters and pricing records of more than 8,000 pieces of equipment.

Schedule control is accomplished via a hierarchical system of schedules built on the specific details required by each level of the organization. These schedules are interrelated; hence, each successive detail level ties into the milestone end dates in the preceding summary level, up to the project milestone summary schedule (MSS)—the highest level. Proceeding from the overview level of the MSS, schedule tools falling within Levels II and III in the hierarchy provide the details needed to effectively control designated activities and allow ample communication and coordination among the project team members.

Bechtel's proprietary cost control system, $ePCWorks^{TM}$, is an in-house, module-based desktop software program developed by Bechtel. This program integrates with other Bechtel applications that support engineering, procurement, construction, and finance and accounting and provides accurate, timely reporting of costs, quantities, and commitments. ePCWorks allows specific modules to be selected, as required, for effective control of project elements.

Reports produced are based on specific project and contractual needs and follow normal business practice. Regular reports include:

- Monthly project progress report
- Monthly client review meetings
- Physical percent-complete curves
- Commodity release and installation curves for concrete, steel, underground large bore pipe, aboveground large bore pipe, small bore pipe, cable, conduit, cable tray, and terminations
- Manpower curves

2.2.5 Startup_

The PSUM is initially assigned to the design office in Frederick to:

- Provide input from a startup and operation and maintenance (O&M) perspective during design
- Develop and issue the Project Startup Manual

Approximately 3 months before energization, the PSUM relocates to the site and assembles the startup team. This team starts up and commissions each system, provides on-the-job training (OJT) to Owner O&M personnel, conducts system-by-system turnovers, conducts performance tests, and brings the project to Commercial Operation.

Bechtel prepares administrative and technical startup procedures compatible with the requirements of the connecting utilities.

Bechtel Startup prepares and submits system turnover packages on a mutually agreed-to schedule. (Note: Some of these systems are turned over as groups of systems or subsystems.)

Bechtel provides OJT and instruction for the customer's O&M personnel, augmented by classroom training provided by the equipment suppliers. The final O&M training program and schedule are mutually developed with the customer.

2.2.6 Contracts

The Contracts department provides subcontract services that meet or exceed project safety, quality, and cost and schedule objectives. These services include preparing and managing construction, service, and engineering subcontracts. The Contracts department provides services through direct on-project staffing and, when necessary, through offproject support. The Contracts department works closely with the customer and Bechtel's Construction, Engineering, Procurement, and Project Controls groups to prepare the subcontracts to be executed for the project. The project contracts administrator (PCA), subcontract formation specialists, and field subcontract administrators use tools and methods designed by the department to provide consistency across the project. They also use the tools of other departments, particularly Project Controls, to monitor project performance against schedule and cost requirements, to identify scope and contract changes, to measure and weigh the consequences of project risk, and to measure the Contracts department's own performance and contribution to the project.

Representative tools include, but are not limited to:

- Subcontract compliance matrix (inclusive of responsibility, notices, requirements, and submittals for the subcontracts, scope book, and permits)
- Subcontract management schedule
- Subcontract management responsibilities
- Permits matrix
- Tax guideline (project specific)
- Subcontract formulation status/tracking report
- Scope change report
- Milestone summary schedule (plus Level II schedules)
- Subcontractor status report (field reporting for home-office- and field-issued subcontracts)
- Backcharge log
- Pro formas for home-office- and field issued subcontracts (long form and short form)

Bechtel conducts job fairs for local business organizations at project outset to promote and coordinate local subcontractor involvement. We also optimize local sourcing for other subcontracts to align with customer expectations and the project's goals.

Bechtel provides opportunities to minority, women-owned, and disadvantaged business enterprise (MBE/WBE/DBE) firms to bid subcontract packages that maximize the use of their respective skills and expertise while increasing their knowledge of engineering, procurement, and construction technology. The subcontractors included in the customer's Diverse Suppliers List are included in the bidders list for the relevant commodities.

2.2.7 Quality Management

Bechtel maintains and implements a robust Quality Management System (QMS) that includes integrated, yet independent, quality assurance (QA)/quality control (QC) functions as part of our standard processes. To maintain a high degree of quality control and thereby minimize rework, we use standard procedures and work processes that incorporate independent checks and off-project reviews. These procedures and work processes are implemented from the beginning of a project through its completion and operation.

2.2.8 Environmental, Safety, and Health ____

Safety and quality are the cornerstones of Bechtel's corporate values. We want our customers and their communities and stakeholders to view us as responsible and responsive in helping to protect the environment, people, and places where we work and live.

The base project document outlining Bechtel's approach to managing safety and health is the Project Environmental, Safety, and Health Plan. This plan addresses the systematic management approach to safety and health in the following areas:

- Project philosophy
- Safety principles
- Ownership
- Duties and responsibilities
- Training
- Contractor's safety plan
- Safety audits/assessments
- Motivation program
- Contractor's Joint Safety Council
- Incident investigations and recording
- Project safe practices

Day-to-day project ES&H management is governed by ES&H procedures. These procedures are developed from existing Bechtel core processes; the requirements of the scope book and EPC contract; the Project Environmental, Safety, and Health Plan; the Project Construction Environmental Control Plan; and applicable regulations and legislation.

2.2.9 Document Control

InfoWorks, Bechtel's proprietary electronic document management system, controls documents in an electronic format throughout their life cycles, beginning with creation or receipt, through distribution, use, maintenance, and final disposition. *InfoWorks* provides complete document management of project documents from a common repository, streamlining and automating the document handling and management process on projects.

Third-party commercial software vendors supply the basic programs, and Bechtel provides configuration and customizations. *InfoWorks* provides a central repository for all project records; no matter where project execution takes place, these records can then be transferred to a customer at facility turnover. All documents, whether generated by the project team or by vendors, are retained in *InfoWorks*, which offers indexing and searching capabilities for faster retrieval of information by designers, constructors, and operations personnel, thus reducing the cost of the facility.

The *InfoWorks* system supports the following project work processes:

- Data control with the capability to reproduce issued deliverables
- Functionality unique to project automated applications
- Information to start a new project based on historical project data
- Consistent user interface across all developed applications
- Interface with third-party software

Bechtel's globalization initiatives have established a corporate capability to leverage and share information and perform multiproject work simultaneously in multiple project execution locations. This capability exists across all global business units (GBUs) in all regions through the standardization of our numbering system for components, commodities, documents, and plant systems.

Corporate standard numbering system procedures define the numbering structure and codes incorporated into Bechtel's computer applications (e.g., *InfoWorks*) for use in project-, department-, and corporate-related work activities.

2.2.10 Information Systems and Technology _____

Information Systems and Technology (IS&T) is Bechtel's strategic technology resource and is actively engaged in all phases of EPC projects, providing systems, technology, and business advocacy that enable the work Bechtel does.

The Power GBU IS&T structure includes a dedicated project IS&T manager (ITM), who is assigned to the project and functions as an integral part of the project leadership team. The ITM develops the necessary Automation Plan in concert with all stakeholders in the Bechtel and client organizations to deliver the optimum level of project automation.

Bechtel Standard Application Programs (BSAPs) support Bechtel's EPC work processes. The BSAPs are considered "best in class" for the EPC industry and are used successfully on hundreds of Bechtel projects across various business lines spanning multiple geographical sites and locations. The BSAPs consist of commercial and/or Bechtel-developed applications that are fully supported by our staff. The IS&T Enterprise Systems group maintains a full suite of standard applications to support the project's engineering, procurement, construction, and support service groups.

Bechtel has developed and established a detailed data exchange plan (known as a data exchange map) to fully define the required data exchanges among the BSAPs. The primary goals are to deliver the information necessary to execute Bechtel's work activities in the most expedient manner and to minimize duplicate data entry across all functions. An information integration solution called DataBroker[™] is used to exchange and validate data transfers among BSAPs and/or commercial applications.

Bechtel IS&T provides a comprehensive suite of collaboration tools to meet the information sharing and retention needs of our projects and customers around the globe. The following tools are currently in use to facilitate collaboration and promote project success:

- *eRoom*—Allows secure Internet exchange of documents between Bechtel and external parties. It is ideal for project collaboration with clients, suppliers, partners, subcontractors, etc., because it enables collaboration both inside and outside the Bechtel firewall. It is also useful for work groups across Bechtel requiring controlled content collaboration capabilities.
- *LiveMeeting/conference calling*—Enables secure global conference calls and computer desktop sharing with Bechtel global offices and external parties associated with a project.
- *BECTransfer*—Allows secure data file exchange, removing the security vulnerabilities associated with the typical file transfer protocol process used by many organizations.
- *Video conferencing*—Enables Bechtel's dispersed work force to communicate with one another and provides a vehicle for interacting with Bechtel's global client base. IS&T has deployed

video conferencing to all major Bechtel offices, including several project sites. Video conferences involving multiple Bechtel sites, including clients, require the use of a video conferencing bridge that IS&T can help establish.

Bechtel has deployed a highly resilient global network that extends to over 200 offices and project entities across the globe. Major network hubs are located in the US, the UK, and Asia.

A Bechtel 24/7 Global Network Operations Center (NOC), Global Security Operations Center (SOC), and Global Helpdesk (GHD) are in place to maintain our global network and infrastructure in the most cost-effective, secure, and efficient manner. The GHD provides around-the-clock service to resolve support issues related to applications and infrastructure products and services. Infrastructure services of specific interest are:

- Microsoft Windows-based server and domain architecture
- Microsoft Outlook-based e-mail environment
- Global voice over IP (VoIP) and video conferencing services
- eRoom, LiveMeeting, and Sharepoint collaborative environments
- Standardized global wireless network architecture
- Change-management structured process for managing changes to the global computing environment

2.3 HSE Philosophy ____

2.3.1 Introduction_

The objectives of the Kårstø CO₂ Carbon Capture and Compression (CCC) Plant's health, safety, and environmental (HSE) policy are:

- Zero accidents or losses
- Zero harm to people and the environment and no loss in material values from preventable accidents
- Zero work-related illnesses

The overall philosophy adopted for the CCC Plant includes:

- Create a clear HSE commitment, provide professional HSE leadership, and provide for effective coordination in overall project design and execution
- Transfer experience from similar applicable projects

• Create a good working relationship among involved stakeholders participating on the project

All HSE-related design elements apply the concept of achieving levels that are as low as reasonably practicable (ALARP) during the assessment and analysis of risk and mitigation strategies. The HSE principles applied during front-end engineering and design (FEED) span the following general areas and project considerations:

- Occupational health and working environment (WE)
- Plant layout and design
- Fire and explosion (F&E) risk assessment and mitigation
- Escape, evacuation, and rescue planning
- Ignition source controls
- Hazard identification and process hazards analysis (PHA) (inherently safer design)
- Process and emergency shutdown
- Fire and gas (F&G) detection
- Emissions and discharges (land, water/sea, air)

Compliance with project objectives has been detailed in various completed FEED study documents and is summarized in the following subsections.

2.3.2 Occupational Health and Working Environment _____

The overall WE design goal is to address and treat all hazards to maintain risk at a level that is ALARP. This approach avoids occupational injury and ensures compliance with the overall project and CCC Plant operational goal of "zero harm" to workers and members of the public, whether present or external to the site. This approach is detailed further in Subsection 2.4.

2.3.3 Plant Layout and Design _

The best available safety techniques for chemical process plant layout and design (e.g., American Petroleum Institute [API], International Organization for Standardization [ISO], Center for Chemical Process Safety [CCPS], American Institute of Chemical Engineers [AICHE]) were considered. Standard industry practices drove the layout and design development of the plot space. To assess the design in its early stages during FEED, a hazard identification (HAZID) study was completed. Action items related to plot space development and layout were incorporated into the design.

The project team undertook plant layout reviews during FEED, and layout change requirements were incorporated into the design. The overall assessment of plant layout safety for HSE purposes is provided in the Layout Safety Review Report.

2.3.4 Fire and Explosion Risk Assessment and Mitigation _____

An F&E strategy was submitted during FEED. The strategy is based on the guidance provided in ISO 13702. The CCC Plant is categorized into three main sections/areas:

- Flue gas tie-in area (blower and quench section)
- Amine process and storage areas
- CO₂ compression and drying section

The flue gas and CO_2 compression/drying sections do not present any credible fire scenarios, and gaseous releases do not create dimensioning events of an explosive nature resulting in extreme overpressure.

Fire hazards associated with the amine process and storage areas are addressed in the design through the provision of fire water protection systems, detection systems, emergency shutdown (ESD)/plant shutdown (PSD) systems, and layout considerations.

CCC Plant staff are expected to respond to a fire condition by escaping to the temporary muster point for the CCC Plant to await instruction. Firefighting activities are to be coordinated with the main site fire brigade for all fire responses.

2.3.5 Escape, Evacuation, and Rescue Planning and Documentation _

An escape, evacuation, and rescue strategy (EERS) was submitted during FEED, based on NORSOK S-001 and ISO-13702 standards. This EERS defined the main stores area as a temporary muster point (designated as TR), which is reflected on preliminary escape route drawings.

The CCC Plant is an onshore facility. No credible fire, toxic gas, or explosion hazards are present that can escalate to the designated muster area under a single-failure event (e.g., localized spill or leak). The formal evacuation and rescue provisions required for offshore facilities are not required. Emergency response plans are to be provided in the event of personnel injury.

2.3.6 Ignition Source Controls_

Prevention of fire in the CCC Plant is a design absolute. Control of ignition sources through inherently safer design practices is considered in the FEED design.

Under a developing process upset condition, combustible gas release, or fire, central control room (CCR) operators can selectively isolate equipment from service as ignition sources or trigger an emergency shutdown of the unit and call a general escape.

The CCC Plant heating, ventilating, and air-conditioning (HVAC) design criteria consider elevated intake locations to prevent gas aspiration. All HVAC intakes consider the installation of combustible gas detection in the intake ductwork. Appropriate safety and automation system (SAS) interlocks shut down fans on gas detection.

The hazardous area classification is in accordance with the requirements of IP15, 3rd Edition. An atmosphere explosibles (ATEX) assessment was completed, and a preliminary area classification drawing was prepared. The required general outdoor classification of Zone 2, Group IIA, Class T2 has been applied. Below-grade and bunded areas are Zone 1. Electrostatic and natural (i.e., lightning) ignition sources are controlled through bonding and grounding systems considered in the design.

There are no credible hot surface ignition sources since process temperatures are well below the ignition temperatures of the chemicals used in the CCC Plant or outside the battery limits.

2.3.7 Hazard Identification and Process Hazards Analysis (Inherently Safer Design)____

To assess the various design elements during early FEED, a HAZID study was completed. In this study, 41 action items were identified and 22 recommendations were entered for treatment during FEED. All risks treated during FEED were considered for incorporation, some during the engineering, procurement, and construction (EPC) design stage.

A hazard operability (HAZOP) assessment (a PHA) was completed in the latter stages of FEED. During this analysis, 104 action items were identified to address risk and hazards related to fire, explosion, exposure to hazardous airborne materials/liquids/solids, material spills, electrical shock, and exposure to ionizing radiation. All risks treated during FEED were considered for incorporation into the design during the EPC design stage.

2.3.8 Process and Emergency Shutdown_

The CCC Plant CCR is a pivotal element in the overall plant design for HSE risk mitigation. The human-machine interface (HMI) in the CCR design ensures operator situational awareness of process conditions and drives appropriate actions during upset conditions or emergencies.

The distributed control system (DCS)-based PSD system provides functions to shut down the CCC Plant automatically in a safe and controlled manner in the event of abnormal operating conditions that could endanger human safety.

The ESD system can actuate the appropriate PSD sequences, provide ignition source control, and safely depressurize the unit. The ESD functions are manually initiated by the operator, usually as the result of a fire, major spill, combustible gas detection, etc. This system is shown conceptually in the SAS architecture diagram, drawing number 10112936-PB-I-DRW-0001 (25474-000-JD-JD-00001).

2.3.9 Fire and Gas Detection_

The F&G system status and alarms are annunciated at the DCS operator stations. A manual operator response is required for F&G alarms.

The F&G detection system is largely an alarm system but does have some executive actions in compliance with CCC Plant HSE requirements (e.g., HVAC system shutdown). This logic is depicted in applicable cause-and-effect charts for the CCC Plant design.

Audible and visual annunciation (horns/bells and strobe lights/ beacons) are placed with consideration to normal paths of travel and prevention of access and/or egress from an enclosed spaced under a leakage condition or exposure.

2.3.10 Emissions and Discharges _

The primary airborne discharge from the CCC Plant is vapor emissions from the absorber towers.

The primary water discharge from the CCC Plant is warmed seawater from the open heat exchange system employed in the design. The CCC Plant design reduces effluents to land, water, and air to minimize their impact on the environment and workers. The design also provides for recycling of effluents into the process.

Emissions and discharge data forms document the potential effluents from the CCC Plant and consider normal operations, upset conditions, fugitive emissions, process waste, and amine degradation byproducts from amine regeneration. Coordination with the main site waste disposal plans (StatOilHydro WR1839 document) is taken into consideration.

Professional services for waste disposal, chemical and waste storage, emissions abatement, and effluent treatment prior to disposal are considered in the design.

A formal Environmental Impact Assessment (EIA) is required during FEED. The emissions and discharge data forms provide input to this.

2.4 Occupational Health Approach _

2.4.1 Occupational Health Objectives and Overview _____

A fundamental principle of the CCC Plant HSE program documentation states that the operations are to achieve zero harm to people. To achieve this objective, the project and operational occupational health approach allows the following actions to be performed:

- Identify the HSE authority requirements applicable to the CCC Plant design
- Define the standards applicable to the HSE design
- Provide necessary and correct input for HSE-related studies and assessments
- Assist in coordinating HSE activities with all project stakeholders
- Implement the HSE strategies, programs, and regulatory requirements and demonstrate risk mitigation in accordance with the overall project goal of achieving levels that are ALARP.

The family of NORSOK standards commonly employed for offshore project development HSE activities is the key source of design guidance. Per NORSOK S-002, Working Environment, Clause 4.4.2.0-1, the plant WE impact is to be assessed during the project development cycle and through construction, commissioning, and operation.

WE impact and risk assessments are to be developed and updated to optimize the design to eliminate hazards to workers in the plant areas; to provide efficient, safe, and healthy workplaces; and to reduce the need for modifications during operations.

To optimize the project design, it is necessary to consider technological solutions to prevent unacceptable WE risks for planned tasks that are foreseeable and reasonable.

Use of NORSOK standards must not result in contravention of any legislation, regulations, codes, or stakeholder requirements.

The front-end engineering and design (FEED) project development stage adopted the NORSOK S-002 approach to WE assessment and complies with the requirements of jurisdictional laws, regulations, and codes, as well as stakeholder HSE requirements. This includes the preparation of a detailed concept WE impact assessment (cWEIA) and submission of WE area charts (WEACs) for all foreseeable working environments that could expose workers to hazard or injury.

2.4.2 Concept Working Environment Impact Assessment _

During the FEED project development stage, a cWEIA was prepared in accordance with the FEED requirements stipulated in NORSOK S-002, Working Environment, in concert with all requirements from Exhibit E8.1, Section 2.0, HSE Requirements. The following are addressed in the FEED-level assessment:

- Job hazard/risk of occupational injuries
- Ergonomics/prevention of musculoskeletal strains and injuries
- Ergonomics/human factors in work systems
- Hazardous chemicals
- Noise and vibration control
- Illumination
- Outdoor operations cold stress
- Outdoor operations precipitation and shelters
- Outdoor operations flaring
- Constructability

2.4.3 Working Environment Area Charts _

Concurrent with the development of the cWEIA, detailed WEACs have been prepared in accordance with the requirements of NORSOK S-002.

A total of 29 WEACs were developed for the various WE exposures. The charts include appropriate WE area limits (WEALs) and requirements as tabulated in NORSOK S-002, Annex A, as modified by stakeholder requirements. Where required by NORSOK S-002, the WEACs include preliminary predictions of worker exposures in relation to the WEALs.

WEACs are updated through the project development cycle to further evaluate and document the design during detailed engineering and then to validate the design during construction, commissioning, and operation.

Certain requirements depend on occupancy or "manning." Therefore, manning levels are required to be defined on the WEACs. Three manning levels are defined in NORSOK S-002:

•	Permanently Manned:	Are	as manned a	at least	8 hours	per	day at
		least 50% of the time					
	T ('() (1) T ()	T A 7	1	c	1 · 1		

- Intermittently Manned: Work areas for which inspection, maintenance, and other tasks are planned to last at least 2 hours a day during at least 50% of the days
- Normally Unmanned: All other work areas

Functional and working area requirements applicable to the various staffing levels have been considered in the design.

2.5 Risk Management

The project conducts weekly risk management meetings chaired by the PM or assistant PM. All department supervisors and engineering group supervisors or their deputies attend this meeting. The agenda for the meetings is as follows:

- Review newly identified risks
- Review and provide input to the analysis of these risks BEFORE response measures
- Identify the person(s) responsible for completing the Risk Response and Monitoring form for newly identified risks; add name(s) to the Risk Register along with schedule for completing the form
- Update the Risk Register with newly identified risks
- Update the Risk Register with information on previously identified risks, including:

- Review updates to the Risk Response and Monitoring forms for previously identified risks
- Review and provide input to the analysis of the risks AFTER response measures
- Update the Risk Register
- Review status of the Risk Management Document
- Identify which risks need to be included in the monthly report



SECTION 2.6

IS

REDACTED

3.0-Tie-In to Existing CCPP

3.0 Tie-In to Existing CCPP_

3.1 Existing Stack Demolition and/or Modification ____

The existing Naturkraft combined cycle power plant (CCPP) uses a 50-meter-tall, 20-meter-diameter, carbon steel stack to exhaust the combustion turbine flue gas to atmosphere. The flue gas passes through the heat recovery steam generator (HRSG) before exiting the stack through a motor-operated stack damper, which, when closed during plant shutdown, bottles up the HRSG to maintain the HRSG internals hot to allow rapid CCPP restart.

The stack requires modification to accept the new Kårstø CO₂ Carbon Capture and Compression (CCC) Plant flue gas duct connection. The existing stack is used at its current location and height. This maintains the current emissions point location for this source and leaves all upper structures, platforms, and equipment on the stack unchanged. A new exterior structural steel support structure constructed around the stack, with the major portion on the south side of the existing stack, provides lateral bracing of the stack and the new stack breeching (see Figure 3-1). Part of the new support structure is placed on part of the existing HRSG stack foundation, and part is placed on two new foundations placed as part of the modification work.



Figure 3-1. HRSG Stack Modification with Duct Work

The stack is fitted with support shoes at the mid-point level. These shoes are fitted to seats on the support structure to transfer the weight of the upper portion of the stack to the new support structure and relieve the weight from the lower half of the stack. No modification of or connection to the existing HRSG steel stair tower is required.

The stack is modified by cutting an 80-hole pattern in the east face of the stack (see Figure 3-2) exactly like the hole pattern currently being used at the HRSG breeching connection on the west face of the stack. This modification is achieved during plant shutdown. The new stack breeching is placed as a single piece and connected to the stack and new flue gas duct, using the required expansion joints.



Figure 3-2. HRSG Stack—New Steel Support Structure and Stack Hole Pattern

The existing stack damper is reused but modified with the addition of a pneumatic controller outfitted with a local air reservoir to permit the damper to be modulated from full open to full closed rapidly.

The chemical treatment equipment and stack continuous emissions monitoring system (CEMS) located at the base of the stack are shifted to a nearby location on the stack foundation. The electrical and piping are reconnected using electrical terminal boxes and flanges. The CEMS umbilical is entirely replaced and the system recalibrated. The existing auxiliary boiler is not changed or modified. The auxiliary boiler stack is rerouted from the boiler up the new steel tower, but the upper portion running alongside the HRSG stack remains unchanged. This maintains the current emissions point location for this source.

The flue gas duct, its support bridge steel and two support towers, and the two flue gas duct guillotine isolation dampers located within the CCPP, along with the new stack support structure, are installed during normal CCPP plant operation. The portion of flue gas duct located within the CCPP is designed to be fabricated off site and lifted into place in one piece.

3.2 Alternate Stack Study (If required) _

Other stack modification options involving lower costs and possibly a shorter outage exist for constructing the connection of the CCC Plant flue gas duct to the HRSG stack. One such option is to penetrate the existing stack's east face by perforating the side with 80 holes the same size and location as the current west face design. The openings then would be reinforced with ribbing vertically and horizontally to provide the necessary structural reinforcing to avoid the need for an exterior steel support structure. These options are most appropriately pursued during the project's engineering, procurement, and construction (EPC) phase when opportunities to coordinate outages and modifications acceptable to Naturkraft can be openly discussed.

3.3 Emissions Dispersion for Modified/New CCPP Stack _

The present CCPP HRSG stack is modified so that an exit breeching can be attached on its east side to redirect the combustion turbine flue gas into the ducting to the CCC Plant instead of out the top of the stack.

At startup, the existing stack damper is open, permitting the flue gas to exit the stack at the top, at the current mass flow and temperature, velocity, and gas composition. Once the CCC Plant becomes available, its flue gas blowers are started, the HRSG stack damper is slowly closed in synchronism with the blower variable frequency drive (VFD), and 100% of the CCPP flue gas is redirected to the CCC Plant.

The CCC Plant uses two flue gas blowers to create a negative pressure in the duct, causing the flue gas to be pulled into the plant. The use of variable speed drives on these blowers plus, as necessary, inlet damper control on each blower, enables the CCC Plant to control the flue gas flow so that essentially no flue gas exits the HRSG stack.

Some small amount of stack damper leakage can be expected through the present split-half Raumag Janich DN 7000 damper. This leakage is expected to be a minimal amount coming into the stack during normal and part load operation and affects neither CCC Plant nor CCPP operations. Emissions from the HRSG stack during CCC Plant operation are expected to be essentially zero.

Based on CCC Plant design, no change is necessary in the HRSG stack emissions parameters, such as mass flow and velocity, temperature, and gas composition, during CCPP operation without the CCC Plant, and these stack emissions parameters are essentially zero when the CCC Plant is operating. Under partial output operation of the CCPP (plant turn-down) with the CCC Plant not in operation, flue gas mass flow and velocity, temperature, and gas composition remain unchanged from the present design. With the CCC Plant in operation, the emissions from the CCPP are again essentially zero, with minimum stack damper leakage. Under partial operation of the CCC Plant, CCPP flue gas mass flow out of the HRSG stack is reduced proportionally, with velocity, temperature, and gas composition unchanged from the present design.

3.4 Flue Gas Ductwork to CCC Plant

The flue gas duct to the CCC Plant is approximately 6 x 6 meters square and made of carbon steel up to the fogging system grid, at which point it changes to stainless steel all the way to the absorbers. The ductwork is supported by bridge steel to permit offsite fabrication and to permit installation at the site by crane. This also permits the individual duct sections to be removed for future heavy haul access as required. The support towers and their foundations are placed as early as they become available from the fabricator. The duct is fully insulated for thermal protection and for noise. Platforms are provided for access to instrumentation and to service the guillotine isolation dampers.

Two guillotine isolation dampers in series are provided at the HRSG stack to allow positive shutoff of the flue gas. These are strictly openclosed devices with a seal air system to provide positive pressure between the dampers to prevent gas from entering the ductwork during interior duct maintenance.

Piping, power, air, instrumentation, and controls to service the ductwork and the CCC Plant tie-in are provided from the CCC Plant and are routed along with the ductwork.

3.5 Conclusions and Recommendations

The design provides the necessary stack modifications without revising the location of the emissions points of the CCPP combustion turbine and auxiliary boiler, with minimum impact to other Naturkraft equipment and facilities, and is achievable within the prescribed maximum 4-week breaker-to-breaker CCPP outage requirement.

4.0-Flue Gas Cooling

4.0 Flue Gas Cooling _____

4.1 Cooling Alternatives _

The Kårstø CO₂ Carbon Capture and Compression (CCC) Plant flue gas comes from the Naturkraft combined cycle power plant (CCPP) gas turbine/heat recovery steam generator (HRSG) discharge. It is relatively dry compared with that of coal-fired power plant flue gas, which is normally downstream of a wet flue gas desulfurization process. Methods of cooling the CCC Plant flue gas include the following alternatives:

- Indirect flue gas cooling using water-cooled fin-tube coils
- Evaporative cooling using direct contact water spray or fogging
- Direct-contact cooling using a packed bed with a side-water cooler

The first option is considered to be very costly. It requires the cooler to have a cross-sectional area the same as the HRSG. If seawater cooling is used in the tube side, the cold water may cause flue gas condensation on the fin-tube, so a stainless steel fin-tube material would be required. The flue gas from the CCPP is relatively dry, but to keep it from drying out the amine solvent must be saturated with water before it is sent to the amine scrubber. This cooling system, being dry, would not provide the needed water for saturating the flue gas, only if the wet bulb is above the cooled temperature.

The second option of using evaporative cooling by a spraying or fogging system can reduce the flue gas temperature and saturate the flue gas with water. This is a low-cost option because water spraying does not require special equipment and provides a very efficient means of cooling by using water evaporation. However, it cannot reduce the flue gas to below its dew point. The flue gas has a dew point of about 48 °C, and the design flue gas temperature entering the absorber tower is therefore set at about 50 °C. This temperature was chosen to achieve a balance between capital and operating costs.

The third option is to use a packed bed, direct-contact cooling section, either in a separate vessel (quench tower) or as an integral packed bed in the absorber bottom section. The packed bed can be sized to cool the flue gas to as low as 25 °C with the available 11 °C seawater temperature.

The current alternative selected is the second option, using just a fogger, as the most economical approach for a generic monoethanolamine (MEA) solvent.

4.2 Cooling Equipment Selection and Layout _

As noted, the evaporative fogger has been selected for the FEED study base case. It involves two stages of water spraying. The primary fogger is a single spray grid located in the main duct run from the CCPP upstream of the flue gas blowers. Because the flue gas blowers increase the flue gas temperature by about 5 °C, a trim fogger is added downstream of the blower to further cool the flue gas to near its dew point. The fogging system consists of spray nozzles with spray trees. The spray water is supplied by two 100% pumping systems. A water tank is provided to supply water to the pumps.

4.3 Cooling Performance

Cooling the flue gas affects steam consumption and electrical power consumption, as described below.

4.3.1 Steam Consumption ____

The amine plant reboiler steam consumption is influenced mainly by the following parameters:

- Inlet flue gas temperature
- Solvent CO₂ loading

Inlet flue gas temperature affects steam rate because, at lower gas temperature, the CO_2 loading in the amine solvent can be increased. At higher CO_2 loading, the amine circulation rate is reduced, and the steam needed to regenerate the rich amine is also reduced.

Solvent concentration also plays an important role in steam consumption. At higher concentrations, CO_2 loading is increased per cubic meter of circulating solvent, and the heat needed to regenerate the rich amine is reduced.

Simulation runs performed to document the effects of flue gas temperature at absorber inlet and solvent concentration on steam use rate produced the results shown in Table 4-1.

MEA (%)	Flue Gas Temperature (°C)	CO ₂ Capture Efficiency (%)	Steam Rate - Gross (kg steam per kg CO ₂)	Case
35	50	85.3	1.56	Normal
35	35	84.4	1.46	Normal
36	35	85.5	1.44	Normal
38	35	85.7	1.38	Winter

 Table 4-1. Results of Simulation Runs

The table shows that the reduction of flue gas temperature has a significant impact on steam rate. To reduce the flue gas temperature from 50 $^{\circ}$ C to 35 $^{\circ}$ C requires a packed bed cooling section or separate quench tower.

Increasing the MEA concentration is an approach that has a positive impact on steam rate, but it increases the corrosiveness of the solvent on carbon steel. Because the design employs an all stainless steel (SS) system, a higher concentration is potentially feasible without negative impacts on equipment life.

4.3.2 Electric Power Consumption _

Cooling the flue gas temperature to 50 °C reduces the power consumption of the flue gas blower. A further reduction in electric power consumption is possible by further reducing the flue gas to as low as 25 °C as noted above.

4.4 Conclusions and Recommendations_

The current design employs a fogger to reduce the flue gas temperature entering the absorber to 50 °C. This simple design provides a system that has a minimum capital cost. If economically justified, a lower steam rate is possible by including a separate direct contact cooler (DCC) or a short packed bed at the bottom section of the absorber tower to further cool the flue gas and increase its rich amine loading factor.

Further flue gas cooling leads to a lower flue gas effluent temperature at the absorber overhead (top) discharge, depending on wash water temperature. A low-temperature discharge flue gas has low buoyancy, and may have a negative impact on flue gas dispersion.

5.0-CCC Plant Process Design
5.0 CCC Plant Process Design_____

5.1 Design Basis _____

5.1.1 Battery Limit Conditions _____

The Norwegian Government intends to develop the Kårstø CO_2 Capture and Compression (CCC) Plant in association with an existing 420 MW gas-fired Naturkraft combined cycle power plant (CCPP) in Kårstø, Norway. The CCC Plant is required to recover at least 85% of the CO₂ contained in the flue gas from the CCPP and deliver liquefied CO₂ to the CCC Plant battery limit (B/L). B/L conditions for the incoming flue gas and the CO₂ product stream are presented in this section.

The flue gas conditions for the seasonal cases are shown in Table 5.1-1.

Parameter	Normal	Summer	Winter
Mass flow (100% load) (kg/s)	704	645	725
Temperature (C)	90	85	100
Composition			
Oxygen (wt %)	14.4	14.2	14.5
Nitrogen (wt %)	73.6	72.7	73.8
Argon (wt %)	1.2	1.2	1.2
Water (wt %)	4.9	4.9	4.9
CO ₂ (wt %)	5.9	5.9	5.9
NO _x (ppmv)	4	4	4
NH ₃ (ppmv)	4	4	4
SO ₂ (ppmv)	0.1	0.1	0.1

 Table 5.1-1
 CCPP Flue Gas Conditions

The CO₂ product is required to meet the criteria shown in Table 5.1-2.

Table 5.1-2 CO₂ Product Specifications

Composition	Specification
Carbon dioxide (mol %)	>99.6
Nitrogen (wt %)	<0.04
Water (ppmw)	<50
Hydrogen sulfide (ppmw)	<100
Oxygen (wt %)	<200
Ammonia	Trace
Amine	Trace
Physical Properties	
Temperature (C)	50 max.
Pressure (barg)	200
Phase	Liquid

5.1.2 Process Variables and Configuration

The process variables and configuration were established to capture a minimum of 85% of the yearly emitted CO₂ from the flue gas produced by the CCPP.

The CO_2 must be captured via an amine absorption process. The amine solution employed in the base design case is aqueous monoethanolamine (MEA) at 35% (wt).

Due to Kårstø ship size restrictions, the largest diameter vessel that can be received is 12 meters. To treat the flue gas from the CCPP, a single cylindrical absorber vessel would have to be approximately 17 meters in diameter. Cylindrical vessels were chosen because their fluid flow patterns are well documented and understood versus those of other geometric configurations, and vessels of a maximum of 12 meters in diameter were selected to operate in parallel.

Downstream of the absorbers, the flows combine into a single-train configuration because the equipment sizes are small enough to be handled by ship.

To meet the water specifications in the product CO_2 , a molecular sieve dryer is specified.

5.2 Process Overview_

5.2.1 Process Description of Normal Operation _

The CCC Plant consists of the following systems:

- Flue gas diversion The flue gas is directed from the existing stack to the plant.
- Flue gas cooling—The flue gas as supplied is too hot to process efficiently in the absorber and is cooled to its saturation temperature before entering the absorber.
- CO₂ absorption—Parallel absorbers use an amine solution to remove the CO₂ from the flue gas.
- Heat integration—Heat is recovered from internal streams to enhance plant energy efficiency.
- CO₂ stripping The amine is regenerated for reuse by liberating the CO₂ from the amine solution.
- CO₂ compression and drying—The CO₂ is compressed, dried, further compressed, and liquefied to meet the CO₂ specifications.

- Amine reclamation—Heat stable salts (HSS) are removed from the amine solution.
- Amine storage—Fresh amine and lean amine are stored and injected into the absorption system to maintain the amine solution concentration.

Refer to the following diagrams at the end of Section 5.0 for the design:

- 10112936-PB-P-FLD-0001 (25474-000-M5-YA-00001), Block Flow Diagram
- 10112936-PB-P-HMB-0002 (25474-000-M4-CN-00002), [Overall] Process Heat and Mass Balance Diagram
- 10112936-PB-P-FLD-0003 (25474-000-M5-BA-00001), Process Flow Diagram Blower and Quench Section
- 10112936-PB-P-FLD-0004 (25474-000-M5-CN-00001), Process Flow Diagram Absorber T-101
- 10112936-PB-P-FLD-0005 (25474-000-M5-CN-00002), Process Flow Diagram Absorber T-102
- 10112936-PB-P-FLD-0006 (25474-000-M5-CN-00003), Process Flow Diagram Lean Amine Cooling, Sheet 1 of 2
- 10112936-PB-P-FLD-0007 (25474-000-M5-CN-00004), Process Flow Diagram Lean Amine Cooling, Sheet 2 of 2
- 10112936-PB-P-FLD-0008 (25474-000-M5-CN-00005), Process Flow Diagram Stripper
- 10112936-PB-P-FLD-0009 (25474-000-M5-CY-00001), Process Flow Diagram Fresh and Lean Amine Storage
- Water Balance Split Flow Design
- 10112936-PB-P-HMB-0001 (25474-000-M4-CN-00001), Heat and Mass Balance Diagrams

5.2.2 Flue Gas Diversion and Cooling_____

The flue gas is diverted from the existing CCPP stack in a manner that does not affect power plant operation. The duct that directs the flue gas to the CCC Plant is tied into the existing stack near its base. A pair of shutoff dampers installed at this point isolate the duct from the main stack when the plant is shut down. In normal operation, the shutoff dampers are wide open and the existing stack damper is closed. The stack damper motor operator is replaced by a modulating pneumatic operator. The stack damper is closed when the plant is in operation, to divert 100% of the flue gas into the plant, and is modulated during

plant startup/shutdown or if the plant is operating at reduced capacity.

The flue gas is drawn through the duct to the CCC Plant by two blowers operating in parallel. The flue gas blowers (K-101/K-102) are controlled using variable frequency drives (VFDs) (and suction throttling dampers as secondary) to control the pressure at the heat recovery steam generator (HRSG) outlet and to maintain the desired flow through each blower. It is necessary to maintain precise pressure control on the duct to avoid any negative impact on CCPP operation and to prevent air ingress into the CCC Plant through the stack opening.

Both upstream and downstream of the flue gas blowers (K-101/K-102), the flue gas water fogger system (X-101 A/B/C) cools the flue gas to approximately 50 °C before it enters the absorber towers.

The water used in the flue gas water fogger system (X-101 A/B/C) is recycled process water that is directed to the process surge water tank (TK-104).

5.2.3 CO₂ Absorption

The CO_2 is absorbed from the flue gas using two absorption towers operating in parallel.

Cooled flue gas enters the bottom of the CO_2 absorbers (T-101, T-102) and passes through the stainless steel structured packing. The flue gas is contacted counter-currently with 35% (wt) MEA solution as it passes through the absorption section of the tower.

Partially regenerated amine (semi-lean amine) is injected partway through the packed bed section to absorb part of the CO_2 from the flue gas. Fully regenerated lean amine is directed to the top of the packed bed section. As it leaves the absorption section, the flue gas passes through a mist eliminator to limit amine solution carryover into the water wash section of the absorber tower.

Internal to the absorbers, the water wash section serves to reduce both the ammonia and MEA content in the flue gas to < 5 ppm each. In addition, the water wash section cools the flue gas to approximately 40–45 °C to reduce the amount of water vapor leaving the tower. Wash water is prevented from entering the absorption section of the column by using a chimney tray. The water is collected on the chimney tray and pumped out by the wash water recirculation pump (P-102 A/B [absorber 1], P-104 A/B [absorber 2]). The recirculated water is first

cooled in the wash water cooler (E-101 [absorber 1], E-104 [absorber 2]) and is then injected above the second bed of packing on flow control.

Above the first bed, fresh process water makeup is supplied from the discharge of the absorber makeup water pump (P-119 A/B). Level control on the chimney tray sends the excess water (makeup water and water condensed from the flue gas) and collected amine back to the lean amine stream. This blowdown of the water wash system keeps the amine concentration from building up in the water wash system and helps to maintain the lean amine concentration at 35% (wt).

The rich amine leaves the bottom of the CO_2 absorbers (T-101, T-102) through the rich amine pump (P-101 A/B [absorber 1], P-124 A/B [absorber 2]). An equalization line between the two towers ensures that the liquid is pumped out of the towers at equal rates. A high level control signal from the absorber bottoms diverts any excess lean amine to the lean amine solvent storage tank to balance system inventories.

5.2.4 CO₂ Stripping_

The rich amine flow is preheated in the lean/rich amine heat exchanger (E-108) prior to being fed to the stripper (T-103).

The rich amine falls through the packed section of the stripper (T-103), where it is counter-currently heated with steam generated in the stripper reboiler (E-110). As the temperature of the rich amine increases, the CO_2 is liberated from the solution.

Plate-and-frame thermosyphon reboilers are used to heat the column. Liquid is diverted into the stripper reboiler (E-110) via a segregated sump compartment. Excess liquid overflows from the reboiler sump compartment to the lean amine sump compartment for return to the absorber. The heating medium supplied to the stripper reboiler (E-110) is 2 barg saturated steam.

The level in the bottom of the stripper (T-103) is controlled by balancing the flow of rich amine feed to the stripper (T-103) with lean amine that is fed to the CO_2 absorbers (T-101, T-102) in a three-element arrangement.

Vapor leaves the top of the stripper (T-103) and is fed to the overhead stripper condenser (E-111), cooling the stream to approximately 50 °C. The condensed MEA and water are separated from the gas stream in the stripper reflux drum (V-102). From the stripper reflux drum (V-102), approximately 10% of the liquid is pumped back to the column as reflux via the reflux pump (P-107 A/B), while the balance flows to the process water surge tank (TK-104). The gas stream leaving the

stripper reflux drum (V-102) is approximately 97% CO₂, with the balance of the composition being predominantly water vapor.

The lean amine flows from the bottom of the stripper (T-103) to the suction of the lean amine pump (P-105 A/B).

5.2.5 Heat Integration _

Approximately 25% (wt) of the rich amine leaving the rich amine filter (F-102 A/B) is diverted to a series of exchangers (the semi-lean/rich amine heat exchanger [E-103], the flash-feed heat exchanger [E-107] and the flash-feed heater [E-109]), where it is heated to approximately 120 °C. The rich amine is flashed in the semi-lean flash drum (V-101). The CO₂-rich vapor leaves the top of the semi-lean flash drum (V-101) and is directed to the stripper (T-103). The semi-lean amine leaves the bottom of the semi-lean flash drum (V-101), is pumped via the flash drum pump (P-106 A/B), and is cooled in the semi-lean/rich amine heat exchanger (E-103) before being fed to the two CO₂ absorbers (T-101, T-102).

The lean amine pump (P-105 A/B) forces the stripper bottoms fluid through the lean amine filter (F-105 A/B) to remove particulates. The flow passes through the flash-feed heat exchanger (E-107), where part of the rich amine is heated to produce semi-lean amine, which is described above. The stripper bottoms fluid is then further cooled as it exchanges heat with the bulk rich amine flow in the lean/rich amine heat exchanger (E-108).

The stripper bottoms fluid is even further cooled in the lean amine cooler (E-102) before the flow is split and fed back to each of the two CO_2 absorbers (T-101, T-102). The temperature of the lean amine returning to the CO_2 absorbers (T-101, T-102) is a key variable in controlling the overall recovery of CO_2 , maintaining the system water balance and the heat input required to the stripper (T-103).

5.2.6 CO₂ Compression and Drying

The gas stream leaving the stripper reflux drum (V-102) is approximately 97% CO₂, with the balance of the composition being predominantly water vapor. Any liquid carried over from the stripper reflux drum (V-102) or that condenses in the line is removed in the CO₂ compressor suction drum (V-103). The gas enters the CO₂ compressor (K-103) suction at less than 1 barg and is compressed to approximately 92 barg. Some of the heat generated during compression is recovered by generating steam in steam generators (E-112/114/116) where the steam is directed to the semi-lean amine flash feed heat exchanger (E-109).

 CO_2 is dried to less than 50 ppmvw by passing the partially compressed gas to the CO_2 drying package (X-104), an adsorption bed dryer.

The gas is then cooled in the CO₂ cooler (E-117), where the CO₂ stream is totally condensed, becoming a liquid. The liquid CO₂ is then fed to the CO₂ surge drum (V-106), where it is pumped to the B/L by the CO₂ product send-out pump at a pressure of 200 barg on level control. Any noncondensable gas that collects in the CO₂ surge drum is vented back to the CO₂ absorbers (T-101, T-102) stack.

5.2.7 Amine Reclamation

On an annual basis, approximately 0.5–1% of the lean amine mass flow from the lean amine pump (P-105 A/B) discharge is fed to the amine reclaimer (X-102). During normal operation, the amine is subject to thermal degradation and undergoes chemical reactions, producing undesirable compounds. Chemical reactions with oxygen and sulfur dioxide and other flue gas contaminants in the flue gas can produce acids, which combine with amine, producing heat stable salts (HSS). Amine bound in HSS does not absorb CO₂. In the amine reclaimer (X-102), amine is released from the HSS by heating with high pressure steam and through a neutralization reaction with soda ash. Water is added to the amine reclaimer (X-102) to improve amine recovery and reduce the amount of amine degradation that occurs in the reclaiming process. Much of the amine and water from the lean amine solution is vaporized and returned to the stripper (T-103). The residual sludge (a very viscous liquid when hot, and with usable heating value) is removed for proper disposal.

5.2.8 Amine Storage _

Fresh, concentrated amine (85%) is delivered by truck and stored in the amine storage tank (TK-101). To maintain the solution concentration at 35% MEA, fresh amine is made up to the system (TK-102) as required using the fresh amine metering pump (P-110 A/B).

The lean amine solvent storage tank (TK-102) is used to store lean amine removed from the system based on the absorber tower level control as required. During a plant shutdown, this tank is also used to store the amine inventory. Amine is returned to the system using the lean amine solvent fill pump (P-112 A/B).

5.3 Process and Equipment Alternatives_____

5.3.1 Flue Gas Cooling_____

To improve amine absorption of CO_2 in the CCC Plant, the flue gas must be cooled from its supply temperature of 90 °C. Two cooling options were investigated: a water fogger system and a quench tower. The lowest capital cost cooling system, the fogging system, was selected.

5.3.2 Absorber Towers _____

Based on the best knowledge of fluid flow patterns discussed in Subsection 5.1.2, two cylindrical absorbers, each 12 meters in diameter, were selected to operate in parallel. The value of the cylindrical geometry was confirmed when the internal packing suppliers completed a computational flow dynamics (CFD) model showing good flow distribution through the packing with no flow straighteners required. The use of 12 meter cylindrical towers also permit these to be fabricated off site.

5.3.3 Heat Exchange Equipment _____

The large mass flows associated with this CO_2 capture process require a significant amount of heat transfer at many points in the process. To optimize the heat transfer and reduce the plot space required, plateand-frame heat exchangers were selected in all low pressure (LP) services. The CO_2 compression system is the only area using shell-andtube heat exchangers. The duties in this area are relatively much smaller than those in the amine section; therefore, the effect on plot space is not as pronounced.

5.4 HSE Considerations for Design_____

5.4.1 Equipment Selection _____

The CCC Plant equipment and process have been selected to reduce the risk and magnitude of impact on the health and safety of workers and neighbors and the impact on the surrounding environment. Specific examples include the following:

• Closed amine drain system—All amine-containing streams are drained into a closed system to limit fugitive emissions and worker exposure.

- Sound limits Generally, equipment is selected to produce a noise level not exceeding 85 dB at 1 meter. A noise study was conducted to ensure that the noise level does not exceed permit limits.
- Pump seals—Pumps are specified to have high integrity seals to reduce the risk of environmental releases.

5.4.2 Plant Layout and Design_____

The equipment has been laid out using industry best practices to ensure that incompatible pieces of equipment/processes are kept a sufficient distance apart and to ensure safe access to and egress from the operating areas.

The plant layout was reviewed regularly for hazard identification (HAZID) and hazard and operability (HAZOP) purposes, to ensure that the layout was compatible with health, safety, and environment (HSE) requirements.

5.4.3 Process and Emergency Shutdown

The plant has process and emergency shutdown systems to safely shut down specific pieces of equipment and put the entire plant in order to protect equipment and the safety of the workers during upset or abnormal operating conditions.

5.4.4 Fire and Gas Detection_

The plant has detection equipment and audible/visible alarms to alert operating personnel of unsafe conditions.

5.5 Hazards and Safety Analysis _____

5.5.1 HAZID____

A CCC Plant HAZID review was conducted on October 15, 2008, to identify possible HSE hazards related to the plant design. Participation included senior members from the Gassnova, Fichtner, and Bechtel teams. Process flow diagrams were used in conjunction with the preliminary plot plan as a basis for the review.

Using the HAZID review methodology, recommendations were developed to be resolved by completion of the front-end engineering and design (FEED) stage or during detailed engineering.

The HAZID Report 10112936-PB-S-HSE-0003 (25474-0001-U4R-0000-00001, Rev. 0) contains a complete explanation of the methodology and the list of recommendations.

5.5.2 HAZOP ____

A CCC Plant FEED stage process HAZOP study was conducted from November 24–26, 2008, to identify and address potential risks associated with the plant design.

The study was conducted with senior members from the Gassnova, Fichtner, and Bechtel teams to identify situations that pose a hazard to health, safety, the environment, and equipment. The team used the fault tree analysis (FTA) method to review the process flow diagrams, piping and instrumentation diagrams (P&IDs), and 3D model to identity potential risks. The study produced a list of recommendations to reduce the risk associated with designing and operating this plant.

The HAZOP report 10112936-PB-S-HSE-0013 (25474-000-U4R-0000-00003, Rev. 0) contains a complete explanation of the methodology and the list of recommendations.

5.6 Equipment Selections

The two absorber towers and one stripper column are stainless steel, fitted with stainless steel structured packing to achieve a low pressure drop across the vessel internals.

Plate-and-frame heat exchangers were selected for most plant heat transfer services. These exchangers have a smaller plot space requirement for a given area than other types of heat exchangers. Also, they can have much lower approach temperatures than other configurations and, therefore, increase the amount of heat exchanged between streams and increase the plant's energy efficiency.

Stainless steel has been selected for the amine portion and cooled flue gas equipment in the plant and pipe to avoid corrosion problems associated with the high amine concentration employed and to avoid onerous inhibitor programs. Titanium has been selected to provide corrosion protection for equipment in contact with seawater.

5.7 Plant Layout

The main focus of the CCC Plant arrangement is on safety, followed by ease of operation and employing the most economical and costeffective measures that successfully and effectively minimize piping quantities, use the most cost-effective materials, and integrate automation and controls requirements.

5.7.1 Arrangement_

The CCC Plant is located adjacent to the Kårstø gas terminal and the CCPP owned and operated by Naturkraft AS. The plant site size specifications of 70 m x 210 m define the fixed area in which an arrangement has been developed that includes two flue gas blowers, two absorber columns, one stripper column, a CO₂ compressor building, an electrical building, a tanks/unloading area, and a control/administration/workshop/stores building. As the origination of the flue gas duct into the plant, the breach connection to the existing CCPP HRSG is the determining factor with respect to how the absorbers are arranged. The two 11.8 m diameter absorber columns are set to accommodate the incoming 6.2 m square flue gas duct in an equal distribution through the two flue gas blowers, with the assistance of the variable frequency drives (VFDs). The associated equipment, pumps, exchangers, etc., are strategically located to accommodate the shortest possible pipe runs and symmetrical configuration for the process design.

To control the average circuit and umbilical lengths, the electrical building and the continuous emissions monitoring system (CEMS) building have been located to be central to the process.

The tank unloading area is located to accommodate a road design that allows trucks to enter and exit the facility through the northeast gate and exit through the southeast gate without having to travel around the plant process area. The control/administration/workshop/stores building and parking are set to the far east of the site, since the building acts as a safety bunker, placing it nearest the safety egress point. The plant loop road provides access to all sides of the process area. The pipe racks are designed to make available an additional access through the center of the site by permitting access under the center east-west pipe rack.

5.7.2 Piping_

The piping is routed with particular attention to achieving the shortest route. Certain process parameters have been incorporated with regard to equipment and piping symmetry. Special attention has been given to pipe supports and hangers. The piping sizes and wall thicknesses are based on the system design pressures and temperatures. The piping sizes and pipe class designations for each system are shown on their respective P&IDs. The piping material, size, and schedule information for each system is provided in Pipe Class Selection 10112936-PB-L-TED-0001 (25474-000-3DS-P72G-00001). In addition, LCC Pipe Design Report 10112936-PB-L-TED-003 (25474-000-3OR-M90G-00001) outlines the evaluation used in the system piping design for the FEED Study. It evaluates the major systems that have the most impact on overall plant design, capital costs, and operating cost.

5.7.3 Piping and Arrangement Safety _____

Safety measures are planned and incorporated with regard to head clearances, walkways, clear safety escape routes, pull spaces, and machinery maintenance areas.

5.8 Process Performance and Optimization _

The CCC Plant process has been simulated for five operating cases: normal (reclaimer off), normal (reclaimer on), summer, winter, and turndown. In each case, the goal was to achieve the specified CO₂ recovery rate of 85% while minimizing any recovery exceeding this level in an effort to reduce plant energy consumption and capital investment. The water balance is for the modeled cases. This plant can be run in a "water balanced" condition. The simulation was calculated for the base case with a requirement for the import of a small amount of water, to eliminate an issue arising with possibly having to dump amine-laden water to the ocean when the system produces too much. There is some indication that the amine limit in seawater may need to be be as low as reasonably possible (ALARP). A small desalination system is provided in case makeup water is required.

Table 5.8-1 summarizes the CO_2 recovery level and the energy consumption (as measured in pounds of steam consumed in the stripper reboiler per pound of CO_2 leaving the stripper overhead) for this process.

Case	CO ₂ Recovery (%)	Energy Consumption (lb/lb)
Normal (reclaimer off)	85.3	1.56
Normal (reclaimer on)	85.2	1.47
Summer	85.1	1.58
Winter	85.1	1.55
Turndown	85.7	1.59

Table 5.8-1 CCC Plant Performance

5.9 Process Cooling_

The cooling of various process streams is essential to the CCC Plant's operation. The process design philosophy maximizes heat recovery to limit the quantity of externally supplied heating energy or heat sink medium. Where necessary to reject heat from the process, once-through seawater cooling is used. The cold supply temperature of the seawater makes it an excellent heat sink medium, providing significant process benefits in terms of water recovery from the absorber off-gas and improving compressor efficiency. The temperature rise for seawater cooling is limited to 10 °C, per project requirements with a maximum discharge temperature of 21 °C.

A cooling philosophy study 10112936-PB-P-TDO-0008 (25474-000-30R-M84G-00001) was performed and provides additional information on this topic.

5.10 Steam, Water, and Chemical Requirements _____

The CCC Plant utilities are as follows:

- Steam and condensate
- Cooling (seawater)
- Potable water
- Fire water
- Fuel gas (natural)
- Compressed air
- Inerting gases (nitrogen)
- Desalination water

The requirements for these utilities are summarized in Table 7.1-1, Utility Requirements, of Section 7.0.

5.11 Exhaust, Emissions, and Waste _____

The CCC Plant employs a 35% (wt) aqueous solution of MEA to capture CO_2 gas from the CCPP diverted flue gas stream.

MEA and ammonia emissions from the absorber outlet are 3 ppm and 4 ppm, respectively, which is less than the 5 ppm limit stipulated in the design basis. The process configuration can be modified to reduce these emissions further with some additional capital expenditure, should further restrictions be imposed.

The plant is expected to generate airborne, liquid, and solid wastes under normal operating conditions. The amine system emissions are summarized in Table 5.11-1.

Emission (1)	Flow Doto		Annually Emitted
	FIOW Rale	гюж туре	Quantity (2)
Airdorne		-	
Oxygen	182,472 kg/h	Continuous	3.197E+09 kg
Nitrogen	932,643 kg/h	Continuous	1.634E+10 kg
Water	65,918 kg/h	Continuous	1.155E+09 kg
Carbon dioxide	10,961 kg/h	Continuous	1.920E+07 kg
Sulfur dioxide	0.28 kg/h	Continuous	4.872E+03 kg
MEA	7.79 kg/h	Continuous	1.364E+05 kg
Argon	15,206 kg/h	Continuous	2.664E+08 kg
NO	4.23 kg/h	Continuous	7.406E+04 kg
NO ₂	1.06 kg/h	Continuous	1.851E+04 kg
Ammonia	2.99 kg/h	Continuous	5.246E+04 kg
Liquid			
Lubricating oil	To be determined	Intermittent	To be determined
	in EPCI phase		in EPCI phase
Solid			
Reclaimer Waste (3)	225 kg/h	Intermittent	1.971E+06 kg
F-101 Filter cartridges (4)	14 elements/	Intermittent	28 elements
	change		
F-102 Filter cartridges (4)	57 elements/	Intermittent	114 elements
	change		
F-105 Filter cartridges (4)	57 elements/	Intermittent	114 elements
	change		
Activated carbon	21,736 kg/month	Intermittent	2.608E+05 kg

Table 5.11-1 Exhaust and Emissions Summary

Notes:

- 1. Emissions from each absorber tower. Expected to contain small amounts (< 1 ppmv per component) each of piperazine, formaldehyde, and acetaldehyde. These *decomposition products* of amine degradation reactions occur in the circulating process streams over time.
- 2. Annually emitted quantity is based on 8760 hours per year operation for continuous operations, and is <u>total</u> for two absorber towers.
- 3. The quantity is based on 170.5 kg/hr of sludge on a dry basis. The additional quantity includes flushing water. The annually emitted quantity is based on 8760 hours per year operation for continuous operations. Actual operation is expected to be from 2 to 10% of plant operation time. Waste is emitted intermittently.
- 4. Filters are changed semi-annually.

5.12 Conclusions and Recommendations____

The proposed amine absorption process using MEA is capable of absorbing CO_2 from the CCPP flue gas and achieving a CO_2 recovery rate of at least 85%.

The quality of the LP steam available at the site is a constraint that increases CCC Plant operating and capital costs. An investigation is recommended of the possibility of elevating the LP steam pressure by a minimum of 1 bar. Additional recommendations for improvement options to be examined in the engineering, procurement, construction, and installation (EPCI) phase are found in Section 17.0.



13	14	15	16	
	NOTES:			
	1.			М
			:	
				L
				K
			-	
				J
				Н
				G
			-	
				F
\sim				
}				F
\longrightarrow				L
				D
				С
	RE-ISSUED FOR APPROVAL		DM GR - RS Brz VCE	D
	DATE R	evisions	GK UM - RS - 79225 BY CHK DES ENGR. PROJ APPR	U
	GASSNOVA	CO2 KARSTO	PROJECT	
Owner Dr 10112 Contract	awing No. 2936-PB-P-FLD-0001 ar	BLOCK FLOW	DIAGRAM	
	BECHTEL	•		А
BEC		594x841 A1" scole: N.T.S. JOB NO. DR	AWING NO. REV.	
13	14	254/4 000-M	5-YA-00001 1 16	





				· · · · · · · · · · · · · · · · · · ·	
7	8	9	10	11	12

13		14			15	16	
	N	OTES:					
	1.	. –					м
\longrightarrow							
Ś							K
}							
}							
}							
}							J
AMINE							H
							G
s							
							F
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~							
							E
							D
s							
/							
						··· · · · · · ·	
		RE-ISSUED FOR APPROVAL	-			DM UP - RS BRE W	
	0 10/10/00 NO. DATE		REM	sions		GR DM - RS BY CHK DES ENGR. PROJ APPR	
	owner	ASSNOVA		C02	KARSTO	PROJECT	
	Swiner Drawing N 101129.36			PROC	ESS FI O	W DIAGRAM	
	Contractor			BLOWER		NCH SECTION	
	<b>CHI</b>	BECHTEL POWER	Sheet Size	594x841 "A1"	Scale: N.T.S.		A
	<b>B</b>	/ CURPORATION Frederick, maryland		25474	DR 000-M	5-BA-00001 1	
13		14			15	16	



13	14		5	16	
	NOTES: 1. –				Μ
					L
					К
		·			J
λL					Н
CONTROL					G
AL _EVEL CONTROL INE					F
					E
AL	· · · · · · · · · · · · · · · · · · ·				D
>					С
	1       12       RE-ISSUED FOR APPROVAL         0       10/10/08       ISSUED FOR APPROVAL         NO.       DATE         Owner       GASSNOVA	revisions CO2	KARSTO	DM UP - RS BP2 GR DM - RS by CHK DES ENGR. PROJ APPR PROJECT	В
	Towner Drawing No. 10112936-PB-P-FLD-0004 Contractor BECHTEL POWER CORPORATION FREDERICK, MARYLAND	PROC A ^{sheet Size} 594x841 "A1" JOB NO. 25474	ESS FLOW BSORBER ^{Scodee} n.t.s. DRA 000-M5	UIAGRAM T-101 wing no. rev. -CN-00001 1	A
13	14		15	16	



13	14	15	16	
	NOTES: 1			Μ
				 L
	·			к
				J
AL				H
				G
				 F
JAL				E
MINE TO STORAGE	Ξ			D
				С
	1     12     RE-ISSUED FOR APPROVAL       0     10/10/08     ISSUED FOR APPROVAL       No.     DATE	REVISIONS	DM UP - RS BNZ UES GR DM - RS BY CHK DES ENGR PROJ APPR	B
	Owner Drowing No. 10112936-PB-P-FLD-0005 Contractor BECHTEL POWER CORPORATION FREDERICK, MARYLAND	CUZ NARSI           PROCESS FI           ABSORB           Sheet Size           594x841 "A1"           Scole:           N.T.S.           JOB NO.           25474	DIAGRAM ER T-102 DRAWING NO. REV.	- - - - -
13	14	15	16	



					· · · · ·
7	8	9	10	11	12
	1	1			

13			14			15		16	
		NOTES:							
		1. –							м
·····									
{								:	L
·····									
									к
									0
AKE UP									
									Н
L								:	
									G
CONTROL								r.	
MS									
									E
$\longrightarrow$									<u> </u>
$\sim$									
									D
O REBOILER									
									·
									С
		RE-ISSUED I					DM UP -	RS BR-ups	
	NO. D	10/08 ISSUED FOR	AFFRUVAL	REVISIONS			GR DM – ву снк des	RS	L L
	Owner	GASSN			C02	KARSTO	PROJEC	T	
	Owner Drawin							· · · · · · · · · · · · · · · · · · ·	   
	Contractor	JO-LQ-L-L			LEA	N AMINE			
	Ø	BEC	HTEL WFR	Size 594x8	41 "A1"	SHEEL ]	UF 2		A
	BECH	CORPO			NO. 71		AWING NO.	REV.	
1.3			14	204	/ 4	15	ט–נא–0( 	16	
		I		1			I		1



7	8	9	10	11	12

13		14		,	15	1	6	
		NOTES:						
		1. –						N 4
								IVI
							-	
							· · · · · · · · · · · · · · · · · · ·	L
								K
ANK							:	
								Ŭ
								Η
							-	
								G
								F
								E
								U
								С
]	1 12 N	RE-ISSUED FOR APPROVAL			· · · · · · · · · · · · · · · · · · ·	DM UP -	RS BRE NES	-
	<u></u> 10/1	10/08 ISSUED FOR APPROVAL				GR DM -	RS	В
	NQ. D/ Owner Se		REVISIONS	000			NGR. PROJ APPR	
	Owner Drowin				NAK210	FRUJEUI		
	101129 Contractor	36-PB-P-FLD-0007		PROC LEA	ESS FLOUNN AMINF	N DIAGRAM COOLING		
	G	BECHTEL	et Size		SHEET 2	OF 2		А
	BECH		JOB	NO.	n.i.s DR	AWING NO.	REV.	
1 7			25	4/4	000-M5 15	-CN-000	04   1	
L)		14			10	1 1	0	l



13	14		15	16	
	NOTES:				
	1. –				м
FIRST STAGE					
A					
>					
					К
					J
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~					
					H
IAL					
					G
					F
					- - -
					E
ROM OSBL					
~~~~~					
					D
}					:
					C
_					
4		-		DM UP - RS Bre we	
4	<u>10/10/08</u> NO, DATE	REVISIONS		GR DM - RS BY CHK DES ENGR. PROJ APPR	
	GASSNOVA	C02	KARSTO	PROJECT	
ж с	Winer Drawing No. ()1129.36-PR-P-FI D-0008	PROC	ESS FI ON		
	Contractor		STRIPP	ER	
	BECHTEL POWER	Sheet Size 594x841 "A1"	Scale: N.T.S.		A
	CORPORATION FREDERICK, MARYLAND	<u>лов No.</u> 25474	DR. 000-M.5	AWING NO. REV. 5-CN-00005 1	
13	14		15	16	



7	8	9	10	11	12

13	14	15	16	
	NOTES: 1. –			М
				L
				К
				J
				Н
				G
2				F
				E
				D
				С
1         12           0         10/           NG.         10           Owner         2           ************************************	RE-ISSUED FOR APPROVAL (10/08 ISSUED FOR APPROVAL DATE GASSNOVA	REVISIONS CO2 KARSTO	DM UP - RS BOL GR DM - RS by CHK DES ENGR. PROJ APPR PROJECT	В
Owner Draw 101129 Contractor BECT 13	BECHTEL POWER CORPORATION FREDERICK, MARYLAND	PROCESS FLOW FRESH & LEAN A 594x841 "A1" Scole: N.T.S. JOB NO. DR 25474 000-M 15	W DIAGRAM MINE STORAGE AWING NO. REV. 5-CY-00001 1 16	A

#### **CCC Plant Water Balance**



Stream No.	001	003	010	100 + 200	102 + 202	103 + 203	107 + 207	323	333	414	415	417	527
Case	Flue Gas From CCPP	Process Water to Foggers	Softened Water	Cooled Flue Gas to Absorbers	Excess Water to Absorbers	Off Gas to Atmosphere	Process Water to Upper Bed	Reflux Purge	Process Water to Absorbers	CO2 Product	Inter-stage Liquid	Dryer Water	Vent Steam
Normal	124185	59284	2237	183468	148594	131836	10800	68180	3883	6	3555	93	5515
Winter	117567	67852	5828	185420	160014	128956	10800	70035	867	6	3658	96	5669
Summer	139319	47519	3642	186838	135814	147980	10800	63923	12490	5	3249	85	5113
Normal Reclaimer On	124185	59288	4172	183472	149654	133462	10800	67975	5603	6	3551	93	5197
Turn down	96864	45897	4359	142760	111248	105194	10800	50750	967	4	2558	67	4043

Units = kg/hr of water

Karsto CCC Plant–Water Balance for Split Flow Design, Revision 0

Kårstø CO₂ Capture and Compression Plant

Kårstø, Norway

Heat and Mass Balance Diagrams (25474-000-M4-CN-00001)

for Front-End Engineering and Design (FEED) Study Report

# Contents

Attachment	Page
1.0 Normal Case-Reclaimer Off	A1 to A7
2.0 Normal Case-Reclaimer On	<b>B1 to B7</b>
3.0 Summer Case-Reclaimer Off	C1 to C7
4.0 Winter Case-Reclaimer Off	D1 to D7
5.0 Turn down Case-Reclaimer Off	E1 to E7

Process Streams		001	002	003	004	005	006	007	008	009	010	100	101	102	103	Process Streams
		Flue Gas From	Flue Gas From	Process Water to	Process Water to	Process Water to	Abs 1. Flue Gas	Process Water to	Process Water to	Abs 2. Flue Gas	Softened	Cooled Flue Gas	Warm Wash	Excess Water to	Off Gas to Atmosphere	
		CCPP	Common Fogger	Foggers	Common Fogger	Abs. 1 Fogger	Blower Discharge	Absorbers	Abs. 2 Fogger	Blower Discharge	Water	to Abs. 1	Water (Abs. 1)	Absorbers	(Abs. 1)	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		12.8084*	12.4336	1.04054E-08	1.04054E-08	1.04054E-08	12.4336	1.04054E-08*	1.04054E-08	12.4336	0	12.3515	0.000214797	0.000214797	13.1744	Oxygen
Nitrogen		74.7787*	72.5908	9.25780E-09	9.25780E-09	9.25780E-09	72.5908	9.25780E-09*	9.25780E-09	72.5908	0	72.1115	0.000673590	0.000673590	76.9164	Nitrogen
vvater		7.74143*	10.4383	99.9138	99.9138	99.9138	10.4383	99.9138"	99.9138	10.4383	100	11.0291	99.3907	99.3907	8.45335	water
Carbon Dioxide		3.81568	3.70576	0.0588102	0.0588102	0.0588102	3.70576	0.0588102" 9.07610E.09*	0.0588102	3.70576	0	3.68167			0.575377	Carbon Dioxide
		9.00294E-00 0*	9.57672E-06	0.07019E-08	0.07019E-00	0.07019E-00	9.57672E-06	0.07019E-08	0.07019E-00	9.57672E-06	0	9.514022-06	0.456031	0.456031	0.000290E-05	
Argon		0 854973*	0.829957	8 26903E-10	8 26903E-10	8 26903E-10	0.829957	8 26903E-10*	8 26903E-10	0.829957	0	0.000001430	1 51314E-05	1 51314E-05	0.000234403	Argon
NO		0.000316434*	0.000307175	8.14342E-13	8.14342E-13	8.14342E-13	0.000307175	8.14342E-13*	8.14342E-13	0.000307175	0	0.000305147	7.84911E-09	7.84911E-09	0.000325473	NO
NO2		5.15967E-05*	5.00872E-05	4.78076E-09	4.78076E-09	4.78076E-09	5.00872E-05	4.78076E-09*	4.78076E-09	5.00872E-05	0	4.97565E-05	1.19001E-08	1.19001E-08	5.30586E-05	NO2
NH3		0.000396083*	0.000463089	0.00268616	0.00268616	0.00268616	0.000463089	0.00268616*	0.00268616	0.000463089	0	0.000477768	0.000220370	0.000220370	0.000406187	NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen		11405.2*	11405.2	3.42713E-07	2.79269E-07	3.17217E-08	5702.58	8.48797E-08*	3.17217E-08	5702.58	0	5702.58	0.160147	0.00891279	5702.5	Oxygen
Nitrogen		66586.2*	66586.2	3.04916E-07	2.48469E-07	2.82231E-08	33293.1	7.55185E-08*	2.82231E-08	33293.1	0	33293.1	0.502213	0.0279500	33292.8	Nitrogen
Water		6893.30*	9574.88	3290.77	2681.58	304.595	4787.45	815.025*	304.595	4787.45	124.178	5092.04	74103.3	4124.12	3658.98	Water
Carbon Dioxide		3397.64*	3399.22	1.93698	1.57840	0.179288	1699.61	0.479732*	0.179288	1699.61	0	1699.79	113.465	6.31477	249.048	Carbon Dioxide
Sulfur Dioxide		0.00878239*	0.00878455	2.65998E-06	2.16756E-06	2.46209E-07	0.00439228	6.58797E-07*	2.46209E-07	0.00439228	0	0.00439252	8.10752E-05	4.51213E-06	0.00434101	Sulfur Dioxide
MEA		0*	0.663240	0.813912	0.663240	0.0753361	0.331620	0.201582*	0.0753361	0.331620	0	0.406956	340.006	18.9226	0.127465	MEA
Argon		761.305*	761.305	2.72350E-08	2.21932E-08	2.52088E-09	380.653	6.74528E-09*	2.52088E-09	380.653	0	380.652	0.0112816	0.000627863	380.645	Argon
NO		0.281766*	0.281766	2.68212E-11	2.18561E-11	2.48259E-12	0.140883	6.64281E-12*	2.48259E-12	0.140883	0	0.140883	5.85211E-06	3.25692E-07	0.140879	NO
		0.0459440*	0.0459441	1.57459E-07	1.28310E-07	1.45745E-08	0.0229721	3.89980E-08"	1.45745E-08	0.0229721	0	0.0229721	8.87243E-06	4.93783E-07	0.0229661	
Mass Fraction		0.352690	0.424763	0.0664716	0.0720936	0.00010097	0.212392	0.0219118	0.00010097	0.212392	0	0.220361	0.164303	0.00914404	0.175615	Mass Fraction
		1/ 3000*	14 1200	1 8/556E-08	1.845565-08	1.84556E-08	1/ 1200	1 84556E-08*	1.845565-08	1/ 1200	<u>,,</u>	14 0700	0.000376588	0.000376588	15 1151	
Nitrogen		73 5995*	72 2197	1 43750E-08	1.04350E-08	1.43750E-08	72 2197	1.04350E-08*	1.04350E-08	72 2197	0	71 9134	0.000370387	0.00103387	77 2557	Nitrogen
Water		4.89997*	6.67852	99.7703	99.7703	99.7703	6.67852	99.7703*	99.7703	6.67852	100	7.07331	98.1052	98.1052	5.46029	Water
Carbon Dioxide		5.89996*	5.79204	0.143461	0.143461	0.143461	5.79204	0.143461*	0.143461	5.79204	0	5.76809	0.366964	0.366964	0.907915	Carbon Dioxide
Sulfur Dioxide		2.21998E-05*	2.17890E-05	2.86783E-07	2.86783E-07	2.86783E-07	2.17890E-05	2.86783E-07*	2.86783E-07	2.17890E-05	0	2.16979E-05	3.81693E-07	3.81693E-07	2.30366E-05	Sulfur Dioxide
MEA		0*	0.00156855	0.0836684	0.0836684	0.0836684	0.00156855	0.0836684*	0.0836684	0.00156855	0	0.00191672	1.52623	1.52623	0.000644952	MEA
Argon		1.19999*	1.17750	1.83098E-09	1.83098E-09	1.83098E-09	1.17750	1.83098E-09*	1.83098E-09	1.17750	0	1.17250	3.31192E-05	3.31192E-05	1.25959	Argon
NO		0.000333598*	0.000327344	1.35441E-12	1.35441E-12	1.35441E-12	0.000327344	1.35441E-12*	1.35441E-12	0.000327344	0	0.000325955	1.29043E-08	1.29043E-08	0.000350164	NO
NO2		8.33994E-05*	8.18361E-05	1.21911E-08	1.21911E-08	1.21911E-08	8.18361E-05	1.21911E-08*	1.21911E-08	8.18361E-05	0	8.14891E-05	2.99961E-08	2.99961E-08	8.75209E-05	NO2
NH3		0.000236998*	0.000280092	0.00253568	0.00253568	0.00253568	0.000280092	0.00253568*	0.00253568	0.000280092	0	0.000289658	0.000205629	0.000205629	0.000248028	NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen		364951*	364951	1.09664E-05	8.93629E-06	1.01506E-06	182476	2.71605E-06*	1.01506E-06	182476	0	182476	5.12452	0.285199	182472	Oxygen
Nitrogen		1.86531E+06*	1.86531E+06	8.54172E-06	6.96047E-06	7.90626E-07	932654	2.11553E-06*	7.90626E-07	932654	0	932653	14.0687	0.782975	9.32643E+05	Nitrogen
Water		124185*	172494	59284.1	48309.4	5487.37	86247.2	14682.9*	5487.37	86247.2	2237.11	91734.4	1.33499E+06	74297.2	65918	Water
Carbon Dioxide		149529*	149598	85.2455	69.4648	7.89037	/4/99.1	21.1128*	7.89037	/4/99.1	0	74806.9	4993.56	277.910	10960.5	Carbon Dioxide
		0.562633	0.502772	0.000170408	0.000138862	1.57731E-05	0.281380	4.22000E-00	1.57731E-05	0.281380	0	0.281402	0.00519399	0.000289064	0.278102	
Argon		0 30412 6*	40.5127	49.7163 1.08798E-06	40.5127 8 86574E-07	4.00176 1.00704E-07	20.2564	12.3132 2 69461E-07*	4.00176 1.00704E-07	20.2364	0	24.0001	20766.6	0 0250819	15206.0	Argon
NO		8.45470*	8.45470	8.04801E-10	6.55815E-10	7.44927E-11	4.22735	1.99325E-10*	7.44927E-11	4.22735	0	4.22735	0.000175599	9.77273E-06	4.22723	NO
NO2		2.11367*	2.11368	7.24400E-06	5.90298E-06	6.70508E-07	1.05684	1.79412E-06*	6.70508E-07	1.05684	0	1.05684	0.000408180	2.27167E-05	1.05657	NO2
NH3		6.00649*	7.23428	1.50672	1.22779	0.139462	3.61714	0.373169*	0.139462	3.61714	0	3.75660	2.79816	0.155728	2.99423	NH3
Process Streams		001	002	003	004	005	006	007	008	009	010	100	101	102	103	Process Streams
Property	Units															Units Property
Temperature	C	90*	47.1439	49.4136	49.4136	49.4134	59.6823	47.2373*	49.4134	59.6823	20.0000	50.2334	52.9286	52.9286	42.7843	C Temperature
Pressure	bar	1.0017*	1.0017	138*	138	138	1.08857	4.13685*	138	1.08857	4.13685	1.08857	4.48079	4.48079	1.01273	bar Pressure
Mole Fraction Vapor	%	100	100	0	0	0	100	0	0	100	0	100	0	0	100	% Mole Fraction Vapor
Molecular Weight	kg/kmol	28.4622	28.1573	18.0412	18.0412	18.0412	28.1573	18.0412	18.0412	28.1573	18.0153	28.0905	18.2513	18.2513	27.8903	kg/kmol Molecular Weight
Mass Density	kg/m^3	0.944399	1.05981	989.875	989.875	989.875	1.10824	988.904	989.875	1.10824	997.903	1.13808	987.729	987.729	1.07581	kg/m^3 Mass Density
Molar Flow	kmol/h	89044.3	91728.2	3293.61	2683.89	304.858	45864.1	815.728	304.858	45864.1	124.178	46168.9	74557.7	4149.41	43284.4	kmol/h Molar Flow
Mass Flow	kg/h	2.53440E+06*	2.58282E+06	59420.6	48420.6	5500	1.29141E+06	14716.7*	5500	1.29141E+06	2237.11	1.29691E+06	1.36078E+06	75732.3	1.20722E+06	kg/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	2.10950E+06	2.17308E+06	78027.1	63582.6	7222.22	1.08654E+06	19325.0	7222.22	1.08654E+06	2941.84	1.09376E+06	1.76630E+06	98301.3	1.02543E+06	m^3/h Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	2962.14	3010.62	59.4975	48.4832	5.50711	1505.31	14.7357	5.50711	1505.31	2.23931	1510.82	1362.77	75.8433	1407.19	m^3/h Std Liquid Volumetric Flow
Specific Gravity		0.983118	0.972586	0.990811	0.990811	0.990811	0.972586	0.989839	0.990811	0.972586	0.998846	0.970278	0.988662	0.988662	0.963364	Specific Gravity
Mass Enthalpy	kJ/kg	-1117.26	-1391.25	-15732.4	-15732.4	-15732.4	-1377.89	-15753.3	-15732.4	-1377.89	-15885.0	-1438.77	-15552.4	-15552.4	-795.631	KJ/Kg Mass Enthalpy
Dynamic Viscosity		0.0205100	0.0186190	0.556163	0.556163	0.556164	0.0191597	0.563552	0.556164	0.0191597	1.01302	0.0187333	0.524860	0.524860	0.0186124	
Surface Tension	dvne/cm	0.0293	0.0205	0.0300	0.030 0	0.0300	0.0274	0.0325 68 3735	0.0300	0.0274	73 8205	0.0267	0.0282	0.0282	0.0265	
	ayric/offi			01.3491	01.9491	01.3432		00.0730	01.3432		10.0200		01.0193	07.0193		aynoronn oundoe rension

Process Streams		104	105	106	107	108	109	110	111	200	201	202	203	204	Process Streams
		Lean Amine	Cooled Semi-Lean	Rich Amine	Process Water to	Cooled Wash Water to	Cooled Wash	Cooled Wash Water to	Combined Wash Water to	Cooled Flue Gas	Warm Wash Water	Excess Water to	Off Gas to Atmosphere	Lean Amine	
		(Abs. 1)	Amine (Abs. 1)	(Abs. 1)	Upper Bed (Abs. 1)	Lower Bed (Abs. 1)	Water (Abs. 1)	Upper Bed (Abs. 1)	Upper Bed (Abs. 1)	to Abs. 1	(Abs. 2)	Absorbers	(Abs. 2)	(Abs. 2)	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		2.03133E-05	4.10160E-07	0.000204316	1.04054E-08	0.000214797	0.000214797	0.000214797	0.000171839	12.3515	0.000214797	0.000214797	13.1744	2.03133E-05	Oxygen
Nitrogen		6.37014E-05	8.71616E-07	0.000641523	9.25780E-09	0.000673590	0.000673590	0.000673590	0.000538874	72.1115	0.000673590	0.000673590	76.9164	6.37014E-05	Nitrogen
water		82.3485	79.0389	78.7083	99.9138	99.3907	99.3907	99.3907	99.4953	11.0291	99.3907	99.3907	8.45335	82.3485	water
Carbon Dioxide		3.29511	6.U3259	6.59730	0.0588102	0.152185	0.152185	0.152185	0.133510	3.68167	0.152185	0.152185	0.575377	3.29511	Carbon Dioxide
		1.04242E-08	3.00188E-08	1.02893E-07	8.07619E-08	1.08/42E-0/ 0.456031	1.08742E-07	1.08/42E-0/	1.03140E-07	9.51402E-06	1.08742E-07	1.08/42E-0/	0.000290E-05	1.04242E-08	
Argon		1 43098E-06	2 771/3E-08	14.0932 1.43827E-05	0.0247119 8.26003E-10	1.51314E-05	1 5131/E-05	1.5131/E-05	1 21053E-05	0.000881430	1.51314E-05	1 51314E-05	0.000294483	1 43098E-06	Argon
NO		7 42291E-10	2.46260E-11	7.46719E-09	8 14342F-13	7.84911F-09	7 84911E-09	7.84911E-09	6 27945E-09	0.00305147	7.84911E-09	7 84911E-09	0.00325473	7 42291E-10	NO
NO2		1.13371E-09	1.97765E-10	1.12648E-08	4.78076E-09	1.19001E-08	1.19001E-08	1.19001E-08	1.04762E-08	4.97565E-05	1.19001E-08	1.19001E-08	5.30586E-05	1.13371E-09	NO2
NH3		0.000219977	0.000303949	0.000322211	0.00268616	0.000220370	0.000220370	0.000220370	0.000713528	0.000477768	0.000220370	0.000220370	0.000406187	0.000219977	NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen		0.00891280	4.31312E-05	0.109161	3.12162E-08	0.157570	0.160147	0.00257756	0.00257759	5702.58	0.160147	0.00891279	5702.5	0.00891280	Oxygen
Nitrogen		0.0279500	9.16566E-05	0.342750	2.77734E-08	0.494130	0.502213	0.00808308	0.00808311	33293.1	0.502213	0.0279500	33292.8	0.0279500	Nitrogen
Water		36131.7	8311.50	42051.9	299.741	72910.7	74103.3	1192.69	1492.43	5092.04	74103.3	4124.12	3658.98	36131.7	Water
Carbon Dioxide		1445.78	634.370	3524.77	0.176431	111.639	113.465	1.82622	2.00265	1699.79	113.465	6.31477	249.048	1445.78	Carbon Dioxide
Sulfur Dioxide		4.57379E-06	3.15669E-06	5.49733E-05	2.42286E-07	7.97703E-05	8.10752E-05	1.30490E-06	1.54719E-06	0.00439252	8.10752E-05	4.51213E-06	0.00434101	4.57379E-06	Sulfur Dioxide
MEA		6298.96	1569.81	7850.20	0.0741356	334.534	340.006	5.47237	5.54651	0.406956	340.006	18.9226	0.127465	6298.96	MEA
Argon		0.000627864	2.91436E-06	0.00768432	2.48071E-09	0.0111000	0.0112816	0.000181577	0.000181579	380.652	0.0112816	0.000627863	380.645	0.000627864	Argon
NO		3.25692E-07	2.58960E-09	3.98953E-06	2.44303E-12	5.75792E-06	5.85211E-06	9.41893E-08	9.41917E-08	0.140883	5.85211E-06	3.25692E-07	0.140879	3.25692E-07	NO
NO2		4.97433E-07	2.07964E-08	6.01850E-06	1.43423E-08	8.72963E-06	8.87243E-06	1.42801E-07	1.57143E-07	0.0229721	8.87243E-06	4.93783E-07	0.0229661	4.97433E-07	NO2
NH3		0.0965183	0.0319624	0.172149	0.00805848	0.161658	0.164303	0.00264444	0.0107029	0.220581	0.164303	0.00914404	0.175815	0.0965183	NH3
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fraction
Oxygen		2.59434E-05	5.04548E-07	0.000250893	1.84556E-08	0.000376588	0.000376588	0.000376588	0.000301970	14.0700	0.000376588	0.000376588	15.1151	2.59434E-05	Oxygen
Nitrogen		7.12240E-05	9.38656E-07	0.000689655	1.43750E-08	0.00103387	0.00103387	0.00103387	0.000829010	71.9134	0.00103387	0.00103387	77.2557	7.12240E-05	Nitrogen
Water		59.2118	54.7391	54.4146	99.7703	98.1052	98.1052	98.1052	98.4351	7.07331	98.1052	98.1052	5.46029	59.2118	Water
Carbon Dioxide		5.78798	10.2062	11.1421	0.143461	0.366964	0.366964	0.366964	0.322676	5.76809	0.366964	0.366964	0.907915	5.78798	Carbon Dioxide
Sulfur Dioxide		2.66543E-08	7.39302E-08	2.52961E-07	2.86783E-07	3.81693E-07	3.81693E-07	3.81693E-07	3.62886E-07	2.16979E-05	3.81693E-07	3.81693E-07	2.30366E-05	2.66543E-08	
MEA		30	30.0040	34.4422 2.20400E.0E	0.0836684	2 211025 05	2 211025 05	2 211025 05	1.24038	0.00191672	2 211025 05	2 211025 05	0.000644952	30	Argon
		2.28100E-00	4.25013E-00	2.20490E-03	1.03098E-09	3.31192E-03 1 200//3E-08	1 200/3E-08	1 200/3E-08	2.03008E-03	0.000325955	1 200/3E-08	1 200/3E-08	0.000350164	2.28100E-00 8 88986E-10	
NO2		2 08172E-09	3 49764E-10	1 98878E-08	1.00441E 12	2 99961F-08	2 99961E-08	2 99961E-08	2 64680E-08	8 14891F-05	2 99961E-08	2 99961E-08	8 75209E-05	2 08172E-09	NO2
NH3		0.000149526	0.000198996	0.000210582	0.00253568	0.000205629	0.000205629	0.000205629	0.000667337	0.000289658	0.000205629	0.000205629	0.000248028	0.000149526	NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen		0.285199	0.00138015	3.49301	9.98880E-07	5.04205	5.12452	0.0824789	0.0824799	182476	5.12452	0.285199	182472	0.285199	Oxygen
Nitrogen		0.782975	0.00256761	9.60158	7.78027E-07	13.8423	14.0687	0.226435	0.226435	932653	14.0687	0.782975	9.32643E+05	0.782975	Nitrogen
Water		650923	149734	757576	5399.92	1.31351E+06	1.33499E+06	21486.6	26886.5	91734.4	1.33499E+06	74297.2	65918	650923	Water
Carbon Dioxide		63628.1	27918.3	155123	7.76463	4913.19	4993.56	80.3709	88.1356	74806.9	4993.56	277.910	10960.5	63628.1	Carbon Dioxide
Sulfur Dioxide		0.000293014	0.000202230	0.00352180	1.55217E-05	0.00511039	0.00519399	8.35968E-05	9.91186E-05	0.281402	0.00519399	0.000289064	0.278102	0.000293014	Sulfur Dioxide
MEA		384760	95888.6	479514	4.52843	20434.4	20768.6	334.270	338.798	24.8581	20768.6	1155.85	7.7860	384760	MEA
Argon		0.0250819	0.000116423	0.306973	9.90994E-08	0.443424	0.450678	0.00725363	0.00725373	15206.3	0.450678	0.0250819	15206.0	0.0250819	Argon
NO		9.77275E-06	7.77039E-08	0.000119710	7.33057E-11	0.000172773	0.000175599	2.82625E-06	2.82633E-06	4.22735	0.000175599	9.77273E-06	4.22723	9.77275E-06	NO
NO2		2.28847E-05	9.56750E-07	0.000276884	6.59823E-07	0.000401611	0.000408180	6.56964E-06	7.22946E-06	1.05684	0.000408180	2.27167E-05	1.05657	2.28847E-05	NO2
NH3		1.64376	0.544336	2.93179	0.137240	2.75312	2.79816	0.0450362	0.182276	3.75660	2.79816	0.155728	2.99423	1.64376	NH3
Process Streams		104	105	106	107	108	109	110	111	200	201	202	203	204	Process Streams
	Units	F 1 0000		50.0565	17.00-0	00.000			05	50.000	F0 0000	F0 0000	10	<b>51 0000</b>	
l emperature	۲C اد	54.0660	58.8945	53.3528	47.2376	20.0000	20.0000	20.0000	25.5617	50.2334	52.9286	52.9286	42.7843	54.0660	C l'emperature
Melo Fraction Vener	uar v	3.68912	5.15772	1.08857	4.13685	3.44658	3.44658	3.44658	3.44658	1.08857	4.48079	4.48079	1.01273	3.68912	Dar Pressure
Molecular Wordst	70 ka/kmcl	0 25 05 47	0	0	10 0440	40.0540	19 2542	10.0540	10 2000	100	10.0540	10 0540	100	0 25 05/7	ka/kmol Molecular Wojcht
Molecular Weight	kg/m/2	25.0547	20.0120	20.0303	10.0412	10.2513	10.2513	10.2313	10.2093	20.0905	10.2013	10.2013	27.0903	25.0547	kg/million Molecular Weight
Molar Flow	kmol/b	1000.00	1142.49	53/27 5	900.904 200	535.014 73357 7	999.014 7/557 7	399.814	397.898	1.13008	901.129 71557 7	901.129 1110 11	1.07581	100.00	kmol/h Molar Flow
Mass Flow	ka/b	+3070.0 1 09931F±06	0010.7	1 39223E±06	5412 36	1 33888F±06	1 36078E±06	21001 A	27314 0	1 29601F±06	1.36078E±06	75722 2	43204.4 1 20722F±06	+3070.0 1 09931F±06	ko/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	1.03946F+06	213342	1.26572E+06	7107 13	1 73788F∔06	1.76630E+06	21301.0 28428 5	35535.7	1.09376F+06	1 76630F+06	98301 3	1 02543F+06	1.03946F+06	m^3/h Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	1106.22	277.877	1417.30	5.41936	1340 84	1362.77	21.9337	27.3531	1510.82	1362.77	75.8433	1407 19	1106.22	m^3/h Std Liquid Volumetric Flow
Specific Gravity		1.08959	1.14357	1.15300	0.989839	1.00076	1.00076	1.00076	0.998842	0.970278	0.988662	0.988662	0.963364	1.08959	Specific Gravity
Mass Enthalpy	kJ/ka	-11403.7	-11154.7	-11195.7	-15753.3	-15688.5	-15688.5	-15688.5	-15701.3	-1438.77	-15552.4	-15552.4	-795.631	-11403.7	kJ/kg Mass Enthalpy
Dynamic Viscosity	сР	1.76569	2.16333	2.58560	0.563550	1.04930	1.04930	1.04930	0.907633	0.0187333	0.524860	0.524860	0.0186124	1.76569	cP Dynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.4170	0.3877	0.3816	0.6325	0.5881	0.5881	0.5881	0.5977	0.0267	0.6282	0.6282	0.0265	0.4170	W/(m*℃) Thermal Conducti vity
Surface Tension	dyne/cm	59.3829	92.7571	95.5100	68.3735	73.3744?	73.3744?	73.3744?	72.3816?		67.0193	67.0193		59.3829	dyne/cm Surface Tension

Process Streams		205	206	207	208	209	210	211	300	302	303	304	305	306	Process Streams
		Cooled Semi-Lean Amine (Abs. 2)	Rich Amine (Abs. 2)	Process Water to Upper Bed (Abs. 2)	Cooled Wash Water to Lower Bed (Abs. 2)	Cooled Wash Water (Abs. 2)	Cooled Wash Water to Upper Bed (Abs. 2)	Combined Wash Water to Upper Bed (Abs. 2)	Combined Cold Rich Amine	Hot Rich Amine	Stripper Bottoms to E-108 Inlet	Rich Amine to E-103	Lean Amine	Filtered Lean Amine	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		4.10160E-07	0.000204316	1.04054E-08	0.000214797	0.000214797	0.000214797	0.000171839	0.000204316	0.000204316	0	0.000204316	2.03133E-05	2.03133E-05	Oxygen
Nitrogen		8.71616E-07	0.000641523	9.25780E-09	0.000673590	0.000673590	0.000673590	0.000538874	0.000641523	0.000641523	0	0.000641523	6.37014E-05	6.37014E-05	Nitrogen
Water		79.0389	78.7083	99.9138	99.3907	99.3907	99.3907	99.4953	78.7083	78.7083	80.5160	78.7083	82.3485	82.3485	Water
Carbon Dioxide		6.03259	6.59730	0.0588102	0.152185	0.152185	0.152185	0.133510	6.59730	6.59730	3.63314	6.59730	3.29511	3.29511	Carbon Dioxide
Sulfur Dioxide		3.00188E-08	1.02893E-07	8.07619E-08	1.08742E-07	1.08742E-07	1.08742E-07	1.03146E-07	1.02893E-07	1.02893E-07	0	1.02893E-07	1.04242E-08	1.04242E-08	Sulfur Dioxide
MEA		14.9282	14.6932	0.0247119	0.456031	0.456031	0.456031	0.369767	14.6932	14.6932	15.8506	14.6932	14.3561	14.3561	MEA
Argon		2.77143E-08	1.43827E-05	8.26903E-10	1.51314E-05	1.51314E-05	1.51314E-05	1.21053E-05	1.43827E-05	1.43827E-05	0	1.43827E-05	1.43098E-06	1.43098E-06	Argon
NO		2.46260E-11	7.46719E-09	8.14342E-13	7.84911E-09	7.84911E-09	7.84911E-09	6.27945E-09	7.46719E-09	7.46719E-09	0	7.46719E-09	7.42291E-10	7.42291E-10	NO
NO2		1.97765E-10	1.12648E-08	4.78076E-09	1.19001E-08	1.19001E-08	1.19001E-08	1.04762E-08	1.12648E-08	1.12648E-08	0	1.12648E-08	1.13371E-09	1.13371E-09	NO2
NH3		0.000303949	0.000322211	0.00268616	0.000220370	0.000220370	0.000220370	0.000713528	0.000322211	0.000322211	0.000215357	0.000322211	0.000219977	0.000219977	NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen		4.31312E-05	0.109161	3.12162E-08	0.157570	0.160147	0.00257756	0.00257759	0.218322	0.174657	0	0.0436643	0.0142605	0.00356512	Oxygen
Nitrogen		9.16566E-05	0.342750	2.77734E-08	0.494130	0.502213	0.00808308	0.00808311	0.685499	0.548399	0	0.137100	0.0447200	0.0111800	Nitrogen
Water		8311.50	42051.9	299.741	72910.7	74103.3	1192.69	1492.43	84103.7	67283.0	63799.5	16820.7	57810.8	14452.7	Water
Carbon Dioxide		634.370	3524.77	0.176431	111.639	113.465	1.82622	2.00265	7049.54	5639.63	2878.84	1409.91	2313.25	578.312	Carbon Dioxide
Sulfur Dioxide		3.15669E-06	5.49733E-05	2.42286E-07	7.97703E-05	8.10752E-05	1.30490E-06	1.54719E-06	0.000109947	8.79572E-05	0	2.19893E-05	7.31807E-06	1.82952E-06	Sulfur Dioxide
MEA		1569.81	7850.20	0.0741356	334.534	340.006	5.47237	5.54651	15700.4	12560.3	12559.8	3140.08	10078.3	2519.58	MEA
Argon		2.91436E-06	0.00768432	2.48071E-09	0.0111000	0.0112816	0.000181577	0.000181579	0.0153686	0.0122949	0	0.00307373	0.00100458	0.000251146	Argon
NO		2.58960E-09	3.98953E-06	2.44303E-12	5.75792E-06	5.85211E-06	9.41893E-08	9.41917E-08	7.97905E-06	6.38324E-06	0	1.59581E-06	5.21107E-07	1.30277E-07	
		2.07964E-08	0.01850E-06	1.43423E-08	8.72963E-06	8.87243E-06	1.42801E-07	1.57 143E-07	1.20370E-05	9.02959E-00	0 170645	2.40740E-06	7.95893E-07	1.98973E-07	
		0.0319624	0.172149	0.00605646	0.101050	0.104303	0.00204444	0.0107029	0.344296	0.275436	0.170645	0.0688596	0.154429	0.0366073	
		5.04548E-07	0.000250893	1 84556E-08	0 000376588	0.000376588	0 000376588	0.000301970	0 000250893	0.000250893	<i>,</i> ,	0.000250893	2 59434E-05	2 59/3/E-05	
Nitrogen		9 38656E-07	0.000230893	1.04550E-08	0.000370388	0.000370388	0.000370388	0.000301970	0.000230893	0.000230893	0	0.000230893	7 12240E-05	7 12240E-05	Nitrogen
Water		54 7391	54 4146	99 7703	98 1052	98 1052	98 1052	98 4351	54 4146	54 4146	56 2517	54 4146	59 2118	59 2118	Water
Carbon Dioxide		10 2062	11 1421	0 143461	0.366964	0.366964	0.366964	0.322676	11 1421	11 1421	6 20071	11 1421	5 78798	5 78798	Carbon Dioxide
Sulfur Dioxide		7.39302E-08	2.52961E-07	2.86783E-07	3.81693E-07	3.81693E-07	3.81693E-07	3.62886E-07	2.52961E-07	2.52961E-07	0.2001 1	2.52961E-07	2.66543E-08	2.66543E-08	Sulfur Dioxide
MEA		35.0545	34.4422	0.0836684	1.52623	1.52623	1.52623	1.24038	34.4422	34.4422	37.5474	34.4422	35	35	MEA
Argon		4.25613E-08	2.20490E-05	1.83098E-09	3.31192E-05	3.31192E-05	3.31192E-05	2.65568E-05	2.20490E-05	2.20490E-05	0	2.20490E-05	2.28160E-06	2.28160E-06	Argon
NO		2.84066E-11	8.59845E-09	1.35441E-12	1.29043E-08	1.29043E-08	1.29043E-08	1.03476E-08	8.59845E-09	8.59845E-09	0	8.59845E-09	8.88986E-10	8.88986E-10	NO
NO2		3.49764E-10	1.98878E-08	1.21911E-08	2.99961E-08	2.99961E-08	2.99961E-08	2.64680E-08	1.98878E-08	1.98878E-08	0	1.98878E-08	2.08172E-09	2.08172E-09	NO2
NH3		0.000198996	0.000210582	0.00253568	0.000205629	0.000205629	0.000205629	0.000667337	0.000210582	0.000210582	0.000142233	0.000210582	0.000149526	0.000149526	NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen		0.00138015	3.49301	9.98880E-07	5.04205	5.12452	0.0824789	0.0824799	6.98603	5.58882	0	1.39721	0.456318	0.114080	Oxygen
Nitrogen		0.00256761	9.60158	7.78027E-07	13.8423	14.0687	0.226435	0.226435	19.2032	15.3625	0	3.84063	1.25276	0.313190	Nitrogen
Water		149734	757576	5399.92	1.31351E+06	1.33499E+06	21486.6	26886.5	1.51515E+06	1.21212E+06	1.14937E+06	303030	1.04148E+06	260369	Water
Carbon Dioxide		27918.3	155123	7.76463	4913.19	4993.56	80.3709	88.1356	310247	248197	126696	62049.3	101805	25451.2	Carbon Dioxide
Sulfur Dioxide		0.000202230	0.00352180	1.55217E-05	0.00511039	0.00519399	8.35968E-05	9.91186E-05	0.00704359	0.00563487	0	0.00140872	0.000468823	0.000117206	Sulfur Dioxide
MEA		95888.6	479514	4.52843	20434.4	20768.6	334.270	338.798	959029	767223	767190	191806	615616	153904	MEA
Argon		0.000116423	0.306973	9.90994E-08	0.443424	0.450678	0.00725363	0.00725373	0.613947	0.491157	0	0.122789	0.0401310	0.0100328	Argon
NO		7.77039E-08	0.000119710	7.33057E-11	0.000172773	0.000175599	2.82625E-06	2.82633E-06	0.000239420	0.000191536	0	4.78841E-05	1.56364E-05	3.90910E-06	NO
NO2		9.56750E-07	0.000276884	6.59823E-07	0.000401611	0.000408180	6.56964E-06	7.22946E-06	0.000553768	0.000443014	0	0.000110754	3.66155E-05	9.15386E-06	NO2
		0.544336	2.93179	0.137240	2.75312	2.79816	0.0450362	0.182276	5.86357	4.69086	2.90618	1.17271	2.63001	0.657503	
Process Streams	Unito	205	200	207	200	209	210	211	300	302	303	304	305	300	Flocess Streams
	Units	50.0045	52.2520	47.0070	20,0000	20,0000	20,0000	25 5047	52 4007	447*	400.054	E2 4007	54.0000	E4.0000	
l'emperature	ل hor	58.8945	53.3528	47.2376	20.0000	20.0000	20.0000	25.5617	53.4987	0 70702	126.354	53.4987	54.0660	54.0660	C l'emperature
Mele Fraction Vapor	0/	5.15772	1.06657	4.13005	3.44050	3.44036	3.44030	3.44030	10.7412	9.70702	5.41200	10.7412	3.00912	3.00912	Molo Eraction Vapor
Molecular Weight	/0 ka/kmol	26.0126	26.0583	18 0412	18 2513	18 2513	18 2513	18 2093	26.0583	26.0583	25 7862	26.0583	25 0547	25.0547	ka/kmol Molecular Weight
Mass Density	kg/m/3	1142 49	1151 91	988 904	999 814	999 814	999 814	997 898	1151 99	1132 35	1067 79	1151 99	1088 56	1088 56	kg/m/3 Mass Density
Molar Flow	kmol/h	10515 7	53427 5	300.904 200	73357 7	74557 7	1200	337.090 1500	106855	85483 0	79238 3	21371 0	70202.6	17550.6	kmol/h Molar Flow
Mass Flow	ka/h	273542	1.39223F+06	5412.36	1.33888F+06	1.36078F+06	21901 6	27314 0	2.78446F+06	2.22757F+06	2.04326F+06	556892	1.75890F+06	439726	kg/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	249122	1.26572E+06	7107.13	1.73788E+06	1.76630E+06	28428 5	35535 7	2.53144E+06	2.02515E+06	1.87719E+06	506288	1.66313E+06	415783	m^3/h Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	277.877	1417.30	5.41936	1340.84	1362.77	21.9337	27.3531	2834.60	2267,68	2056.85	566.920	1769.96	442.490	m^3/h Std Liquid Volumetric Flow
Specific Gravity		1.14357	1.15300	0.989839	1.00076	1.00076	1.00076	0.998842	1.15307	1.13342	1.06880	1.15307	1.08959	1.08959	Specific Gravity
Mass Enthalpy	kJ/kg	-11154.7	-11195.7	-15753.3	-15688.5	-15688.5	-15688.5	-15701.3	-11194.4	-10966.7	-10823.5	-11194.4	-11403.7	-11403.7	kJ/kg Mass Enthalpy
Dynamic Viscosity	сР	2.16333	2.58560	0.563550	1.04930	1.04930	1.04930	0.907633	2.57968	0.687667	0.518578	2.57968	1.76569	1.76569	cP Dynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.3877	0.3816	0.6325	0.5881	0.5881	0.5881	0.5977	0.3817	0.3948	0.4154	0.3817	0.4170	0.4170	W/(m*℃) Thermal Conducti vity
Surface Tension	dyne/cm	92.7571	95.5100	68.3735	73.3744?	73.3744?	73.3744?	72.3816?	92.9823?	87.0585	46.6229?	92.9823	59.3829	59.3829	dyne/cm Surface Tension

Process Streams		307	309	310	311	312	313	314	315	316	317	318	319	320	322	323	324	325	Process Streams
			Rich Amine	Rich Amine	Rich Amine		Hot Semi-	Stripper	Bottoms to	Reclaimer	Reclaimer	Stripper Reboiler	Stripper Reboiler	Stripper	Stripper		Cooled Stripper	Stripper Overhead	
		Fresh Amine	to E-107	to E-109	to V-101	Flash Gas	Lean Amine	Bottoms	E-107	Feed	Product	Inlet	Discharge	Overhead	Reflux	Reflux Purge	Overhead	Liquid	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		0	0.000204316	0.000204316	0.000204316	0.0128335	4.10161E-07	0	0	0	0	0	0	0.00298447	2.19560E-07	2.19560E-07	0.00298447	2.19560E-07	Oxygen
Nitrogen		0	0.000641523	0.000641523	0.000641523	0.0403213	8.71618E-07	0	0	0	0	0	0	0.00937200	3.66121E-07	3.66121E-07	0.00937200	3.66121E-07	Nitrogen
Water		0	78.7083	78.7083	78.7083	58.2345	79.0389	80.5160	80.5160	80.5160	95.6822	80.5160	80.5160	60.2801	99.8826	99.8826	60.2801	99.8826	Water
Carbon Dioxide		0	6.59730	6.59730	6.59730	41.5730	6.03259	3.63314	3.63314	3.63314	4.31750	3.63314	3.63314	39.6905	0.0880881	0.0880881	39.6905	0.0880881	Carbon Dioxide
Sulfur Dioxide		0	1.02893E-07	1.02893E-07	1.02893E-07	4.61648E-06	3.00188E-08	0	0	0	0	0	0	1.42132E-06	7.10486E-08	7.10486E-08	1.42132E-06	7.10486E-08	Sulfur Dioxide
MEA		100	14.6932	14.6932	14.6932	0.137029	14.9282	15.8506	15.8506	15.8506	0	15.8506	15.8506	0.0151947	0.0263917	0.0263917	0.0151947	0.0263917	MEA
Argon		0	1.43827E-05	1.43827E-05	1.43827E-05	0.000903482	2.77144E-08	0	0	0	0	0	0	0.000210094	1.63991E-08	1.63991E-08	0.000210094	1.63991E-08	Argon
NO		0	7.46719E-09	7.46719E-09	7.46719E-09	4.68433E-07	2.46261E-11	0	0	0	0	0	0	1.09047E-07	1.18544E-11	1.18544E-11	1.09047E-07	1.18544E-11	NO
		0	1.12648E-08	1.12648E-08	1.12048E-08	0.90718E-07	1.97766E-10	0.000215257	0 000215257	0 000215257	0 000355033	0 000215257	0.000215257	1.64052E-07	1.70519E-10	1.70519E-10	1.64052E-07	1.70519E-10	
NH3 Molar Flow		kmol/h	0.000322211	0.000322211	0.000322211	0.00145348	0.000303946	0.000215357	0.000215357	0.000215357	0.000255923	0.000215357	0.000215357	0.00166651	0.00288469	0.00288469	0.00100051	0.00288469	
			0.0436643	0.0426642	0.0436643	0.0425790	8 62627E 05	<u> </u>	KIIIO//II	<u> </u>	0		0	0.219226	0.24250E.07	8 21015E 06	0.219226	0.24250E.06	
Nitrogen		0	0.0430043	0.137100	0.0430043	0.136917	0.000183314	0	0	0	0	0	0	0.210230	9.24330E-07	1 38724E-05	0.210200	3.24330E-00	Nitrogen
Water		0	16820 7	16820 7	16820 7	197 743	16623.0	63799.5	63799.5	0	0	42533.0	42533.0	4407 92	420 507	3784 57	4407.92	4205 07	Water
Carbon Dioxide		0	1409.91	1409 91	1409 91	141 167	1268 74	2878 84	2878 84	0	0	1919 23	1919 23	2902.33	0.370852	3 33767	2902.33	3 70852	Carbon Dioxide
Sulfur Dioxide		0	2 19893E-05	2 19893E-05	2 19893E-05	1 56759E-05	6 31338E-06	20/0.01	2010.01	0	0	0 10 10.20	0	0.000103932	2 99116E-07	2 69204F-06	0 000103932	2 99116E-06	Sulfur Dioxide
MEA		0.255161	3140.08	3140.08	3140.08	0.465301	3139.61	12559.8	12559.8	0	0	8373.19	8373.19	1.11110	0.111110	0.99999	1.11110	1.11110	MEA
Argon		0	0.00307373	0.00307373	0.00307373	0.00306790	5.82872E-06	0	0	0	0	0	0	0.0153629	6.90405E-08	6.21365E-07	0.0153629	6.90405E-07	Argon
NO		0	1.59581E-06	1.59581E-06	1.59581E-06	1.59063E-06	5.17922E-09	0	0	0	0	0	0	7.97393E-06	4.99070E-11	4.49163E-10	7.97393E-06	4.99070E-10	NO
NO2		0	2.40740E-06	2.40740E-06	2.40740E-06	2.36581E-06	4.15929E-08	0	0	0	0	0	0	1.19961E-05	7.17889E-10	6.46100E-09	1.19961E-05	7.17889E-09	NO2
NH3		0	0.0688596	0.0688596	0.0688596	0.00493551	0.0639241	0.170645	0.170645	0	0	0.113764	0.113764	0.121862	0.0121446	0.109301	0.121862	0.121446	NH3
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fraction
Oxygen		0	0.000250893	0.000250893	0.000250893	0.0142160	5.04549E-07	0	0	0	0	0	0	0.00336972	3.89243E-07	3.89243E-07	0.00336972	3.89243E-07	Oxygen
Nitrogen		0	0.000689655	0.000689655	0.000689655	0.0391020	9.38658E-07	0	0	0	0	0	0	0.00926385	5.68231E-07	5.68231E-07	0.00926385	5.68231E-07	Nitrogen
Water		0	54.4146	54.4146	54.4146	36.3179	54.7390	56.2517	56.2517	56.2517	90.0711	56.2517	56.2517	38.3185	99.6932	99.6932	38.3185	99.6932	Water
Carbon Dioxide		0	11.1421	11.1421	11.1421	63.3369	10.2062	6.20071	6.20071	6.20071	9.92868	6.20071	6.20071	61.6348	0.214782	0.214782	61.6348	0.214782	Carbon Dioxide
Sulfur Dioxide		0	2.52961E-07	2.52961E-07	2.52961E-07	1.02382E-05	7.39302E-08	0	0	0	0	0	0	3.21290E-06	2.52175E-07	2.52175E-07	3.21290E-06	2.52175E-07	Sulfur Dioxide
MEA		100	34.4422	34.4422	34.4422	0.289756	35.0545	37.5474	37.5474	37.5474	0	37.5474	37.5474	0.0327497	0.0893148	0.0893148	0.0327497	0.0893148	MEA
Argon		0	2.20490E-05	2.20490E-05	2.20490E-05	0.00124944	4.25613E-08	0	0	0	0	0	0	0.000296143	3.62953E-08	3.62953E-08	0.000296143	3.62953E-08	Argon
NO		0	8.59845E-09	8.59845E-09	8.59845E-09	4.86583E-07	2.84067E-11	0	0	0	0	0	0	1.15456E-07	1.97071E-11	1.97071E-11	1.15456E-07	1.97071E-11	NO
NO2		0	1.98878E-08	1.98878E-08	1.98878E-08	1.10960E-06	3.49764E-10	0	0	0	0	0	0	2.66308E-07	4.34628E-10	4.34628E-10	2.66308E-07	4.34628E-10	NO2
NH3		0	0.000210582	0.000210582	0.000210582	0.000856915	0.000198994	0.000142233	0.000142233	0.000142233	0.000227745	0.000142233	0.000142233	0.00100145	0.00272183	0.00272183	0.00100145	0.00272183	NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow										
Oxygen		0	1.39721	1.39721	1.39721	1.39445	0.00276030	0	0	0	0	0	0	6.98330	2.95781E-05	0.000266203	6.98330	0.000295781	Oxygen
Nitrogen		0	3.84063	3.84063	3.84063	3.83550	0.00513524	0	0	0	0	0	0	19.1981	4.31792E-05	0.000388612	19.1981	0.000431792	Nitrogen
Water		0	303030	303030	303030	3562.40	299468	1.14937E+06	1.14937E+06	0	0	766244	766244	79409.9	7575.56	68180.0	79409.9	75755.6	Water
Carbon Dioxide		0	62049.3	62049.3	62049.3	6212.69	55836.6	126696	126696	0	0	84464.3	84464.3	127730	16.3210	146.889	127730	163.210	Carbon Dioxide
Sulfur Dioxide		0	0.00140872	0.00140872	0.00140872	0.00100426	0.000404459	0	0	0	0	0	0	0.00665830	1.91625E-05	0.000172462	0.00665830	0.000191625	Sulfur Dioxide
MEA		15.58600	191806	191806	191806	28.4220	191777	767190	767190	0	0	511460	511460	67.8693	6.78692	61.0823	67.8693	67.8692	MEA
Argon		0	0.122789	0.122789	0.122789	0.122556	0.000232846	0	0	0	0	0	0	0.613717	2.75803E-06	2.48223E-05	0.613717	2.75803E-05	Argon
NO		0	4.78841E-05	4.78841E-05	4.78841E-05	4.77287E-05	1.55408E-07	0	0	0	0	0	0	0.000239266	1.49752E-09	1.34776E-08	0.000239266	1.49752E-08	NO
NO2		0	0.000110754	0.000110754	0.000110754	0.000108840	1.91350E-06	0	0	0	0	0	0	0.000551887	3.30268E-08	2.97241E-07	0.000551887	3.30268E-07	NO2
		0	1.17271	1.17271	1.17271	0.0840544	1.08866	2.90618	2.90618	0	0	1.93745	1.93745	2.07537	0.206829	1.86146	2.07537	2.06829	
Process Streams	Unite	307	309	310	311	312	313	314	315	310	317	318	319	320	322	323	324	325	Process Streams
	Units	00.0000*	4.00*	440 770*	101 500	440 740	140 700	407 540	407.044			407.540	100.115	404.070	40 7470	40.7470	40.0000*	40.0040	
Temperature	ل ا	20.0000*	108"	112.778	121.523	113.716	113.769	127.543	127.611	6 40000	C 40000	127.543	130.115	104.872	48.7470	48.7470	48.8889"	48.6910	
Mele Erection Vanor	0/	4.13065	9.70702	0.07201	7.03059	2.39962	5.64719	2.31016	0.10220	0.10220	0.10220	2.31010	2.31010	1.90543	5.24044	5.24044	1.02755	1.79306	Mole Eraction Vapor
Molecular Weight	/0 ka/kmol	61 0221	26 0593	26 0592	26 0593	28 8860	26 0127	25 7862	25 7862	25 7860	10 1276	25 7862	13.2009	28 2404	18 0/05	18 0/05	42.0994 28 2101	18 0/05	ka/kmol Molecular Weight
Mass Density	kg/m/2	1021 /20	1136.03	112/ 10	20.0000	20.0009	112/ 16	1067 02	1067 04	20.7002	13.1370	1067.02	20.1002	1 72007	088 100	088 120	20.3404 1 50755	0.0495	ka/m/3 Mass Density
Molar Flow	kmol/h	0 255161	21371 0	21371 0	21371 0	330 564	21031 /	70228 2	70228 2	0	٥	52825 5	502109	7312 /0	300.420 421 ∩∩2	3789.01	4.09200	4210.02	kmol/h Molar Flow
Mass Flow	ka/h	15 58600	556802	556892	556802	9808 95	547083	2.04326F+06	2.04326F+06	0	0	1.36217F+06	1.36217F+06	207236	7598.87	68389 0	207236	75988 7	kg/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	6 04488	506288	506288	506288	8044 43	498244	1.87719F+06	1.87719F+06	0	0	1.25146F+06	1 25146F+06	173234	9973 71	89763.4	173234	99737 1	m^3/h Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	0.01527880	566 920	566 920	566 920	11 1652	555 754	2056.85	2056 85	0	0	1371 23	1371 23	235 125	7 60988	68 4889	235 125	76 0988	m^3/h Std Liquid Volumetric Flow
Specific Gravity		1.022390	1.13711	1.13517	1.13145	0,997785	1.12522	1.06803	1.06805	0	0	1.06803	107 1.20	0,978911	0,989354	0,989354	200.120	0.989329	Specific Gravity
Mass Enthalpy	kJ/ka	-4445.34	-11001 1	-10983 0	-10949 3	-10440.2	-10957.9	-10819 1	-10818.6	-10818.6		-10819 1	-10503.6	-10557.6	-15741.5	-15741.5	-11500 7	-15742 1	kJ/kg Mass Enthalpv
Dynamic Viscositv	cP	26.81740	0.793000	0.734002	0.642577	0.0170309	0.705350	0.509977	0.509959			0.509977	10000.0	0.0165419	0.548086	0.548086	11000.7	0.548234	cP Dynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.2355	0.3944	0.3947	0.3948	0.0247	0.3985	0.4153	0.4153			0.4153		0.0240	0.6335	0.6335		0.6334	W/(m*℃) Thermal Cond uctivity
Surface Tension	dyne/cm	48.9361	88.2210	87.8667	86.9593		86.8087	46.4196?	46.4011?			46.4196?			68.0583	68.0583		68.0693	dyne/cm Surface Tension

Process Streams		330	332	333	334	400	401	402	403	404	405	406	407	408	409	410	Process Streams
		Hot Semi-	Cold Rich Amine to Lean / Rich Exchanger	Process Water to	Lean Amine to E-102 Inlet	602	1st Stage Suction	Hot 1st Stage	Cooled 1st Stage	Cold 1st Stage	2nd Stage Suction	Hot 2nd Stage	Cooled 2nd Stage	Cold 2nd Stage	Drver Inlet	3rd Stage Suction	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		4.10161E-07	0.000204316	1.04054E-08*	0	0.00703418	0.00703424	0.00703424	0.00703424	0.00703424	0.00747761	0.00747761	0.00747761	0.00747761	0.00751327	0.00752665	Oxygen
Nitrogen		8.71618E-07	0.000641523	9.25780E-09*	0	0.0220896	0.0220898	0.0220898	0.0220898	0.0220898	0.0234821	0.0234821	0.0234821	0.0234821	0.0235942	0.0236362	Nitrogen
Water		79.0389	78.7083	99.9138*	80.5160	6.53832	6.53752	6.53752	6.53752	6.53752	0.658028	0.658028	0.658028	0.658028	0.188668	0.0110000	Water
Carbon Dioxide		6.03259	6.59730	0.0588102*	3.63314	93.4320	93.4328	93.4328	93.4328	93.4328	99.3105	99.3105	99.3105	99.3105	99.7797	99.9573	Carbon Dioxide
Sulfur Dioxide		3.00188E-08	1.02893E-07	8.07619E-08*	0	3.25367E-06	3.25370E-06	3.25370E-06	3.25370E-06	3.25370E-06	3.44125E-06	3.44125E-06	3.44125E-06	3.44125E-06	3.45190E-06	3.45804E-06	Sulfur Dioxide
MEA		14.9282	14.6932	0.0247119*	15.8506	7.95992E-08	7.95734E-08	7.95734E-08	7.95734E-08	7.95734E-08	2.81680E-09	2.81680E-09	2.81680E-09	2.81680E-09	4.54389E-10	4.55197E-10	MEA
Argon		2.77144E-08	1.43827E-05	8.26903E-10*	0	0.000495175	0.000495179	0.000495179	0.000495179	0.000495179	0.000526390	0.000526390	0.000526390	0.000526390	0.000528900	0.000529842	Argon
NO		2.46261E-11	7.46719E-09	8.14342E-13*	0	2.57010E-07	2.57012E-07	2.57012E-07	2.57012E-07	2.57012E-07	2.73211E-07	2.73211E-07	2.73211E-07	2.73211E-07	2.74514E-07	2.75002E-07	NO
NO2		1.97766E-10	1.12648E-08	4.78076E-09*	0	3.86443E-07	3.86446E-07	3.86446E-07	3.86446E-07	3.86446E-07	3.97825E-07	3.97825E-07	3.97825E-07	3.97825E-07	3.95625E-07	3.96329E-07	NO2
NH3		0.000303946	0.000322211	0.00268616*	0.000215357	1.34106E-05	1.34106E-05	1.34106E-05	1.34106E-05	1.34106E-05	1.00720E-05	1.00720E-05	1.00720E-05	1.00720E-05	8.93896E-06	8.95487E-06	NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen		8.62627E-05	0.174657	2.24473E-08*	0	0.218227	0.218227	0.218227	0.218227	0.218227	0.218226	0.218226	0.218226	0.218226	0.218225	0.218225	Oxygen
Nitrogen		0.000183314	0.548399	1.99717E-08*	0	0.685302	0.685302	0.685302	0.685302	0.685302	0.685300	0.685300	0.685300	0.685300	0.685299	0.685299	Nitrogen
water		16623.0	67283.0	215.542*	63799.5	202.843	202.817	202.817	202.817	202.817	19.2038	19.2038	19.2038	19.2038	5.47990	0.318930	water
Carbon Dioxide		1268.74	5639.63	0.126870*	2878.84	2898.62	2898.62	2898.62	2898.62	2898.62	2898.27	2898.27	2898.27	2898.27	2898.13	2898.13	Carbon Dioxide
		0.31338E-06	8.79572E-05	1.74226E-07*	12550.0	2 460475 00	2 469655 00	2 469655 00	0.000100941	2 469655 00	8 220545 00	8 22054 5 00	0.000100429	0.000100429		1 310795 00	
		5 82872E-06	0.0122040	1 783865-00*	12009.8	2.4094/E-00	2.40000E-06	2.40000E-Ub	2.40000E-Ub	2.40000E-Ub	0.22001E-08	0.22001E-08	0.22001E-08	0.22001E-08	0.0152621	0.0153621	
NO		5 17922F-00	6 38324F-06	1 75676E-12*	0	7 97343F-06	7 97343E-06	7 97343E-06	7 973435-06	7 97343E-06	7 97336F-06	7 97336F-06	7 97336F-06	7 973365-06	7 97333E-06	7 97333E-06	NO
NO2		4.15929E-08	9 62959E-06	1 03134F-08*	0	1.19889E-05	1.19889E-05	1.19889F-05	1 19889F-05	1 19889E-05	1.16101E-05	1.16101E-05	1 16101F-05	1 16101F-05	1.14910E-05	1.14910E-05	NO2
NH3		0.0639241	0.275438	0.00579480*	0.170645	0.000416047	0.000416044	0.000416044	0.000416044	0.000416044	0.000293941	0.000293941	0.000293941	0.000293941	0.000259635	0.000259635	NH3
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fraction
Oxygen		5.04549E-07	0.000250893	1.84556E-08*	0	0.00532047	0.00532049	0.00532049	0.00532049	0.00532049	0.00545868	0.00545868	0.00545868	0.00545868	0.00546949	0.00547348	Oxygen
Nitrogen		9.38658E-07	0.000689655	1.43750E-08*	0	0.0146270	0.0146271	0.0146271	0.0146271	0.0146271	0.0150070	0.0150070	0.0150070	0.0150070	0.0150368	0.0150477	Nitrogen
Water		54.7390	54.4146	99.7703*	56.2517	2.78426	2.78391	2.78391	2.78391	2.78391	0.270444	0.270444	0.270444	0.270444	0.0773255	0.00450362	Water
Carbon Dioxide		10.2062	11.1421	0.143461*	6.20071	97.1953	97.1957	97.1957	97.1957	97.1957	99.7086	99.7086	99.7086	99.7086	99.9017	99.9745	Carbon Dioxide
Sulfur Dioxide		7.39302E-08	2.52961E-07	2.86783E-07*	0	4.92708E-06	4.92709E-06	4.92709E-06	4.92709E-06	4.92709E-06	5.02944E-06	5.02944E-06	5.02944E-06	5.02944E-06	5.03101E-06	5.03468E-06	Sulfur Dioxide
MEA		35.0545	34.4422	0.0836684*	37.5474	1.14930E-07	1.14892E-07	1.14892E-07	1.14892E-07	1.14892E-07	3.92525E-09	3.92525E-09	3.92525E-09	3.92525E-09	6.31441E-10	6.31901E-10	MEA
Argon		4.25613E-08	2.20490E-05	1.83098E-09*	0	0.000467581	0.000467582	0.000467582	0.000467582	0.000467582	0.000479726	0.000479726	0.000479726	0.000479726	0.000480677	0.000481027	Argon
NO		2.84067E-11	8.59845E-09	1.35441E-12*	0	1.82290E-07	1.82291E-07	1.82291E-07	1.82291E-07	1.82291E-07	1.87025E-07	1.87025E-07	1.87025E-07	1.87025E-07	1.87395E-07	1.87531E-07	NO
NO2		3.49764E-10	1.98878E-08	1.21911E-08*	0	4.20241E-07	4.20242E-07	4.20242E-07	4.20242E-07	4.20242E-07	4.17535E-07	4.17535E-07	4.17535E-07	4.17535E-07	4.14074E-07	4.14376E-07	NO2
NH3		0.000198994	0.000210582	0.00253568*	0.000142233	5.39857E-06	5.39854E-06	5.39854E-06	5.39854E-06	5.39854E-06	3.91324E-06	3.91324E-06	3.91324E-06	3.91324E-06	3.46337E-06	3.46590E-06	NH3
		kg/n	kg/n	Kg/n	kg/n	kg/n	kg/n	kg/n	kg/n	kg/n	kg/n	kg/n	kg/n	kg/n	Kg/n	kg/n	
Oxygen		0.00276030	5.58882	7.18288E-07*	0	6.98300	6.98300	6.98300	6.98300	6.98300	6.98296	6.98296	6.98296	6.98296	6.98294	6.98294	Oxygen
Nitrogen		0.00513524	15.3625	5.59474E-07*	0	19.1976	19.1976	19.1976	19.1976	19.1976	19.1976	19.1976	19.1976	19.1976	19.1976	19.1976	Nitrogen
Waler Corbon Diovido		299400	1.21212E+00	5005.05	1.14937 E+00	107567	107567	107567	3033.00	107567	345.962	345.962	345.902	345.962	90.7220	107545	Carbon Diavida
Sulfur Dioxide		0.000404459	0.00563487	1 11616E-05*	120090	0.00646668	0.00646668	0.00646668	0.00646668	0.00646668	0.00643386	0.00643386	0.00643386	0.00643386	0.00642313	0.00642313	
MEA		191777	767223	3 25636*	767190	0.00040000	0.00040000	0.00040000	0.00040000	0.00040000	5.02134E-06	5.02134E-06	5 02134E-06	5 02134E-06	8.06165E-07	8.06165E-07	MEA
Argon		0.000232846	0.491157	7.12617E-08*	0	0.613689	0.613689	0.613689	0.613689	0.613689	0.613685	0.613685	0.613685	0.613685	0.613683	0.613683	Argon
NO		1.55408E-07	0.000191536	5.27136E-11*	0	0.000239251	0.000239251	0.000239251	0.000239251	0.000239251	0.000239249	0.000239249	0.000239249	0.000239249	0.000239248	0.000239248	NO
NO2		1.91350E-06	0.000443014	4.74474E-07*	0	0.000551557	0.000551557	0.000551557	0.000551557	0.000551557	0.000534128	0.000534128	0.000534128	0.000534128	0.000528651	0.000528651	NO2
NH3		1.08866	4.69086	0.0986884*	2.90618	0.00708550	0.00708544	0.00708544	0.00708544	0.00708544	0.00500597	0.00500597	0.00500597	0.00500597	0.00442171	0.00442171	NH3
Process Streams		330	332	333	334	400	401	402	403	404	405	406	407	408	409	410	Process Streams
Property	Units																Units Property
Temperature	C	113.716	53.4987	47.2376*	58.7658	48.7012	48.7012	176.667*	129.444*	26*	25.8867	176.667*	129.444*	26*	25.9261	25.9261	°C Temperature
Pressure	bar	2.39982	10.7412	4.13685*	4.72333	1.79306	1.79306	6.03551	5.75972	5.41498	5.34604	23.1075	22.8317	22.4870	22.4181	22.4181	bar Pressure
Mole Fraction Vapor	%	0	0	0	0	99.9991	100	100	100	94.0633	100	100	100	99.5254	100	100	% Mole Fraction Vapor
Molecular Weight	kg/kmol	26.0127	26.0583	18.0412	25.7862	42.3055	42.3057	42.3057	42.3057	42.3057	43.8338	43.8338	43.8338	43.8338	43.9558	44.0019	kg/kmol Molecular Weight
Mass Density	kg/m^3	1124.14	1151.99	988.904	1099.87	2.85806	2.85805	6.88501	7.37041	10.0902	9.71145	27.9168	31.3459	45.7894	45.5572	45.5944	kg/m^3 Mass Density
Molar Flow	kmol/h	21031.4	85483.9	215.728	79238.3	3102.38	3102.35	3102.35	3102.35	3102.35	2918.39	2918.39	2918.39	2918.39	2904.53	2899.37	kmol/h Molar Flow
Mass Flow	kg/h	547083	2.22757E+06	3891.99*	2.04326E+06	131248	131247	131247	131247	131247	127924	127924	127924	127924	127671	127578	kg/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	498244	2.02515E+06	5110.69	1.87719E+06	73496.7	73496.1	73496.1	73496.1	73496.1	69137.9	69137.9	69137.9	69137.9	68809.5	68687.3	m^3/h Std Vapor Volumetric Flow
Sta Liquia Volumetric Flow	m^3/h	555.754	2267.68	3.89702	2056.85	159.027	159.026	159.026	159.026	159.026	155.696	155.696	155.696	155.696	155.441	155.348	mr/3/h Sta Liquid Volumetric Flow
Specific Gravity	14.1/14/2	1.12520	1.15307	0.989839	1.10091	0045.40	1.46129	1.46129	1.46129	0400.40	1.51407	1.51407	1.51407	0070 10	1.51828	1.51988	Specific Gravity
	кJ/Kg	-10958.4	-11194.4	-15753.3	-11071.7	-9045.10	-9045.08	-8924.50	-8971.65	-9130.16	-8956.04	-8823.38	-8871.30	-8978.42	-8965.08	-8961.76	kJ/kg IViass Enthalpy
Thermal Conductivity	UF \\\/(m*%)	0.705427	2.57968	0.563550	1.853/5		0.0101454 0.0107	0.0216019	0.0197044		0.0152834	0.0220095	0.0201805		0.0109386	0.0159403	
Surface Tension	dvne/cm	87 6007	0.3817	68 3735	57 9268		0.010/	0.0287	0.0251		0.0172	0.0296	0.0201		0.0169	0.0189	dvne/cm Surface Tension
	3,	01.0001	52.5625	00.0700	01.0200										L		-,

Process Streams		411	412	413	414	415	416	417	501	502	503	504	505	506	509	510	511	Process Streams	
		Hot 3rd Stage	Cooled 3rd Stage	Cold 3rd Stage		Inter-stage	Liquefied	-	SCW Supply	SCW Return	SCW Supply	SCW Return	SCW Supply to	SCW Return	SCW Supply	SCW Return	LP Steam		
Molo Fraction		Discharge	Discharge	Discharge	CO2 Product	Liquid	CO2	Dryer Water	to E-101	From E-101	to E-104	From E-104	E-102	From E-102	to E-111	From E-111	from E-112	Mole Freetien	
		70 0.00752665	70	0.00752665	70	70 0.41706E.07	70 0.00752665	70	70	76	70	76	70	70	7 <b>0</b>	76	70		
Nitrogen		0.00752005	0.00732003	0.00732003	0.00752005	1 46808E-06	0.00732003	0*	0*	0	0*	0	0*	0	0*	0	0	Nitrogen	
Water		0.0110000	0.0110000	0.0110000	0.0110000	99.7532	0.0110000	100*	100*	100	100*	100	100*	100	100*	100	100	Water	
Carbon Dioxide		99 9573	99 9573	99 9573	99 9573	0 246748	99 9573	0*	0*	0	0*	0		0	0*	0	0	Carbon Dioxide	
Sulfur Dioxide		3.45804E-06	3.45804E-06	3.45804E-06	3.45804E-06	3.43669E-07	3.45804E-06	0*	0*	0	0*	0	0*	0	0*	0	0	Sulfur Dioxide	
MEA		4.55197E-10	4.55197E-10	4.55197E-10	4.55197E-10	1.24120E-06	4.55197E-10	0*	0*	0	0*	0	0*	0	0*	0	0	MEA	
Argon		0.000529842	0.000529842	0.000529842	0.000529842	7.18473E-08	0.000529842	0*	0*	0	0*	0	0*	0	0*	0	0	Argon	
NO		2.75002E-07	2.75002E-07	2.75002E-07	2.75002E-07	5.10678E-11	2.75002E-07	0*	0*	0	0*	0	0*	0	0*	0	0	NO	
NO2		3.96329E-07	3.96329E-07	3.96329E-07	3.96329E-07	2.51704E-07	3.96329E-07	0*	0*	0	0*	0	0*	0	0*	0	0	NO2	
NH3		8.95487E-06	8.95487E-06	8.95487E-06	8.95487E-06	7.89279E-05	8.95487E-06	0*	0*	0	0*	0	0*	0	0*	0	0	NH3	
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow	
Oxygen		0.218225	0.218225	0.218225	0.218225	5 1.86311E-06	0.218225	0*	0*	0	0*	0	0*	0	0*	0	0	Oxygen	
Nitrogen		0.685299	0.685299	0.685299	0.685299	2.90423E-06	0.685299	0*	0*	0	0 0*	0	0*	0	0*	0	0	Nitrogen	
Water		0.318930	0.318930	0.318930	0.318930	197.337	0.318930	5*	253439*	253439	253439*	253439	45264.4*	45264.4	267730*	267730	147.981	Water	
Carbon Dioxide		2898.13	2898.13	2898.13	2898.13	0.488129	2898.13	0*	0*	0	0*	0	0*	0	0*	0	0	Carbon Dioxide	
		0.000100261	0.000100261	1.21078E.09	1.210795.09	6.79864E-07	1.210785.08	0*	0*	0	0 0*	0	0*	0	0*	0	0		
Argon		0.0153621	0.0153621	0.0153621	0.0153621	2.45540E-06	0.0153621	0*	0*	0	0*	0	0*	0	0*	0	0	Argon	
		7 97333E-06	7 97333E-06	7 97333E-06	7 97333E-06	1.42132E-07	7 97333E-06	0*	0*	0	0*	0	0*	0	0*	0	0	NO	
NO2		1.14910E-05	1.14910E-05	1.14910E-05	1.14910E-05	4.97934E-07	1.14910E-05	0*	0*	0	0*	0	0*	0	0*	0	0	NO2	
NH3		0.000259635	0.000259635	0.000259635	0.000259635	0.000156139	0.000259635	0*	0*	0	0*	0	0*	0	0*	0	0	NH3	
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fraction	
Oxygen		0.00547348	0.00547348	0.00547348	0.00547348	1.66689E-06	0.00547348	0*	0*	0	) 0*	0	0*	0	0*	0	0	Oxygen	
Nitrogen		0.0150477	0.0150477	0.0150477	0.0150477	2.27473E-06	0.0150477	0*	0*	0	0*	0	0*	0	0*	0	0	Nitrogen	
Water		0.00450362	0.00450362	0.00450362	0.00450362	99.3993	0.00450362	100*	100*	100	100*	100	100*	100	100*	100	100	Water	
Carbon Dioxide		99.9745	99.9745	99.9745	99.9745	0.600641	99.9745	0*	0*	0	0*	0	0*	0	0*	0	0	Carbon Dioxide	
Sulfur Dioxide		5.03468E-06	5.03468E-06	5.03468E-06	5.03468E-06	5 1.21778E-06	5.03468E-06	0*	0*	0	0*	0	0*	0	0*	0	0	Sulfur Dioxide	
MEA		6.31901E-10	6.31901E-10	6.31901E-10	6.31901E-10	4.19351E-06	6.31901E-10	0*	0*	0	0 0*	0	0*	0	0*	0	0	MEA	
Argon		0.000481027	0.000481027	0.000481027	0.000481027	1.58753E-07	0.000481027	0*	0*	0	0*	0	0*	0	0*	0	0	Argon	
NO		1.87531E-07	1.8/531E-0/	1.8/531E-0/	1.8/531E-0/	8.47563E-11	1.87531E-07	0^	0^	0	0^	0	0^	0	0*	0	0		
		4.14370E-07	4.14370E-07	4.14370E-07	4.14376E-07	0.40494E-07	4.14376E-07	0*	0*	0	0*	0	0*	0	0*	0	0		
Mass Flow		3.40390E-00 ka/h	3.40390E-00	3.40390E-00 ka/h	5.40590⊑-00 kg/h	ka/h	3.40390E-00 ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	Mass Flow	
Oxvgen		6.98294	6.98294	6.98294	6.98294	5.96173E-05	6,98294	0*	0*	0	0*	0	0*	0	0*	0	0	Oxvgen	
Nitrogen		19.1976	19.1976	19.1976	19.1976	8.13573E-05	19.1976	0*	0*	0	0*	0	0*	0	0*	0	0	Nitrogen	
Water		5.74562	5.74562	5.74562	5.74562	3555.08	5.74562	9.29764E+01*	4.56577E+06*	4.56577E+06	4.56577E+06*	4.56577E+06	815451*	815451	4.82324E+06*	4.82324E+06	2665.92	Water	
Carbon Dioxide		127545	127545	127545	127545	21.4823	127545	0*	0*	0	0*	0	0*	0	0*	0	0	Carbon Dioxide	
Sulfur Dioxide		0.00642313	0.00642313	0.00642313	0.00642313	4.35546E-05	0.00642313	0*	0*	0	0*	0	0*	0	0*	0	0	Sulfur Dioxide	
MEA		8.06165E-07	8.06165E-07	8.06165E-07	8.06165E-07	0.000149984	8.06165E-07	0*	0*	0	0*	0	0*	0	0*	0	0	MEA	
Argon		0.613683	0.613683	0.613683	0.613683	5.67790E-06	0.613683	0*	0*	0	0*	0	0*	0	0*	0	0	Argon	
NO		0.000239248	0.000239248	0.000239248	0.000239248	3.03137E-09	0.000239248	0*	0*	0	0*	0	0*	0	0*	0	0	NO	
NO2		0.000528651	0.000528651	0.000528651	0.000528651	2.29077E-05	0.000528651	0*	0*	0	0*	0	0*	0	0*	0	0	NO2	
NH3		0.00442171	0.00442171	0.00442171	0.00442171	0.00265914	0.00442171	0*	0*	0	0*	0	0*	0	0*	0	0	NH3	
Property	Unito	411	412	413	414	415	416	417	501	502	503	504	505	000	509	510	511	Process Streams	
Temperature	c σ	176 667*	120 ////*	20*	18 2022	25 0067	27 0000	25 0261*	11*	04	11*	24	11*	Q4*	11*	Q1*	125 925		
Pressure	bar	93 5826	93 3068	20 92 9620	201 000*	5 34604	92 8031	20.9201	1 99994*	1 31042	1 9999*	1 31042	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	1.31042	1 9999*	0.965686	2 37913	bar Pressure	
Mole Fraction Vapor	%	100	100	0_000_0	100	0 0	0	0	0	0	0 0	0	0	0	0	0	100*	% Mole Fraction Vapor	
Molecular Weight	kg/kmol	44.0019	44.0019	44.0019	44.0019	18.0794	44.0019	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	kg/kmol Molecular Weight	
Mass Density	kg/m^3	123.168	148.590	722.629?	778.531	997.558	722.520	996.48	1000.00	997.602	1000.00	997.602	1000.00	997.602	1000.00	997.597	1.31446	kg/m^3 Mass Density	
Molar Flow	kmol/h	2899.37	2899.37	2899.37	2899.37	197.825	2899.37	5	253439	253439	253439	253439	45264.4	45264.4	267730	267730	147.981	kmol/h Molar Flow	
Mass Flow	kg/h	127578	127578	127578	127578	3576.57	127578	9.29764E+01	4.56577E+06	4.56577E+06	4.56577E+06	4.56577E+06	815451	815451	4.82324E+06	4.82324E+06	2665.92	kg/h Mass Flow	
Std Vapor Volumetric Flow	m^3/h	68687.3	68687.3	68687.3	68687.3	4686.57	68687.3	1.22266E+02	6.00408E+06	6.00408E+06	6.00408E+06	6.00408E+06	1.07233E+06	1.07233E+06	6.34265E+06	6.34265E+06	3505.74	m^3/h Std Vapor Volumetric Flow	
Std Liquid Volumetric Flow	m^3/h	155.348	155.348	155.348	155.348	3.58474	155.348	0.09	4570.26	4570.26	4570.26	4570.26	816.254	816.254	4827.98	4827.98	2.66855	m^3/h Std Liquid Volumetric Flow	
Specific Gravity		1.51988	1.51988	0.723312?	1.51988	0.998501	0.723203?	0.99742	1.00095	0.998544	1.00095	0.998544	1.00095	0.998544	1.00095	0.998540	0.622268	Specific Gravity	
Mass Enthalpy	kJ/kg	-8844.38	-8902.60	-9167.60	-9147.65	-15823.4	-9167.60	-15861.2	-15921.7	-15881.2	-15921.7	-15881.2	-15921.7	-15881.2	-15921.7	-15881.2	-13240.4	kJ/kg Mass Enthalpy	
Dynamic Viscosity	cP	0.0242104	0.0230638	0.0609531	0.0692270	0.865915	0.0609671	0.87930	1.29092	0.987185	1.29092	0.987185	1.29092	0.987185	1.29092	0.987115	0.0106144	cP Dynamic Viscosity	
Thermal Conductivity	W/(m*℃)	0.0342	0.0319	0.107258?	0.0909	0.6021	0.1073	0.6076	0.5854	0.6006	0.5854	0.6006	0.5854	0.6006	0.5854	0.6006	0.0270	W/(m*°C) Thermal Conductivity	
Surrace Lension	dyne/cm			0?		72.3391?	0?	72.6316	75.6475	73.6192	75.6475	73.6192	75.6475	73.6192	75.6475	73.6192		ayne/cm Surface Lension	
Process Streams		512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527	Process	Streams
----------------------------	-------------	-----------------------------	------------------------	----------------------	------------------------	--------------------------	------------------------	--------------------------	-------------------------	-------------------------	-------------------------	------------------------	--------------------------	------------------------	----------------------	-----------------------------	------------	---------------	---------------------------
		LP Condensate from E-109	LP Steam from E-114	LP Steam to E-109	SCW Supply to E-113	SCW Return From E-113	SCW Supply to E-115	SCW Return From E-115	Condenstate to E-112	Condenstate to E-114	Condenstate to E-116	SCW Supply to E-117	SCW Return From E-117	LP Steam from E-116	LP Steam to E-110	LP Condensate from E-110	Vent Steam		
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fracti	on
Oxygen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxygen	
Nitrogen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen	
Water		100	100	100	100*	100	100*	100	100*	100*	100*	100*	100	100	100*	100	100	Water	
Carbon Dioxide		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Carbon Diox	tide
Sulfur Dioxide		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Dioxid	le
MEA		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	MEA	
Argon		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon	
NO		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO	
NO2		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO2	
NH3		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3	
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow	
Oxygen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxygen	
Nitrogen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen	
Water		472.535	146.600	472.184	28097.7*	28097.7	18508.6*	18508.6	147.981*	146.600*	177.604*	45663.5*	45663.5	177.604	11015.5*	11015.5	306.121	Water	
Carbon Dioxide		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Carbon Diox	kide
Sulfur Dioxide		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Dioxid	le
		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0		
Argon		0	0	0	0*	0	0*	0	0**	0*	0*	0"	0	0	0*	0	0	Argon	
		0	0	0	U^ ^*	0	U^ ^*	0	0^	U^ ^*	0^	U^ ^*	0	0	0^	0	0		
		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0		
Mass Fraction		%	0	%	%	<u> </u>	%	0	<u> </u>	%	<u> </u>	<u> </u>	0	<u> </u>	<u> </u>	%	<u> </u>	Mass Fracti	ion
		<i>,</i> ,	<i>,</i> ,	<i>,</i> ,	×۵ ۱	<u></u> 0	۰» ۱۰	<i>,</i> ,	,,, 0*	× ۱	<u>/</u> 0	,, 0*	<u></u> 0	<i>,</i> ,	/0 	<i>,</i> ,,	/0		
Nitrogen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen	
Water		100	100	100	100*	100	100*	100	100*	100*	100*	100*	100	100	100*	100	100	Water	
Carbon Dioxide		0	0	0	0*	0	0*	0	0*	0*	.00	0*	0	0	0*	0	0	Carbon Diox	ride
Sulfur Dioxide		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Dioxic	le
MEA		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	MEA	
Argon		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon	
NŐ		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO	
NO2		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO2	
NH3		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3	
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow	
Oxygen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxygen	
Nitrogen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen	
Water		8512.84	2641.03	8506.53	506188*	506188	333438*	333438	2665.92*	2641.03*	3199.58*	822641*	822641	3199.58	198447*	198447	5514.86	Water	
Carbon Dioxide		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Carbon Diox	tide
Sulfur Dioxide		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Dioxid	le
MEA		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	MEA	
Argon		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon	
NO		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO	
NO2		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO2	
		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3	
Process Streams	Unite	512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527	l luite - F	Process Streams
Tomporatura	onits or	405 005	405.005	105 005	4.0*	00*	4.0+	0.0*	00.0000*	00.0000*	00.0000*	4.04	0.0*	105.005	405*	400 504	440 405	Jonits F	
Pressure	bar	120.035	120.035	120.035 2 27012	10° 1000*	۲۵٬۵۲۰ - ۲۵٬۵۶	1 0000*	20° 1 21042	90.0009" 2 27012*	30.0009° 2 37012*	90.0009° 2 27012*	10000*	20" 1 21042	1∠0.835 2 27012	2 0000*	2 0000	140.435	bar r	
Mole Fraction Vapor	%	2.37913	2.37913	2.57913	1.9999	1.31042	1.9999	1.31042	2.3/913	2.3/913	2.31313	1.9999	1.31042	2.37913	2.5555	2.5559	2.3499	ом г м	Iole Fraction Vapor
Molecular Weight	ka/kmol	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	ka/kmol M	Allecular Weight
Mass Density	kg/m^3	938 857	1 31446	1,31446	998 879	996 185	998 879	996 185	959 505	959 505	959 505	998 879	996 185	1 31446	1 62556	932 265	1 23159	ka/m^3	lass Density
Molar Flow	kmol/h	472.535	146.600	472.184	28097 7	28097 7	18508 6	18508 6	147.981	146.600	177.604	45663 5	45663 5	177.604	11015 5	11015 5	306.121	kmol/h	Aolar Flow
Mass Flow	kg/h	8512.84	2641.03	8506.53	506188	506188	333438	333438	2665.92	2641.03	3199.58	822641	822641	3199.58	198447*	198447	5514.86	kg/h	lass Flow
Std Vapor Volumetric Flow	m^3/h	11194.6	3473.01	11186.3	665648	665648	438477	438477	3505.74	3473.01	4207.51	1.08179E+06	1.08179E+06	4207.51	260961	260961	7252.15	5 m^3/h 5	Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	8.52122	2.64363	8.51490	506.686	506.686	333.766	333.766	2.66855	2.64363	3.20273	823.450	823.450	3.20273	198.642	198.642	5.52029	m^3/h S	td Liquid Volumetric Flow
Specific Gravity		0.939745	0.622268	0.622268	0.999823	0.997127	0.999823	0.997127	0.960412	0.960412	0.960412	0.999823	0.997127	0.622268	0.622268	0.933146	0.622268	5	Specific Gravity
Mass Enthalpy	kJ/kg	-15448.2	-13240.4	-13240.4	-15904.0	-15862.9	-15904.0	-15862.9	-15561.8	-15561.8	-15561.8	-15904.0	-15862.9	-13240.4	-13224.7	-15390.4	-13200.2	kJ/kg N	lass Enthalpy
Dynamic Viscosity	сР	0.219521	0.0106144	0.0106144	1.12405	0.874153	1.12405	0.874153	0.279294	0.279294	0.279294	1.12405	0.874153	0.0106144	0.0110023	0.206890	0.0114855	CP D	Dynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.6847	0.0270	0.0270	0.5931	0.6077	0.5931	0.6077	0.6758	0.6758	0.6758	0.5931	0.6077	0.0270	0.0278	0.6856	0.0287	/ W/(m*°C) T	hermal Conductivity
Surface Tension	dyne/cm	53.1489			74.6291	72.6168	74.6291	72.6168	58.4280	58.4280	58.4280	74.6291	72.6168			51.6045		dyne/cm	Surface Tension

Process Streams		001	002	003	004	005	006	007	008	009	010	100	101	102	103	Process Streams
		Flue Gas From	Flue Gas From	Process Water to	Process Water to	Process Water to	Abs 1. Flue Gas	Process Water to	Process Water to	Abs 2. Flue Gas	Softened	Cooled Flue	Warm Wash	Excess Water to	Off Gas to Atmosphere	
		CCPP	Common Fogger	Foggers	Common Fogger	Abs. 1 Fogger	Blower Discharge	Absorbers	Abs. 2 Fogger	Blower Discharge	Water	Gas to Abs. 1	Water (Abs. 1)	Absorbers	(Abs. 1)	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		12.8084*	12.4336	1.00873E-08	1.00873E-08	1.00873E-08	12.4336	1.00873E-08*	1.00873E-08	12.4336	0	12.3515	0.000214102	0.000214102	13.1597	Oxygen
Nitrogen		74.7787*	72.5907	8.97434E-09	8.97434E-09	8.97434E-09	72.5907	8.97434E-09*	8.97434E-09	72.5907	0	72.1113	0.000671827	0.000671827	76.8340	Nitrogen
Water		7.74143*	10.4385	99.9163	99.9163	99.9163	10.4385	99.9163*	99.9163	10.4385	100	11.0294	99.3931	99.3931	8.54853	Water
Carbon Dioxide		3.81568*	3.70570	0.0570861	0.0570861	0.0570861	3.70570	0.0570861*	0.0570861	3.70570	0	3.68161	0.150800	0.150800	0.578188	Carbon Dioxide
Sulfur Dioxide		9.86294E-06*	9.57664E-06	7.83447E-08	7.83447E-08	7.83447E-08	9.57664E-06	7.83447E-08*	7.83447E-08	9.57664E-06	0	9.51392E-06	0	0 0	5.42419E-10	Sulfur Dioxide
MEA		0*	0.000701788	0.0239842	0.0239842	0.0239842	0.000701788	0.0239842*	0.0239842	0.000701788	0	0.000855530	0.455022	0.455022	0.000301589	MEA
Argon		0.854973*	0.829956	8.01637E-10	8.01637E-10	8.01637E-10	0.829956	8.01637E-10*	8.01637E-10	0.829956	0	0.824476	1.50791E-05	1.50791E-05	0.878463	Argon
NO		0.000316434*	0.000307175	7.89452E-13	7.89452E-13	7.89452E-13	0.000307175	7.89452E-13"	7.89452E-13	0.000307175	0	0.000305146	7.82469E-09	7.82469E-09	0.000325125	
		5.15967E-05	5.00871E-05	4.04330E-09	4.04330E-09	4.04330E-09	5.0087 IE-05	4.04330E-09	4.04330E-09	5.00871E-05	0	4.97564E-05	1.18385E-08	0.000210170	5.30018E-05 0.000408706	
Molar Flow		6.000390083	kmol/h	kmol/h	kmol/h	6.00201003	kmol/h	kmol/h	6.00201083	kmol/h	kmol/h	0.000473299	kmol/h	kmol/h	0.000408708	Molar Flow
Oxvaen		11405 2*	11405.2	3 32250E-07	2 70743E-07	3 07532E-08	5702 58	9 19251F-08*	3 07532E-08	5702 58	0	5702 58	0 159636	0.00894710	11404 4	
Nitrogen		66586.2*	66586.2	2 95592E-07	2 40872E-07	2 73601E-08	33293 1	8 17828E-08*	2 73601E-08	33293 1	0	33293 1	0.500920	0 0280750	66585.5	Nitrogen
Water		6893.30*	9575.06	3290.99	2681.76	304.616	4787.53	910.534*	304.616	4787.53	231.576	5092.15	74108.4	4153.54	7408.28	Water
Carbon Dioxide		3397.64*	3399.18	1.88027	1.53220	0.174039	1699.59	0.520224*	0.174039	1699.59	0	1699.76	112.438	6.30179	501.066	Carbon Dioxide
Sulfur Dioxide		0.00878239*	0.00878449	2.58048E-06	2.10278E-06	2.38850E-07	0.00439224	7.13953E-07*	2.38850E-07	0.00439224	0	0.00439248	0	0 0	4.70068E-07	Sulfur Dioxide
MEA		0*	0.643738	0.789980	0.643738	0.0731209	0.321869	0.218567*	0.0731209	0.321869	0	0.394990	339.269	19.0149	0.261362	MEA
Argon		761.305*	761.305	2.64039E-08	2.15160E-08	2.44396E-09	380.652	7.30529E-09*	2.44396E-09	380.652	0	380.652	0.0112431	0.000630139	761.289	Argon
NO		0.281766*	0.281766	2.60026E-11	2.11889E-11	2.40681E-12	0.140883	7.19425E-12*	2.40681E-12	0.140883	0	0.140883	5.83416E-06	3.26986E-07	0.281758	NO
NO2		0.0459440*	0.0459441	1.52941E-07	1.24628E-07	1.41563E-08	0.0229720	4.23148E-08*	1.41563E-08	0.0229720	0	0.0229721	8.82692E-06	4.94721E-07	0.0459322	NO2
NH3		0.352690*	0.422926	0.0861919	0.0702359	0.00797796	0.211463	0.0238471*	0.00797796	0.211463	0	0.219441	0.163422	0.00915927	0.354191	NH3
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fraction
Oxygen		14.3999*	14.1299	1.78921E-08	1.78921E-08	1.78921E-08	14.1299	1.78921E-08*	1.78921E-08	14.1299	0	14.0700	0.000375386	0.000375386	15.1035	Oxygen
Nitrogen		73.5995*	72.2197	1.39355E-08	1.39355E-08	1.39355E-08	72.2197	1.39355E-08*	1.39355E-08	72.2197	0	71.9134	0.00103121	0.00103121	77.2001	Nitrogen
Water		4.89997*	6.67864	99.7771	99.7771	99.7771	6.67864	99.7771*	99.7771	6.67864	100	7.07346	98.1118	98.1118	5.52371	Water
Carbon Dioxide		5.89996*	5.79196	0.139261	0.139261	0.139261	5.79196	0.139261*	0.139261	5.79196	0	5.76799	0.363641	0.363641	0.912670	Carbon Dioxide
Sulfur Dioxide		2.21998E-05*	2.17889E-05	2.78212E-07	2.78212E-07	2.78212E-07	2.17889E-05	2.78212E-07*	2.78212E-07	2.17889E-05	0	2.16977E-05	0	0	1.24637E-09	Sulfur Dioxide
MEA		1 10000*	0.00152243	0.0812082	0.0812082	0.0812082	0.00152243	0.0812082"	0.0812082	0.00152243	0	0.00186036	1.52292	1.52292	0.000660747	
Argon		1.19999*	1.17750	1.77511E-09	1.77511E-09	1.77511E-09	1.17750	1.77511E-09"	1.77511E-09	1.17750	0	1.17250	3.30060E-05	3.30060E-05	1.25868	Argon
		0.000333596 9.22004E.05*	0.000327344 9.19261E.05	1.31307 E-12	1.31307E-12	1.31307E-12	0.000327344 9.19261E.05	1.31307E-12	1.31307E-12	0.000327344 9.19261E.05	0	0.000325955 9.14901E.05	1.20047E-00	1.20047E-00	0.000349911 9.74570E.05	NO2
NU2 NH3		0.000236998*	0.000278867	0.00247034	0.00247034	0.00247034	0.000278867	0.00247034*	0.00247034	0.000278867	0	0.000288161	0.000204527	0 000204527	0.000249653	NH3
Mass Flow		kg/h	kg/h	ka/h	kg/h	kg/h	kg/h	ka/h	ka/h	kg/h	ka/h	ka/h	ka/h	kg/h	ka/h	Mass Flow
Oxvaen		364951*	364951	1.06316E-05	8 66346E-06	9 84065E-07	182476	2 94149F-06*	9 84065E-07	182476	0	182476	5 10817	0 286297	364926	Oxvaen
Nitrogen		1.86531E+06*	1.86531E+06	8.28054E-06	6.74764E-06	7.66451E-07	932653	2.29102E-06*	7.66451E-07	932653	0	932653	14.0325	0.786476	1.86529E+06	Nitrogen
Water		124185*	172497	59288.1	48312.7	5487.74	86248.7	16403.5*	5487.74	86248.7	4171.91	91736.4	1.33508E+06	74827.1	133462	Water
Carbon Dioxide		149529*	149596	82.7499	67.4311	7.65937	74798.0	22.8948*	7.65937	74798.0	0	74805.7	4948.34	277.339	22051.7	Carbon Dioxide
Sulfur Dioxide		0.562633*	0.562768	0.000165315	0.000134712	1.53017E-05	0.281384	4.57385E-05*	1.53017E-05	0.281384	0	0.281399	0	0	3.01144E-05	Sulfur Dioxide
MEA		0*	39.3215	48.2544	39.3215	4.46645	19.6608	13.3508*	4.46645	19.6608	0	24.1272	20723.6	5 1161.49	15.9648	MEA
Argon		30412.6*	30412.6	1.05478E-06	8.59521E-07	9.76313E-08	15206.3	2.91832E-07*	9.76313E-08	15206.3	0	15206.3	0.449139	0.0251728	30412.0	Argon
NO		8.45470*	8.45470	7.80235E-10	6.35797E-10	7.22190E-11	4.22735	2.15871E-10*	7.22190E-11	4.22735	0	4.22735	0.000175060	9.81158E-06	8.45446	NO
NO2		2.11367*	2.11368	7.03611E-06	5.73358E-06	6.51266E-07	1.05684	1.94671E-06*	6.51266E-07	1.05684	0	1.05684	0.000406087	2.27599E-05	2.11313	NO2
NH3		6.00649*	7.20264	1.46789	1.19615	0.135869	3.60132	0.406129*	0.135869	3.60132	0	3.73719	2.78316	0.155987	6.03205	NH3
Process Streams		001	002	003	004	005	006	007	008	009	010	100	101	102	103	Process Streams
Property	Units	0.01	17.0001	10.0171	10.0171	10.0170	50.0405	10 11505	40.0470	50.0405		50.4570	50 4050	50.4050	40.0000	Onits Property
I emperature	°C har	90^	47.0834	48.6174	48.6174	48.61/3	59.6195	46.4459^	48.6173	59.6195	20.0000	50.1573	53.1358	53.1358	42.9986	C l'emperature
Mela Fraction Vanar	Dar o/	1.0017	1.0017	138	138	138	1.08857	4.13085	138	1.08857	4.13085	1.08857	4.48079	4.48079	1.01273	Dar Pressure
Molecular Weight	/0 ka/kmol	28 4622	100 28 1572	18 0404	18 0/0/	18 0404	100 28 1573	18 0404	18 0404	100 28 1573	18 0153	28 0005	18 2505	18 2505	27 8806	ka/kmol Molecular Weight
Mass Density	kg/m^3	0 944399	1 06001	990 203	990 203	990 203	1 10845	989 227	990 203	1 10845	997 903	1 13834	987 623	987 623	1 07471	kg/m^3 Mass Density
Molar Flow	kmol/h	89044 3	91728 3	3293 75	2684 01	304 871	45864 1	911 297	304 871	45864 1	231.576	46169.0	74560 9	4178.90	43330 7	kmol/h Molar Flow
Mass Flow	kg/h	2.53440E+06*	2.58282E+06	59420.6	48420.6	5500	1.29141E+06	16440.2*	5500	1.29141E+06	4171.91	1.29691E+06	1.36078E+06	76267.2	1.20809E+06	kg/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	2.10950E+06	2.17308E+06	78030.3	63585.3	7222.53	1.08654E+06	21589.0	7222.53	1.08654E+06	5486.15	1.09376E+06	1.76638E+06	99000.0	1.02652E+06	m^3/h Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	2962.14	3010.62	59.4969	48.4828	5.50706	1505.31	16.4613	5.50706	1505.31	4.17602	1510.82	1362.76	76.3786	1408.08	m^3/h Std Liquid Volumetric Flow
Specific Gravity		0.983118	0.972585	0.991139	0.991139	0.991139	0.972585	0.990162	0.991139	0.972585	0.998846	0.970277	0.988557	0.988557	0.963026	Specific Gravity
Mass Enthalpy	kJ/kg	-1117.26	-1391.32	-15736.3	-15736.3	-15736.3	-1377.97	-15757.2	-15736.3	-1377.97	-15885.0	-1438.86	-15552.1	-15552.1	-804.331	kJ/kg Mass Enthalpy
Dynamic Viscosity	сР	0.0205100	0.0186164	0.564032	0.564032	0.564033	0.0191570	0.571712	0.564033	0.0191570	1.01302	0.0187300	0.522996	0.522996	0.0186184	cP Dynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.0293	0.0265	0.6342	0.634 2	0.6342	0.0274	0.631690?	0.6342	0.0274	0.5991	0.0267	0.6285	0.6285	0.0266	W/(m*℃) Thermal Conductivity
Surface Tension	dyne/cm			68.1058	68.1058	68.1058		68.5295	68.1058		73.8205		66.9806	66.9806		dyne/cm Surface Tension

Process Streams		104	105	106	107	108	109	110	111	200	201	202	203	204	Process Str	reams
		Lean Amine	Cooled Semi-Lean	Rich Amine	Process Water to	Cooled Wash Water to	Cooled Wash	Cooled Wash Water to	Combined Wash Water to	Cooled Flue	Warm Wash	Excess Water to	Off Gas to Atmosphere	Lean Amine		
		(Abs. 1)	Amine (Abs. 1)	(Abs. 1)	Upper Bed (Abs. 1)	Lower Bed (Abs. 1)	Water (Abs. 1)	Upper Bed (Abs. 1)	Upper Bed (Abs. 1)	Gas to Abs. 1	Water (Abs. 2)	Absorbers	(Abs. 2)	(Abs. 2)		
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction	
Oxygen		2.03887E-05	4.09355E-07	0.000204302	1.00873E-08	0.000214102	0.000214102	0.000214102	0.000171284	12.3515	0.000214102	0.000214102	2 13.1597	2.03887E-05	Oxygen	
Nitrogen		6.39773E-05	8.69854E-07	0.000641464	8.97434E-09	0.000671827	0.000671827	0.000671827	0.000537464	72.1113	0.000671827	0.000671827	7 76.8340	6.39773E-05	Nitrogen	
Water		82.3414	78.9990	78.6680	99.9163	99.3931	99.3931	99.3931	99.4977	11.0294	99.3931	99.3931	1 8.54853	82.3414	Water	
Carbon Dioxide		3.30108	6.04490	6.61087	0.0570861	0.150800	0.150800	0.150800	0.132057	3.68161	0.150800	0.150800	0.578188	3.30108	Carbon Dioxide	÷
Sulfur Dioxide		2.35290E-10	2.99841E-08	1.02902E-07	7.83447E-08	0	0	0	1.56689E-08	9.51392E-06	0	C	5.42419E-10	2.35290E-10	Sulfur Dioxide	
MEA		14.3573	14.9558	14.7200	0.0239842	0.455022	0.455022	0.455022	0.368815	0.000855530	0.455022	0.455022	0.000301589	14.3573	MEA	
Argon		1.43596E-06	2.76605E-08	1.43819E-05	8.01637E-10	1.50791E-05	1.50791E-05	1.50791E-05	1.20634E-05	0.824476	1.50791E-05	1.50791E-05	0.878463	1.43596E-06	Argon	
NO		7.45138E-10	2.45771E-11	7.46666E-09	7.89452E-13	7.82469E-09	7.82469E-09	7.82469E-09	6.25991E-09	0.000305146	7.82469E-09	7.82469E-09	0.000325125	7.45138E-10	NO	
NO2		1.14131E-09	1.97407E-10	1.12650E-08	4.64336E-09	1.18385E-08	1.18385E-08	1.18385E-08	1.03995E-08	4.97564E-05	1.18385E-08	1.18385E-08	5.30018E-05	1.14131E-09	NO2	
NH3		0.000222485	0.000302942	0.000321162	0.00261683	0.000219179	0.000219179	0.000219179	0.000698710	0.000475299	0.000219179	0.000219179	0.000408706	0.000222485	NH3	
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow	
Oxygen		0.00894712	4.29752E-05	0.108975	3.02618E-08	0.157067	0.159636	0.00256922	0.00256925	5702.58	0.159636	0.00894710	11404.4	0.00894712	Oxygen	
Nitrogen		0.0280750	9.13196E-05	0.342159	2.69230E-08	0.492858	0.500920	0.00806193	0.00806195	33293.1	0.500920	0.0280750	66585.5	0.0280750	Nitrogen	
Water		36133.7	8293.52	41961.7	299.749	72915.6	74108.4	1192.72	1492.47	5092.15	74108.4	4153.54	4 7408.28	36133.7	Water	
Carbon Dioxide		1448.60	634.610	3526.26	0.171258	110.628	112.438	1.80960	1.98086	1699.76	112.438	6.30179	501.066	1448.60	Carbon Dioxide	٤
Sulfur Dioxide		1.03252E-07	3.14781E-06	5.48884E-05	2.35034E-07	0	0	0	2.35034E-07	0.00439248	0		4.70068E-07	1.03252E-07	Sulfur Dioxide	
		6300.36	15/0.10	/851.68	0.0719527	333.808	339.269	5.46027	5.53222	0.394990	339.269	19.0149	0.261362	6300.36		
Argon		0.000630140	2.90388E-06	0.00767137	2.40491E-09	0.0110621	0.0112431	0.000180949	0.000180951	380.652	0.0112431	0.000630139	761.289	0.000630140	Argon	
		3.26987E-07	2.58017E-09	3.98274E-06	2.30830E-12	5.74027E-06	5.83416E-06	9.38963E-08	9.38987E-08	0.140883	5.83416E-06	3.26986E-07	7 0.281758	3.26987E-07		
NH3		0.0076328	0.0318037	0.0087E-00	0.00785050	0.00400E-00	0.020922-00	0.00263015	0.0104806	0.0229721	0.02092E-00	4.947212-07	7 0.0459322	0.0976328		
Mass Fraction		0.0970320	%	%	%	%	%	%	0.0104000	%	%	0.00913921	0.354191	0.0970320	Mass Fraction	
		2 60274E 05	5 022665 07	0.000250722	1 79021E 09	0 000275296	0.000275286	0 000275296	0.000201006	14.0700	0.000275296	0.000275286	70	2 60274E 05		
Oxygen		2.60374E-03	0.26215E.07	0.000250732	1.70921E-00	0.000375366	0.000375366	0.000375566	0.000301006	71 0124	0.000375366	0.000375386	1 77 2001	2.00374E-05	Nitrogon	
Water		59 2018	54 6797	54 3552	99 7771	98 1118	98 1118	98 1118	98.4418	7 07346	98 1118	98 1118	5 52371	59 2018	Water	
		5 79799	10 2211	11 1586	0 139261	0.363641	0.363641	0.363641	0.319179	5 76799	0.363641	0 363641	0 912670	5 79799	Carbon Dioxide	۵
Sulfur Dioxide		6.01577E-10	7 38017E-08	2 52837E-07	2 78212F-07	0.000011	0.000011	0.000011	5 51287E-08	2 16977E-05	0.000011	0.000011	1 24637E-09	6.01577E-10	Sulfur Dioxide	,
MEA		35	35.0990	34,4850	0.0812082	1.52292	1.52292	1.52292	1.23724	0.00186036	1.52292	1.52292	0.000660747	35	MEA	
Argon		2.28936E-06	4.24540E-08	2.20351E-05	1.77511E-09	3.30060E-05	3.30060E-05	3.30060E-05	2.64661E-05	1.17250	3.30060E-05	3.30060E-05	5 1.25868	2.28936E-06	Argon	
NO		8.92322E-10	2.83338E-11	8.59287E-09	1.31307E-12	1.28647E-08	1.28647E-08	1.28647E-08	1.03158E-08	0.000325955	1.28647E-08	1.28647E-08	0.000349911	8.92322E-10	NO	
NO2		2.09551E-09	3.48928E-10	1.98767E-08	1.18412E-08	2.98423E-08	2.98423E-08	2.98423E-08	2.62753E-08	8.14891E-05	2.98423E-08	2.98423E-08	8.74579E-05	2.09551E-09	NO2	
NH3		0.000151219	0.000198222	0.000209776	0.00247034	0.000204527	0.000204527	0.000204527	0.000653507	0.000288161	0.000204527	0.000204527	0.000249653	0.000151219	NH3	
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow	
Oxygen		0.286297	0.00137515	3.48708	9.68343E-07	5.02596	5.10817	0.0822120	0.0822130	182476	5.10817	0.286297	7 364926	0.286297	Oxygen	
Nitrogen		0.786476	0.00255817	9.58503	7.54205E-07	13.8066	14.0325	0.225842	0.225843	932653	14.0325	0.786476	6 1.86529E+06	0.786476	Nitrogen	
Water		650958	149410	755952	5400.06	1.31360E+06	1.33508E+06	21487.1	26887.2	91736.4	1.33508E+06	74827.1	1 133462	650958	Water	
Carbon Dioxide		63752.3	27928.8	155189	7.53700	4868.70	4948.34	79.6397	87.1767	74805.7	4948.34	277.339	22051.7	63752.3	Carbon Dioxide	e
Sulfur Dioxide		6.61469E-06	0.000201660	0.00351636	1.50572E-05	0	0	0	1.50572E-05	0.281399	0	C	0 3.01144E-05	6.61469E-06	Sulfur Dioxide	
MEA		384846	95906.7	479605	4.39509	20390.0	20723.6	333.530	337.925	24.1272	20723.6	1161.49	9 15.9648	384846	MEA	
Argon		0.0251728	0.000116004	0.306456	9.60714E-08	0.441910	0.449139	0.00722854	0.00722863	15206.3	0.449139	0.0251728	3 30412.0	0.0251728	Argon	
NO		9.81161E-06	7.74210E-08	0.000119506	7.10651E-11	0.000172243	0.000175060	2.81746E-06	2.81753E-06	4.22735	0.000175060	9.81158E-06	6 8.45446	9.81161E-06	NO	
NO2		2.30414E-05	9.53432E-07	0.000276438	6.40860E-07	0.000399551	0.000406087	6.53565E-06	7.17651E-06	1.05684	0.000406087	2.27599E-05	5 2.11313	2.30414E-05	NO2	
NH3		1.66274	0.541633	2.91748	0.133698	2.73836	2.78316	0.0447928	0.178491	3.73719	2.78316	0.155987	6.03205	1.66274	NH3	
Process Streams		104	105	106	107	108	109	110	111	200	201	202	203	204	Process Str	reams
Property	Units														Units Pro	operty
Temperature	C	55.0223	58.8758	53.3439	46.4461	20.0000	20.0000	20.0000	25.3983	50.1573	53.1358	53.1358	42.9986	55.0223	°℃ Ten	nperatu re
Pressure	bar	3.68912	5.15772	1.08857	4.13685	3.44658	3.44658	3.44658	3.44658	1.08857	4.48079	4.48079	9 1.01273	3.68912	bar Pre	essure
Mole Fraction Vapor	%	0	0	0	0	0	0	0	0	100	0	C	100	0	% Mo	le Fraction Vapor
Molecular Weight	kg/kmol	25.0567	26.0277	26.0734	18.0404	18.2505	18.2505	18.2505	18.2085	28.0905	18.2505	18.2505	5 27.8806	25.0567	kg/kmol Mo	lecular Weight
Mass Density	kg/m^3	1088.37	1142.83	1152.26	989.227	999.804	999.804	999.804	997.937	1.13834	987.623	987.623	3 1.07471	1088.37	kg/m^3 Ma	iss Density
Molar Flow	kmol/h	43882.8	10498.3	53340.3	300	73360.9	74560.9	1200	1500	46169.0	74560.9	4178.90	43330.7	43882.8	kmol/h Mo	lar Flow
Mass Flow	kg/h	1.09956E+06	273246	1.39076E+06	5412.13	1.33888E+06	1.36078E+06	21900.7	27312.8	1.29691E+06	1.36078E+06	76267.2	2 1.20809E+06	1.09956E+06	kg/h Ma	iss Flow
Std Vapor Volumetric Flow	m^3/h	1.03960E+06	248709	1.26366E+06	7107.13	1.73795E+06	1.76638E+06	28428.5	35535.7	1.09376E+06	1.76638E+06	99000.0	1.02652E+06	1.03960E+06	m^3/h Std	J Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	1106.49	277.584	1415.84	5.41908	1340.83	1362.76	21.9326	27.3517	1510.82	1362.76	76.3786	1408.08	1106.49	m^3/h Std	Liquid Volumetric Flow
Specific Gravity	1.14	1.08940	1.14391	1.15334	0.990162	1.00075	1.00075	1.00075	0.998880	0.970277	0.988557	0.988557	0.963026	1.08940	Spe	ecific Gravity
Mass Enthalpy	kJ/kg	-11399.9	-11148.9	-11189.9	-15757.2	-15689.1	-15689.1	-15689.1	-15702.5	-1438.86	-15552.1	-15552.1	-804.331	-11399.9	кJ/kg Ма	lss Enthalpy
Dynamic Viscosity		1.72388	2.17395	2.59849	0.571710	1.04927	1.04927	1.04927	0.911176	0.0187300	0.522996	0.522996	0.0186184	1.72388	CP Dyr	namic Viscosity
Surface Tension	w/(m^°C)	0.4173	0.3874	0.3813	0.6317	0.5881	0.5881	0.5881	0.5975	0.0267	0.6285	0.6285	0.0266	0.4173	vv/(m°C) The	urface Toncion
Surface rension	uyne/cm	59.2253	92.8370	95.5904	68.5295	/3.3/6/	13.3/6/	/3.3/6/	72.4157		00.9806	00.9806		59.2253	ayne/cm Su	nace rension

Process Streams		205	206	207	208	209	210	211	300	302	303	304	305	306	307	Process Streams
		Cooled Semi-Lean	Rich Amine	Process Water to	Cooled Wash Water to	Cooled Wash	Cooled Wash Water to	Combined Wash Water to	Combined Cold	Hot Rich	Stripper Bottoms to	Rich Amine		Filtered Lean	Fresh	
Mole Fraction		Amine (Abs. 2)	(Abs. 2)	Upper Bed (Abs. 2)	Lower Bed (Abs. 2)	Water (Abs. 2)	Upper Bed (Abs. 2)	Upper Bed (Abs. 2)	Rich Amine	Amine %	E-108 Inlet	to E-103	Lean Amine	Amine %	Amine %	Mole Fraction
		70 4 00355E-07	70 0.000204302	70 1 00873E-08	70	0.000214102	70	70	70	70	70	70	70 2.03887E-05	70 2.03887E-05	70	
Nitrogen		4.09353E-07 8.69854E-07	0.000641464	8.97434E-09	0.000214102	0.000214102	0.000214102	0.000537464	0.000204302	0.000204302	0	0.000204302	6.39773E-05	6.39773E-05	0	) Nitrogen
Water		78.9990	78.6680	99.9163	99.3931	99.3931	99.3931	99.4977	78.6680	78.6680	80.4728	78.6680	82.3414	82.3414	0	Water
Carbon Dioxide		6.04490	6.61087	0.0570861	0.150800	0.150800	0.150800	0.132057	6.61087	6.61087	3.64688	6.61087	3.30108	3.30108	0	Carbon Dioxide
Sulfur Dioxide		2.99841E-08	1.02902E-07	7.83447E-08	0	0	0	1.56689E-08	1.02902E-07	1.02902E-07	0	1.02902E-07	2.35290E-10	2.35290E-10	0	Sulfur Dioxide
MEA		14.9558	14.7200	0.0239842	0.455022	0.455022	0.455022	0.368815	14.7200	14.7200	15.8801	14.7200	14.3573	14.3573	100	MEA
Argon		2.76605E-08	1.43819E-05	8.01637E-10	1.50791E-05	1.50791E-05	1.50791E-05	1.20634E-05	1.43819E-05	1.43819E-05	0	1.43819E-05	1.43596E-06	1.43596E-06	0	Argon
NO		2.45771E-11	7.46666E-09	7.89452E-13	7.82469E-09	7.82469E-09	7.82469E-09	6.25991E-09	7.46666E-09	7.46666E-09	0	7.46666E-09	7.45138E-10	7.45138E-10	0	NO
NO2		1.97407E-10	1.12650E-08	4.64336E-09	1.18385E-08	1.18385E-08	1.18385E-08	1.03995E-08	1.12650E-08	1.12650E-08	0	1.12650E-08	1.14131E-09	1.14131E-09	0	NO2
NH3 Molar Flow		0.000302942	0.000321162	0.00261683	0.000219179 kmol/b	0.000219179	0.000219179	0.000698710	0.000321162	0.000321162	0.000214993	0.000321162	0.000222485	0.000222485	0 kmol/h	NH3 Molar Flow
		4 207525 05	0 109075	2.02619E.09	0 157067	0.159626	0.00256022	0.00256025	0.217051	0 17/260	KIIIOI/II	0.0425001	0.0142154	0.00257995	KIIIOI/II	
Nitrogen		4.29732E-03 9 13196E-05	0.342159	2 69230E-08	0.157007	0.159030	0.00230922	0.00230923	0.217951	0.174300	0	0.136863	0.0143134	0.00357885	0	) Nitrogen
Water		8293.52	41961.7	299.749	72915.6	74108.4	1192.72	1492.47	83923.4	67138.7	63649.0	16784.7	57813.9	14453.5	0	) Water
Carbon Dioxide		634.610	3526.26	0.171258	110.628	112.438	1.80960	1.98086	7052.51	5642.01	2884.45	1410.50	2317.77	579.442	0	Carbon Dioxide
Sulfur Dioxide		3.14781E-06	5.48884E-05	2.35034E-07	0	0	0	2.35034E-07	0.000109777	8.78214E-05	0	2.19553E-05	1.65203E-07	4.13007E-08	0	Sulfur Dioxide
MEA		1570.10	7851.68	0.0719527	333.808	339.269	5.46027	5.53222	15703.3	12562.7	12560.1	3140.67	10080.6	2520.15	2.49009	MEA
Argon		2.90388E-06	0.00767137	2.40491E-09	0.0110621	0.0112431	0.000180949	0.000180951	0.0153427	0.0122742	0	0.00306854	0.00100822	0.000252056	0	Argon
NO		2.58017E-09	3.98274E-06	2.36836E-12	5.74027E-06	5.83416E-06	9.38963E-08	9.38987E-08	7.96547E-06	6.37237E-06	0	1.59309E-06	5.23180E-07	1.30795E-07	0	NO
NO2		2.07243E-08	6.00881E-06	1.39301E-08	8.68486E-06	8.82692E-06	1.42062E-07	1.55993E-07	1.20176E-05	9.61408E-06	0	2.40352E-06	8.01344E-07	2.00336E-07	0	NO2
NH3		0.0318037	0.171309	0.00785050	0.160792	0.163422	0.00263015	0.0104806	0.342617	0.274094	0.170046	0.0685235	0.156212	0.0390531	0	NH3
Mass Fraction		% 5.000005.07	%	%	%	%	%	%	%	%	%	%	% 0.00074E.05	%	%	
Oxygen		5.03266E-07	0.000250732	1.78921E-08	0.000375386	0.000375386	0.000375386	0.000301006	0.000250732	0.000250732	0	0.000250732	2.60374E-05	2.60374E-05	0	Oxygen
Nitrogen Water		9.30215E-07 54.6797	0.000689193 54 3552	1.39355E-08	0.00103121	0.00103121	0.00103121	0.000826876	0.000689193	0.000689193 54 3552	56 1862	0.000689193 54 3552	7.15265E-05 59.2018	7.15265E-05 59.2018	0	Nitrogen Water
Carbon Dioxide		10 2211	11 1586	0 139261	0 363641	0.363641	0.363641	0.319179	11 1586	11 1586	6 22024	11 1586	5 79799	5 79799	0	) Carbon Dioxide
Sulfur Dioxide		7.38017E-08	2.52837E-07	2.78212E-07	0	0	0	5.51287E-08	2.52837E-07	2.52837E-07	0	2.52837E-07	6.01577E-10	6.01577E-10	0	) Sulfur Dioxide
MEA		35.0990	34.4850	0.0812082	1.52292	1.52292	1.52292	1.23724	34.4850	34.4850	37.5935	34.4850	35	35	100	MEA
Argon		4.24540E-08	2.20351E-05	1.77511E-09	3.30060E-05	3.30060E-05	3.30060E-05	2.64661E-05	2.20351E-05	2.20351E-05	0	2.20351E-05	2.28936E-06	2.28936E-06	0	Argon
NO		2.83338E-11	8.59287E-09	1.31307E-12	1.28647E-08	1.28647E-08	1.28647E-08	1.03158E-08	8.59287E-09	8.59287E-09	0	8.59287E-09	8.92322E-10	8.92322E-10	0	NO
NO2		3.48928E-10	1.98767E-08	1.18412E-08	2.98423E-08	2.98423E-08	2.98423E-08	2.62753E-08	1.98767E-08	1.98767E-08	0	1.98767E-08	2.09551E-09	2.09551E-09	0	/ NO2
NH3		0.000198222	0.000209776	0.00247034	0.000204527	0.000204527	0.000204527	0.000653507	0.000209776	0.000209776	0.000141903	0.000209776	0.000151219	0.000151219	0	/ NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen		0.00137515	3.48708	9.68343E-07	5.02596	5.10817	0.0822120	0.0822130	6.97416	5.57933	0	1.39483	0.458075	0.114519	0	Oxygen
Nitrogen		0.00255817	9.58503	7.54205E-07	13.8066	14.0325	0.225842	0.225843	19.1700	15.3360	0	3.83401	1.25836	0.314590	0	Nitrogen
vvater Carbon Diovido		149410	155952	5400.06	1.31360E+06	1.33508E+06	21487.1	26887.2	1.51190E+06	1.20952E+06	1.14665E+06	302381	1.04153E+06	260383	0	Water
Sulfur Dioxide		0 000201660	0.00351636	1.50572E-05	4000.70	4340.34	19.0397	1 50572E-05	0 00703271	0.00562617	120343	0.00140654	1 05835E-05	2 64588E-06	0	) Sulfur Dioxide
MEA		95906.7	479605	4.39509	20390.0	20723.6	333.530	337.925	959209	767367	767212	191842	615753	153938	152.102	2 MEA
Argon		0.000116004	0.306456	9.60714E-08	0.441910	0.449139	0.00722854	0.00722863	0.612911	0.490329	0	0.122582	0.0402765	0.0100691	0	) Argon
NO		7.74210E-08	0.000119506	7.10651E-11	0.000172243	0.000175060	2.81746E-06	2.81753E-06	0.000239013	0.000191210	0	4.78025E-05	1.56986E-05	3.92464E-06	0	NO
NO2		9.53432E-07	0.000276438	6.40860E-07	0.000399551	0.000406087	6.53565E-06	7.17651E-06	0.000552876	0.000442301	0	0.000110575	3.68662E-05	9.21656E-06	0	NO2
NH3		0.541633	2.91748	0.133698	2.73836	2.78316	0.0447928	0.178491	5.83495	4.66796	2.89597	1.16699	2.66038	0.665095	0	NH3
Process Streams		205	206	207	208	209	210	211	300	302	303	304	305	306	307	Process Streams
Property	Units															Units Property
Temperature	ĉ	58.8758	53.3439	46.4461	20.0000	20.0000	20.0000	25.3983	53.4896	117*	126.351	53.4896	55.0223	55.0223	20.0000*	℃ Temp erature
Pressure	bar	5.15772	1.08857	4.13685	3.44658	3.44658	3.44658	3.44658	10.7412	9.70702	5.41280	10.7412	3.68912	3.68912	8.6049*	bar Pressure
Molecular Weight	% ka/kmol	0 דדרה אר	0 26 0724	10 0404	10 2505	19 2505	10 2505	10 2005	0 26 0724	0 26 0724	0	0 26 0724	25.0567	25 0567	61 0924	70 IVIDIE Fraction Vapor
Mass Density	kg/m/3	20.0277 1142 83	20.0734	10.0404 QRQ 227	10.2000 QQQ 201	10.2000 900 R04	10.2000	10.2085 007 027	20.0734	20.0734	20.0025 1068 27	20.0734	20.0007	20.0007 1088 37	993 667	kg/m/3 Mass Density
Molar Flow	kmol/h	10498.3	53340.3	300	73360.9	74560 9	1200	1500	106680	85344 4	79093 8	21336.1	70212.4	17553.1	2.49009	kmol/h Molar Flow
Mass Flow	kg/h	273246	1.39076E+06	5412.13	1.33888E+06	1.36078E+06	21900.7	27312.8	2.78152E+06	2.22522E+06	2.04081E+06	556304	1.75929E+06	439824	152.102	kg/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	248709	1.26366E+06	7107.13	1.73795E+06	1.76638E+06	28428.5	35535.7	2.52731E+06	2.02185E+06	1.87377E+06	505462	1.66336E+06	415841	58.9913	sm^3/h Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	277.584	1415.84	5.41908	1340.83	1362.76	21.9326	27.3517	2831.68	2265.34	2054.46	566.336	1770.39	442.598	0.149104	m^3/h Std Liquid Volumetric Flow
Specific Gravity		1.14391	1.15334	0.990162	1.00075	1.00075	1.00075	0.998880	1.15342	1.13382	1.06928	1.15342	1.08940	1.08940	0.994606	Specific Gravity
Mass Enthalpy	kJ/kg	-11148.9	-11189.9	-15757.2	-15689.1	-15689.1	-15689.1	-15702.5	-11188.6	-10960.9	-10817.3	-11188.6	-11399.9	-11399.9	-4324.37	kJ/kg Mass Enthalpy
Dynamic Viscosity	cP	2.17395	2.59849	0.571710	1.04927	1.04927	1.04927	0.911176	2.59253	0.689861	0.520015	2.59253	1.72388	1.72388	7.17196	cP Dynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.3874	0.3813	0.6317	0.5881	0.5881	0.5881	0.5975	0.3814	0.3945	0.4150	0.3814	0.4173	0.4173	0.2403	W/(m*C) Thermal Conductivity
Surface Tension	dyne/cm	92.8370	95.5904	68.5295	73.3767	73.3767	73.3767	72.4157	93.0610	87.1491	46.6093	93.0610	59.2253	59.2253	45.6798	dyne/cm Surface Tension

Rich Amine Rich Amine Rich Amine Hot Semi- Stringer Stringer Bottoms to Reclaimer Reclaimer Stringer Stringer Stringer Stringer Stringer Overse		
to E-107 to E-109 to V-101 Flash Gas Lean Amine Bottoms E-107 Feed Product Reboiler Inlet Discharge Overhead Reflux Reflux Reflux Purge Overhead Liquid	d Hot Semi- Lean Amine	
Mole Fraction         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         <	%	Mole Fraction
Oxygen 0.000204302 0.000204302 0.000204302 0.0128108 4.09351E-07 0 0 0 0 0 0 0 0 0 0 0.00298592 2.19422E-07 2.19422E-07 0.00298592 0.19422E-07 0.00298592 0.1942	07 4.09351E-07	7 Oxygen
Nitrogen 0.000641464 0.000641464 0.000641464 0.0402487 8.69846E-07 0 0 0 0 0 0 0 0 0 0.00937631 3.65882E-07 3.65882E-07 0.00937631 3.65882E	07 8.69846E-07	7 Nitrogen
Water 78.6680 78.6680 78.6680 58.2029 78.9990 80.4728 80.4728 80.4728 80.7711 80.4728 80.4728 60.2360 99.8826 99.8826 60.2360 99.8	26 78.9990	) Water
Carbon Dioxide 6.61087 6.61087 6.61087 41.6046 6.04490 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688 3.64688	45 6.04490	0 Carbon Dioxide
Sulfur Dioxide 1.02902E-07 1.02902E-07 1.02902E-07 1.02902E-07 4.61139E-06 2.99837E-08 0 0 0 0 0 0 0 1.42233E-06 7.10243E-08 7.10243E-08 1.42233E-06 7.10243E	08 2.99837E-08	3 Sulfur Dioxide
MEA 14.7200 14.7200 14.7200 0.137153 14.9558 15.8801 15.8801 15.8801 15.683 15.8801 0.0151863 0.0263988 0.0263988 0.0263988 0.0151863 0.0263	88 14.9558	3 MEA
Argon 1.43819E-05 1.43819E-05 1.43819E-05 0.000901892 2.76603E-08 0 0 0 0 0 0 0 0 0 0.000210198 1.63891E-08 0.000210198 1.63891E	08 2.76603E-08	3 Argon
NO 7.46666E-09 7.46666E-09 7.46666E-09 4.67603E-07 2.45769E-11 0 0 0 0 0 0 0 1.09099E-07 1.18469E-11 1.18469E-11 1.09099E-07 1.18469E	11 2.45769E-11	1 NO
NO2 1.12650E-08 1.12650E-08 1.12650E-08 6.95566E-07 1.97405E-10 0 0 0 0 0 0 0 1.64147E-07 1.70429E-10 1.70429E-10 1.64147E-07 1.70429E	10 1.97405E-10	NO2
NH3 0.000321162 0.000321162 0.000321162 0.00144795 0.000302938 0.000214993 0.000214993 0.000214993 0.000214993 0.000214993 0.000214993 0.00165885 0.00287376 0.00287376 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376 0.00165885 0.00287376	76 0.000302938	3 NH3
Molar Flow kmol/h	kmol/h	Molar Flow
Oxygen 0.0435901 0.0435901 0.0435901 0.0435901 0.0435042 8.59494E-05 0 0 0 0 0 0 0 0 0 0.217866 9.20999E-07 8.28899E-06 0.217866 9.20999E	06 8.59494E-05	5 Oxygen
Nitrogen 0.136863 0.136863 0.136863 0.136681 0.000182637 0 0 0 0 0 0 0.684136 1.53575E-06 1.38217E-05 0.684136 1.53575E	05 0.000182637	7 Nitrogen
Water 16784.7 16784.7 16784.7 197.651 16587.0 64084.8 63649.0 435.776 435.776 42723.2 4395.08 419.245 3773.21 4395.08 4192	45 16587.0	) Water
Carbon Dioxide 1410.50 1410.50 1410.50 1410.50 141.285 1269.22 2904.20 2884.45 19.7486 1936.14 1936.14 2899.21 0.369/24 3.32/52 2899.21 3.69	24 1269.22	2 Carbon Dioxide
	06 6.29553E-06	
IVIER 3140.07 3140.07 3140.07 0.403737 3140.20 12040.1 1200.1 63.9937 63.9939 6430.70 6430.70 1.10800 0.110800 0.997253 1.10800 1.10 Argon 0.00306854 0.00306854 0.00306854 0.00366274 5.807695.06 0.0 0.0 0.0 0.0 0.0 0.0153370 6.970115.00 6.101305	00 3140.20 07 5 80760E 06	
	10 5 16029E-00	
	10 3.10023E-08	3 NO2
NH3 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685235 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685255 0.0685555 0.0685555 0.0685555 0.0685555 0.06855555 0.06855555 0.06855555 0.06855555555555555555555555555555555555	23 0.0636064	4 NH3
Mass Fraction % % % % % % % % % % % % % % % % % % %	%	Mass Fraction
Oxvaen 0.000250732 0.000250732 0.000250732 0.0141868 5.03261E-07 0 0 0 0 0 0 0 0 0 0 0.00337000 3.89000E-07 0.00337000 3.89000E-07 0.00337000 3.89000E-07 0.00337000 3.89000E-07 0.00337000 3.89000E-07 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000 0.00337000	07 5.03261E-07	7 Oxvaen
Nitrogen 0.000689193 0.000689193 0.000689193 0.000689193 0.0390206 9.36206E-07 0 0 0 0 0 0 0 0 0 0 0.00926436 5.67860E-07 0.00926436 5.67860E	07 9.36206E-07	7 Nitrogen
Water 54.3552 54.3552 54.3552 36.2878 54.6796 56.1862 56.1862 56.1862 56.6817 56.1862 56.1862 38.2749 99.6932 99.6932 38.2749 99.6	32 54.6796	6 Water
Carbon Dioxide 11.1586 11.1586 11.1586 63.3669 10.2211 6.22024 6.22024 6.22024 6.27510 6.22024 6.22024 61.6784 0.214773 0.214773 61.6784 0.214	73 10.2211	1 Carbon Dioxide
Sulfur Dioxide 2.52837E-07 2.52837E-07 2.52837E-07 1.02240E-05 7.38008E-08 0 0 0 0 0 0 0 3.21389E-06 2.52089E-07 2.52089E-07 3.21389E-06 2.52089E	07 7.38008E-08	3 Sulfur Dioxide
MEA 34.4850 34.4850 34.4850 0.289935 35.0990 37.5935 37.5935 37.5935 37.0431 37.5935 0.0327184 0.0893387 0.0893387 0.0327184 0.0893	87 35.0990	MEA
Argon 2.20351E-05 2.20351E-05 2.20351E-05 0.00124688 4.24536E-08 0 0 0 0 0 0 0 0 0 0.000296171 3.62730E-08 3.62730E-08 0.000296171 3.62730E	08 4.24536E-08	3 Argon
NO 8.59287E-09 8.59287E-09 8.59287E-09 4.85581E-07 2.83335E-11 0 0 0 0 0 0 1.15465E-07 1.96947E-11 1.96947E-11 1.15465E-07 1.96947E	11 2.83335E-11	1 NO
NO2 1.98767E-08 1.98767E-08 1.98767E-08 1.98767E-08 1.10745E-06 3.48924E-10 0 0 0 0 0 0 0 2.66355E-07 4.34398E-10 2.66355E-07 4.34398E	10 3.48924E-10	) NO2
NH3 0.000209776 0.000209776 0.000209776 0.000853405 0.000198219 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.000141903 0.0001400000000000000000000000000000000	52 0.000198219	9 NH3
Mass Flow kg/h kg/h kg/h kg/h kg/h kg/h kg/h kg/h	kg/h	Mass Flow
Oxygen 1.39483 1.39483 1.39208 0.00275028 0 0 0 0 0 0 0 0 0.97144 2.94709E-05 0.000265238 6.97144 0.000294	09 0.00275028	3 Oxygen
Nitrogen 3.83401 3.83401 3.83401 3.82889 0.00511629 0 0 0 0 0 0 0 0 19.1650 4.30215E-05 0.000387193 19.1650 0.000430	15 0.00511629	9 Nitrogen
Water 302381 302381 302381 302381 300.74 298820 1.19451E+06 1.14005E+06 7850.03 7850.03 709070 79178.6 7552.82 67975.4 79178.6 7552	14 559570	Carbon Diovide
Calbur Dioxide 02073.3 02073.3 02073.3 02073.3 0217.00 33037.0 127813 120943 009.123 03200.3 03200.3 127393 10.2714 140.442 127393 10.2	84 0.00040331F	5 Sulfur Dioxide
MEA 191842 191842 191842 28 4499 191813 772465 767212 5252 76 5130 61 514977 67 6838 6 76836 60 9153 67 6838 6 76838 6 76836	36 191813	3 MEA
Argon 0.122582 0.122582 0.122582 0.122582 0.000232005 0 0 0 0 0 0 0 0 0 0.612682 2.74807E-06 2.47326E-05 0.612682 2.74807E	05 0.000232005	5 Argon
NO 4.78025E-05 4.78025E-05 4.7627E-05 1.54840E-07 0 0 0 0 0 0 0 0 0 0 0.000238859 1.49208E-09 1.34287E-08 0.000238859 1.49208F	08 1.54840E-07	7 NO
NO2 0.000110575 0.000110575 0.000110575 0.000108668 1.90684E-06 0 0 0 0 0 0 0 0 0 0 0.000551002 3.29103E-08 2.96192E-07 0.000551002 3.29103E	07 1.90684E-06	5 NO2
NH3 1.16699 1.16699 1.16699 0.0837404 1.08325 2.91580 2.89597 0.0198274 0.0198274 1.94387 1.94387 2.06132 0.205427 1.84884 2.06132 2.05	1.08325	5 NH3
Process Streams 309 310 311 312 313 314 315 316 317 318 319 320 322 323 324 325	330	Process Streams
Property Units Units		Units Property
Temperature C 108* 112.778* 121.526 113.709 113.762 127.540 127.608 127.608 169.974 127.540 129.980 104.851 48.7469 48.7469 48.8889* 48.6	09 113.709	9 °C Temperature
Pressure bar 9.70702 8.67281 7.63859 2.39982* 5.84719 2.31016 6.10228 6.10228 2.3499 2.31016 2.31016 1.96543 5.24044 5.24044 1.82753 1.79	06 2.39982	2 bar Pressure
Mole Fraction Vapor         %         0         0         100         0         0         100*         0         17.9797         100         0         42.4467	0 0	0 % Mole Fraction Vapor
Molecular Weight         kg/kmol         26.0734         26.0734         28.8951         26.0278         25.8025         25.8025         25.6717         25.8025         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519         18.0495         28.3519	95 26.0278	3 kg/kmol Molecular Weight
Mass Density Kg/m ²³ 1136.42 1134.49 1130.77 2.17996 1124.54 1067.51 1067.53 1067.53 1.66311 1067.51 9.96644 1.79079 988.420 988.420 4.58931 988.	95 1124.52	2 kg/m^3 Mass Density
	38 20996.5	
Invises Flow         Kg/n         Sob304         Sob304 <thsob304< th="">         Sob304         <thsob30< td=""><td>546492</td><td>2 Kg/II Mass Flow</td></thsob30<></thsob304<>	546492	2 Kg/II Mass Flow
Std Liquid Volumetric Flow mx3/b 566 336 566 336 11 1600 555 166 2068 52 2054 46 14 0660 12 0462 1270 02 1270 02 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69 2922 224 727 7 69704 69704 69704 7 69704 7 69704 7 69704 7 69704 7 7 69704 7 7 7 69704 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7	.o 49/41/	Sim Vapor Volumetric Flow
Specific Gravity 1.13749 1.13756 1.13184 0.998070 1.12560 1.06852 1.06854 1.06854 0.886720 1.06852 0.0703077 0.980354 0.980354 0.980354 0.980354 0.980354 0.980354	29 1 1255	Specific Gravity
Mass Enthalpy k.//kg -10995.3 -10977.2 -10943.5 -10438.9 -10952 1 -10812.9 -10812.4 -9100.06 -10812.9 -10517.3 -10555.7 -15741.5 -15741.5 -11497.7 -157	-10952 6	6 kJ/kg Mass Enthalov
Dynamic Viscosity CP 0.795671 0.736405 0.644543 0.0170327 0.707635 0.511379 0.511360 0.511360 0.0149774 0.511379 0.1165440 0.548088 0.548088 0.548088	36 0.707712	2 cP Dynamic Viscosity
Thermal Conductivity W/(m*C) 0.3944 0.3944 0.3944 0.0247 0.3982 0.4149 0.4149 0.4149 0.0325 0.4149 0.0240 0.6335 0.6335 0.6335 0.6	34 0.3982	2 W/(m*℃) Thermal Conductivity
Surface Tension dyne/cm 88.3099 87.9568 87.0508 86.8984 46.4059 46.3874 46.3874 46.4059 68.0584 68.0584 68.0584 68.0584 68.0584	93 87.6911	1 dyne/cm Surface Tension

Process Streams		332	333	334	400	401	402	403	404	405	406	407	408	409	410	411	Process Streams
		Cold Rich Amine to Lean /	Process Water to	Lean Amine to		1st Stage	Hot 1st Stage	Cooled 1st Stage	Cold 1st Stage	2nd Stage	Hot 2nd Stage	Cooled 2nd Stage	Cold 2nd Stage		3rd Stage	Hot 3rd Stage	
		Rich Exchanger	Absorbers	E-102 Inlet	CO2	Suction	Discharge	Discharge	Discharge	Suction	Discharge	Discharge	Discharge	Dryer Inlet	Suction	Discharge	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		0.000204302	1.00873E-08*	0	0.00702977	0.00702983	0.00702983	0.00702983	0.00702983	0.00747291	0.00747291	0.00747291	0.00747291	0.00750856	0.00752192	0.00752192	Oxygen
Nitrogen		0.000641464	8.97434E-09*	0	0.0220751	0.0220753	0.0220753	0.0220753	0.0220753	0.0234668	0.0234668	0.0234668	0.0234668	0.0235787	0.0236207	0.0236207	Nitrogen
Water		78.6680	99.9163*	80.4728	6.53828	6.53748	6.53748	6.53748	6.53748	0.658027	0.658027	0.658027	0.658027	0.188667	0.0110000	0.0110000	Water
Carbon Dioxide		5.51087 1.02002E.07	0.0570861"	3.64688	93.4321	93.4329 2.25257E.06	93.4329 2.25257E.06	93.4329 2.25257E.06	93.4329	99.3105 2 44005E 06	99.3105 2.44005E-06	99.3105 2.44005E-06	99.3105 2 44005E 06	99.7797 2.45070E.06	99.9573 2.45684E.06	99.9573 2 456945 06	Carbon Dioxide
		1.02902E-07	0.0239842*	15 8801	7 96099E-08	7.95840E-08	7 95840E-08	7 95840E-08	7 95840E-08	2 81700E-00	2.81700E-09	2.81700E-09	2 81700E-00	3.43070E-00	4 55231E-10	4 55231E-10	MEA
Argon		1.43819E-05	8.01637E-10*	13.0001	0.000494870	0.000494874	0.000494874	0.000494874	0.000494874	0.000526066	0.000526066	0.000526066	0.000526066	0.000528575	0.000529515	0.000529515	Argon
NO		7.46666E-09	7.89452E-13*	0	2.56848E-07	2.56850E-07	2.56850E-07	2.56850E-07	2.56850E-07	2.73038E-07	2.73038E-07	2.73038E-07	2.73038E-07	2.74340E-07	2.74829E-07	2.74829E-07	NO
NO2		1.12650E-08	4.64336E-09*	0	3.86238E-07	3.86241E-07	3.86241E-07	3.86241E-07	3.86241E-07	3.97611E-07	3.97611E-07	3.97611E-07	3.97611E-07	3.95412E-07	3.96116E-07	3.96116E-07	NO2
NH3		0.000321162	0.00261683*	0.000214993	1.33580E-05	1.33580E-05	1.33580E-05	1.33580E-05	1.33580E-05	1.00477E-05	1.00477E-05	1.00477E-05	1.00477E-05	8.91735E-06	8.93322E-06	8.93322E-06	NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen		0.174360	3.14014E-08*	0	0.217856	0.217856	0.217856	0.217856	0.217856	0.217855	0.217855	0.217855	0.217855	0.217854	0.217854	0.217854	Oxygen
Nitrogen		0.547454	2.79368E-08*	0	0.684121	0.684121	0.684121	0.684121	0.684121	0.684119	0.684119	0.684119	0.684119	0.684118	0.684118	0.684118	Nitrogen
Water		67138.7	311.036*	63649.0	202.625	202.598	202.598	202.598	202.598	19.1832	19.1832	19.1832	19.1832	5.47403	0.318588	0.318588	Water
Carbon Dioxide		5642.01	0.177707*	2884.45	2895.51	2895.51	2895.51	2895.51	2895.51	2895.16	2895.16	2895.16	2895.16	2895.02	2895.02	2895.02	Carbon Dioxide
		8.78214E-05	2.43885E-07*	12560.1	0.000100798	0.000100798	0.000100798	0.000100798		0.000100287	0.000100287	0.000100287	0.000100287	1.21947E-09	1.21947E 09	1.21947E.09	
		0.0122742	0.0746621 2.49547E-00*	12560.1	2.407 10E-00	2.40033E-00	2.40033E-00 0.0153363	2.40033E-00	2.40033E-00	0.21231E-08	0.0153362	0.0153362	0.21231E-08	0.0153362	0.0153362	0.0153362	Argon
NO		6.37237E-06	2.49547E-09	0	7 95986E-06	7 95986E-06	7 95986E-06	7 95986E-06	7 95986E-06	7 95979E-06	7 95979E-06	7 95979E-06	7 95979E-06	7 95976E-06	7 95976E-06	7 95976E-06	NO
NO2		9.61408E-06	1.44546E-08*	0	1.19697E-05	1.19697E-05	1.19697E-05	1.19697E-05	1.19697E-05	1.15914E-05	1.15914E-05	1.15914E-05	1.15914E-05	1.14725E-05	1.14725E-05	1.14725E-05	NO2
NH3		0.274094	0.00814611*	0.170046	0.000413973	0.000413969	0.000413969	0.000413969	0.000413969	0.000292917	0.000292917	0.000292917	0.000292917	0.000258730	0.000258730	0.000258730	NH3
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fraction
Oxygen		0.000250732	1.78921E-08*	0	0.00531713	0.00531715	0.00531715	0.00531715	0.00531715	0.00545525	0.00545525	0.00545525	0.00545525	0.00546606	0.00547004	0.00547004	Oxygen
Nitrogen		0.000689193	1.39355E-08*	0	0.0146175	0.0146175	0.0146175	0.0146175	0.0146175	0.0149972	0.0149972	0.0149972	0.0149972	0.0150269	0.0150379	0.0150379	Nitrogen
Water		54.3552	99.7771*	56.1862	2.78424	2.78389	2.78389	2.78389	2.78389	0.270443	0.270443	0.270443	0.270443	0.0773254	0.00450362	0.00450362	Water
Carbon Dioxide		11.1586	0.139261*	6.22024	97.1953	97.1957	97.1957	97.1957	97.1957	99.7086	99.7086	99.7086	99.7086	99.9017	99.9745	99.9745	Carbon Dioxide
Sulfur Dioxide		2.52837E-07	2.78212E-07*	0	4.92537E-06	4.92539E-06	4.92539E-06	4.92539E-06	4.92539E-06	5.02769E-06	5.02769E-06	5.02769E-06	5.02769E-06	5.02926E-06	5.03293E-06	5.03293E-06	Sulfur Dioxide
MEA		34.4850	0.0812082*	37.5935	1.14945E-07	1.14907E-07	1.14907E-07	1.14907E-07	1.14907E-07	3.92554E-09	3.92554E-09	3.92554E-09	3.92554E-09	6.31488E-10	6.31948E-10	6.31948E-10	MEA
		2.20351E-05 8 50287E-09	1.77511E-09 1.31307E-12*	0	0.000467293	0.000467294	0.000467294	0.000467294	0.000467294	0.000479431 1 86907E-07	0.000479431 1 86907E-07	1 86907E-07	1 86907E-07	0.000480381	0.000480731 1.87/13E-07	0.000480731	
NO2		1.98767E-08	1.31307E-12	0	4 20017E-07	4 20019E-07	4 20019E-07	4 20019E-07	4 20019E-07	4 17310F-07	4 17310E-07	4 17310E-07	4 17310E-07	4 13851E-07	4 14152E-07	4 14152E-07	NO2
NH3		0.000209776	0.00247034*	0.000141903	5.37741E-06	5.37738E-06	5.37738E-06	5.37738E-06	5.37738E-06	3.90378E-06	3.90378E-06	3.90378E-06	3.90378E-06	3.45500E-06	3.45752E-06	3.45752E-06	NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen		5.57933	1.00481E-06*	0	6.97114	6.97114	6.97114	6.97114	6.97114	6.97110	6.97110	6.97110	6.97110	6.97108	6.97108	6.97108	Oxygen
Nitrogen		15.3360	7.82605E-07*	0	19.1645	19.1645	19.1645	19.1645	5 19.1645	19.1645	19.1645	19.1645	19.1645	19.1645	19.1645	19.1645	Nitrogen
Water		1.20952E+06	5603.40*	1.14665E+06	3650.34	3649.86	3649.86	3649.86	3649.86	345.591	345.591	345.591	345.591	98.6161	5.73946	5.73946	Water
Carbon Dioxide		248302	7.82080*	126943	127430	127430	127430	127430	127430	127415	127415	127415	127415	127409	127409	127409	Carbon Dioxide
Sulfur Dioxide		0.00562617	1.56242E-05*	0	0.00645751	0.00645751	0.00645751	0.00645751	0.00645751	0.00642474	0.00642474	0.00642474	0.00642474	0.00641402	0.00641402	0.00641402	Sulfur Dioxide
MEA		767367	4.56059*	767212	0.000150701	0.000150651	0.000150651	0.000150651	0.000150651	5.01633E-06	5.01633E-06	5.01633E-06	5.01633E-06	8.05362E-07	8.05362E-07	8.05362E-07	MEA
Argon		0.490329	9.96890E-08 [*]	0	0.612654	0.612654	0.612654	0.612654	0.612654	0.612650	0.612650	0.612650	0.612650	0.612649	0.612649	0.612649	Argon
		0.000191210	6.64992E-07*	0	0.000236644	0.000230044	0.000230044	0.000230044	0.000230644	0.000236642	0.000230042	0.000230042	0.000236642	0.000238841	0.000236641	0.000236641	NO2
NH3		4.66796	0.138732*	2.89597	0.00705017	0.00705011	0.00705011	0.00705011	0.00705011	0.000333200	0.00498852	0.00498852	0.00498852	0.00440630	0.00440630	0.00440630	NH3
Process Streams		332	333	334	400	401	402	403	404	405	406	407	408	409	410	411	Process Streams
Property	Units																Units Property
Temperature	C	53.4896	46.4461*	58.7365	48.7010	48.7010	176.667*	129.444*	26*	25.8867	176.667*	129.444*	26*	25.9261	25.9261	176.667*	C Temperature
Pressure	bar	10.7412	4.13685*	4.72333	1.79306	1.79306	6.03552	5.75973	5.41499	5.34604	23.1076	22.8318	22.4870	22.4181	22.4181	93.5828	bar Pressure
Mole Fraction Vapor	%	0	0	0	99.9991	100	100	100	94.0633	100	100	100	99.5254	100	100	100	% Mole Fraction Vapor
Molecular Weight	kg/kmol	26.0734	18.0404	25.8025	42.3055	42.3057	42.3057	42.3057	42.3057	43.8338	43.8338	43.8338	43.8338	43.9558	44.0019	44.0019	kg/kmol Molecular Weight
Mass Density	kg/m^3	1152.33	989.227	1100.29	2.85806	2.85805	6.88502	7.37042	10.0902	9.71146	27.9169	31.3460	45.7895	45.5574	45.5945	123.168	kg/m^3 Mass Density
Molar Flow	kmol/h	85344.4	311.297	79093.8	3099.06	3099.03	3099.03	3099.03	3099.03	2915.26	2915.26	2915.26	2915.26	2901.42	2896.26	2896.26	kmol/h Molar Flow
Mass Flow	kg/h	2.22522E+06	5615.92*	2.04081E+06	131107	131107	131107	131107	131107	127787	127787	127787	127787	127534	127441	127441	kg/n Mass Flow
Std Liquid Volumetric Flow	m/3/h	2.02185E+06	(3/4.75	1.8/3//E+06	13418.0	13411.4	13411.4	13417.4	13417.4	09063.9	69063.9 155 520	69063.9 155 520	69063.9 155 500	68/35.8 155 275	155 192	00013.7	mrovn Sta Vapor Volumetric Flow
Specific Gravity	nr 9/11	2200.34	0.02313	2004.40	100.000	1 46120	1 26129	1 46120	100.000	1 51407	1 51407	1 51407	100.029	1 51828	1 51988	1 51988	Specific Gravity
Mass Enthalpy	kJ/ka	-11188 6	-15757 1	-11065.5	-9045.10	-9045.08	-8924.50	-8971 65	-9130.16	-8956.04	-8823.38	-8871 30	-8978 43	-8965.08	-8961.76	-8844.38	kJ/kg Mass Enthalov
Dynamic Viscosity	cP	2.59253	0.571710	1.86287	,	0.0161454	0.0216019	0.0197044		0.0152834	0.0220095	0.0201805	00.0.10	0.0159386	0.0159403	0.0242104	cP Dynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.3814	0.6317	0.4050		0.0187	0.0287	0.0251		0.0172	0.0296	0.0261		0.0189	0.0189	0.0342	W/(m*℃) Thermal Conductivit y
Surface Tension	dyne/cm	93.0610	68.5295	57.9132													dyne/cm Surface Tension

Cooled 3rd Stage Discharge         Cold 3rd Stage Discharge         Cold 3rd Stage Discharge         Liquefie Liquef         Liquefie CO2         SCW Supply to E-101         SCW Supply to E-102	i <mark>raction</mark> n n n Dioxide Dioxide
Discharge         Discharge         Discharge         Discharge         Discharge         CO2 Produ         Liquid         CO2         Dig         Water         to E-101         From E-104         to E-102         From E-111         From E-112         from E-112 </th <th>r<mark>raction</mark> n en n Dioxide Dioxide</th>	r <mark>raction</mark> n en n Dioxide Dioxide
Mole Praction         no	n en n Dioxide Dioxide
Cx/gen         Cx/07/2192         Cx/07/2192<	n Dioxide Dioxide
Mindgen       0.0250201       0.0250201       0.0250201       0.010000       0.010000       0.010000       0.0110000       0.0110000       0.0110000       0.0110000       0.0110000       0.0110000       0.0110000       0.0110000       0.0110000       0.0110000       0.0110000       0.0110000       0.0110000       0.011000       0.011000       0.011000       0.011000       0.011000       0.011000       0.011000       0.011000       0.011000       0.011000       0.011000       0.001000       0.011000       0.001000       0.000       0.000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.0000       0.00000       0.00000       0.00000       0.00000       0.00000       0.00000       0.00000       0.000000       0.000000       0.00000       0.0000000       0.0000000       0.00000000       0.00000000000000000000000000000000000	ı Dioxide Dioxide
Carbon Dioxide       99.9573       99.9573       99.9573       99.9573       99.9573       99.9573       99.9573       99.9573       99.9573       99.9573       0.246748       99.9573       0.246748       99.9573       0.246748       99.9573       0.246748       99.9573       0.246748       99.9573       0.246748       99.9573       0.246748       99.9573       0.246748       99.9573       0.246748       99.9573       0.246748       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0 <th< td=""><td>n Dioxide Dioxide</td></th<>	n Dioxide Dioxide
Sulfur Dioxide       3.45684E-06       3.45684E-06 <td>Dioxide</td>	Dioxide
MEA4.55231E-104.55231E-104.55231E-101.24129E-064.55231E-100000000000MEAArgon0.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.000529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.00529510.0052951 <td></td>	
Argon0.005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.0005295150.000529515<	
NO       2.74829E-07       2.74829E-07       2.74829E-07       2.74829E-07       5.10357E-11       2.74829E-07       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0 <th< td=""><td></td></th<>	
NO2       3.96116E-07       3.96116E-07       3.96116E-07       3.96116E-07       3.96116E-07       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0	
NH3       8.93322E-06       8.93322E-06       7.87373E-05       8.93322E-06       0*       0       0*       0       0*       0       0*       0       0       0       0       NH3         Molar Flow       kmol/h       kmol/	
Molar Flow kmol/h	
	Flow
Uxygen U.217854 U.217854 U.217854 U.217854 1.86006E-06 U.217854 U* U* 0 0* 0 0* 0 0* 0 0 0 0 0 0 0 0 0	า
Nitrogen 0.684118 0.684118 0.684118 2.89939E-06 0.684118 0* 0* 0 0* 0 0* 0 0* 0 0 0* 0 0 0 0 0	n
Water 0.318588 0.318588 0.318588 19/.137 0.318588 5^ 255336 255336 255336 34919.3 266937 266937 147.823 472.152 146.443 Water	Diovido
Calbon Dioxide 2095.02 2095.02 2095.02 0.467635 2095.02 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
$\begin{array}{cccccccccccccccccccccccccccccccccccc$	
NO 7.95976E-06 7.95976E-06 7.95976E-06 1.00859E-10 7.95976E-06 0* 0* 0 0* 0 0* 0 0* 0 0 0* 0 0 0 0 0	
NO2 1.14725E-05 1.14725E-05 1.14725E-05 4.97162E-07 1.14725E-05 0* 0* 0 0* 0 0* 0 0* 0 0* 0 0 0 NO2	
NH3 0.000258730 0.000258730 0.000258730 0.000155604 0.000258730 0* 0* 0 0* 0 0* 0 0* 0 0* 0 0 0* 0 0 NH3	
Mass Fraction         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         %         <	Fraction
Oxygen 0.00547004 0.00547004 0.00547004 1.66584E-06 0.00547004 0* 0* 0* 0 0* 0 0* 0 0* 0 0* 0 0*	n
Nitrogen 0.0150379 0.0150379 0.0150379 2.27325E-06 0.0150379 0* 0* 0 0* 0 0* 0 0* 0 0* 0 0 0 Nitrogen	n
Water 0.00450362 0.00450362 0.00450362 99.3993 0.00450362 100* 100* 100 100* 100 100* 100 100* 100 100	
Carbon Dioxide 99.9745 99.9745 99.9745 0.600642 99.9745 0* 0* 0 0* 0 0* 0 0* 0 0* 0 0 0 0 0 0	Dioxide
Sulfur Dioxide 5.03293E-06 5.03293E-06 5.03293E-06 1.21736E-06 5.03293E-06 0* 0* 0 0* 0 0* 0 0* 0 0 0 0 0 0 0 0	Dioxide
NO2 $4.14152E-07$ $4.14152E-07$ $6.40150E-07$ $4.14152E-07$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$ $0^{*}$	
NH3 3.45752E-06 3.45752E-06 7.41693E-05 3.45752E-06 0* 0* 0 0* 0 0* 0 0* 0 0 0* 0 0 0 NH3	
Mass Flow kg/h kg/h kg/h kg/h kg/h kg/h kg/h kg/h	Flow
Oxygen 6.97108 6.97108 6.97108 5.95196E-05 6.97108 0* 0* 0 0* 0 0* 0 0* 0 0* 0 0 0 0 Oxygen	า
Nitrogen 19.1645 19.1645 19.1645 8.12219E-05 19.1645 0* 0* 0 0* 0 0* 0 0* 0 0* 0 0 Nitrogen	n
Water 5.73946 5.73946 5.73946 5.73946 3551.48 5.73946 9.28767E+01* 4.59995E+06* 4.59995E+06 4.59995E+06 629082* 629082 4.80895E+06* 4.80895E+06 2663.07 8505.95 2638.20 Water	
Carbon Dioxide 127409 127409 127409 21.4606 127409 0* 0* 0 0* 0 0* 0 0* 0 0* 0 0 0 0 Carbon D	Dioxide
Sulfur Dioxide 0.00641402 0.00641402 0.00641402 4.34955E-05 0.00641402 0* 0* 0 0* 0 0* 0 0* 0 0* 0 0 0 0 Sulfur Div	Dioxide
MEA 8.05362E-07 8.05362E-07 8.05362E-07 0.000149843 8.05362E-07 0* 0* 0 0* 0 0* 0 0* 0 0 0 0 0 0 0 0	
Argon U.612649 U.612649 U.612649 5.66866E-06 U.612649 0* 0* 0 0* 0 0* 0 0* 0 0 0* 0 0 0 0 0	
NH3 0,00440630 0,00440630 0,00440630 0,00265002 0,00440630 0* 0* 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0	
Process Streams 412 413 414 415 416 417 501 502 503 504 505 506 509 510 511 512 513 Proces	ess Streams
Property Units Uni	Property
Temperature C 129.444* 28* 48.2022 25.8867 27.9889 25.9261* 11* 21 11* 21 11* 21* 11* 21* 11* 21* 125.835 125.835 125.835 C	Temperature
Pressure bar 93.3070 92.9622 201.000* 5.34604 92.8933 22.4181* 1.9999* 0.965686 1.9999* 0.965686 1.9999* 0.965686 2.37913 2.37913 2.37913 bar	Pressure
Mole Fraction Vapor % 100 0 100 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Mole Fraction Vapor
Molecular Weight kg/kmol 44.0019 44.0019 44.0019 18.0794 44.0019 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153	Molecular Weight
Mass Density kg/m^3 148.590 722.630? 778.532 997.558 722.521 996.48 1000.00 997.597 1000.00 997.597 1000.00 997.602 1000.00 997.597 1.31446 938.857 1.31446 kg/m^3	Mass Density
Molar Flow kmol/h 2896.26 2896.26 2896.26 197.625 2896.26 5 255336 255336 255336 34919.3 34919.3 266937 266937 147.823 472.152 146.443 kmol/h	Molar Flow
Mass Flow kg/h 127441 127441 127441 3572.94 127441 9.28767E+01 4.59995E+06 4.59995E+06 4.59995E+06 629082 629082 4.80895E+06 4.80895E+06 2663.07 8505.95 2638.20 kg/h	Mass Flow
Std Vapor Volumetric Flow m^3/h 68613.7 68613.7 68613.7 68613.7 4681.82 68613.7 1.22135E+02 6.04902E+06 6.04902E+06 6.04902E+06 6.04902E+06 6.04902E+06 6.32386E+06 6.32386E+06 3501.99 11185.5 3469.29 m^3/h	Std Vapor Volumetric Flow
Std Liquid Volumetric Flow m^3/h 155.182 155.182 155.182 3.58111 155.182 0.09 4604.47 4604.47 4604.47 629.701 629.701 4813.68 4813.68 2.66569 8.51432 2.64080 m^3/h	Std Liquid Volumetric Flow
Specific Gravity 1.51988 0.723313? 1.51988 0.998501 0.723204? 0.99742 1.00095 0.998540 1.00095 0.998544 1.00095 0.998544 0.622268 0.939745 0.622268 0.939745 0.622268	Specific Gravity
Ivides Ellulallyy NJ/NY -05902.00 -9107.00 -9107.00 -106023.4 -9107.00 -10601.2 -10921.7 -10581.2 -10921.7 -10581.2 -10921.7 -10581.2 -10921.7 -10581.2 -10921.7 -10581.2 -10220.4 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -9107.00 -910	iviass ⊑ninaipy Dynamic Viscosity
Dynamic viscosity Ci 0.0250050 0.0009522 0.0092271 0.005915 0.0009071 0.07950 1.29092 0.907115 1.29092 0.907115 1.29092 0.907115 0.0100144 02 0.2907115 0.0100144 02 0.907115 0.0100144 02 0.907115 0.0100144 02 0.907115 0.0100144 02 0.907115 0.0009071 0.07950 0.907115 0.0009071 0.097015 0.29092 0.907115 0.29092 0.907115 0.29092 0.907115 0.0009071 0.07950 0.907015 0.29092 0.907115 0.29092 0.907115 0.29092 0.907115 0.29092 0.907115 0.29092 0.907115 0.0009071 0.07950 0.29092 0.907115 0.29092 0.907115 0.29092 0.907115 0.29092 0.907115 0.29092 0.907115 0.0009071 0.07950 0.29092 0.907115 0.29092 0.907115 0.29092 0.907115 0.0009071 0.07950 0.29092 0.907115 0.29092 0.907115 0.29092 0.907115 0.0009071 0.07950 0.9000000000 0.900000000000000000000	C) Thermal Conductivity
Surface Tension dyne/cm 0.0000 72.3391 0.0000 72.6316 75.6475 73.6192 75.6475 73.6192 75.6475 73.6192 75.6475 73.6192 53.1489 dyne/cm	m Surface Tension

Process Streams		514	515	516	517	518	519	520	521	522	523	524	525	526	527	Process	Streams
		LP Steam	SCW Supply	SCW Return From E-113	SCW Supply	SCW Return From F-115	Condenstate	Condenstate	Condenstate	SCW Supply	SCW Return From F-117	LP Steam from F-116	LP Steam	LP Condensate from F-110	Vent Steam		
Mole Fraction		10 E-103 %	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fract	ion
Oxygen		0	) 0*	0	0*	0	0*	0*	0*	0*		0	0*	0	0	Oxygen	
Nitrogen		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen	
Water		100	100*	100	100*	100	100*	100*	100*	100*	100	100	100*	100	100	Water	
Carbon Dioxide		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Carbon Dic	xide
Sulfur Dioxide		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Diox	ide
MEA		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	MEA	
Argon		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon	
NO		0	0*	0	0*	0	0*	0*	0*	0*	. 0	0	0*	0	0	NÔ	
NO2		0	0*	0	0*	0	0*	0*	0*	0*	. 0	0	0*	0	0	NO2	
NH3		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3	
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flov	v
Oxygen		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxygen	
Nitrogen		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen	
Water		471.679	28067.5*	28067.5	18488.8*	18488.8	147.823*	146.443*	177.413*	45614.6*	45614.6	177.413	10380.1*	10380.1	288.503	Water	
Carbon Dioxide		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Carbon Dic	oxide
Sulfur Dioxide		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Diox	ide
MEA		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	MEA	
Argon		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon	
NO		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO	
NO2		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO2	
NH3		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3	
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Frac	tion
Oxygen		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxygen	
Nitrogen		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen	
Water		100	100*	100	100*	100	100*	100*	100*	100*	100	100	100*	100	100	Water	
Carbon Dioxide		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Carbon Dic	oxide
Sulfur Dioxide		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Diox	ide
MEA		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	MEA	
Argon		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon	
NO		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO	
NO2		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO2	
NH3		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3	
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow	1
Oxygen		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxygen	
Nitrogen		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen	
Water		8497.42	505645*	505645	333081*	333081	2663.07*	2638.20*	3196.15*	821760*	821760	3196.15	187000*	187000	5197.47	Water	
Carbon Dioxide		0	0^	0	0*	0	0*	0^	0*	0*	0	0	0^	0	0	Carbon Dic	oxide
Sulfur Dioxide		0	0^	0	0*	0	0*	0^	0*	0*	0	0	0^	0	0	Sulfur Diox	ide
MEA		0	0	0	0*	0	0	0	0	0	0	0	0	0	0		
Argon		0	0	0	0*	0	0*	0*	0*	0*	0	0	0"	0	0	Argon	
NO		0	0	0	0*	0	0*	0*	0*	0*	0	0	0"	0	0		
		0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0			
Process Streams		514	515	516	517	519	510	520	521	522	522	524	525	526	527	Brocoss	Stroome
Property	Unite	514	313	510	517	510	513	320	JZI	JZZ	525	J24	JZJ	520	JZI	Unite	Broperty
Tomporaturo	S Into	125 925	16*	26*	16*	26*	00 0000*	00 0000*	00 0000*	16*	26*	125 925	125*	122 504	146 425	er e	Tomporatura
Drooquiro	bor	120.000		1 21042	1 0000*	1 21042	90.0009	90.0009	90.0009	1 0000*	20	125.035	2 0000*	2 0000	2 2400*	bor	Drocouro
Mole Fraction Vapor	0/	2.37913	1.9999	1.31042	1.9999	1.31042	2.37913	2.37913	2.37913	1.9999	1.31042	2.37913	2.9999	2.9999	2.3499	0/	Molo Eractio
Molecular Weight	ka/kmol	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	ka/kmol	Molecular W
Mass Density	kg/m/2	1 31//6	002 270	006 195	000 270	006 195	950 505	950 505	950 505	0.0155	006 195	1 21//6	1 62556	032 265	1 22150	kg/m/2	Mase Deneit
Molar Flow	kmol/h	471 670	28067 5	28067 5	18488 8	18488 8	147 823	146 443	177 413	45614 6	45614 6	177 413	10380 1	10380 1	288 503	kmol/h	Molar Flow
Mass Flow	ka/h	8407 42	505645	505645	333081	333081	2663.07	2638.20	3106 15	821760	821760	3106 15	187000*	187000	5107 47	ka/h	Mass Flow
Std Vapor Volumetric Flow	m^3/h	11174 2	664032	664032	438008	438008	3501.00	3460.20	4203.00	1 08063E±06	1 08063E±06	4203.00	245909	245000	6834 77	m^3/h	Std Vapor V
Std Liquid Volumetric Flow	m^3/h	8 50579	506 142	506 142	333 400	333 400	2 66569	2 64080	3 19930	822 560	822 560	3 19930	187 184	187 184	5 20258	m^3/h	Std Liquid V
Specific Gravity		0.622268	0 999823	0 997127	0 999823	0 997127	0.960412	0.960412	0.960412	0.999823	0.997127	0.622268	0 622268	0 933146	0.622268		Specific Gra
Mass Enthalov	kJ/ka	-13240 4	-15904 0	-15862 9	-15904 0	-15862 9	-15561 8	-15561 8	-15561.8	-15904 0	-15862 9	-13240 4	-13224 7	-15390.4	-13200 2	kJ/ka	Mass Enthal
Dynamic Viscosity	cP	0.0106144	1 12405	0 874153	1 12405	0 874153	0.279294	0.279294	0.279294	1 12405	0.874153	0.0106144	0.0110023	0 206890	0.0114855	cP	Dynamic Vis
Thermal Conductivity	 W/(m*℃)	0.0270	0 5931	0 6077	0 5931	0 6077	0 6758	0 6758	0 6758	0 5931	0 6077	0 0270	0.0278	0.6856	0.0287	յ. W/(m*℃)	Thermal Cor
Surface Tension	dyne/cm	0.0270	74 6291	72 6168	74 6291	72 6168	58 4280	58 4280	58 4280	74 6291	72 6168	0.0210	0.0270	51 6045	0.0201	dyne/cm	Surface Ten
	-,		. 1.0201	0100		0100	55.1200	00.1200	00.1200					51.0040	1		

Bechtel: 25474-000-M4-CN-00001 Owner: 10112936-PB-P-HMB-0001 Revision 1

;	
;	
Ire	
tion Vapor	
Weight	
eity	
Sity	

r Volumetric Flow

d Volumetric Flow

Gravity

thalpy

Viscosity Co nductivity

Tension

Process Streams		001	002	003	004	005	006	007	008	009	010	100	101	102	103	Process Streams
		Flue Gas From	Flue Gas From	Process Water to	Process Water to	Process Water to	Abs 1. Flue Gas	Process Water to	Process Water to	Abs 2. Flue Gas	Softened	Cooled Flue	Warm Wash	Excess Water to	Off Gas to Atmosphere	
		CCPP	Common Fogger	Foggers	Common Fogger	Abs. 1 Fogger	Blower Discharge	Absorbers	Abs. 2 Fogger	Blower Discharge	Water	Gas to Abs. 1	Water (Abs. 1)	Absorbers	(Abs. 1)	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	Iole Fraction
Oxygen		12.5495*	12.2421	9.79466E-09	9.79466E-09	9.79466E-09	12.2421	9.79466E-09	9.79466E-09	12.2421	0	12.1586	0.000206160	0.000206160	12.8898 (	Dxygen
Nitrogen		73.3905*	71.5929	8.78164E-09	8.78164E-09	8.78164E-09	71.5929	8.78164E-09	8.78164E-09	71.5929	0	71.1044	0.000652141	0.000652141	75.3812	litrogen
Water		9.41850*	11.6351	99.9151	99.9151	99.9151	11.6351	99.9151	99.9151	11.6351	100	12.2375	99.3082	99.3082	10.2755	Vater
Carbon Dioxide		3.79120*	3.69975	0.0576852	0.0576852	0.0576852	3.69975	0.0576852	0.0576852	3.69975	0	3.67490	0.170016	0.170016	0.579779 (	Carbon Dioxide
Sulfur Dioxide		9.93210E-06*	9.69066E-06	7.49449E-08	7.49449E-08	7.49449E-08	9.69066E-06	7.49449E-08	7.49449E-08	9.69066E-06	0	9.62505E-06	1.02631E-07	1.02631E-07	1.00913E-05	Sulfur Dioxide
MEA		^U	0.000608395	0.0248384	0.0248384	0.0248384	0.000608395	0.0248384	0.0248384	0.000608395	0	0.000773726	0.520705	0.520705	0.000445242	
Argon		0.849489*	0.828681	7.87137E-10	7.87137E-10	7.87137E-10	0.828681	7.8/13/E-10	7.8/13/E-10	0.828681	0	0.823027	1.46786E-05	1.46786E-05	0.8725227	Argon
		7 020605 05*	7 725205 05	7.00073E-13	6 77192E 00	6 77192E 00	7 725205 05	6 77192E 00	6 77192E 00	7 72520 5 05	0	7 69261E 05	1 74040E 09	1 74040E 08	0.0003202171	102
NU2 NH3		0.000396864*	0.000446394	0.00241901	0.00241901	0.00241901	0.000446394	0.00241901	0.00241901	0.000446394	0	0.000459854	0.000190453	0.000190453	0.0004067591	102
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Nolar Flow
Oxvaen		10304 2*	10304 2	2 58574F-07	2 01934E-07	2 83200E-08	5152 09	1 24179E-07	2 83200E-08	5152.09	0	5152 09	0 153435	0.00782513	5152.00 (	)xvgen
Nitrogen		60259.8*	60259.8	2.31831E-07	1.81049E-07	2.53910E-08	30129.9	1.11336E-07	2.53910E-08	30129.9	0	30129.9	0.485357	0.0247531	30129.6	litrogen
Water		7733.38*	9793.30	2637.71	2059.92	288.892	4896.65	1266.75	288.892	4896.65	202.180	5185.54	73910.3	3769.41	4107.09	Vater
Carbon Dioxide		3112.90*	3114.09	1.52286	1.18928	0.166789	1557.04	0.731348	0.166789	1557.04	0	1557.21	126.535	6.45324	231.736	Carbon Dioxide
Sulfur Dioxide		0.00815509*	0.00815664	1.97851E-06	1.54512E-06	2.16694E-07	0.00407832	9.50171E-07	2.16694E-07	0.00407832	0	0.00407854	7.63833E-05	3.89553E-06	0.00403347	Sulfur Dioxide
MEA		0*	0.512086	0.655720	0.512086	0.0718170	0.256043	0.314908	0.0718170	0.256043	0	0.327860	387.536	19.7642	0.177962	1EA
Argon		697.502*	697.502	2.07800E-08	1.62282E-08	2.27591E-09	348.751	9.97954E-09	2.27591E-09	348.751	0	348.751	0.0109246	0.000557149	348.744	rgon
NO		0.260783*	0.260783	2.07466E-11	1.62021E-11	2.27225E-12	0.130392	9.96351E-12	2.27225E-12	0.130392	0	0.130392	5.75004E-06	2.93251E-07	0.130388	10
NO2		0.0651087*	0.0651088	1.78773E-07	1.39613E-07	1.95799E-08	0.0325544	8.58550E-08	1.95799E-08	0.0325544	0	0.0325544	1.30206E-05	6.64047E-07	0.0325463	102
NH3		0.325858*	0.375731	0.0638607	0.0498721	0.00699426	0.187865	0.0306689	0.00699426	0.187865	0	0.194860	0.141745	0.00722897	0.162580	IH3
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	lass Fraction
Oxygen		14.1999*	13.9760	1.73726E-08	1.73726E-08	1.73726E-08	13.9760	1.73726E-08	1.73726E-08	13.9760	0	13.9145	0.000360803	0.000360803	14.8919	Dxygen
Nitrogen		72.6995*	71.5533	1.36358E-08	1.36358E-08	1.36358E-08	71.5533	1.36358E-08	1.36358E-08	71.5533	0	71.2383	0.000999173	0.000999173	76.2430	litrogen
Water		5.99996*	7.47836	99.7729	99.7729	99.7729	7.47836	99.7729	99.7729	7.47836	100	7.88470	97.8496	97.8496	6.68368	Vater
Carbon Dioxide		5.89996*	5.80916	0.140718	0.140718	0.140718	5.80916	0.140718	0.140718	5.80916	0	5.78420	0.409232	0.409232	0.921255	Carbon Dioxide
Sulfur Dioxide		2.24998E-05*	2.21493E-05	2.66131E-07	2.66131E-07	2.66131E-07	2.21493E-05	2.66131E-07	2.66131E-07	2.21493E-05	0	2.20530E-05	3.59604E-07	3.59604E-07	2.33417E-05	Sulfur Dioxide
MEA		°0 4 40000t	0.00132587	0.0840978	0.0840978	0.0840978	0.00132587	0.0840978	0.0840978	0.00132587	0	0.00169028	1.73959	1.73959	0.000981947	
		1.19999	0.000221695	1.74295E-09	1.74295E-09	1.74295E-09	0.000221695	1.74295E-09	1.74295E-09	0.000221695	0	0.000220224	3.20709E-05	3.20709E-05	0.000252417	
		0.000330998	0.000331085	1.30708E-12	1.30708E-12	1.30708E-12	0.000331085	1.30708E-12	1.30708E-12	0.000331085	0	0.000330224	4 40204E-08	4 40204E-08	0.0003334171	102
NH3		0.000238998*	0.000120300	0.00228353	0.00228353	0.00228353	0.000120300	0.00228353	0.00228353	0.000120300	0	0.000720407	0.000177398	0.000177398	0.0001502501	143
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	lass Flow
Oxvaen		329722*	329722	8.27406E-06	6.46165E-06	9.06206E-07	164861	3.97359E-06	9.06206E-07	164861	0	164861	4.90972	0.250395	164858	Dxvgen
Nitrogen		1.68808E+06*	1.68808E+06	6.49437E-06	5.07179E-06	7.11288E-07	844041	3.11890E-06	7.11288E-07	844041	0	844041	13.5965	0.693419	844032	litrogen
Water		139319*	176429	47519.0	37110.1	5204.47	88214.5	22820.9	5204.47	88214.5	3642.33	93419.0	1.33152E+06	67906.9	73990.3	Vater
Carbon Dioxide		136997*	137049	67.0203	52.3396	7.34032	68524.7	32.1863	7.34032	68524.7	0	68532.0	5568.73	284.004	10198.6	Carbon Dioxide
Sulfur Dioxide		0.522446*	0.522545	0.000126751	9.89863E-05	1.38822E-05	0.261273	6.08716E-05	1.38822E-05	0.261273	0	0.261286	0.00489340	0.000249562	0.258399	Sulfur Dioxide
MEA		0*	31.2798	40.0534	31.2798	4.38680	15.6399	19.2355	4.38680	15.6399	0	20.0267	23671.9	1207.26	10.8704	1EA
Argon		27863.8*	27863.8	8.30121E-07	6.48285E-07	9.09180E-08	13931.9	3.98663E-07	9.09180E-08	13931.9	0	13931.9	0.436414	0.0222570	13931.6	rgon
NO		7.82508*	7.82508	6.22526E-10	4.86163E-10	6.81814E-11	3.91254	2.98966E-10	6.81814E-11	3.91254	0	3.91254	0.000172536	8.79931E-06	3.91243	10
NO2		2.99536*	2.99536	8.22453E-06	6.42297E-06	9.00782E-07	1.49768	3.94980E-06	9.00782E-07	1.49768	0	1.49768	0.000599019	3.05498E-05	1.49731	102
NH3		5.54954*	6.39889	1.08758	0.849348	0.119116	3.19944	0.522307	0.119116	3.19944	0	3.31856	2.41399	0.123113	2.76883	IH3
Process Streams		001	002	003	004	005	006	007	800	009	010	100	101	102	103	Process Streams
Property	Units															Inits Property
Temperature	°C	85*	49.2778	48.6255	48.6255	48.6254	61.8714	46.4539	48.6254	61.8714	20.0000	52.0985	55.3962	55.3962	46.5841	C Temperature
Pressure	bar	1.0017*	1.0017	138"	138	138	1.08857	4.13685"	138	1.08857	4.13685	1.08857	4.48079	4.48079	1.01273	Ar Pressure
Molecular Woight	70 ka/kmcl		100	19.0400	10 0400	10 0400	100	19.0400	49.0400	100	10 0150	100	10 2020	10 2020	100 5	
Mass Density	kg/m/3	20.2191	20.0289	10.0409	10.0409	10.0409	20.0289	18.0409	10.0409	20.0289	10.0153 007 002	27.90U7 1 12627	10.2030	10.2030	27.0908	a/m/3 Mass Density
Molar Flow	kmol/b	82108 /	1.04004 84170 1	390.200 2630 05	990.205 2061 68	990.200 280 127	1.09002	309.229 1267 83	990.200 280 127	1.09002	202 120	1.12037	300.001 74425 2	3705 66	30060 71	mol/h Molar Flow
Mass Flow	ka/h	2.32200F+06*	2 35919F+06	47627 2	37194 6*	5216 31	1 17960F+06	23343.4	5216 31	1 17960F+06	3642.33	1.18481F+06	1.36078E+06	60300 3	1 10703F±061	g/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	1.94518E+06	1.99403E+06	62541 6	48842.0	6849 79	997013	30035 4	6849 79	997013	4789.73	1.00386E+06	1.76317E+06	89921 0	946899 r	n^3/h Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	2709.46	2746.70	47.6884	37.2424	5.22302	1373.35	22.9022	5.22302	1373.35	3.64591	1378.57	1362.84	69.5043	1288.07 r	n^3/h Std Liquid Volumetric Flow
Specific Gravity		0.976812	0.968149	0.991141	0.991141	0.991141	0.968149	0.990164	0.991141	0.968149	0.998846	0.965795	0.987734	0.987734	0.956677	Specific Gravity
Mass Enthalpy	kJ/kg	-1269.64	-1497.71	-15735.9	-15735.9	-15735.9	-1484.20	-15756.7	-15735.9	-1484.20	-15885.0	-1546.95	-15515.2	-15515.2	-956.808	J/kg Mass Enthalpy
Dynamic Viscosity	сР	0.0202531	0.0186674	0.563976	0.563976	0.563977	0.0192098	0.571655	0.563977	0.0192098	1.01302	0.0187686	0.505559	0.505559	0.0187141	P Dynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.0290	0.0266	0.6342	0.6342	0.6342	0.0275	0.6317	0.6342	0.0275	0.5991	0.0268	0.6291	0.6291	0.0267	V/(m*℃) Thermal Conductivity
Surface Tension	dyne/cm			68.1036	68.1036	68.1036		68.5273	68.1036		73.8205		66.5042	66.5042		yne/cm Surface Tension

Process Streams		104	105	106	107	108	109	110	111	200	201	202	203	204	Process Streams
		Lean Amine	Cooled Semi-Lean	Rich Amine	Process Water to	Cooled Wash Water to	Cooled Wash	Cooled Wash Water to	Combined Wash Water to	Cooled Flue	Warm Wash	Excess Water to	Off Gas to Atmosphere	Lean Amine	
		(Abs. 1)	Amine (Abs. 1)	(Abs. 1)	Upper Bed (Abs. 1)	Lower Bed (Abs. 1)	Water (Abs. 1)	Upper Bed (Abs. 1)	Upper Bed (Abs. 1)	Gas to Abs. 1	Water (Abs. 2)	Absorbers	(Abs. 2)	(Abs. 2)	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		1.94394E-05	4.09154E-07	0.000198362	9.79466E-09	0.000206160	0.000206160	0.000206160	0.000164930	12.1586	0.000206160	0.000206160	12.8898	1.94394E-05	Oxygen
Nitrogen		6.14921E-05	8.76929E-07	0.000627346	8.78164E-09	0.000652141	0.000652141	0.000652141	0.000521715	71.1044	0.000652141	0.000652141	75.3812	6.14921E-05	Nitrogen
Water		82.4057	78.9860	78.6727	99.9151	99.3082	99.3082	99.3082	99.4296	12.2375	99.3082	99.3082	10.2755	82.4057	Water
Carbon Dioxide		3.24734	6.03129	6.57340	0.0576852	0.170016	0.170016	0.170016	0.147550	3.67490	0.170016	0.170016	0.579779	3.24734	Carbon Dioxide
Sulfur Dioxide		1.02990E-08	2.93751E-08	9.91719E-08	7.49449E-08	1.02631E-07	1.02631E-07	1.02631E-07	9.70937E-08	9.62505E-06	1.02631E-07	1.02631E-07	1.00913E-05	1.02990E-08	Sulfur Dioxide
MEA		14.3466	14.9824	14.7528	0.0248384	0.520705	0.520705	0.520705	0.421532	0.000773726	0.520705	0.520705	0.000445242	14.3466	MEA
Argon		1.38408E-06	2.79491E-08	1.41229E-05	7.87137E-10	1.46786E-05	1.46786E-05	1.46786E-05	1.17430E-05	0.823027	1.46786E-05	1.46786E-05	0.872522	1.38408E-06	Argon
NO		7.28504E-10	2.52085E-11	7.43319E-09	7.85873E-13	7.72594E-09	7.72594E-09	7.72594E-09	6.18091E-09	0.000307715	7.72594E-09	7.72594E-09	0.000326217	7.28504E-10	NO
NO2		1.70581E-09	3.03185E-10	1.68366E-08	6.77183E-09	1.74949E-08	1.74949E-08	1.74949E-08	1.53503E-08	7.68261E-05	1.74949E-08	1.74949E-08	8.14275E-05	1.70581E-09	NO2
NH3		0.000208783	0.000276320	0.000292817	0.00241901	0.000190453	0.000190453	0.000190453	0.000636165	0.000459854	0.000190453	0.000190453	0.000406759	0.000208783	NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen		0.00782516	3.92876E-05	0.0967313	2.93840E-08	0.150961	0.153435	0.002474	0.002474	5152.09	0.153435	0.00782513	5152.00	0.00782516	Oxygen
Nitrogen		0.0247531	8.42039E-05	0.305926	2.63449E-08	0.477532	0.485357	0.007826	0.007826	30129.9	0.485357	0.0247531	30129.6	0.0247531	Nitrogen
Water		33171.7	7584.34	38364.9	299.745	72718.6	73910.3	1191.7	1491.4	5185.54	73910.3	3769.41	4107.09	33171.7	Water
Carbon Dioxide		1307.19	579.132	3205.53	0.173055	124.495	126.535	2.040	2.213	1557.21	126.535	6.45324	231.736	1307.19	Carbon Dioxide
Sulfur Dioxide		4.14578E-06	2.82064E-06	4.83613E-05	2.24835E-07	7.51517E-05	7.63833E-05	1.23157E-06	1.45641E-06	0.00407854	7.63833E-05	3.89553E-06	0.00403347	4.14578E-06	Sulfur Dioxide
MEA		5775.12	1438.63	7194.21	0.0745151	381.287	387.536	6.248	6.323	0.327860	387.536	19.7642	0.177962	5775.12	MEA
Argon		0.000557152	2.68371E-06	0.00688705	2.36141E-09	0.0107484	0.0109246	0.0001761	0.0001761	348.751	0.0109246	0.000557149	348.744	0.000557152	Argon
NO		2.93253E-07	2.42055E-09	3.62481E-06	2.35762E-12	5.65733E-06	5.75004E-06	9.27112E-08	9.27136E-08	0.130392	5.75004E-06	2.93251E-07	0.130388	2.93253E-07	
NO2		6.86659E-07	2.91122E-08	8.21040E-06	2.03155E-08	1.28107E-05	1.30206E-05	2.09939E-07	2.30254E-07	0.0325544	1.30206E-05	6.64047E-07	0.0325463	6.86659E-07	NO2
NH3 Mass Fraction		0.0840440	0.0265326	0.142793	0.00725703	0.139460	0.141745	0.002285	0.009542	0.194860	0.141745	0.00722897	0.162580	0.0840440	Mass Fraction
		76	78	/6	/0	/6	78	/8	76	/8	/8	/8	/0	76	
Oxygen		2.48435E-05	5.02866E-07	0.000243400	1.73726E-08	0.000360803	0.000360803	0.000360803	0.000289415	13.9145	0.000360803	0.000360803	14.8919	2.48435E-05	Oxygen
Nitrogen Wotor		6.07990E-05	9.43543E-07	54 3404	1.30330E-00	0.000999173	0.000999173	0.000999173	0.00001470	71.2303	0.000999173	0.000999173	6 60260	0.07990E-00	Weter
Vvalei Carbon Dioxido		59.2919	10 1050	11 0024	0 140719	97.0490	97.0490	97.0490	90.2302	7.00470	97.0490	97.0490	0.00300	59.2919	Carbon Dioxido
Sulfur Dioxide		2 63515E-08	7 22810E-08	2 43630E-07	2 66131E-07	0.409232 3 5960//E_07	0.409232 3 59604E-07	0.409232 3 59604E-07	3 41108E-07	2 20530E-05	0.409232 3.59604E-07	0.409232 3 59604E-07	2 33/17E-05	2 63515E-08	Sulfur Dioxide
MFA		2.00010E-00	35 1507	34 5560	0.0840978	1 73959	1 73959	1 73959	1 41202	0.00169028	1 73959	1 73950	0.000981947	2.00010E-00	MEA
Argon		2 20828E-06	4 28838F-08	2 16346E-05	1 74295F-09	3 20709E-05	3 20709E-05	3 20709E-05	2 57254F-05	1 17587	3 20709E-05	3 20709E-05	1 25847	2 20828F-06	Argon
NO		8.73049E-10	2.90528E-11	8.55292E-09	1.30708E-12	1.26793E-08	1.26793E-08	1.26793E-08	1.01707E-08	0.000330224	1.26793E-08	1.26793E-08	0.000353417	8.73049E-10	NO
NO2		3.13428E-09	5.35733E-10	2.97026E-08	1.72686E-08	4.40204E-08	4.40204E-08	4.40204E-08	3.87270E-08	0.000126407	4.40204E-08	4.40204E-08	0.000135255	3.13428E-09	NO2
NH3		0.000142011	0.000180747	0.000191229	0.00228353	0.000177398	0.000177398	0.000177398	0.000594136	0.000280091	0.000177398	0.000177398	0.000250113	0.000142011	NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen		0.250396	0.00125715	3.09529	9.40252E-07	4.83056	4.90972	0.07916	0.07916	164861	4.90972	0.250395	164858	0.250396	Oxygen
Nitrogen		0.693419	0.00235884	8.57003	7.38010E-07	13.3773	13.5965	0.2192	0.2192	844041	13.5965	0.693419	844032	0.693419	Nitrogen
Water		597598	136634	691154	5399.99	1.31005E+06	1.33152E+06	2.14688E+04	2.68688E+04	93419.0	1.33152E+06	67906.9	73990.3	597598	Water
Carbon Dioxide		57528.8	25487.3	141074	7.61609	5478.95	5568.73	89.79	97.40	68532.0	5568.73	284.004	10198.6	57528.8	Carbon Dioxide
Sulfur Dioxide		0.000265594	0.000180701	0.00309821	1.44038E-05	0.00481450	0.00489340	0.00007890	0.00009330	0.261286	0.00489340	0.000249562	0.258399	0.000265594	Sulfur Dioxide
MEA		352762	87875.9	439444	4.55161	23290.2	23671.9	381.7	386.2	20.0267	23671.9	1207.26	10.8704	352762	MEA
Argon		0.0222571	0.000107209	0.275124	9.43337E-08	0.429377	0.436414	0.007037	0.007037	13931.9	0.436414	0.0222570	13931.6	0.0222571	Argon
NO		8.79939E-06	7.26314E-08	0.000108766	7.07429E-11	0.000169754	0.000172536	0.000002782	0.000002782	3.91254	0.000172536	8.79931E-06	3.91243	8.79939E-06	NO
NO2		3.15901E-05	1.33932E-06	0.000377724	9.34624E-07	0.000589361	0.000599019	0.000009658	0.000010593	1.49768	0.000599019	3.05498E-05	1.49731	3.15901E-05	NO2
NH3		1.43131	0.451864	2.43183	0.123591	2.37507	2.41399	0.03892	0.16251	3.31856	2.41399	0.123113	2.76883	1.43131	NH3
Process Streams		104	105	106	107	108	109	110	111	200	201	202	203	204	Process Streams
Property	Units														Units Property
Temperature	C	58.4696	61.211	55.3047	46.4540	26	26.0000	26	30.1718	52.0985	55.3962	55.3962	46.5841	58.4696	C Temperature
Pressure	bar	3.68912	5.15772	1.08857	4.13685	3.44658	3.44658	3.44658	3.44658	1.08857	4.48079	4.48079	1.01273	3.68912	bar Pressure
Mole Fraction Vapor	%	0	0	0	0	0	0	0	0	100	0	C	100	0	Mole Fraction Vapor
Molecular Weight	kg/kmol	25.0382	26.0357	26.0778	18.0409	18.2838	18.2838	18.2838	18.2353	27.9607	18.2838	18.2838	27.6968	25.0382	kg/kmol Molecular Weight
Mass Density	kg/m^3	1085.91	1142.18	1151.43	989.229	998.34	998.340	998.34	996.640	1.12637	986.801	986.801	1.05570	1085.91	kg/m^3 Mass Density
Notar Flow	kmol/h	40254.2	9602.13	48765.2	300	73225.2	74425.2	1200.0	1500.0	42374.2	74425.2	3795.66	39969.7	40254.2	
	kg/n	1.00789E+06	249998	1.2/169E+06	5412.28	1.33884E+06	1.36078E+06	2.19406E+04	2.73529E+04	1.18481E+06	1.36078E+06	69399.3	1.10703E+06	1.00789E+06	Kg/n Mass Flow
Sta Vapor Volumetric Flow	m^3/h	953639	227479	1.1552/E+06	7107.13	1./3474E+06	1.76317E+06	2.84285E+04	3.55357E+04	1.00386E+06	1.76317E+06	89921.0	946899	953639	Std Vapor Volumetric Flow
Sta Liquia Volumetric Flow	m^3/h	1014.05	253.949	1294.42	5.41924	1340.86	1362.84	21.97	27.39	1378.57	1362.84	69.5043	1288.07	1014.05	Std Liquid Volumetric Flow
Specific Gravity	14.1/14	1.08694	1.14325	1.15252	0.990164	0.999284	0.999284	0.999284	0.997582	0.965795	0.987734	0.987734	0.956677	1.08694	Specific Gravity
	кJ/Kg	-11392.3	-11136.3	-11178.5	-15756.7	-15637.2	-15637.2	-15637.2	-15660.9	-1546.95	-15515.2	-15515.2	-956.808	-11392.3	
	CP	1.57094	2.04854	2.46135	0.571653	0.909174	0.909174	0.909174	0.818804	0.0187686	0.505559	0.505559	0.018/141	1.57094	
	dvne/em	0.4195	0.38822	0.3823	0.0317	0.0949	0.0949	0.0949	0.0020	0.0208	0.0291	0.0291	0.0267	0.4195	dyne/cm Surface Tonsion
	uyne/Cm	50.7098	92.0036	95.4097	08.0273	72.1981?	12.1981	72.1981?	/1.2/09?		00.5042	00.5042	·L	56.7098	ayne/cm Sullace rensi0n

Process Streams		205	206	207	208	209	210	211	300	302	303	304	305	306	307	Process Streams
		Cooled Semi-Lean	Rich Amine	Process Water to	Cooled Wash Water to	Cooled Wash	Cooled Wash Water to	Combined Wash Water to	Combined Cold	Hot Rich	Stripper Bottoms to	Rich Amine		Filtered Lean	Fresh	
		Amine (Abs. 2)	(Abs. 2)	Upper Bed (Abs. 2)	Lower Bed (Abs. 2)	Water (Abs. 2)	Upper Bed (Abs. 2)	Upper Bed (Abs. 2)	Rich Amine	Amine	E-108 Inlet	to E-103	Lean Amine	Amine	Amine	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		4.09154E-07	0.000198362	9.79466E-09	0.000206160	0.000206160	0.000206160	0.000164930	0.000198362	0.000198362	0	0.000198362	1.94394E-05	1.94394E-05	0	Oxygen
Nitrogen		8.76929E-07	0.000627346	8.78164E-09	0.000652141	0.000652141	0.000652141	0.000521715	0.000627346	0.000627346	0	0.000627346	6.14921E-05	6.14921E-05	0	Nitrogen
Water		78.9860	78.6727	99.9151	99.3082	99.3082	99.3082	99.4296	78.6727	78.6727	80.4612	78.6727	82.4057	82.4057	0	Water
Carbon Dioxide		2 02751E 09	0.07340	0.0576852 7 40440E 09	1.02621E.07	1.02621E.07	1 02621E 07	0.147550	0.07340	0.57340	3.60148	0.57340	3.24734 1.0200E.09	3.24734	0	Carbon Dioxide
MFA		2.937312-08	9.91719E-08 14 7528	0 0248384	0 520705	0 520705	0 520705	9.709372-08	9.91719E-08 14 7528	9.91719E-08 14 7528	15 9371	9.91719E-08 14 7528	14 3466	14.3466	100	MEA
Argon		2.79491E-08	1.41229E-05	7.87137E-10	1.46786E-05	1.46786E-05	1.46786E-05	1.17430E-05	1.41229E-05	1.41229E-05	0	1.41229E-05	1.38408E-06	1.38408E-06	0	Argon
NO		2.52085E-11	7.43319E-09	7.85873E-13	7.72594E-09	7.72594E-09	7.72594E-09	6.18091E-09	7.43319E-09	7.43319E-09	0	7.43319E-09	7.28504E-10	7.28504E-10	0	NO
NO2		3.03185E-10	1.68366E-08	6.77183E-09	1.74949E-08	1.74949E-08	1.74949E-08	1.53503E-08	1.68366E-08	1.68366E-08	0	1.68366E-08	1.70581E-09	1.70581E-09	0	NO2
NH3		0.000276320	0.000292817	0.00241901	0.000190453	0.000190453	0.000190453	0.000636165	0.000292817	0.000292817	0.000190351	0.000292817	0.000208783	0.000208783	0	NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen		3.92876E-05	0.0967313	2.93840E-08	0.150961	0.153435	0.002474	0.002474	0.193463	0.154770	0	0.0386925	0.0125203	0.00313006	0	Oxygen
Nitrogen		8.42039E-05	0.305926	2.63449E-08	0.477532	0.485357	0.007826	0.007826	0.611852	0.489482	0	0.122370	0.0396050	0.00990125	0	Nitrogen
Water		7584.34	38364.9	299.745	72718.6	73910.3	1191.7	1491.4	76729.7	61383.8	58111.3	15345.9	53074.8	13268.7	0	Water
Carbon Dioxide		579.132	3205.53	0.173055	124.495	126.535	2.040	2.213	6411.06	5128.85	2601.09	1282.21	2091.50	522.876	0	
		2.82064E-06	4.83613E-05	2.24835E-07	7.51517E-05	7.63833E-05	1.23157E-06	1.45641E-06	9.67227E-05	1.73781E-05	11510.2	1.93445E-05	6.63324E-06	1.65831E-06	0.252151	
		2 68371E-06	0.00688705	2 36141E-09	0 0107484	0 0109246	0.240	0.023	0.0137741	0.0110103	11510.2	0.00275482	9240.19	0.000222861	0.353151	Argon
NO		2.00371E-00 2.42055E-09	3 62481E-06	2.30141E-03	5 65733E-06	5 75004F-06	9 27112F-08	9 27136E-08	7 24961E-06	5 79969E-06	0	1 44992F-06	4 69205E-07	1 17301F-07	0	NO
NO2		2.91122E-08	8.21040E-06	2.03155E-08	1.28107E-05	1.30206E-05	2.09939E-07	2.30254E-07	1.64208E-05	1.31366E-05	0	3.28416E-06	1.09866E-06	2.74664E-07	0	NO2
NH3		0.0265326	0.142793	0.00725703	0.139460	0.141745	0.002285	0.009542	0.285585	0.228468	0.137477	0.0571171	0.134470	0.0336176	0	NH3
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fraction
Oxygen		5.02866E-07	0.000243400	1.73726E-08	0.000360803	0.000360803	0.000360803	0.000289415	0.000243400	0.000243400	0	0.000243400	2.48435E-05	2.48435E-05	0	Oxygen
Nitrogen		9.43543E-07	0.000673911	1.36358E-08	0.000999173	0.000999173	0.000999173	0.000801470	0.000673911	0.000673911	0	0.000673911	6.87990E-05	6.87990E-05	0	Nitrogen
Water		54.6541	54.3494	99.7729	97.8496	97.8496	97.8496	98.2302	54.3494	54.3494	56.1503	54.3494	59.2919	59.2919	0	Water
Carbon Dioxide		10.1950	11.0934	0.140718	0.409232	0.409232	0.409232	0.356101	11.0934	11.0934	6.13977	11.0934	5.70783	5.70783	0	Carbon Dioxide
Sulfur Dioxide		7.22810E-08	2.43630E-07	2.66131E-07	3.59604E-07	3.59604E-07	3.59604E-07	3.41108E-07	2.43630E-07	2.43630E-07	0	2.43630E-07	2.63515E-08	2.63515E-08	0	Sulfur Dioxide
MEA		35.1507	34.5560	0.0840978	1.73959	1.73959	1.73959	1.41202	34.5560	34.5560	37.7098	34.5560	35	35	100	MEA
Argon		4.28838E-08	2.16346E-05	1.74295E-09	3.20709E-05	3.20709E-05	3.20709E-05	2.57254E-05	2.16346E-05	2.16346E-05	0	2.16346E-05	2.20828E-06	2.20828E-06	0	Argon
NO NO2		2.90528E-11	8.55292E-09	1.30708E-12	1.26793E-08	1.26793E-08	1.26793E-08	1.01707E-08	8.55292E-09	8.55292E-09	0	8.55292E-09	8.73049E-10	8.73049E-10	0	NO NO2
NU2 NH3		0.000180747	0.000191229	0.00228353	4.40204E-08	4.40204E-08	4.40204E-00	0.000594136	0.000191229	0.000101220	0 000125576	0.000191229	0.000142011	0.000142011	0	NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxvgen		0.00125715	3.09529	9.40252E-07	4.83056	4.90972	0.07916	0.07916	6.19057	4.95246	0	1.23811	0.400633	0.100158	0	Oxvgen
Nitrogen		0.00235884	8.57003	7.38010E-07	13.3773	13.5965	0.2192	0.2192	17.1401	13.7120	0	3.42801	1.10947	0.277368	0	Nitrogen
Water		136634	691154	5399.99	1.31005E+06	1.33152E+06	2.14688E+04	2.68688E+04	1.38231E+06	1.10585E+06	1.04689E+06	276462	956157	239039	0	Water
Carbon Dioxide		25487.3	141074	7.61609	5478.95	5568.73	89.79	97.40	282147	225718	114473	56429.5	92046.0	23011.5	0	Carbon Dioxide
Sulfur Dioxide		0.000180701	0.00309821	1.44038E-05	0.00481450	0.00489340	0.00007890	0.00009330	0.00619642	0.00495714	0	0.00123928	0.000424951	0.000106238	0	Sulfur Dioxide
MEA		87875.9	439444	4.55161	23290.2	23671.9	381.7	386.2	878889	703111	703078	175778	564419	141105	21.5716	MEA
Argon		0.000107209	0.275124	9.43337E-08	0.429377	0.436414	0.007037	0.007037	0.550248	0.440198	0	0.110050	0.0356114	0.00890284	0	Argon
NO		7.26314E-08	0.000108766	7.07429E-11	0.000169754	0.000172536	0.000002782	0.000002782	0.000217533	0.000174026	0	4.35065E-05	1.40790E-05	3.51975E-06	0	NO
NO2		1.33932E-06	0.000377724	9.34624E-07	0.000589361	0.000599019	0.000009658	0.000010593	0.000755447	0.000604358	0	0.000151089	5.05442E-05	1.26360E-05	0	NO2
Process Streams		0.451864	2.43183	0.123591	2.37507	2.41399	0.03892 <b>210</b>	0.16251	4.86367	3.89094 <b>302</b>	2.34130	0.972734	2.29010	0.572525	0 307	Process Streams
Property	Unite	205	200	201	200	209	210	211	300	302	303	304	303	300	307	Linits Property
Tomporaturo	S S	61 211	55 2047	46 4540	26	26,0000	26	20 1719	55.4506	117*	126.496	55 4506	59,4606	58 4606	20,0000	
Pressure	bar	5 15772	1 08857	40.4540	20 3 44658	20.0000	20 3 <i>44</i> 658	3 44658	55.4506 10.7412	9 70702	5 41280	55.4506 10 7412	3 68912	3 68912	20.0000	bar Pressure
Mole Fraction Vapor	%	0.13772	0.00007	4.10000	0.11008	0.0	0.00	0.44030	0.7412	0.10102	0.41200	0.7412	0.00312	0.00312	0	% Mole Fraction Vapor
Molecular Weight	ka/kmol	26.0357	26.0778	18.0409	18.2838	18.2838	18.2838	18.2353	26.0778	26.0778	25.8152	26.0778	25.0382	25.0382	61.0831	ka/kmol Molecular Weight
Mass Density	kg/m^3	1142.18	1151.43	989.229	998.34	998.340	998.34	996.640	1151.50	1132.22	1067.22	1151.50	1085.91	1085.91	1021.42	kg/m^3 Mass Density
Molar Flow	kmol/h	9602.13	48765.2	300	73225.2	74425.2	1200.0	1500.0	97530.3	78024.3	72222.7	19506.1	64406.7	16101.7	0.353151	kmol/h Molar Flow
Mass Flow	kg/h	249998	1.27169E+06	5412.28	1.33884E+06	1.36078E+06	2.19406E+04	2.73529E+04	2.54337E+06	2.03470E+06	1.86444E+06	508675	1.61263E+06	403157	21.5716	kg/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	227479	1.15527E+06	7107.13	1.73474E+06	1.76317E+06	2.84285E+04	3.55357E+04	2.31054E+06	1.84843E+06	1.71099E+06	462107	1.52582E+06	381456	8.36631	m^3/h Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	253.949	1294.42	5.41924	1340.86	1362.84	21.97	27.39	2588.84	2071.07	1876.54	517.768	1622.48	405.621	0.0211464	m^3/h Std Liquid Volumetric Flow
Specific Gravity		1.14325	1.15252	0.990164	0.999284	0.999284	0.999284	0.997582	1.15259	1.13329	1.06823	1.15259	1.08694	1.08694	1.02239	Specific Gravity
Mass Enthalpy	kJ/kg	-11136.3	-11178.5	-15756.7	-15637.2	-15637.2	-15637.2	-15660.9	-11177.3	-10956.3	-10807.4	-11177.3	-11392.3	-11392.3	-4445.34	kJ/kg Mass Enthalpy
Dynamic Viscosity	cP	2.04854	2.46135	0.571653	0.909174	0.909174	0.909174	0.818804	2.45591	0.689788	0.518855	2.45591	1.57094	1.57094	26.8174	CP Dynamic Viscosity
I nermal Conductivity	vv/(m*℃)	0.3882	0.3823	0.6317	0.5949	0.5949	0.5949	0.6026	0.3823	0.3946	0.4151	0.3823	0.4195	0.4195	0.2355	w/(m^C) I nermal Conductivity
Surface Lension	ayne/cm	92.6636	95.4097	68.5273	72.1981?	72.1981	72.1981?	71.2709?	92.8998	87.0839	46.5956	92.8998	58.7098	58.7098	48.9361	ayne/cm Surface Lension

Process Streams		309	310	311	312	313	314	315	316	317	318	319	320	322	323	324	325	330	Process Streams
		Rich Amine to E-107	Rich Amine to E-109	Rich Amine to V-101	Flash Gas	Hot Semi- Lean Amine	Stripper Bottoms	Stripper Bottoms to E-107	Reclaimer Feed	Reclaimer Product	Stripper Reboiler Inlet	Stripper Reboiler Discharge	Stripper Overhead	Stripper Reflux	Reflux Purge	Cooled Stripper Overhead	Stripper Overhead Liquid	Hot Semi- Lean Amine	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		0.000198362	0.000198362	0.000198362	0.0127944	4.09154E-07	0	0	0	0	0	0	0.00285148	2.12922E-07	2.12922E-07	0.00285148	3 2.12922E-07	4.09154E-07	Oxygen
Nitrogen		0.000627346	0.000627346	0.000627346	0.0404907	8.76928E-07	0	0	0	0	0	0	0.00901936	3.57631E-07	3.57631E-07	0.00901936	6 3.57631E-07	8.76928E-07	Nitrogen
Water		78.6727	78.6727	78.6727	58.7343	78.9860	80.4612	80.4612	80.4612	95.7155	80.4612	80.4612	60.8657	99.8812	99.8812	60.8657	99.8812	78.9860	Water
Carbon Dioxide		6.57340	6.57340	6.57340	41.0691	6.03129	3.60148	3.60148	3.60148	4.28427	3.60148	3.60148	39.1048	0.0887872	0.0887872	39.1048	0.0887872	6.03129	Carbon Dioxide
Sulfur Dioxide		9.91719E-08	9.91719E-08	9.91719E-08	4.54047E-06	2.93751E-08	0	0	0	0	0	0	1.34698E-06	6.82892E-08	6.82892E-08	1.34698E-06	6.82892E-08	2.93751E-08	Sulfur Dioxide
MEA		14.7528	14.7528	14.7528	0.141059	14.9824	15.9371	15.93/1	15.9371	0	15.9371	15.9371	0.0158995		0.0273178	0.0158995		14.9824	MEA
		7.43319E-09	7.43319E-09	7.43319E-09	4 78816E-07	2.79490E-08	0	0	0	0	0	0	1.06825E-07	1.00040E-00	1.00040E-00	1.06825E-07	1 17871E-11	2.79490E-08	NO
NO2		1.68366E-08	1.68366E-08	1.68366E-08	1.06889E-06	3 03185E-10	0	0	0	0	0	0	2 41283E-07	2 54548E-10	2 54548E-10	2 41283E-07	2 54548E-10	3 03185E-10	NO2
NH3		0.000292817	0.000292817	0.000292817	0.00134263	0.000276319	0.000190351	0.000190351	0.000190351	0.000226439	0.000190351	0.000190351	0.00155578	0.00266401	0.00266401	0.00155578	0.00266401	0.000276319	NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen		0.0386925	0.0386925	0.0386925	0.0386140	7.85750E-05	0	0	0	0	0	0	0.193385	8.40445E-07	7.56401E-06	0.193385	5 8.40445E-06	7.85750E-05	Oxygen
Nitrogen		0.122370	0.122370	0.122370	0.122202	0.000168408	0	0	0	0	0	0	0.611685	1.41164E-06	1.27047E-05	0.611685	5 1.41164E-05	0.000168408	Nitrogen
Water		15345.9	15345.9	15345.9	177.262	15168.7	58111.3	58111.3	0	0	38740.8	38740.8	4127.86	394.250	3548.25	4127.86	3942.50	15168.7	Water
Carbon Dioxide		1282.21	1282.21	1282.21	123.948	1158.26	2601.09	2601.09	0	0	1734.06	1734.06	2652.06	0.350460	3.15414	2652.06	3.50460	1158.26	Carbon Dioxide
Sulfur Dioxide		1.93445E-05	1.93445E-05	1.93445E-05	1.37033E-05	5.64127E-06	0	0	0	0	0	0	9.13509E-05	2.69550E-07	2.42595E-06	9.13509E-05	5 2.69550E-06	5.64127E-06	Sulfur Dioxide
MEA		2877.68	2877.68	2877.68	0.425719	2877.26	11510.2	11510.2	0	0	7673.46	7673.46	1.07829	0.107829	0.970458	1.07829	0 1.07829 6 24907E 07	2877.26	MEA
Argon		0.00275482	0.00275482	0.00275482	0.00274945	5.36741E-06	0	0	0	0	0	0	0.0137688 7 24482E-06	0.34897E-08	5.71407E-07	0.0137688 7.24482E-06	6.34897E-07	5.36741E-06	Argon
NO2		3 28416E-06	3 28416E-06	3 28416E-06	3 22594E-06	5.82243E-08	0	0	0	0	0	0	1.63636E-05	4.05250E-11	9.04274F-09	1.63636E-05	1 00475F-08	5.82243E-08	NO2
NH3		0.0571171	0.0571171	0.0571171	0.00405210	0.0530650	0.137477	0.137477	0	0	0.0916512	0.0916512	0.105512	0.0105153	0.0946380	0.105512	0.105153	0.0530650	NH3
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fraction
Oxygen		0.000243400	0.000243400	0.000243400	0.0142364	5.02866E-07	0	0	0	0	0	0	0.00323692	3.77464E-07	3.77464E-07	0.00323692	2 3.77464E-07	5.02866E-07	Oxygen
Nitrogen		0.000673911	0.000673911	0.000673911	0.0394428	9.43542E-07	0	0	0	0	0	0	0.00896335	5.55037E-07	5.55037E-07	0.00896335	5.55037E-07	9.43542E-07	Nitrogen
Water		54.3494	54.3494	54.3494	36.7942	54.6541	56.1503	56.1503	56.1503	90.1431	56.1503	56.1503	38.8993	99.6886	99.6886	38.8993	99.6886	54.6541	Water
Carbon Dioxide		11.0934	11.0934	11.0934	62.8504	10.1950	6.13977	6.13977	6.13977	9.85672	6.13977	6.13977	61.0528	0.216480	0.216480	61.0528	0.216480	10.1950	Carbon Dioxide
Sulfur Dioxide		2.43630E-07	2.43630E-07	2.43630E-07	1.01149E-05	7.22809E-08	0	0	0	0	0	0	3.06127E-06	2.42373E-07	2.42373E-07	3.06127E-06	6 2.42373E-07	7.22809E-08	Sulfur Dioxide
MEA		34.5560	34.5560	34.5560	0.299618	35.1507	37.7098	37.7098	37.7098	0	37.7098	37.7098	0.0344534	0.0924459	0.0924459	0.0344534	0.0924459	35.1507	MEA
Argon		2.16346E-05	2.16346E-05	2.16346E-05	0.00126551	4.28838E-08	0	0	0	0	0	0	0.000287718	3.55984E-08	3.55984E-08	0.000287718	3.55984E-08	4.28838E-08	Argon
		2.97026E-08	0.55292E-09	2 97026E-08	4.99603E-07	2.90528E-11	0	0	0	0	0	0	3.93790E-07	1.95940E-11 6.48784E-10	1.95946E-11 6.48784E-10	1.13714E-07 3.93790E-07	6.48784E-10	2.90526E-11 5 35733E-10	NO2
NH3		0.000191229	0.000191229	0.000191229	0.000795118	0.000180747	0.000125576	0.000125576	0.000125576	0.000201599	0.000125576	0.000125576	0.000939952	0.00251353	0.00251353	0.000939952	0.00251353	0.000180747	NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen		1.23811	1.23811	1.23811	1.23560	0.00251431	0	0	0	0	0	0	6.18808	2.68932E-05	0.000242039	6.18808	0.000268932	0.00251431	Oxygen
Nitrogen		3.42801	3.42801	3.42801	3.42329	0.00471767	0	0	0	0	0	0	17.1354	3.95448E-05	0.000355903	17.1354	0.000395448	0.00471767	Nitrogen
Water		276462	276462	276462	3193.42	273268	1.04689E+06	1.04689E+06	0	0	697927	697927	74364.5	7102.53	63922.7	74364.5	5 71025.3	273268	Water
Carbon Dioxide		56429.5	56429.5	56429.5	5454.87	50974.6	114473	114473	0	0	76315.1	76315.1	116716	15.4236	138.812	116716	5 154.236	50974.6	Carbon Dioxide
Sulfur Dioxide		0.00123928	0.00123928	0.00123928	0.000877883	0.000361401	0	0	0	0	0	0	0.00585229	1.72684E-05	0.000155416	0.00585229	0.000172684	0.000361401	Sulfur Dioxide
MEA		175778	175778	175778	26.0042	175752	703078	703078	0	0	468719	468719	65.8652	6.58650	59.2785	65.8652	65.8650	175752	MEA
Argon		0.110050	0.110050	0.110050	0.109835	0.000214417	0	0	0	0	0	0	0.550036	2.53629E-06	2.28266E-05	0.550036	2.53629E-05	0.000214417	Argon
		4.33003E-03	4.33003E-03	4.33003E-03	4.33012E-03	2 67864E-06	0	0	0	0	0	0	0.000217389	4 62240E-08	1.25045E-08	0.000217389	4 62240F-07	2 67864E-06	NO2
NH3		0.972734	0.972734	0.972734	0.0690093	0.903725	2.34130	2.34130	0	0	1.56087	1.56087	1.79692	0.179082	1.61173	1.79692	1.79082	0.903725	NH3
Process Streams		309	310	311	312	313	314	315	316	317	318	319	320	322	323	324	325	330	Process Streams
Property	Units																		Units Property
Temperature	C	108*	112.778*	121.600	113.998	114.052	127.675	127.743			127.675	130.233	105.163	48.7488	48.7488	48.8889*	* 48.6928	113.998	C Temperature
Pressure	bar	9.70702	8.67281	7.63859	2.39982*	5.84719	2.31016	6.10228	6.10228	6.10228	2.31016	2.31016	1.96543	5.24044	5.24044	1.82753	3 1.79306	2.39982	bar Pressure
Mole Fraction Vapor	%	0	0	0	100	0	0	0			0	19.5697	100	0	0	41.7716	δ 0	0	% Mole Fraction Vapor
Molecular Weight	kg/kmol	26.0778	26.0778	26.0778	28.7576	26.0356	25.8152	25.8152	25.8152	19.1289	25.8152	25.8152	28.1884	18.0501	18.0501	28.1884	18.0501	26.0356	kg/kmol Molecular Weight
Mass Density	kg/m^3	1135.90	1133.97	1130.21	2.16808	1124.28	1066.45	1066.47		_	1066.45	9.16267	1.77910	988.425	988.425	4.63637	988.400	1124.26	kg/m^3 Mass Density
IVIOIAT FIOW	kmol/h	19506.1	19506.1	19506.1	301.803	19204.3	72222.7	72222.7	0	0	48148.5	48148.5	6781.92	394.719	3552.47	6781.92	3947.19	19204.3	kmoi/h Molar Flow
Std Vapor Volumetric Flow	ky/li m^3/b	2080/5 462107	208075 462107	2006/5 462107	00/9.13 71/0.94	499995 151057	1.00444E+06	1.00444E+06	0	0	1.24296E+06	1.24296E+06 1.14066E±06	191172	1124.12	04122.4 84150 6	1911/2	2 /124/.2 03510.7	499995 454057	m/3/h Std Vanor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	517 768	517 768	517 768	9 86900	507 898	1876 54	1876 54	0	0	1251 03	1251 03	216 657	7 13504	64 2154	216 657	7 71 3504	507 898	m^3/h Std Liquid Volumetric Flow
Specific Gravity		1.13698	1.13504	1.13128	0.993321	1.12535	1.06746	1.06748	0	Ű	1.06746	1201.00	0.973661	0.989359	0.989359	210.007	0.989334	1.12533	Specific Gravity
Mass Enthalpy	kJ/kg	-10990.6	-10972.6	-10938.6	-10460.2	-10946.4	-10803.0	-10802.4	-10802.4		-10803.0	-10482.4	-10582.7	-15741.1	-15741.1	-11540.8	-15741.6	-10946.9	kJ/kg Mass Enthalpy
Dynamic Viscosity	сР	0.795626	0.736343	0.643765	0.0170095	0.705187	0.510247	0.510228			0.510247		0.0165147	0.548094	0.548094		0.548241	0.705264	cP Dynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.3942	0.3945	0.3946	0.0247	0.3982	0.4149	0.4149			0.4149		0.0240	0.6334	0.6334		0.6334	0.3982	W/(m*℃) Thermal Cond uctivity
Surface Tension	dyne/cm	88.2489	87.8920	86.9700		86.8515	46.3922	46.3737			46.3922			68.0573	68.0573		68.0682	87.6418	dyne/cm Surface Tension

Process Streams		332	333	334	400	401	402	403	404	405	406	407	408	409	410	411	Process Streams
		Cold Rich Amine to Lean	Process Water to	Lean Amine to		1st Stage	Hot 1st Stage	Cooled 1st Stage	Cold 1st Stage	2nd Stage	Hot 2nd Stage	Cooled 2nd Stage	Cold 2nd Stage		3rd Stage	Hot 3rd Stage	
		Rich Exchanger	Absorbers	E-102 Inlet	CO2	Suction	Discharge	Discharge	Discharge	Suction	Discharge	Discharge	Discharge	Dryer Inlet	Suction	Discharge	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		0.000198362	9.79466E-09*	0	0.00682169	0.00682175	0.00682175	0.00682175	0.00682175	0.00725176	0.00725176	0.00725176	0.00725176	0.00728635	0.00729932	0.00729932	Oxygen
Nitrogen		0.000627346	8.78164E-09*	0	0.0215778	0.0215779	0.0215779	0.0215779	0.0215779	0.0229382	0.0229382	0.0229382	0.0229382	0.0230476	0.0230887	0.0230887	Nitrogen
Water		78.6727	99.9151*	80.4612	6.53882	6.53804	6.53804	6.53804	6.53804	0.658039	0.658039	0.658039	0.658039	0.188670	0.0110001	0.0110001	Water
Carbon Dioxide		6.57340	0.0576852*	3.60148	93.4323	93.4331	93.4331	93.4331	93.4331	99.3112	99.3112	99.3112	99.3112	99.7805	99.9581	99.9581	Carbon Dioxide
		9.91719E-08	7.49449E-08 [^]	15 0271	3.12747E-06	3.12750E-06	3.12750E-06	3.12750E-06	3.12750E-06	3.30779E-06	3.30779E-06	3.30779E-06	3.30779E-06	3.31803E-06	3.32393E-06	3.32393E-06	
Argon		14.7520 1 /1220E-05	0.0240304	15.9371	0.41497 E-00	0.41229E-00	0.41229E-00	0.41229E-00	0.41229E-00	2.97760E-09	2.97760E-09	2.97760E-09	2.97760E-09	4.60323E-10	4.01170E-10	4.01170E-10	Argon
NO		7 43319F-09	7.87137E-10	0	2.55557E-07	2.55559E-07	2.55559E-07	2 55559E-07	2 55559E-07	2 71668E-07	2 71668E-07	2 71668E-07	2 71668E-07	2 72963E-07	2 73449E-07	2 73449E-07	NO
NO2		1.43366E-08	6 77183E-09*	0	5 76900E-07	5 76904E-07	5 76904E-07	5 76904F-07	5 76904E-07	5 93889E-07	5 93889E-07	5 93889E-07	5 93889E-07	5 90605E-07	5 91656E-07	5 91656E-07	NO2
NH3		0.000292817	0.00241901*	0.000190351	1.26484E-05	1.26484E-05	1.26484E-05	1.26484E-05	1.26484E-05	9.48676E-06	9.48676E-06	9.48676E-06	9.48676E-06	8.41952E-06	8.43450E-06	8.43450E-06	NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen		0.154770	6.79663E-08*	0	0.193376	0.193376	0.193376	0.193376	0.193376	0.193375	0.193375	0.193375	0.193375	0.193375	0.193375	0.193375	Oxygen
Nitrogen		0.489482	6.09368E-08*	0	0.611671	0.611671	0.611671	0.611671	0.611671	0.611669	0.611669	0.611669	0.611669	0.611669	0.611669	0.611669	Nitrogen
Water		61383.8	693.322*	58111.3	185.358	185.334	185.334	185.334	185.334	17.5473	17.5473	17.5473	17.5473	5.00717	0.291417	0.291417	Water
Carbon Dioxide		5128.85	0.400284*	2601.09	2648.55	2648.55	2648.55	2648.55	2648.55	2648.23	2648.23	2648.23	2648.23	2648.11	2648.11	2648.11	Carbon Dioxide
Sulfur Dioxide		7.73781E-05	5.20051E-07*	0	8.86554E-05	8.86554E-05	8.86554E-05	8.86554E-05	8.86554E-05	8.82054E-05	8.82054E-05	8.82054E-05	8.82054E-05	8.80582E-05	8.80582E-05	8.80582E-05	Sulfur Dioxide
MEA		11510.7	0.172356*	11510.2	2.38542E-06	2.38464E-06	2.38464E-06	2.38464E-06	2.38464E-06	7.94006E-08	7.94006E-08	7.94006E-08	7.94006E-08	1.27475E-08	1.27475E-08	1.27475E-08	MEA
Argon		0.0110193	5.46204E-09*	0	0.0137682	0.0137682	0.0137682	0.0137682	0.0137682	0.0137681	0.0137681	0.0137681	0.0137681	0.0137680	0.0137680	0.0137680	Argon
NO		5.79969E-06	5.45326E-12*	0	7.24435E-06	7.24435E-06	7.24435E-06	7.24435E-06	7.24435E-06	7.24429E-06	7.24429E-06	7.24429E-06	7.24429E-06	7.24426E-06	7.24426E-06	7.24426E-06	NO
NO2		1.31366E-05	4.69905E-08*	0	1.63535E-05	1.63535E-05	1.63535E-05	1.63535E-05	1.63535E-05	1.58366E-05	1.58366E-05	1.58366E-05	1.58366E-05	1.56742E-05	1.56742E-05	1.56742E-05	NO2
Mass Fraction		0.228408	0.0167858	0.137477	0.000358549	0.000358546	0.000358546	0.000358546	0.000358546	0.000252974	0.000252974	0.000252974	0.000252974	0.000223448	0.000223448	0.000223448	NEI3 Mass Fraction
		0.000243400	1 73726E-08*	<i>,</i> ,	0.00515976	0.00515977	0.00515977	0.00515977	0.00515977	0.00520380	0.00529380	0.00529380	0.00529380	0.00530429	0.00530815	0.00530815	
Nitrogen		0.000243400	1.36358E-08*	0	0.00313970	0.00313977	0.00313977	0.00313977	0.00313977	0.00529580	0.00329380	0.00529580	0.00529580	0.00530429	0.0146991	0.00550815	Nitrogen
Water		54 3494	99 7729*	56 1503	2 78448	2 78413	2 78413	2 78413	2 78413	0 270447	0 270447	0 270447	0 270447	0.0773262	0.00450366	0.00450366	Water
Carbon Dioxide		11.0934	0.140718*	6.13977	97.1956	97.1960	97.1960	97.1960	97.1960	99.7091	99.7091	99.7091	99.7091	99.9022	99.9750	99.9750	Carbon Dioxide
Sulfur Dioxide		2.43630E-07	2.66131E-07*	0	4.73598E-06	4.73599E-06	4.73599E-06	4.73599E-06	4.73599E-06	4.83438E-06	4.83438E-06	4.83438E-06	4.83438E-06	4.83588E-06	4.83941E-06	4.83941E-06	Sulfur Dioxide
MEA		34.5560	0.0840978*	37.7098	1.21500E-07	1.21461E-07	1.21461E-07	1.21461E-07	1.21461E-07	4.14932E-09	4.14932E-09	4.14932E-09	4.14932E-09	6.67479E-10	6.67966E-10	6.67966E-10	MEA
Argon		2.16346E-05	1.74295E-09*	0	0.000458630	0.000458632	0.000458632	0.000458632	0.000458632	0.000470544	0.000470544	0.000470544	0.000470544	0.000471477	0.000471820	0.000471820	Argon
NO		8.55292E-09	1.30708E-12*	0	1.81260E-07	1.81260E-07	1.81260E-07	1.81260E-07	1.81260E-07	1.85968E-07	1.85968E-07	1.85968E-07	1.85968E-07	1.86336E-07	1.86472E-07	1.86472E-07	NO
NO2		2.97026E-08	1.72686E-08*	0	6.27355E-07	6.27357E-07	6.27357E-07	6.27357E-07	6.27357E-07	6.23311E-07	6.23311E-07	6.23311E-07	6.23311E-07	6.18144E-07	6.18595E-07	6.18595E-07	NO2
NH3		0.000191229	0.00228353*	0.000125576	5.09176E-06	5.09174E-06	5.09174E-06	5.09174E-06	5.09174E-06	3.68584E-06	3.68584E-06	3.68584E-06	3.68584E-06	3.26211E-06	3.26448E-06	3.26448E-06	NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen		4.95246	2.17484E-06*	0	6.18782	6.18782	6.18782	6.18782	6.18782	6.18778	6.18778	6.18778	6.18778	6.18776	6.18776	6.18776	Oxygen
Nitrogen		13.7120	1.70705E-06*	0	17.1350	17.1350	17.1350	17.1350	17.1350	17.1349	17.1349	17.1349	17.1349	17.1349	17.1349	17.1349	Nitrogen
Water		1.10585E+06	12490.4*	1.04689E+06	3339.27	3338.84	3338.84	3338.84	3338.84	316.119	316.119	316.119	316.119	90.2055	5.24996	5.24996	Water
Carbon Dioxide		225718	2 221655 05*	114473	116561	116561	116561	0.00567060	116561	116547	116547	116547	116547	116542	116542	116542	Carbon Dioxide
		0.00495714	10 5281*	703078	0.00567960	0.00567960	0.00567960	0.00567960	0.00567960	0.00565077	4.85003E-06	0.00505077 4.85003E-06	4.85003E-06	7 78654F-07	7 78654F-07	7 78654F-07	
		0.440198	2 18197E-07*	103078	0.000145709	0.000143001	0.000143001	0.000145001	0.000145001	4.850032-00	4.850032-00	4.850032-00	4.850032-00	0.550005	0.550005	0 550005	Argon
NO		0.000174026	1.63631E-10*	0	0.000217375	0.000217375	0.000217375	0.000217375	0.000217375	0.000217373	0.000217373	0.000217373	0.000217373	0.000217372	0.000217372	0.000217372	NO
NO2		0.000604358	2.16182E-06*	0	0.000752353	0.000752352	0.000752352	0.000752352	0.000752352	0.000728572	0.000728572	0.000728572	0.000728572	0.000721102	0.000721102	0.000721102	NO2
NH3		3.89094	0.285871*	2.34130	0.00610627	0.00610622	0.00610622	0.00610622	0.00610622	0.00430827	0.00430827	0.00430827	0.00430827	0.00380544	0.00380544	0.00380544	NH3
Process Streams		332	333	334	400	401	402	403	404	405	406	407	408	409	410	411	Process Streams
Property	Units																Units Property
Temperature	C	55.4506	6 46.4540*	60.9239	48.7028	48.7028	176.667*	129.444*	26*	25.8867	176.667*	129.444*	26*	25.9261	25.9261	176.667*	℃ Temperature
Pressure	bar	10.7412	4.13685*	4.72333	1.79306	1.79306	6.03542	5.75963	5.41489	5.34594	23.1072	22.8314	22.4867	22.4177	22.4177	93.5814	bar Pressure
Mole Fraction Vapor	%	0	0	0	99.9992	100	100	100	94.0627	100	100	100	99.5254	100	100	100	% Mole Fraction Vapor
Molecular Weight	kg/kmol	26.0778	18.0409	25.8152	42.3055	42.3057	42.3057	42.3057	42.3057	43.8339	43.8339	43.8339	43.8339	43.9559	44.0020	44.0020	kg/kmol Molecular Weight
Mass Density	kg/m^3	1151.50	989.229	1098.74	2.85804	2.85803	6.88490	7.37028	10.0901	9.71130	27.9165	31.3456	45.7888	45.5567	45.5938	123.167	kg/m^3 Mass Density
Molar Flow	kmol/h	78024.3	693.912	72222.7	2834.73	2834.70	2834.70	2834.70	2834.70	2666.60	2666.60	2666.60	2666.60	2653.93	2649.22	2649.22	kmol/h Molar Flow
Mass Flow	kg/h	2.03470E+06	12518.8*	1.86444E+06	119925	119924	119924	119924	119924	116887	116887	116887	116887	116656	116571	116571	kg/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	1.84843E+06	16439.1	1.71099E+06	67156.0	67155.4	67155.4	67155.4	67155.4	63172.9	63172.9	63172.9	63172.9	62872.8	62761.1	62761.1	m^3/h Std Vapor Volumetric Flow
Sta Liquid Volumetric Flow	m^3/h	2071.07	12.5349	1876.54	145.307	145.306	145.306	145.306	145.306	142.264	142.264	142.264	142.264	142.031	141.946	141.946	m ² 3/n Std Liquid Volumetric Flow
Specific Gravity	k 1/ka	1.15259	0.990164	1.09978	0045 45	1.46129	1.46129	1.46129	0400.00	1.51407	1.51407	1.51407	0070 47	1.51829	1.51988	1.51988	Specific Gravity
wass Enmalpy	кJ/Kg сР	-111/7.3	-15/56.7	-11048.5	-9045.15	-9045.13	-8924.56	-89/1.71	-9130.22	-8956.09	-8823.42	-88/1.35	-8978.47	-8965.13	-8961.80	-8844.43	
Thermal Conductivity	UF \\\/(m*%)	2.45591	0.57 0.53	0.4050		0.0101455 0.0107	0.0210019	0.0197044		0.0152834 0.0172	0.0220095	0.0201805		0.0109385	0.0159403	0.0242103 0.0242	W/(m*°C) Thermal Conductivity
Surface Tension	dvne/cm	0.3023	68 5273	57 5777		0.0107	0.0207	0.0251		0.0172	0.0290	0.0201		0.0109	0.0109	0.0342	dvne/cm Surface Tension
	,	52.0000	30.0210	00111			1	1	1					1			.,

Process Streams		412	413	414	415	416	417	501	502	503	504	505	506	509	510	511	512	513	514	Process Streams
		Cooled 3rd Stage Discharge	Cold 3rd Stage Discharge	CO2 Product	Inter-stage Liquid	Liquefied CO2	Dryer Water	SCW Supply to E-101	SCW Return From E-101	SCW Supply to E-104	SCW Return From E-104	SCW Supply to E-102	SCW Return From E-102	SCW Supply to E-111	SCW Return From E-111	LP Steam from E-112	LP Condensate from E-109	LP Steam from E-114	LP Steam to E-109	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		0.00729932	0.00729932	0.00729932	9.13336E-07	0.00729932	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Oxygen
Nitrogen		0.0230887	0.0230887	0.0230887	1.43405E-06	0.0230887	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Nitrogen
Water		0.0110001	0.0110001	0.0110001	99.7532	0.0110001	100	100*	100	100*	100	100*	100	100*	100	100	100	100	100	Water
Carbon Dioxide		99.9581	99.9581	99.9581	0.246745	99.9581	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Carbon Dioxide
Sulfur Dioxide		3.32393E-06	3.32393E-06	3.32393E-06	3.30335E-07	3.32393E-06	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Sulfur Dioxide
MEA		4.81178E-10	4.81178E-10	4.81178E-10	1.31203E-06	4.81178E-10	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	MEA
Argon		0.000519702	0.000519702	0.000519702	7.04711E-08	0.000519702	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Argon
NO		2.73449E-07	2.73449E-07	2.73449E-07	5.07785E-11	2.73449E-07	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	NO
NO2		5.91656E-07	5.91656E-07	5.91656E-07	3.75747E-07	5.91656E-07	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	NO2
NH3		8.43450E-06	8.43450E-06	8.43450E-06	7.43403E-05	8.43450E-06	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen		0.193375	0.193375	0.193375	1.65106E-06	0.193375	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Oxygen
Nitrogen		0.611669	0.611669	0.611669	2.59237E-06	0.611669	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Nitrogen
Water		0.291417	0.291417	0.291417	180.327	0.291417	4.71575	272589*	272589	272589*	272589	19431.1*	19431.1	250893*	250893	135.215	434.843	133.952	431.447	Water
Carbon Dioxide		2648.11	2648.11	2648.11	0.446049	2648.11	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Carbon Dioxide
Sulfur Dioxide		8.80582E-05	8.80582E-05	8.80582E-05	5.97156E-07	8.80582E-05	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Sulfur Dioxide
MEA		1.27475E-08	1.27475E-08	1.27475E-08	2.37180E-06	1.27475E-08	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	MEA
Argon		0.0137680	0.0137680	0.0137680	1.27393E-07	0.0137680	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Argon
NO		7.24426E-06	7.24426E-06	7.24426E-06	9.17938E-11	7.24426E-06	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	NO
NO2		1.56742E-05	1.56742E-05	1.56742E-05	6.79249E-07	1.56742E-05	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	NO2
NH3		0.000223448	0.000223448	0.000223448	0.000134387	0.000223448	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	NH3
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fraction
Oxygen		0.00530815	0.00530815	0.00530815	1.61651E-06	0.00530815	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Oxygen
Nitrogen		0.0146991	0.0146991	0.0146991	2.22200E-06	0.0146991	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Nitrogen
Water		0.00450366	0.00450366	0.00450366	99.3993	0.00450366	100	100*	100	100*	100	100*	100	100*	100	100	100	100	100	Water
Carbon Dioxide		99.9750	99.9750	99.9750	0.600635	99.9750	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Carbon Dioxide
Sulfur Dioxide		4.83941E-06	4.83941E-06	4.83941E-06	1.17053E-06	4.83941E-06	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Sulfur Dioxide
MEA		6.67966E-10	6.67966E-10	6.67966E-10	4.43284E-06	6.67966E-10	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	MEA
Argon		0.000471820	0.000471820	0.000471820	1.55712E-07	0.000471820	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Argon
NO		1.86472E-07	1.86472E-07	1.86472E-07	8.42762E-11	1.86472E-07	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	NO
NO2		6.18595E-07	6.18595E-07	6.18595E-07	9.56139E-07	6.18595E-07	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	NO2
NH3		3.26448E-06	3.26448E-06	3.26448E-06	7.00273E-05	3.26448E-06	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen		6.18776	6.18776	6.18776	5.28321E-05	6.18776	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Oxygen
Nitrogen		17.1349	17.1349	17.1349	7.26210E-05	17.1349	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	Nitrogen
Water		5.24996	5.24996	5.24996	3248.64	5.24996	84.9556	4.91078E+06*	4.91E+06	4.91078E+06*	4.91E+06	350057*	350057	4.51991E+06*	4.51991E+06	2435.93	7833.81	2413.17	7772.63	Water
Carbon Dioxide		116542	116542	116542	19.6304	116542	0	0*	0	0^	0	0*	0	0^	0	0	0	0	0	Carbon Dioxide
Sulfur Dioxide		0.00564134	0.00564134	0.00564134	3.82561E-05	0.00564134	0	0*	0	0^	0	0*	0	0^	0	0	0	0	0	Sulfur Dioxide
MEA		7.78654E-07	7.78654E-07	7.78654E-07	0.000144877	7.78654E-07	0	0**	0	0*	0	0*	0	0"	0	0	0	0	0	MEA
		0.000017272	0.000217272	0.000217272	2.06909E-06	0.000217272	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	NO
		0.000217372	0.000217372	0.000217372	2.75457E-09	0.000217372	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	NO2
NU2 NH3		0.000721102	0.000721102	0.000721102	0.00228868	0.000721102	0	0*	0	0*	0	0*	0	0*	0	0	0	0	0	NH3
Process Streams		<b>412</b>	413	<b>Δ1Δ</b>	415	<b>416</b>	<u>417</u>	501	502	503	504	505	506	509	510	511	512	513	514	Process Streams
Property	Unite	714	410	717	410	-10	711		UL	000	707	000		000			012	010		
Tomporoturo	S	120 444*	20*	49 2010	25 9967	27.0990	25 0261	11*	21	11*	21	11*	21*	11*	01*	125.925	125 925	105 925	105 005	
Prossuro	bar	129.444	20	40.2019	23.0007	27.9009	20.9201	1 0000*	0.065696	1 0000*	0.065696	1 0000*	1 21042	1 0000*	0.065696	125.035	120.000	125.635	2 27012	bor Broccuro
Mole Fraction Vapor	%	30.0000	JZ.5009	201.000	0.04094	JZ.0919	۲ <u>۰</u> +۱۱/ ۱	1.9999	0.303080	1.5559	0.300000	1.5555	1.31042	1.9999	0.00000	2.57913	2.31913	2.37913	2.57913	% Mole Fraction Vanor
Molecular Weight	ka/kmol	44 0020	44 0020	44 0020	18 0704	44 0020	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	18 0153	ka/kmol Molecular Weight
Mass Density	kg/m^3	148 588	722 6422	778 5//	997 558	722 534	996 481	1000 00	997 597	1000.00	997 507	10.0100	997 602	1000 00	997 507	1 31446	038 857	1 31446	1 31446	kg/m/3 Mass Density
Molar Flow	kmol/h	2649 22	2649.22	2649.22	180 773	2649 22	4 71575	272580	272589	272580	272589	19431 1	19431 1	250893	250893	135 215	434 843	133 952	431 447	kmol/h Molar Flow
Mass Flow	ka/h	116571	116571	116571	3268 27	116571	84,9556	4.91F+06	4.91F+06	4.91F+06	4.91F+06	350057	350057	4.51991F+06	4.51991F+06	2435.93	7833 81	2413 17	7772 63	kg/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	62761 1	62761 1	62761 1	4282.59	62761 1	111.718	6.46E+06	6,46E+06	6.46E+06	6.46E+06	460331	460331	5.94377E+06	5.94377E+06	3203.30	10301 6	3173.37	10221.2	m^3/h Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	141.946	141.946	141.946	3.27574	141.946	0.0850392	4915.61	4915.61	4915.61	4915.61	350.401	350.401	4524.35	4524.35	2,43833	7.84152	2.41555	7.78028	m^3/h Std Liquid Volumetric Flow
Specific Gravity		1.51988	0.723326?	1.51988	0.998501	0.723217?	0.997422	1.00095	0.998540	1.00095	0.998540	1.00095	0.998544	1.00095	0.998540	0.622268	0.939745	0.622268	0.622268	Specific Gravity
Mass Enthalpy	kJ/ka	-8902.65	-9167.65	-9147.70	-15823.4	-9167.65	-15861.2	-15921.7	-15881.2	-15921.7	-15881.2	-15921.7	-15881.2	-15921.7	-15881.2	-13240.4	-15448.2	-13240.4	-13240.4	kJ/kg Mass Enthalov
Dynamic Viscosity	cP	0.0230637	0.0609552	0.0692290	0.865916	0.0609691	0.879295	1.29092	0.987115	1.29092	0.987115	1.29092	0.987185	1.29092	0.987115	0.0106144	0.219521	0.0106144	0.0106144	cP Dynamic Viscositv
Thermal Conductivity	W/(m*℃)	0.0319	0.1073	0.0909	0.6021	0.1073	0.6076	0.5854	0.6006	0.5854	0.6006	0.5854	0.6006	0.5854	0.6006	0.0270	0.6847	0.0270	0.0270	W/(m*℃) Thermal Conductivity
Surface Tension	dyne/cm		0.0000		72.3392	0.0000	72.6316	75.6475	73.6192	75.6475	73.6192	75.6475	73.6192	75.6475	73.6192		53.1489			dyne/cm Surface Tension
	1.,		0.0000			2.0000			. 5.0.52	. 5.0.110			. 3101.92		. 2.0.JL		5611.60			

Process Streams		515	516	517	518	519	520	521	522	523	524	525	526	527	Process	Streams
		SCW Supply to F-113	SCW Return From E-113	SCW Supply	SCW Return From E-115	Condenstate	Condenstate to F-114	Condenstate to F-116	SCW Supply to F-117	SCW Return From E-117	LP Steam from E-116	LP Steam to E-110	LP Condensate from E-110	Vent Steam		
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fract	ion
Oxvaen		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxvgen	
Nitrogen		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen	
Water		100*	100	100*	100	100*	100*	100*	100*	100	100	100*	100	100	Water	
Carbon Dioxide		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Carbon Dio	oxide
Sulfur Dioxide		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Diox	ide
MEA		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	MEA	
Argon		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon	
NO		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO	
NO2		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO2	
NH3		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3	
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow	V
Oxygen		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxygen	
Nitrogen		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen	
Water		25674.5*	25674.5	16911.8*	16911.8	135.215*	133.952*	162.281*	41724.4*	41724.4	162.281	10213.6*	10213.6	283.831	Water	
Carbon Dioxide		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Carbon Dio	oxide
Sulfur Dioxide		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Diox	ide
MEA		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	MEA	
Argon		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon	
NO		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO	
NO2		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO2	
NH3		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3	
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Frac	tion
Oxygen		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxygen	
Nitrogen		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen	
Water		100*	100	100*	100	100*	100*	100*	100*	100	100	100*	100	100	Water	
Carbon Dioxide		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Carbon Dio	oxide
Sulfur Dioxide		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Diox	ide
MEA		0*	0	0*	0	0*	0*	0^	0^	0	0	0^	0	0	MEA	
Argon		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon	
		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0		
NU2 NH3		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3	
Mass Flow		ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	ka/h	Mass Flow	1
		.t <b>g</b> /.t						1.g/n			<b></b>	1.g/11 		Ng/II		
Nitrogen		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen	
Water		462534*	462534	304670*	304670	2435 93*	2413 17*	2923 53*	751677*	751677	2923 53	184000*	184000	5113 30	Water	
Carbon Dioxide		0*	.02001	0*	00.070	0*	0*	0*	0*	0	0	0*	0	0110100	Carbon Dio	xide
Sulfur Dioxide		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Diox	ide
MEA		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	MEA	
Argon		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon	
NO		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO	
NO2		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO2	
NH3		0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3	
Process Streams		515	516	517	518	519	520	521	522	523	524	525	526	527	Process	Streams
Property	Units														Units	Property
Temperature	C	16*	26*	16*	26*	98.8889*	98.8889*	98.8889*	16*	26*	125.835	135*	133.594	146.435	C	Temperature
Pressure	bar	1.9999*	1.31042	1.9999*	1.31042	2.37913*	2.37913*	2.37913*	1.9999*	1.31042	2.37913	2.9999*	2.9999	2.3499*	bar	Pressure
Mole Fraction Vapor	%	0	0	0	0	0	0	0	0	0	100	100	0*	100	%	Mole Fraction Vapor
Molecular Weight	kg/kmol	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	kg/kmol	Molecular Weight
Mass Density	kg/m^3	998.879	996.185	998.879	996.185	959.505	959.505	959.505	998.879	996.185	1.31446	1.62556	932.265	1.23159	kg/m^3	Mass Density
Molar Flow	kmol/h	25674.5	25674.5	16911.8	16911.8	135.215	133.952	162.281	41724.4	41724.4	162.281	10213.6	10213.6	283.831	kmol/h	Molar Flow
Mass Flow	kg/h	462534	462534	304670	304670	2435.93	2413.17	2923.53	751677	751677	2923.53	184000*	184000	5113.30	kg/h	Mass Flow
Std Vapor Volumetric Flow	m^3/h	608241	608241	400647	400647	3203.30	3173.37	3844.50	988470	988470	3844.50	241964	241964	6724.09	m^3/h	Std Vapor Volumetric F
Std Liquid Volumetric Flow	m^3/h	462.989	462.989	304.970	304.970	2.43833	2.41555	2.92641	752.417	752.417	2.92641	184.181	184.181	5.11833	m^3/h	Std Liquid Volumetric F
Specific Gravity		0.999823	0.997127	0.999823	0.997127	0.960412	0.960412	0.960412	0.999823	0.997127	0.622268	0.622268	0.933146	0.622268		Specific Gravity
Mass Enthalpy	kJ/kg	-15904.0	-15862.9	-15904.0	-15862.9	-15561.8	-15561.8	-15561.8	-15904.0	-15862.9	-13240.4	-13224.7	-15390.4	-13200.2	kJ/kg	Mass Enthalpy
Dynamic Viscosity	cP	1.12405	0.874153	1.12405	0.874153	0.279294	0.279294	0.279294	1.12405	0.874153	0.0106144	0.0110023	0.206890	0.0114855	cP	Dynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.5931	0.6077	0.5931	0.6077	0.6758	0.6758	0.6758	0.5931	0.6077	0.0270	0.0278	0.6856	0.0287	W/(m*℃)	Thermal Conducti vity
Surface Tension	dyne/cm	74.6291	72.6168	74.6291	72.6168	58.4280	58.4280	58.4280	74.6291	72.6168			51.6045		dyne/cm	Surface Tension



Process Streams		001	002	003	004	005	006	007	008	009	010	100	101	102	103	Process Streams
		Flue Gas From	Flue Gas From	Process Water to	Process Water to	Process Water to	Abs 1. Flue Gas	Process Water to	Process Water to	Abs 2. Flue Gas	Softened	Cooled Flue	Warm Wash	Excess Water to	Off Gas to Atmosphere	
Mala Francisco		CCPP	Common Fogger	Foggers	Common Fogger	Abs. 1 Fogger	Blower Discharge	Absorbers	Abs. 2 Fogger	Blower Discharge	Water	Gas to Abs. 1	Water (Abs. 1)	Absorbers	(Abs. 1)	Mala Frankan
		%	%	%	%	%	%	%	<u>%</u>	%	%	%	%	%	<u>%</u>	
Oxygen Nitrogen		12.9413*	12.4873	9.84458E-09 8.72213E-09	9.84458E-09 8.72213E-09	9.84458E-09 8.72213E-09	12.4873	9.84458E-09" 8.72213E-09*	9.84458E-09 8.72213E-09	12.4873	0	12.4292	0.000217153	0.000217153	13.2825	Oxygen Nitrogen
Water		7 13372*	10 3888	0.722132-09	0.72213E-09	0.72213E-09	10 3888	0.72213E-09	0.72213E-09	10 3888	100	10.8056	0.000077240	0.000077240	8 03125	Water
Carbon Dioxide		3.82869*	3 69632	0 0555783	0.0555783	0.0555783	3 69632	0.0555783*	0.0555783	3 69632	100	3 67937	0 147967	0 147967	0.582518	
Sulfur Dioxide		1.00303E-05*	9.68112E-06	7 69346E-08	7 69346E-08	7 69346E-08	9.68112E-06	7 69346E-08*	7 69346E-08	9.68112E-06	0	9.63641E-06	1 11689E-07	1 11689E-07	1.01780E-05	Sulfur Dioxide
MFA		0*	0.000818982	0 0233448	0 0233448	0 0233448	0.000818982	0.0233448*	0 0233448	0.000818982	0	0.000923858	0 435097	0 435097	0.000258332	MFA
Argon		0.857888*	0.827791	7.76934E-10	7.76934E-10	7.76934E-10	0.827791	7.76934E-10*	7.76934E-10	0.827791	0	0.823937	1.52013E-05	1.52013E-05	0.880507	Argon
NO		0.000320748*	0.000309496	7.72946E-13	7.72946E-13	7.72946E-13	0.000309496	7.72946E-13*	7.72946E-13	0.000309496	0	0.000308055	7.95936E-09	7.95936E-09	0.000329203	NO
NO2		8.00800E-05*	7.72709E-05	6.95654E-09	6.95654E-09	6.95654E-09	7.72709E-05	6.95654E-09*	6.95654E-09	7.72709E-05	0	7.69112E-05	1.85653E-08	1.85653E-08	8.21721E-05	NO2
NH3		0.000400788*	0.000478064	0.00260352	0.00260352	0.00260352	0.000478064	0.00260352*	0.00260352	0.000478064	0	0.000487959	0.000236785	0.000236785	0.000411040	NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen		11838.8*	11838.8	3.71087E-07	3.27429E-07	2.18286E-08	5919.38	6.38097E-08*	2.18286E-08	5919.38	0	5919.38	0.178193	0.00970052	5919.27	Oxygen
Nitrogen		68827.6*	68827.6	3.28776E-07	2.90097E-07	1.93398E-08	34413.8	5.65343E-08*	1.93398E-08	34413.8	0	34413.8	0.555735	0.0302532	34413.4	Nitrogen
Water		6525.94*	9849.22	3766.38	3323.28	221.552	4924.61	647.643*	221.552	4924.61	323.492	5146.16	81579.5	4441.04	3579.07	Water
Carbon Dioxide		3502.49*	3504.34	2.09500	1.84853	0.123235	1752.17	0.360242*	0.123235	1752.17	0	1752.29	121.420	6.60991	259.595	Carbon Dioxide
Sulfur Dioxide		0.00917575*	0.00917831	2.90001E-06	2.55883E-06	1.70589E-07	0.00458916	4.98668E-07*	1.70589E-07	0.00458916	0	0.00458933	9.16507E-05	4.98930E-06	0.00453575	Sulfur Dioxide
MEA		0*	0.776446	0.879972	0.776446	0.0517631	0.388223	0.151314*	0.0517631	0.388223	0	0.439986	357.036	19.4364	0.115124	MEA
Argon		784.798*	784.798	2.92862E-08	2.58407E-08	1.72272E-09	392.399	5.03586E-09*	1.72272E-09	392.399	0	392.399	0.0124741	0.000679065	392.391	Argon
		0.293422*	0.293422	2.91358E-11	2.5/081E-11	1./1387E-12	0.146711	5.01001E-12*	1./1387E-12	0.146711	0	0.146711	0.53136E-06	3.55555E-07	0.146707	
NUZ		0.0732575	0.0732577	2.02223E-07	2.313/3E-07	0.00577294	0.0366288	4.00902E-08°	1.04249E-08	0.0306288	0	0.0366289	1.52345E-05	0.29339E-07	0.0366194	
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	0.194303 %	%	%	Mass Fraction
Oxvgen		14 5144*	14 1882	1 74622E-08	1 74622E-08	1 74622F-08	14 1882	1 74622E-08*	1 74622E-08	14 1882	0	14 1459	0.000380930	0.000380930	15 2131	Oxygen
Nitrogen		73.8733*	72.2133	1.35443E-08	1.35443E-08	1.35443E-08	72.2133	1.35443E-08*	1.35443E-08	72.2133	0	71,9975	0.00104005	0.00104005	77.4302	Nitrogen
Water		4.50447*	6.64556	99.7829	99.7829	99.7829	6.64556	99.7829*	99.7829	6.64556	100	6.92379	98.1844	98.1844	5.17878	Water
Carbon Dioxide		5.90586*	5.77619	0.135588	0.135588	0.135588	5.77619	0.135588*	0.135588	5.77619	0	5.75934	0.356992	0.356992	0.917611	Carbon Dioxide
Sulfur Dioxide		2.25224E-05*	2.20224E-05	2.73214E-07	2.73214E-07	2.73214E-07	2.20224E-05	2.73214E-07*	2.73214E-07	2.20224E-05	0	2.19574E-05	3.92255E-07	3.92255E-07	2.33388E-05	Sulfur Dioxide
MEA		0*	0.00177632	0.0790462	0.0790462	0.0790462	0.00177632	0.0790462*	0.0790462	0.00177632	0	0.00200715	1.45698	1.45698	0.000564810	MEA
Argon		1.20119*	1.17420	1.72048E-09	1.72048E-09	1.72048E-09	1.17420	1.72048E-09*	1.72048E-09	1.17420	0	1.17069	3.32907E-05	3.32907E-05	1.25901	Argon
NO		0.000337335*	0.000329754	1.28567E-12	1.28567E-12	1.28567E-12	0.000329754	1.28567E-12*	1.28567E-12	0.000329754	0	0.000328769	1.30928E-08	1.30928E-08	0.000353570	NO
NO2		0.000129128*	0.000126227	1.77408E-08	1.77408E-08	1.77408E-08	0.000126227	1.77408E-08*	1.77408E-08	0.000126227	0	0.000125850	4.68229E-08	4.68229E-08	0.000135312	NO2
NH3		0.000239237*	0.000289094	0.00245786	0.00245786	0.00245786	0.000289094	0.00245786*	0.00245786	0.000289094	0	0.000295573	0.000221069	0.000221069	0.000250562	NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen		378826*	378826	1.18743E-05	1.04773E-05	6.98490E-07	189413	2.04183E-06*	6.98490E-07	189413	0	189413	5.70197	0.310405	189409	Oxygen
Nitrogen		1.92809E+06*	1.92809E+06	9.21014E-06	8.12660E-06	5.41773E-07	964047	1.58372E-06*	5.41773E-07	964047	0	964047	15.5680	0.847496	964037	Nitrogen
Water		117567*	177436	67852.4	59869.7	3991.32	88718.2	11667.5*	3991.32	88718.2	5827.80	92709.5	1.46968E+06	80006.6	64477.9	Water
Carbon Dioxide		154143^	154224	92.1997	81.3527	5.42351	77112.2	15.8541^	5.42351	77112.2	0	//11/.6	5343.65	290.899	11424.6	Carbon Dioxide
		0.587834	0.587997	0.000185786	0.000163929	1.09280E-05	0.293999	3.19405E-05	1.09280E-05	0.293999	0	0.294010	0.00587149	0.000319633	0.290577	
Argon		0° 21251.1*	47.4277	1 160025 06	47.4277	3.10180	23.7139	9.24275	3.10185 6.99101E.09	23.7139	0	20.8757	21808.8	0.0271272	1.03211	Argon
		8 80444*	8 80444	8 74253E-10	7 71399E-10	5.14266E-11	4 40222	1 50331E-10*	5 14266E-11	4 40222	0	4 40222	0.490313	1.06688E-05	4 40210	NO
NO2		3 37025*	3 37026	1 20637E-05	1.06445E-05	7 09630E-07	1 68513	2 07440E-06*	7.09630E-07	1 68513	0	1 68513	0.000700871	3 81541E-05	1 68469	NO2
NH3		6.24410*	7.71882	1.67135	1.47472	0.0983145	3.85941	0.287394*	0.0983145	3.85941	0	3.95772	3.30909	0.180141	3.11960	NH3
Process Streams		001	002	003	004	005	006	007	008	009	010	100	101	102	103	Process Streams
Property	Units															Units Property
Temperature	C	100*	48.1126	47.8879	47.8879	47.8878	60.688 4	45.7207*	47.8878	60.6884	20.0000	54.0026	52.4538	52.4538	41.8036	°C Temperature
Pressure	bar	1.0017*	1.0017	138*	138	138	1.08857	4.13685*	138	1.08857	4.13685	1.08857	4.48079	4.48079	1.01273	bar Pressure
Mole Fraction Vapor	%	100	100	0	0	0	100	0	0	100	0	100	0	0	100	% Mole Fraction Vapor
Molecular Weight	kg/kmol	28.5307	28.1627	18.0398	18.0398	18.0398	28.1627	18.0398	18.0398	28.1627	18.0153	28.1156	18.2412	18.2412	27.9381	kg/kmol Molecular Weight
Mass Density	kg/m^3	0.921229	1.05681	990.501	990.501	990.501	1.10509	989.520	990.501	1.10509	997.903	1.12590	987.882	987.882	1.08100	kg/m^3 Mass Density
Molar Flow	kmol/h	91480.3	94806.3	3769.45	3325.99	221.732	47403.1	648.171	221.732	47403.1	323.492	47624.9	82058.9	4467.14	44564.2	kmol/h Molar Flow
Mass Flow	kg/h	2.61000E+06*	2.67000E+06	68000	60000	4000	1.33500E+06	11692.8*	4000	1.33500E+06	5827.80	1.33900E+06	1.49685E+06	81486.1	1.24504E+06	kg/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	2.16721E+06	2.24600E+06	89300.0	78794.1	5252.94	1.12300E+06	15355.5	5252.94	1.12300E+06	7663.67	1.12825E+06	1.94401E+06	105828	1.05575E+06	m^3/h Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	3051.86	3111.93	68.0868	60.0766	4.00511	1555.97	11.7078	4.00511	1555.97	5.83353	1559.97	1499.04	81.6050	1451.68	m^3/h Std Liquid Volumetric Flow
Specific Gravity	1.14.	0.985483	0.972771	0.991437	0.991437	0.991437	0.972771	0.990455	0.991437	0.972771	0.998846	0.971143	0.988816	0.988816	0.965014	Specific Gravity
wass Enthalpy	кJ/kg	-1054.38	-1384.39	-15739.9	-15739.9	-15739.9	-1370.99	-15760.7	-15739.9	-1370.99	-15885.0	-1413.92	-15562.9	-15562.9	-759.786	KJ/Kg Mass Enthalpy
Dynamic Viscosity		0.0209350	0.0186643	0.571407	0.571407	0.571408	0.0192060	0.579363	0.571408	0.0192060	1.01302	0.0189053	0.528406	0.528406	0.0185848	CP Dynamic Viscosity
Surface Tension	dvne/cm	0.0300	0.0266	0.6334	0.6334	0.6334	0.0274	0.6309	0.6334	0.0274	0.5991 73 9305	0.0270	0.6282	0.6282	0.0265	
Ourrace relision	uyne/cm			08.2493	08.2493	08.2493		00.0724	00.2493		13.0205		07.1227	01.1221		ayne/cm Sunace rension

Process Streams		104	105	106	107	108	109	110	111	200	201	202	203	204	Process S	Streams
		Lean Amine	Cooled Semi-Lean	Rich Amine	Process Water to	Cooled Wash Water to	Cooled Wash	Cooled Wash Water to	Combined Wash Water to	Cooled Flue	Warm Wash	Excess Water to	Off Gas to Atmosphere	Lean Amine		
		(Abs. 1)	Amine (Abs. 1)	(Abs. 1)	Upper Bed (Abs. 1)	Lower Bed (Abs. 1)	Water (Abs. 1)	Upper Bed (Abs. 1)	Upper Bed (Abs. 1)	Gas to Abs. 1	Water (Abs. 2)	Absorbers	(Abs. 2)	(Abs. 2)		
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fractio	on
Oxygen		2.14412E-05	4.10422E-07	0.000205017	9.84458E-09	0.000217153	0.000217153	0.000217153	0.000173724	12.4292	0.000217153	0.000217153	13.2825	2.14412E-05	Oxygen	
Nitrogen		6.68690E-05	8.68573E-07	0.000641035	8.72213E-09	0.000677240	0.000677240	0.000677240	0.000541794	72.2601	0.000677240	0.000677240	77.2221	6.68690E-05	Nitrogen	
Water		82.3389	78.9823	78.6517	99.9185	99.4158	99.4158	99.4158	99.5163	10.8056	99.4158	99.4158	8.03125	82.3389	Water	
Carbon Dioxide		3.30309	6.04871	6.61467	0.0555783	0.147967	0.147967	0.147967	0.129490	3.67937	0.147967	0.147967	0.582518	3.30309	Carbon Dioxi	de
Sulfur Dioxide		1.10598E-08	3.02511E-08	1.03913E-07	7.69346E-08	1.11689E-07	1.11689E-07	1.11689E-07	1.04738E-07	9.63641E-06	1.11689E-07	1.11689E-07	1.01780E-05	1.10598E-08	Sulfur Dioxid	е
MEA		14.3577	14.9687	14.7324	0.0233448	0.435097	0.435097	0.435097	0.352746	0.000923858	0.435097	0.435097	0.000258332	14.3577	MEA	
Argon		1.50094E-06	2.75399E-08	1.43324E-05	7.76934E-10	1.52013E-05	1.52013E-05	1.52013E-05	1.21612E-05	0.823937	1.52013E-05	1.52013E-05	0.880507	1.50094E-06	Argon	
NO		7.85888E-10	2.47223E-11	7.51700E-09	7.72946E-13	7.95936E-09	7.95936E-09	7.95936E-09	6.36764E-09	0.000308055	7.95936E-09	7.95936E-09	0.000329203	7.85888E-10	NO	
NO2		1.83598E-09	3.03958E-10	1.73621E-08	6.95654E-09	1.85653E-08	1.85653E-08	1.85653E-08	1.62436E-08	7.69112E-05	1.85653E-08	1.85653E-08	8.21721E-05	1.83598E-09	NO2	
NH3		0.000223103	0.000310837	0.000329574	0.00260352	0.000236785	0.000236785	0.000236785	0.000710132	0.000487959	0.000236785	0.000236785	0.000411040	0.000223103	NH3	
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow	
Oxygen		0.00970052	4.43877E-05	0.112659	2.95337E-08	0.175587	0.178193	0.00260583	0.00260586	5919.38	0.178193	0.00970052	5919.27	0.00970052	Oxygen	
Nitrogen		0.0302532	9.39373E-05	0.352255	2.61664E-08	0.547609	0.555735	0.00812688	0.00812690	34413.8	0.555735	0.0302532	34413.4	0.0302532	Nitrogen	
Water		37252.2	8542.04	43219.9	299.755	80386.5	81579.5	1192.99	1492.74	5146.16	81579.5	4441.04	3579.07	37252.2	Water	
Carbon Dioxide		1494.40	654.175	3634.83	0.166735	119.645	121.420	1.77561	1.94234	1752.29	121.420	6.60991	259.595	1494.40	Carbon Dioxi	de
Sultur Dioxide		5.00372E-06	3.27170E-06	5.71015E-05	2.30804E-07	9.03104E-05	9.16507E-05	1.34027E-06	1.57107E-06	0.00458933	9.16507E-05	4.98930E-06	0.00453575	5.00372E-06	Sulfur Dioxid	е
MEA		6495.77	1618.88	8095.60	0.0700345	351.814	357.036	5.22116	5.29120	0.439986	357.036	19.4364	0.115124	6495.77	MEA	
Argon		0.000679065	2.97848E-06	0.00787581	2.33080E-09	0.0122916	0.0124741	0.000182416	0.000182418	392.399	0.0124741	0.000679065	392.391	0.000679065	Argon	
		3.55555E-07	2.6/375E-09	4.13067E-06	2.31884E-12	6.43585E-06	6.53136E-06	9.55123E-08	9.55146E-08	0.146711	0.53136E-06	3.55555E-07	0.146707	3.55555E-07		
NU2		8.30642E-07	3.28734E-08	9.54065E-06	2.08696E-08	1.50117E-05	1.52345E-05	2.22784E-07	2.43654E-07	0.0366289	1.52345E-05	8.29339E-07	0.0366194	8.30642E-07	NU2	
NEI3 Mass Fraction		0.100937	0.0336174	0.181104	0.00781055	0.191462	0.194303	0.00284142	0.0106520	0.232390	0.194303	0.0105775	0.183177	0.100937	Mass Fractic	on
		78	78	/8	/0	/6	/6	/6	/6	/6	/8	/6	/6	/6		
Oxygen		2.73807E-05	5.04451E-07	0.000251548	1.74622E-08	0.000380930	0.000380930	0.000380930	0.000305422	14.1459	0.000380930	0.000380930	15.2131	2.73807E-05	Oxygen	
Nitrogen		7.47574E-05	9.34603E-07	0.000688565	1.35443E-08	0.00104005	0.00104005	0.00104005	0.000833885	/1.99/5	0.00104005	0.00104005	77.4302	7.47574E-05	Nitrogen	
Water Corbon Diovido		59.1984	54.0545	54.3308	99.7829	98.1844	98.1844	98.1844	98.5012	6.92379 5.75024	98.1844	98.1844	5.17878	59.1984	Water Corbon Diovi	do
Carbon Dioxide		2 927625 09	7 444055 09	2 552505 07	0.10000	2 022555 07	0.356992	2 022555 07	0.313103	3.75934 2.10574E.05	0.300992	2 022555 07	0.917011	2 927625 09	Carbon Dioxi	a
		2.02/03E-00	7.44403E-00 25.1202	2.55259E-07	2.73214E-07	3.92200E-07	3.92200E-07	3.92235E-07	3.00030E-07	2.19574E-05	3.92255E-07	3.92255E-07	2.33300E-03	2.02703E-00		e
Argon		2 30280E-06	4 22583E-08	2 10530E-05	1 720/8E-09	3 32907E-05	3 32007E-05	3 32907E-05	2 66010E-05	1 17069	3 32007E-05	3 32007E-05	1 25001	2 30280E-06	Argon	
NO		9.41095E-10	4.22303E-00 2.84940E-11	2.19559E-05 8.64871E-09	1.72040E-03	1 30928E-08	1 30928E-08	1 30928E-08	1.04977E-08	0.000328769	1 30928E-08	1 30928E-08	0.000353570	9.41095E-10		
NO2		3.37086E-09	5 37128E-10	3.06273E-08	1.20007E 12	4 68229E-08	4 68229E-08	4 68229E-08	4 10580E-08	0.000125850	4 68229E-08	4 68229E-08	0.000135312	3 37086E-09	NO2	
NH3		0.000151634	0.000203337	0.000215217	0.00245786	0.000221069	0.000221069	0.000221069	0.000664467	0.000295573	0.000221069	0.000221069	0.000250562	0.000151634	NH3	
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow	
Oxvaen		0.310405	0 00142035	3 60495	9 45044F-07	5 61859	5 70197	0.0833836	0 0833845	189413	5 70197	0 310405	189409	0.310405	Oxvaen	
Nitrogen		0.847496	0.00263150	9 86787	7.33009E-07	15 3404	15 5680	0 227661	0 227662	964047	15 5680	0.847496	964037	0.847496	Nitrogen	
Water		671109	153887	778619	5400.18	1.44819E+06	1.46968E+06	21492.0	26892.2	92709.5	1.46968E+06	80006.6	64477.9	671109	Water	
Carbon Dioxide		65767.8	28789.9	159967	7.33791	5265.51	5343.65	78.1437	85.4816	77117.6	5343.65	290.899	11424.6	65767.8	Carbon Dioxi	de
Sulfur Dioxide		0.000320557	0.000209597	0.00365814	1.47862E-05	0.00578563	0.00587149	8.58626E-05	0.000100649	0.294010	0.00587149	0.000319633	0.290577	0.000320557	Sulfur Dioxid	e
MEA		396781	98886.1	494504	4.27792	21489.9	21808.8	318.925	323.203	26.8757	21808.8	1187.23	7.03211	396781	MEA	
Argon		0.0271273	0.000118984	0.314623	9.31109E-08	0.491026	0.498313	0.00728716	0.00728725	15675.6	0.498313	0.0271273	15675.2	0.0271273	Argon	
NO		1.06688E-05	8.02287E-08	0.000123945	6.95793E-11	0.000193115	0.000195981	2.86595E-06	2.86602E-06	4.40222	0.000195981	1.06688E-05	4.40210	1.06688E-05	NO	
NO2		3.82141E-05	1.51236E-06	0.000438922	9.60117E-07	0.000690622	0.000700871	1.02493E-05	1.12094E-05	1.68513	0.000700871	3.81541E-05	1.68469	3.82141E-05	NO2	
NH3		1.71902	0.572522	3.08430	0.133018	3.26070	3.30909	0.0483909	0.181409	3.95772	3.30909	0.180141	3.11960	1.71902	NH3	
Process Streams		104	105	106	107	108	109	110	111	200	201	202	203	204	Р	rocess Streams
Property	Units														Units P	roperty
Temperature	C	53.9381	58.9133	53.3596	45.7208	20.0000	20.0000	20.0000	25.2480	54.0026	52.4538	52.4538	41.8036	53.9381	°C Te	emperatu re
Pressure	bar	3.68912	5.15772	1.08857	4.13685	3.44658	3.44658	3.44658	3.44658	1.08857	4.48079	4.48079	1.01273	3.68912	bar Pi	ressure
Mole Fraction Vapor	%	0	0	0	0	0	0	0	0	100	0	0	100	0	% M	lole Fraction Vapor
Molecular Weight	kg/kmol	25.0574	26.0343	26.0797	18.0398	18.2412	18.2412	18.2412	18.2009	28.1156	18.2412	18.2412	27.9381	25.0574	kg/kmol M	lolecular Weight
Mass Density	kg/m^3	1088.79	1142.94	1152.37	989.520	999.738	999.738	999.738	997.930	1.12590	987.882	987.882	1.08100	1088.79	kg/m^3 M	lass Density
Molar Flow	kmol/h	45242.5	10815.1	54951.0	300	80858.9	82058.9	1200	1500	47624.9	82058.9	4467.14	44564.2	45242.5	kmol/h M	lolar Flow
Mass Flow	kg/h	1.13366E+06	281564	1.43311E+06	5411.93	1.47497E+06	1.49685E+06	21889.5	27301.4	1.33900E+06	1.49685E+06	81486.1	1.24504E+06	1.13366E+06	kg/h M	lass Flow
Std Vapor Volumetric Flow	m^3/h	1.07182E+06	256215	1.30181E+06	7107.13	1.91558E+06	1.94401E+06	28428.5	35535.7	1.12825E+06	1.94401E+06	105828	1.05575E+06	1.07182E+06	m^3/h St	td Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	1140.82	286.034	1458.96	5.41884	1477.12	1499.04	21.9214	27.3403	1559.97	1499.04	81.6050	1451.68	1140.82	m^3/h St	td Liquid Volumetric Flow
Specific Gravity		1.08982	1.14402	1.15346	0.990455	1.00068	1.00068	1.00068	0.998873	0.971143	0.988816	0.988816	0.965014	1.08982	S	pecific Gravity
Mass Enthalpy	kJ/kg	-11403.5	-11146.1	-11187.2	-15760.7	-15697.0	-15697.0	-15697.0	-15709.7	-1413.92	-15562.9	-15562.9	-759.786	-11403.5	kJ/kg M	lass Enthalpy
Dynamic Viscosity	сР	1.77319	2.17583	2.60238	0.579362	1.04740	1.04740	1.04740	0.913216	0.0189053	0.528406	0.528406	0.0185848	1.77319	cP D	ynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.4168	0.3873	0.3812	0.6309	0.5885	0.5885	0.5885	0.5976	0.0270	0.6282	0.6282	0.0265	0.4168	W/(m*℃) Th	nermal Conducti vity
Surface Tension	dyne/cm	59.3976	92.8648	95.6192	68.6724	73.3892	73.3892	73.3892	72.4546		67.1227	67.1227		59.3976	dyne/cm S	urface Tension

Document No.: Bechtel: 25474-000-M4-CN-00001 Owner: 10112936-PB-P-HMB-0001

Process Streams		205	206	207	208	209	210	211	300	302	303	304	305	306	Process	Streams
		Cooled Semi-Lean	Rich Amine	Process Water to	Cooled Wash Water to	Cooled Wash	Cooled Wash Water to	Combined Wash Water to	Combined Cold Rich		Stripper Bottoms to	Rich Amine		Filtered Lean		
Molo Fraction		Amine (Abs. 2)	(Abs. 2)	Upper Bed (Abs. 2)	Lower Bed (Abs. 2)	Water (Abs. 2)	Upper Bed (Abs. 2)	Upper Bed (Abs. 2)	Amine	Hot Rich Amine	E-108 Inlet	to E-103	Lean Amine	Amine	Molo Fron	lion
		% 4 10422E 07	% 0.000205017	% 0.84458E.00	% 0.000217152	% 0.000217152	% 0.000217152	% 0.000172724	% 0.000205017	% 0.000205017	%	% 0.000205017	70 2 14412E 05	% 2 14412E 05		lion
Nitrogen		4.10422E-07 8.68573E-07	0.000205017	9.04450E-09 8 72213E-09	0.000217153	0.000217153	0.000217155	0.000173724	0.000205017	0.000205017	0	0.000205017	2.14412E-05	2.14412E-05	Nitrogen	
Water		78 9823	78 6517	99 9185	99 4158	99 4158	99 4158	99 5163	78 6517	78 6517	80 4568	78 6517	82 3389	82 3389	Water	
Carbon Dioxide		6.04871	6.61467	0.0555783	0.147967	0.147967	0.147967	0.129490	6.61467	6.61467	3.65089	6.61467	3.30309	3.30309	Carbon Die	oxide
Sulfur Dioxide		3.02511E-08	1.03913E-07	7.69346E-08	1.11689E-07	1.11689E-07	1.11689E-07	1.04738E-07	1.03913E-07	1.03913E-07	0	1.03913E-07	1.10598E-08	1.10598E-08	Sulfur Diox	ide
MEA		14.9687	14.7324	0.0233448	0.435097	0.435097	0.435097	0.352746	14.7324	14.7324	15.8921	14.7324	14.3577	14.3577	MEA	
Argon		2.75399E-08	1.43324E-05	7.76934E-10	1.52013E-05	1.52013E-05	1.52013E-05	1.21612E-05	1.43324E-05	1.43324E-05	0	1.43324E-05	1.50094E-06	1.50094E-06	Argon	
NO		2.47223E-11	7.51700E-09	7.72946E-13	7.95936E-09	7.95936E-09	7.95936E-09	6.36764E-09	7.51700E-09	7.51700E-09	0	7.51700E-09	7.85888E-10	7.85888E-10	NO	
NO2		3.03958E-10	1.73621E-08	6.95654E-09	1.85653E-08	1.85653E-08	1.85653E-08	1.62436E-08	1.73621E-08	1.73621E-08	0	1.73621E-08	1.83598E-09	1.83598E-09	NO2	
NH3		0.000310837	0.000329574	0.00260352	0.000236785	0.000236785	0.000236785	0.000710132	0.000329574	0.000329574	0.000220537	0.000329574	0.000223103	0.000223103	NH3	
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow	V
Oxygen		4.43877E-05	0.112659	2.95337E-08	0.175587	0.178193	0.00260583	0.00260586	0.225318	0.180254	0	0.0450636	0.0155208	0.00388021	Oxygen	
Nitrogen		9.39373E-05	0.352255	2.61664E-08	0.547609	0.555735	0.00812688	0.00812690	0.704511	0.563608	0	0.140902	0.0484052	0.0121013	Nitrogen	
Water		8542.04	43219.9	299.755	80386.5	81579.5	1192.99	1492.74	86439.8	69151.9	65574.2	17288.0	59603.5	14900.9	Water	
Carbon Dioxide		654.175	3634.83	0.166735	119.645	121.420	1.77561	1.94234	7269.66	5815.73	2975.56	1453.93	2391.04	597.760	Carbon Die	ide
		3.27170E-00	5.71015E-05	2.30804E-07	9.03104E-05	9.10007E-00	1.34027E-00	1.57107E-00	0.000114203	9.13624E-05	12052 4	2.28400E-05	8.00595E-06	2.00149E-00		ide
Argon		2 97848E-06	0.00787581	2 33080F.00	0.0122016	0 0124741	0.22110 0.000182416	0.29120 0.000182/18	0.0157516	0.0126013	12902.4	0 00315033	0.00108650	0.000271626		
NO		2.57046E 00	4 13067E-06	2.330000E 03	6 43585E-06	6 53136E-06	9.55123E-08	9.55146E-08	8 26134F-06	6 60907E-06	0	1 65227E-06	5 68889E-07	1 42222F-07	NO	
NO2		3.28734E-08	9.54065E-06	2.08696E-08	1.50117E-05	1.52345E-05	2.22784E-07	2.43654E-07	1.90813E-05	1.52650E-05	0	3.81626E-06	1.32903E-06	3.32257E-07	NO2	
NH3		0.0336174	0.181104	0.00781055	0.191462	0.194303	0.00284142	0.0106520	0.362208	0.289766	0.179743	0.0724416	0.161500	0.0403750	NH3	
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Frac	tion
Oxygen		5.04451E-07	0.000251548	1.74622E-08	0.000380930	0.000380930	0.000380930	0.000305422	0.000251548	0.000251548	0	0.000251548	2.73807E-05	2.73807E-05	Oxygen	
Nitrogen		9.34603E-07	0.000688565	1.35443E-08	0.00104005	0.00104005	0.00104005	0.000833885	0.000688565	0.000688565	0	0.000688565	7.47574E-05	7.47574E-05	Nitrogen	
Water		54.6545	54.3308	99.7829	98.1844	98.1844	98.1844	98.5012	54.3308	54.3308	56.1615	54.3308	59.1984	59.1984	Water	
Carbon Dioxide		10.2250	11.1623	0.135588	0.356992	0.356992	0.356992	0.313103	11.1623	11.1623	6.22557	11.1623	5.80137	5.80137	Carbon Die	oxide
Sulfur Dioxide		7.44405E-08	2.55259E-07	2.73214E-07	3.92255E-07	3.92255E-07	3.92255E-07	3.68658E-07	2.55259E-07	2.55259E-07	0	2.55259E-07	2.82763E-08	2.82763E-08	Sulfur Diox	ide
MEA		35.1203	34.5057	0.0790462	1.45698	1.45698	1.45698	1.18383	34.5057	34.5057	37.6128	34.5057	35	35	MEA	
Argon		4.22583E-08	2.19539E-05	1.72048E-09	3.32907E-05	3.32907E-05	3.32907E-05	2.66919E-05	2.19539E-05	2.19539E-05	0	2.19539E-05	2.39289E-06	2.39289E-06	Argon	
		2.04940E-11 5 27129E 10	0.0407 IE-09	1.20007 E-12	1.30920E-00	1.309285-08	1.30920E-00	1.049772-00	0.04071E-09 2.06272E.09	0.0407 TE-09	0	0.0407 TE-09	9.41095E-10	9.41095E-10		
NH3		0.000203337	0.000215217	0.00245786	4.082292-08	4.08229E-08	4.00229E-08	4.103802-08	0.000215217	0.000215217	0 000145527	0.000213E-08	0.000151634	0.000151634	NH3	
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flov	I
Oxygen		0.00142035	3.60495	9.45044E-07	5.61859	5.70197	0.0833836	0.0833845	7.20991	5.76792	0	1.44198	0.496648	0.124162	Oxygen	
Nitrogen		0.00263150	9.86787	7.33009E-07	15.3404	15.5680	0.227661	0.227662	19.7357	15.7886	0	3.94715	1.35599	0.338998	Nitrogen	
Water		153887	778619	5400.18	1.44819E+06	1.46968E+06	21492.0	26892.2	1.55724E+06	1.24579E+06	1.18134E+06	311448	1.07377E+06	268444	Water	
Carbon Dioxide		28789.9	159967	7.33791	5265.51	5343.65	78.1437	85.4816	319934	255947	130953	63986.8	105229	26307.1	Carbon Die	oxide
Sulfur Dioxide		0.000209597	0.00365814	1.47862E-05	0.00578563	0.00587149	8.58626E-05	0.000100649	0.00731628	0.00585302	0	0.00146326	0.000512891	0.000128223	Sulfur Diox	ide
MEA		98886.1	494504	4.27792	21489.9	21808.8	318.925	323.203	989009	791207	791173	197802	634850	158713	MEA	
Argon		0.000118984	0.314623	9.31109E-08	0.491026	0.498313	0.00728716	0.00728725	0.629246	0.503397	0	0.125849	0.0434037	0.0108509	Argon	
NO		8.02287E-08	0.000123945	6.95793E-11	0.000193115	0.000195981	2.86595E-06	2.86602E-06	0.000247891	0.000198312	0	4.95781E-05	1.70701E-05	4.26753E-06	NO	
NO2		1.51236E-06	0.000438922	9.60117E-07	0.000690622	0.000700871	1.02493E-05	1.12094E-05	0.000877845	0.000702276	0	0.000175569	6.11426E-05	1.52856E-05	NO2	
NH3 Broocce Stroome		0.572522	3.08430	0.133018	3.26070	3.30909	0.0483909	0.181409	6.16859 <b>200</b>	4.93487	3.06111	1.23372	2.75043	0.687607	NH3	Brooses Strooms
Property	Units	205	200	201	200	209	210	211	500	302	303	304	303	300	Units	Property
Temperature	c	58,9133	53,3596	45.7208	20.0000	20.0000	20.0000	25.2480	53,5053	117*	126.353	53,5053	53,9381	53,9381	C	Temperature
Pressure	bar	5.15772	1.08857	4.13685	3.44658	3.44658	3.44658	3.44658	10.7412	9.70702	5.41280	10.7412	3.68912	3.68912	bar	Pressure
Mole Fraction Vapor	%	0	0	0	0	0	0	0	0	0	0	0	0	0	%	Mole Fraction Vapor
Molecular Weight	kg/kmol	26.0343	26.0797	18.0398	18.2412	18.2412	18.2412	18.2009	26.0797	26.0797	25.8087	26.0797	25.0574	25.0574	kg/kmol	Molecular Weight
Mass Density	kg/m^3	1142.94	1152.37	989.520	999.738	999.738	999.738	997.930	1152.44	1132.88	1068.43	1152.44	1088.79	1088.79	kg/m^3	Mass Density
Molar Flow	kmol/h	10815.1	54951.0	300	80858.9	82058.9	1200	1500	109902	87921.6	81502.4	21980.4	72388.0	18097.0	kmol/h	Molar Flow
Mass Flow	kg/h	281564	1.43311E+06	5411.93	1.47497E+06	1.49685E+06	21889.5	27301.4	2.86621E+06	2.29297E+06	2.10347E+06	573243	1.81386E+06	453465	kg/h	Mass Flow
Std Vapor Volumetric Flow	m^3/h	256215	1.30181E+06	7107.13	1.91558E+06	1.94401E+06	28428.5	35535.7	2.60363E+06	2.08290E+06	1.93083E+06	520725	1.71490E+06	428726	m^3/h	Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	286.034	1458.96	5.41884	1477.12	1499.04	21.9214	27.3403	2917.91	2334.33	2117.55	583.582	1825.31	456.328	m^3/h	Std Liquid Volumetric Flow
Specific Gravity		1.14402	1.15346	0.990455	1.00068	1.00068	1.00068	0.998873	1.15353	1.13395	1.06944	1.15353	1.08982	1.08982		Specific Gravity
Mass Enthalpy	kJ/kg	-11146.1	-11187.2	-15760.7	-15697.0	-15697.0	-15697.0	-15709.7	-11186.0	-10958.4	-10814.8	-11186.0	-11403.5	-11403.5	kJ/kg	Mass Enthalpy
Dynamic Viscosity		2.17583	2.60238	0.579362	1.04740	1.04740	1.04740	0.913216	2.59641	0.690755	0.520515	2.59641	1.77319	1.77319	CP	Dynamic Viscosity
Surface Tension	vv/(m^C)	0.3873	0.3812	0.6309	0.5885	0.5885	0.5885 2002 27	0.5976 72 1546	0.3813	U.3943 87 1820	0.4149	0.3813	0.4168	0.4168	vv/(m°C) dvpe/cm	Surface Tension
	uyne/um	92.0040	30.0192	00.0724	13.3092	10.0092	13.3092	12.4340	93.0095	07.1030	40.0040	33.0095	33.3370	59.5970	ayne/om	

Process Streams		307	309	310	311	312	313	314	315	316	317	318	319	320	322	323	324	Process	Streams
		Fresh	Rich Amine	Rich Amine	Rich Amine		Hot Semi-	Stripper	Stripper Bottoms to	Reclaimer		Stripper	Stripper Reboiler	Stripper	Stripper		Cooled Stripper		
		Amine	to E-107	to E-109	to V-101	Flash Gas	Lean Amine	Bottoms	E-107	Feed	Reclaimer Product	Reboiler Inlet	Discharge	Overhead	Reflux	Reflux Purge	Overhead		
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fracti	on
Oxygen		0	0.000205017	0.000205017	0.000205017	0.0128445	4.10422E-07	0	0	0	0	0	0	0.00299646	2.20237E-07	2.20237E-07	0.00299646	Oxygen	
Nitrogen		0	0.000641035	0.000641035	0.000641035	0.0401872	8.68573E-07	0	0	0	0	0	0	0.00937033	3.65715E-07	3.65715E-07	0.00937033	Nitrogen	
Water		0	78.6517	78.6517	78.6517	58.2303	78.9823	80.4568	80.4568	80.4568	95.6590	80.4568	80.4568	60.2430	99.8824	99.8824	60.2430	Water	
Carbon Dioxide		0	6.61467	6.61467	6.61467	41.5768	6.04871	3.65089	3.65089	3.65089	4.34072	3.65089	3.65089	39.7275	0.0881969	0.0881969	39.7275	Carbon Diox	tide
Sulfur Dioxide		0	1.03913E-07	1.03913E-07	1.03913E-07	4.65439E-06	3.02511E-08	0	0	0	0	0	0	1.43643E-06	7.17408E-08	7.17408E-08	1.43643E-06	Sulfur Dioxid	le
MEA		100	14.7324	14.7324	14.7324	0.137491	14.9687	15.8921	15.8921	15.8921	0	15.8921	15.8921	0.0152098	0.0264361	0.0264361	0.0152098	MEA	
Argon		0	1.43324E-05	1.43324E-05	1.43324E-05	0.000898013	2.75399E-08	0	0	0	0	0	0	0.000209481	1.63361E-08	1.63361E-08	0.000209481	Argon	
NO		0	7.51700E-09	7.51700E-09	7.51700E-09	4.70351E-07	2.47223E-11	0	0	0	0	0	0	1.09838E-07	1.19293E-11	1.19293E-11	1.09838E-07	NO	
NO2		0	1.73621E-08	1.73621E-08	1.73621E-08	1.07112E-06	3.03957E-10	0	0	0	0	0	0	2.52998E-07	2.62728E-10	2.62728E-10	2.52998E-07	NO2	
NH3 Meler Flow		U kmal/h	0.000329574	0.000329574	0.000329574	0.00148724	0.000310834	0.000220537	0.000220537	0.000220537	0.000262207	0.000220537	0.000220537	0.00170289	0.00294964	0.00294964	0.00170289	NH3 Moler Flow	
		KMOI/N	KMOI/N	KMOI/N	Kmol/n	KMOI/N	KMOI/N	Kmol/n	KMOI/N	KMOI/N	KMOI/N	KMOI/N	KMOI/N	KMOI/N	KMOI/N	KMOI/N	KMOI/N		
Oxygen		0	0.0450636	0.0450636	0.0450636	0.0449748	8.87752E-05	0	0	0	0	0	0	0.225230	9.52432E-07	8.57189E-06	0.225230	Oxygen	
Nitrogen		0	0.140902	0.140902	0.140902	0.140714	0.000187874	0	0	0	0	40740.0	0	0.704324	1.58156E-06	1.42341E-05	0.704324	Nitrogen	
Waler Carbon Dioxido		0	1/200.0	1/200.0	1/200.0	203.092	1209 25	2075 56	2075 56	0	0	437 10.2	437 10.2	4526.19	431.949	3007.34	4520.19	Carbon Diox	ido
Sulfur Dioxide		0	2 28406E-05	2 28406E-05	2 28406E-05	1 62072E-05	6 54339E-06	2373.30	2975.50	0	0	1903.71	1903.71	0.000107970	3 10248E-07	2 70223E-06	0.000107970	Sulfur Diovid	ide ide
		0 237686	3238.24	3238 24	3238 24	0.481421	0.04009E-00	12952 4	12952 4	0	0	8634.94	8634.94	1 14325	0 114325	1 02893	1 14325		10
Argon		0.207000	0.00315033	0.00315033	0.00315033	0.00314437	5 95695E-06	12332.4	12002.4	0	0	0004.04	0004.04	0.0157457	7.06467E-08	6.35820E-07	0.0157457	Argon	
NO		0	1.65227E-06	1.65227E-06	1.65227E-06	1.64692E-06	5.34749E-09	0	0	0	0	0	0	8.25604E-06	5.15892E-11	4.64303E-10	8.25604E-06	NO	
NO2		0	3.81626E-06	3.81626E-06	3.81626E-06	3.75051E-06	6.57467E-08	0	0	0	0	0	0	1.90167E-05	1.13619E-09	1.02257E-08	1.90167E-05	NO2	
NH3		0	0.0724416	0.0724416	0.0724416	0.00520751	0.0672341	0.179743	0.179743	0	0	0.119829	0.119829	0.127999	0.0127559	0.114803	0.127999	NH3	
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fract	on
Oxygen		0	0.000251548	0.000251548	0.000251548	0.0142277	5.04451E-07	0	0	0	0	0	0	0.00338212	3.90443E-07	3.90443E-07	0.00338212	Oxygen	
Nitrogen		0	0.000688565	0.000688565	0.000688565	0.0389704	9.34602E-07	0	0	0	0	0	0	0.00925906	5.67599E-07	5.67599E-07	0.00925906	Nitrogen	
Water		0	54.3308	54.3308	54.3308	36.3138	54.6545	56.1615	56.1615	56.1615	90.0208	56.1615	56.1615	38.2819	99.6927	99.6927	38.2819	Water	
Carbon Dioxide		0	11.1623	11.1623	11.1623	63.3401	10.2250	6.22557	6.22557	6.22557	9.97893	6.22557	6.22557	61.6713	0.215047	0.215047	61.6713	Carbon Diox	tide
Sulfur Dioxide		0	2.55259E-07	2.55259E-07	2.55259E-07	1.03218E-05	7.44403E-08	0	0	0	0	0	0	3.24596E-06	2.54631E-07	2.54631E-07	3.24596E-06	Sulfur Dioxid	le
MEA		100	34.5057	34.5057	34.5057	0.290721	35.1203	37.6128	37.6128	37.6128	0	37.6128	37.6128	0.0327712	0.0894648	0.0894648	0.0327712	MEA	
Argon		0	2.19539E-05	2.19539E-05	2.19539E-05	0.00124182	4.22583E-08	0	0	0	0	0	0	0.000295180	3.61557E-08	3.61557E-08	0.000295180	Argon	
NO		0	8.64871E-09	8.64871E-09	8.64871E-09	4.88555E-07	2.84939E-11	0	0	0	0	0	0	1.16255E-07	1.98316E-11	1.98316E-11	1.16255E-07	NO	
NO2		0	3.06273E-08	3.06273E-08	3.06273E-08	1.70581E-06	5.37127E-10	0	0	0	0	0	0	4.10557E-07	6.69652E-10	6.69652E-10	4.10557E-07	NO2	
NH3		0	0.000215217	0.000215217	0.000215217	0.000876778	0.000203334	0.000145527	0.000145527	0.000145527	0.000233264	0.000145527	0.000145527	0.00102297	0.00278311	0.00278311	0.00102297	NH3	
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow	
Oxygen		0	1.44198	1.44198	1.44198	1.43914	0.00284070	0	0	0	0	0	0	7.20710	3.04767E-05	0.000274290	7.20710	Oxygen	
Nitrogen		0	3.94715	3.94715	3.94715	3.94188	0.00526300	0	0	0	0	0	0	19.7305	4.43049E-05	0.000398744	19.7305	Nitrogen	
Water		0	311448	311448	311448	3673.17	307774	1.18134E+06	1.18134E+06	0	0	787559	787559	81576.6	7781.68	70035.1	81576.6	Water	
Carbon Dioxide		0	63986.8	63986.8	63986.8	6406.90	57579.9	130953	130953	0	0	87302.0	87302.0	131418	16.7858	151.073	131418	Carbon Diox	tide
Sulfur Dioxide		0	0.00146326	0.00146326	0.00146326	0.00104406	0.000419194	0	0	0	0	0	0	0.00691696	1.98757E-05	0.000178881	0.00691696	Sulfur Dioxic	le
MEA		14.5186	197802	197802	197802	29.4067	197772	791173	791173	0	0	527449	527449	69.8334	6.98333	62.8499	69.8334	MEA	
Argon		0	0.125849	0.125849	0.125849	0.125611	0.000237968	0	0	0	0	0	0	0.629011	2.82219E-06	2.53998E-05	0.629011	Argon	
NO		0	4.95781E-05	4.95781E-05	4.95781E-05	4.94177E-05	1.60457E-07	0	0	0	0	0	0	0.000247732	1.54799E-09	1.39319E-08	0.000247732	NO	
		0	0.000175569	0.000175569	0.000175569	0.000172544	3.0247 TE-06	2 06111	2.06111	0	0	2 04074	2 04074	0.000874872	5.22708E-08	4.70437E-07	0.000874872		
Process Streams		307	300	310	1.20072 311	312	1.14003 <b>313</b>	3.00111 <b>31</b> /	3.00111 315	316	317	2.04074 <b>31</b> 8	2.04074 <b>310</b>	320	322	322	2.17988 <b>32/</b>		Process Streams
Proporty	Unite	307	309	510	311	512	313	314	515	510	317	510	319	320	322	323	524	lunite E	Property
	S	20,0000	100*	440 770*	101 550	440 700	440 704	107 5 40	107.010			107.540	100 105	404.050	40 7400	40 7400	40.0000*	s r	
Pressure	bar	20.0000	9 70702	8 67281	7 63859	113.720	5 8/719	2 31016	6 10228	6 10228	6 10228	2 31016	2 31016	1 965/3	40.7409	40.7409 5 24044	40.0009	bar E	
Mole Fraction Vapor	%	4.15005	9.70702	0.07201	7.00009	2.39902	0.04719	2.31010	0.10220	0.10220	0.10220	2.51010	19 1855	1.90343	0.24044	0.24044	42 4389	% N	Alle Fraction Vanor
Molecular Weight	kg/kmol	61 0831	26 0797	26 0797	26 0797	28 8880	26 0343	25 8087	25 8087	25 8087	19 1436	25 8087	25 8087	28 3501	18 0496	18 0496	28,3501	ka/kmol	Aolecular Weight
Mass Density	kg/m^3	1021 42	1136 55	1134 62	1130 90	2 17932	1124 67	1067.66	1067.68	20.0007	10.1100	1067.66	9 34453	1 79065	988 420	988 420	4 58985	kg/m^3	lass Density
Molar Flow	kmol/h	0,237686	21980 4	21980 4	21980 4	350 147	21630.3	81502 4	81502.4	٥	n	54334 9	54334 9	7516 53	432 457	3892 12	7516 53	kmol/h	Iolar Flow
Mass Flow	kg/h	14.5186	573243	573243	573243	10115 1	563128	2.10347E+06	2.10347E+06	0	n	1.40231E+06	1.40231E+06	213094	7805.67	70251.0	213094	kg/h	lass Flow
Std Vapor Volumetric Flow	m^3/h	5.63090	520725	520725	520725	8295.14	512430	1.93083E+06	1.93083E+06	0	0	1.28722E+06	1.28722E+06	178070	10245.1	92206.0	178070	m^3/h 5	Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	0.0142325	583.582	583.582	583.582	11.5137	572.069	2117.55	2117.55	0	0	1411.70	1411.70	241.788	7.81698	70.3528	241.788	m^3/h 5	td Liquid Volumetric Flow
Specific Gravity		1.02239	1.13762	1.13570	1.13197	0.997826	1.12573	1.06867	1.06869			1.06867		0.979243	0.989354	0.989354		5	Specific Gravity
Mass Enthalpy	kJ/kg	-4445.34	-10992.7	-10974.7	-10940.8	-10439.9	-10949.4	-10810.4	-10809.9	-10809.9		-10810.4	-10495.4	-10556.0	-15741.5	-15741.5	-11498.2	kJ/kg N	lass Enthalpy
Dynamic Viscosity	cP	26.8174	0.796759	0.737383	0.645129	0.0170316	0.708349	0.511868	0.511850			0.511868		0.0165437	0.548086	0.548086		cP [	Oynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.2355	0.3940	0.3942	0.3943	0.0247	0.3981	0.4148	0.4148			0.4148		0.0240	0.6335	0.6335		W/(m*℃) T	hermal Conductivi ty
Surface Tension	dyne/cm	48.9361	88.3433	87.9905	87.0818		86.9301	46.4007	46.3822			46.4007			68.0582	68.0582		dyne/cm	Surface Tension

Document No.: Bechtel: 25474-000-M4-CN-00001 Owner: 10112936-PB-P-HMB-0001

Process Streams		325	330	332	333	334	400	401	402	403	404	405	406	407	408	409	Process \$	Streams
		Stripper Overhead	Hot Semi-	Cold Rich Amine to Lean /	Process Water to	Lean Amine to		1st Stage	Hot 1st Stage	Cooled 1st Stage	Cold 1st Stage	2nd Stage	Hot 2nd Stage	Cooled 2nd Stage	Cold 2nd Stage			
		Liquid	Lean Amine	Rich Exchanger	Absorbers	E-102 Inlet	CO2	Suction	Discharge	Discharge	Discharge	Suction	Discharge	Discharge	Discharge	Dryer Inlet		
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction	on
Oxygen		2.20237E-07	4.10422E-07	0.000205017	9.84458E-09*	0	0.00705588	0.00705594	0.00705594	0.00705594	0.00705594	0.00750067	0.00750067	0.00750067	0.00750067	0.00753644	4 Oxygen	
Nitrogen		3.65715E-07	8.68573E-07	0.000641035	8.72213E-09*	0	0.0220651	0.0220653	0.0220653	0.0220653	0.0220653	0.0234561	0.0234561	0.0234561	0.0234561	0.0235680	) Nitrogen	
Water		99.8824	78.9823	78.6517	99.9185*	80.4568	6.53827	6.53747	6.53747	6.53747	6.53747	0.658027	0.658027	0.658027	0.658027	0.188667	Water	
Carbon Dioxide		0.0881969	6.04871	6.61467	0.0555783*	3.65089	93.4321	93.4329	93.4329	93.4329	93.4329	99.3105	99.3105	99.3105	99.3105	99.7797	Carbon Diox	ide
Sulfur Dioxide		7.17408E-08	3.02511E-08	1.03913E-07	7.69346E-08*	0	3.28536E-06	3.28539E-06	3.28539E-06	3.28539E-06	3.28539E-06	3.47476E-06	3.47476E-06	3.47476E-06	3.47476E-06	3.48552E-06	Sulfur Dioxid	e
MEA		0.0264361	14.9687	14.7324	0.0233448*	15.8921	7.99930E-08	7.99671E-08	7.99671E-08	7.99671E-08	7.99671E-08	2.83077E-09	2.83077E-09	2.83077E-09	2.83077E-09	4.56643E-10	MEA	
Argon		1.63361E-08	2.75399E-08	1.43324E-05	7.76934E-10"	0	0.000493272	0.000493276	0.000493276	0.000493276	0.000493276	0.000524367	0.000524367	0.000524367	0.000524367	0.000526868	Argon	
NO NO2		1.19293E-11	2.47223E-11	7.51700E-09	7.72946E-13"	0	2.58635E-07	2.58637E-07	2.58637E-07	2.58637E-07	2.58637E-07	2.74938E-07	2.74938E-07	2.74938E-07	2.74938E-07	2.76249E-07		
		2.02720E-10	3.03957E-10	0.000329574	0.95054E-09	0 000220537	5.95413E-07	5.95417E-07	5.95417E-07	5.95417E-07	5.95417E-07	0.12949E-07	0.12949E-07	0.12949E-07	0.12949E-07	0.09009E-07		
Molar Flow		6.60294904	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	8.17332L-00	Molar Flow	
Oxvaen		9 52432E-06	8 87752E-05	0 180254	4 74224F-09*	0	0 225221	0 225221	0 225221	0 225221	0 225221	0 225219	0 225219	0 225219	0 225219	0 225219	Oxygen	
Nitrogen		1.58156E-05	0.000187874	0.563608	4.20154E-09*	0	0.704308	0.704308	0.704308	0.704308	0.704308	0.704306	0.704306	0.704306	0.704306	0.704305	Nitrogen	
Water		4319.49	17084.1	69151.9	48.1318*	65574.2	208.699	208.672	208.672	208.672	208.672	19.7583	19.7583	19.7583	19.7583	5.63813	3 Water	
Carbon Dioxide		3.81414	1308.35	5815.73	0.0267726*	2975.56	2982.31	2982.31	2982.31	2982.31	2982.31	2981.95	2981.95	2981.95	2981.95	2981.81	Carbon Diox	ide
Sulfur Dioxide		3.10248E-06	6.54339E-06	9.13624E-05	3.70602E-08*	0	0.000104867	0.000104867	0.000104867	0.000104867	0.000104867	0.000104335	0.000104335	0.000104335	0.000104335	0.000104161	Sulfur Dioxid	le
MEA		1.14325	3237.76	12953.0	0.0112455*	12952.4	2.55334E-06	2.55250E-06	2.55250E-06	2.55250E-06	2.55250E-06	8.49983E-08	8.49983E-08	8.49983E-08	8.49983E-08	1.36463E-08	MEA	
Argon		7.06467E-07	5.95695E-06	0.0126013	3.74258E-10*	0	0.0157450	0.0157450	0.0157450	0.0157450	0.0157450	0.0157449	0.0157449	0.0157449	0.0157449	0.0157449	Argon	
NO		5.15892E-10	5.34749E-09	6.60907E-06	3.72336E-13*	0	8.25553E-06	8.25553E-06	8.25553E-06	8.25553E-06	8.25553E-06	8.25546E-06	8.25546E-06	8.25546E-06	8.25546E-06	8.25542E-06	NO	
NO2		1.13619E-08	6.57467E-08	1.52650E-05	3.35104E-09*	0	1.90053E-05	1.90053E-05	1.90053E-05	1.90053E-05	1.90053E-05	1.84048E-05	1.84048E-05	1.84048E-05	1.84048E-05	1.82160E-05	5 NO2	
NH3		0.127559	0.0672341	0.289766	0.00125414*	0.179743	0.000439126	0.000439123	0.000439123	0.000439123	0.000439123	0.000310378	0.000310378	0.000310378	0.000310378	0.000274153	B NH3	
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fracti	on
Oxygen		3.90443E-07	5.04451E-07	0.000251548	1.74622E-08*	0	0.00533688	0.00533690	0.00533690	0.00533690	0.00533690	0.00547551	0.00547551	0.00547551	0.00547551	0.00548636	6 Oxygen	
Nitrogen		5.67599E-07	9.34602E-07	0.000688565	1.35443E-08*	0	0.0146108	0.0146109	0.0146109	0.0146109	0.0146109	0.0149904	0.0149904	0.0149904	0.0149904	0.0150201	Nitrogen	
Water		99.6927	54.6545	54.3308	99.7829*	56.1615	2.78424	2.78389	2.78389	2.78389	2.78389	0.270443	0.270443	0.270443	0.270443	0.0773254	Water	
Carbon Dioxide		0.215047	10.2250	11.1623	0.135588*	6.22557	97.1953	97.1957	97.1957	97.1957	97.1957	99.7086	99.7086	99.7086	99.7086	99.9017	Carbon Diox	ide
Sulfur Dioxide		2.54631E-07	7.44403E-08	2.55259E-07	2.73214E-07*	0	4.97506E-06	4.97508E-06	4.97508E-06	4.97508E-06	4.97508E-06	5.07842E-06	5.07842E-06	5.07842E-06	5.07842E-06	5.08001E-06	Sulfur Dioxid	e
MEA		0.0894648	35.1203	34.5057	0.0790462*	37.6128	1.15498E-07	1.15460E-07	1.15460E-07	1.15460E-07	1.15460E-07	3.94472E-09	3.94472E-09	3.94472E-09	3.94472E-09	6.34574E-10	MEA	
Argon		3.61557E-08	4.22583E-08	2.19539E-05	1.72048E-09"	0					0.000465785	0.000477883	1 88207E 07	0.000477883	0.000477883	1 995905 07	Argon	
		6.69652E-10	2.04939E-11	0.04071E-09 3.06273E-08	1.20307E-12	0	1.03443E-07	1.03443E-07	1.03443E-07	1.03443E-07	6.47489E-07	6.43317E-07	6.43317E-07	1.00207E-07 6.43317E-07	6.43317E-07	6.3708/E-07		
NH3		0.00278311	0.000203334	0.000215217	0.00245786*	0 000145527	5.53813E-06	5.53810E-06	5.53810E-06	5.53810E-06	5.53810E-06	4.01610E-06	4.01610E-06	4 01610E-06	4.01610E-06	3 55441E-06	NH3	
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow	
Oxvaen		0.000304767	0.00284070	5.76792	1.51746E-07*	0	7.20679	7.20679	7.20679	7.20679	7.20679	7.20675	7.20675	7.20675	7.20675	7.20673	3 Oxvaen	
Nitrogen		0.000443049	0.00526300	15.7886	1.17699E-07*	0	19.7301	19.7301	19.7301	19.7301	19.7301	19.7300	19.7300	19.7300	19.7300	19.7300	) Nitrogen	
Water		77816.8	307774	1.24579E+06	867.108*	1.18134E+06	3759.77	3759.28	3759.28	3759.28	3759.28	355.951	355.951	355.951	355.951	101.572	Water	
Carbon Dioxide		167.858	57579.9	255947	1.17825*	130953	131250	131250	131250	131250	131250	131234	131234	131234	131234	131228	Carbon Diox	ide
Sulfur Dioxide		0.000198757	0.000419194	0.00585302	2.37422E-06*	0	0.00671820	0.00671820	0.00671820	0.00671820	0.00671820	0.00668411	0.00668411	0.00668411	0.00668411	0.00667296	Sulfur Dioxid	le
MEA		69.8333	197772	791207	0.686907*	791173	0.000155966	0.000155914	0.000155914	0.000155914	0.000155914	5.19196E-06	5.19196E-06	5.19196E-06	5.19196E-06	8.33558E-07	MEA	
Argon		2.82219E-05	0.000237968	0.503397	1.49508E-08*	0	0.628983	0.628983	0.628983	0.628983	0.628983	0.628979	0.628979	0.628979	0.628979	0.628977	7 Argon	
NO		1.54799E-08	1.60457E-07	0.000198312	1.11724E-11*	0	0.000247716	0.000247716	0.000247716	0.000247716	0.000247716	0.000247714	0.000247714	0.000247714	0.000247714	0.000247713	NO	
NO2		5.22708E-07	3.02471E-06	0.000702276	1.54166E-07*	0	0.000874350	0.000874349	0.000874349	0.000874349	0.000874349	0.000846720	0.000846720	0.000846720	0.000846720	0.000838038	3 NO2	
NH3		2.17240	1.14503	4.93487	0.0213587*	3.06111	0.00747855	0.00747849	0.00747849	0.00747849	0.00747849	0.00528590	0.00528590	0.00528590	0.00528590	0.00466897	7 NH3	
Process Streams		325	330	332	333	334	400	401	402	403	404	405	406	407	408	409	F I I I I	rocess Streams
Property	Units																Units P	roperty
l emperature	°C har	48.6909	113.728	53.5053	45.7208*	58.7730	48.7010	48.7010	1/6.66/^	129.444^	26^	25.8867	1/6.667^	129.444^	26*	25.9261	l C le	emperature
Mole Fraction Vanar	0/	1.79306	2.39982	10.7412	4.13685	4.72333	1.79306	1.79306	0.03552	5.75973	04.0622	5.34605	23.1076	22.8318	22.4870	22.4181		Ide Fraction Vanar
Molecular Weight	/0 kg/kmol	18 0/06	26 U343 0	0 26 0707	18 0309	0 25 8097	33.3391 12 2055	100	42 3057	100	94.0033 19 2057	100	100	\7 8330 100	55.0204 ⊿ว גכסס	100	ka/kmol	Iolecular Weight
Mass Density	kg/m^2	0.0490	20.0343	1152 //	989 520	20.0007 1100 41	-+2.3035 2 85806	2 85805	42.3037 6 88503	42.3037 7 370/12	42.3037 10 0902	43.0330 9 711/7	43.0330	31 3460	45.0530	45.557	1 kg/m^3	lass Density
Molar Flow	kmol/h	4324 57	21630 3	87921 6	48 1711	81502 4	3191 96	3191 93	3191 93	3101 03	3191 93	3002.66	3002 66	3002 66	3002 66	2988 40	) kmol/h	Iolar Flow
Mass Flow	ka/h	78056 7	563128	2.29297E+06	868.994*	2.10347E+06	135037	135037	135037	135037	135037	131618	131618	131618	131618	131357	ka/h	lass Flow
Std Vapor Volumetric Flow	m^3/h	102451	512430	2.08290E+06	1141.19	1.93083E+06	75618.9	75618.3	75618.3	75618.3	75618.3	71134.3	71134.3	71134.3	71134.3	70796.4	1 m^3/h S	td Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	78.1698	572.069	2334.33	0.870104	2117.55	163.618	163.618	163.618	163.618	163.618	160.192	160.192	160.192	160.192	159.930	) m^3/h S	td Liquid Volumetric Flow
Specific Gravity		0.989329	1.12571	1.15353	0.990455	1.10145		1.46129	1.46129	1.46129		1.51407	1.51407	1.51407		1.51828	s s	pecific Gravity
Mass Enthalpy	kJ/kg	-15742.0	-10949.8	-11186.0	-15760.7	-11062.9	-9045.10	-9045.07	-8924.50	-8971.65	-9130.15	-8956.04	-8823.38	-8871.30	-8978.42	-8965.08	3 kJ/kg M	lass Enthalpy
Dynamic Viscosity	cP	0.548233	0.708427	2.59641	0.579362	1.86394		0.0161454	0.0216019	0.0197044		0.0152834	0.0220095	0.0201805		0.0159386	CP D	ynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.6334	0.3981	0.3813	0.6309	0.4048		0.0187	0.0287	0.0251		0.0172	0.0296	0.0261		0.0189	W/(m*℃) TI	hermal Conductivit y
Surface Tension	dyne/cm	68.0691	87.7229	93.0895	68.6724	57.9010											dyne/cm S	surface Tension

b) d Singe         b) d Singe         b) d Singe         b) d Singe         SCM Samply         SCM Reum         SCM Samply         SCM Reum         SCM Samply         SCM Samply<	Process Streams	410	411	412	413	414	415	416	417	501	502	503	504	505	506	509	510	511	Process S	Streams
Det Praction         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N         N <t< th=""><th></th><th>3rd Stage</th><th>Hot 3rd Stage</th><th>Cooled 3rd Stage</th><th>Cold 3rd Stage</th><th></th><th>Inter-stage</th><th>Liquefied</th><th>Dryer</th><th>SCW Supply</th><th>SCW Return</th><th>SCW Supply</th><th>SCW Return</th><th>SCW Supply</th><th>SCW Return</th><th>SCW Supply</th><th>SCW Return</th><th>LP Steam</th><th></th><th></th></t<>		3rd Stage	Hot 3rd Stage	Cooled 3rd Stage	Cold 3rd Stage		Inter-stage	Liquefied	Dryer	SCW Supply	SCW Return	SCW Supply	SCW Return	SCW Supply	SCW Return	SCW Supply	SCW Return	LP Steam		
Description         Description <thdescription< th=""> <thdescription< th=""></thdescription<></thdescription<>	Mole Fraction	Suction	Discharge	Discharge	Discharge	CO2 Product	Liquid	CO2	Water %	to E-101 %	From E-101	to E-104	From E-104	to E-102 %	From E-102	to E-111 %	From E-111	from E-112	Mole Fractic	n
Ombus         Out23810         Out23810 <thout23810< th="">         Out23810         <th< td=""><td></td><td>/8</td><td>78</td><td>/6</td><td>78</td><td>/6</td><td>70 0.44606E.07</td><td>/0</td><td>/0</td><td>/8</td><td>/8</td><td>/6</td><td>/8</td><td>/6</td><td>/0</td><td>/6</td><td>/0</td><td>/6</td><td></td><td></td></th<></thout23810<>		/8	78	/6	78	/6	70 0.44606E.07	/0	/0	/8	/8	/6	/8	/6	/0	/6	/0	/6		
num         0.011000         0.011000         0.011000         0.011000         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01         0.01 </td <td>Nitrogen</td> <td>0.00754980</td> <td>0.00734980</td> <td>0.00734980</td> <td>0.00734980</td> <td>0.00734980</td> <td>9.44000E-07</td> <td>0.00734980</td> <td>0</td> <td>0*</td> <td>0</td> <td>0*</td> <td>0</td> <td>0*</td> <td>0</td> <td>0*</td> <td>0</td> <td></td> <td>Nitrogen</td> <td></td>	Nitrogen	0.00754980	0.00734980	0.00734980	0.00734980	0.00734980	9.44000E-07	0.00734980	0	0*	0	0*	0	0*	0	0*	0		Nitrogen	
Onthon         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         99 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         90 307 3         <	Water	0.0110000	0.0110000	0.0230100	0.0230100	0.0230100	99 7532	0.0110000	100	100*	100	100*	100	100*	100	100*	100	100	Water	
Sainty Division         3.4972e-10         3.	Carbon Dioxide	99.9573	99.9573	99.9573	99.9573	99.9573	0.246722	99.9573	0	0*	0	0*	0	0*	0	0*	0		Carbon Dioxi	de
MEA         4.5746E-10         4.5746E-10         4.5746E-10         4.5746E-10         2.1701E-00         2.1701E-00 <td>Sulfur Dioxide</td> <td>3.49172E-06</td> <td>3.49172E-06</td> <td>3.49172E-06</td> <td>3.49172E-06</td> <td>3.49172E-06</td> <td>3.46978E-07</td> <td>3.49172E-06</td> <td>0</td> <td>0*</td> <td>0</td> <td>0*</td> <td>0</td> <td>0*</td> <td>0</td> <td>0*</td> <td>0</td> <td>C</td> <td>Sulfur Dioxid</td> <td>9</td>	Sulfur Dioxide	3.49172E-06	3.49172E-06	3.49172E-06	3.49172E-06	3.49172E-06	3.46978E-07	3.49172E-06	0	0*	0	0*	0	0*	0	0*	0	C	Sulfur Dioxid	9
Argon         0.00527905         0.00527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.000527905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905         0.00057905	MEA	4.57456E-10	4.57456E-10	4.57456E-10	4.57456E-10	4.57456E-10	1.24761E-06	4.57456E-10	0	0*	0	0*	0	0*	0	0*	0	C	MEA	
NO         278741E-07         2.78741E-07         2.78741E-07         2.78741E-07         1.0385E-10         2.78741E-07         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0	Argon	0.000527806	0.000527806	0.000527806	0.000527806	0.000527806	7.15640E-08	0.000527806	0	0*	0	0*	0	0*	0	0*	0	C	Argon	
NO2         61:0444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:06444-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:0644-07         61:064         61:064         61:064         61:064         61:064         61:064         61:0644-07         61:0644-07         61:064         61:064         61:064         61:064         61:064         61:064         61:064         61:064         61:064         61:064         61:064         61:064         61:064         61:064         61:064         61:064         61:064         61:06         61:064         61:06 <td>NO</td> <td>2.76741E-07</td> <td>2.76741E-07</td> <td>2.76741E-07</td> <td>2.76741E-07</td> <td>2.76741E-07</td> <td>5.13855E-11</td> <td>2.76741E-07</td> <td>0</td> <td>0*</td> <td>0</td> <td>0*</td> <td>0</td> <td>0*</td> <td>0</td> <td>0*</td> <td>0</td> <td>C</td> <td>NO</td> <td></td>	NO	2.76741E-07	2.76741E-07	2.76741E-07	2.76741E-07	2.76741E-07	5.13855E-11	2.76741E-07	0	0*	0	0*	0	0*	0	0*	0	C	NO	
NH3         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0	NO2	6.10644E-07	6.10644E-07	6.10644E-07	6.10644E-07	6.10644E-07	3.87768E-07	6.10644E-07	0	0*	0	0*	0	0*	0	0*	0	C	NO2	
Molar Flow         Kmol/h         Kmo	NH3	9.19025E-06	9.19025E-06	9.19025E-06	9.19025E-06	9.19025E-06	8.09937E-05	9.19025E-06	0	0*	0	0*	0	0*	0	0*	0	C	NH3	
Oxygen         0.225219         0.225219         0.225219         0.225219         0.225219         0.225219         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0        0        0         0<	Molar Flow	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow	
Nintegen         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.704305         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405         0.705405	Oxygen	0.225219	0.225219	0.225219	0.225219	0.225219	1.92286E-06	0.225219	0	0*	0	0*	0	0*	0	0*	0	C	Oxygen	
Mater         0.326139         0.326139         0.326139         0.326139         0.326139         0.326139         0.236139         0.236139         0.236139         0.236139         0.236139         0.236139         0.21501         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101         0.101 </td <td>Nitrogen</td> <td>0.704305</td> <td>0.704305</td> <td>0.704305</td> <td>0.704305</td> <td>0.704305</td> <td>2.98485E-06</td> <td>0.704305</td> <td>0 5 20000</td> <td>0^</td> <td>0</td> <td>0^</td> <td>0</td> <td>0^ 47027.0*</td> <td>47027.0</td> <td>0^</td> <td>0</td> <td>452.054</td> <td>Nitrogen</td> <td></td>	Nitrogen	0.704305	0.704305	0.704305	0.704305	0.704305	2.98485E-06	0.704305	0 5 20000	0^	0	0^	0	0^ 47027.0*	47027.0	0^	0	452.054	Nitrogen	
Carloon Hooked         Loon 1000         Loon 1000 <thloon 1000<="" th=""></thloon>	Water Carbon Dioxide	0.328139	2081.81	2081.81	0.328139	2081.81	203.060	0.328139	5.30999	275071	2/50/1	2/50/1	275071	47837.2	4/83/.2	275025	275025	152.254	Vvaler Carbon Dioxi	de
Considered         Conside	Sulfur Dioxide	0.000104161	0.000104161	0.000104161	0.000104161	0.000104161	7.06317E-07	0.000104161	0	0*	0	0*	0	0*	0	0*	0		Sulfur Dioxid	
Argon         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.0157449         0.00160167         0.0167403         0.002         0.0157449         0.00274153         0.000274153         0.000274153         0.000274153         0.000274153         0.000274153         0.000274153         0.000274153         0.000274153         0.000274153         0.000274153         0.000274153         0.000274153         0.000249036         0.000	MEA	1.36463E-08	1.36463E-08	1.36463E-08	1.36463E-08	1.36463E-08	2.53966E-06	1.36463E-08	0	0*	0	0*	0	0*	0	0*	0	0	MEA	•
NO         8.25542E-06         8.25542E-06         8.25542E-06         8.25542E-06         8.25542E-06         1.04602E-10         8.25542E-06         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0         0	Argon	0.0157449	0.0157449	0.0157449	0.0157449	0.0157449	1.45677E-07	0.0157449	0	0*	0	0*	0	0*	0	0*	0	C	Argon	
NO2       1.82160E-05       1.82160E-05       1.82160E-05       1.82160E-05       0.89349E-07       1.82160E-05       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       <	NO	8.25542E-06	8.25542E-06	8.25542E-06	8.25542E-06	8.25542E-06	1.04602E-10	8.25542E-06	0	0*	0	0*	0	0*	0	0*	0	C	NO	
NH30.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0002741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.0005741530.000574153 <t< td=""><td>NO2</td><td>1.82160E-05</td><td>5 1.82160E-05</td><td>1.82160E-05</td><td>1.82160E-05</td><td>1.82160E-05</td><td>7.89349E-07</td><td>1.82160E-05</td><td>0</td><td>0*</td><td>0</td><td>0*</td><td>0</td><td>0*</td><td>0</td><td>0*</td><td>0</td><td>C</td><td>NO2</td><td></td></t<>	NO2	1.82160E-05	5 1.82160E-05	1.82160E-05	1.82160E-05	1.82160E-05	7.89349E-07	1.82160E-05	0	0*	0	0*	0	0*	0	0*	0	C	NO2	
Mass Fraction%%%%%%%%%%%%%%%%%%Mass FractionOxygen0.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.004791780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.004791780.00	NH3	0.000274153	0.000274153	0.000274153	0.000274153	0.000274153	0.000164873	0.000274153	0	0*	0	0*	0	0*	0	0*	0	C	NH3	
Oxygen0.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.005490360.001503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.004791780.004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.0004791780.000479178 <th< td=""><td>Mass Fraction</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>%</td><td>Mass Fraction</td><td>on</td></th<>	Mass Fraction	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fraction	on
Nitrogen0.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503110.01503120.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004503620.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.004701780.00	Oxygen	0.00549036	0.00549036	0.00549036	0.00549036	0.00549036	1.67186E-06	0.00549036	0	0*	0	0*	0	0*	0	0*	0	C	Oxygen	
Water       0.00450362       0.00450362       0.00450362       0.00450362       0.00450362       99.9393       0.00450362       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100       100	Nitrogen	0.0150311	0.0150311	0.0150311	0.0150311	0.0150311	2.27199E-06	0.0150311	0	0*	0	0*	0	0*	0	0*	0	C	Nitrogen	
Carbon Dioxide       99.9745       99.9745       99.9745       99.9745       99.9745       99.9745       0.600579       99.9745       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0       0 <t< td=""><td>Water</td><td>0.00450362</td><td>0.00450362</td><td>0.00450362</td><td>0.00450362</td><td>0.00450362</td><td>99.3993</td><td>0.00450362</td><td>100</td><td>100*</td><td>100</td><td>100*</td><td>100</td><td>100*</td><td>100</td><td>100*</td><td>100</td><td>100</td><td>Water</td><td></td></t<>	Water	0.00450362	0.00450362	0.00450362	0.00450362	0.00450362	99.3993	0.00450362	100	100*	100	100*	100	100*	100	100*	100	100	Water	
Sulfur Dioxide       5.08371E-06       5.08371E-06 <td>Carbon Dioxide</td> <td>99.9745</td> <td>99.9745</td> <td>99.9745</td> <td>99.9745</td> <td>99.9745</td> <td>0.600579</td> <td>99.9745</td> <td>0</td> <td>0*</td> <td>0</td> <td>0*</td> <td>0</td> <td>0*</td> <td>0</td> <td>0*</td> <td>0</td> <td>C</td> <td>Carbon Dioxi</td> <td>de</td>	Carbon Dioxide	99.9745	99.9745	99.9745	99.9745	99.9745	0.600579	99.9745	0	0*	0	0*	0	0*	0	0*	0	C	Carbon Dioxi	de
MEA       6.35036E-10       6.35036E-10 <t< td=""><td></td><td>5.08371E-06</td><td>5.08371E-06</td><td>5.08371E-06</td><td>5.08371E-06</td><td>5.08371E-06</td><td>1.22951E-06</td><td>5.08371E-06</td><td>0</td><td>0*</td><td>0</td><td>0*</td><td>0</td><td>0*</td><td>0</td><td>0*</td><td>0</td><td>0</td><td>Sulfur Dioxid</td><td>9</td></t<>		5.08371E-06	5.08371E-06	5.08371E-06	5.08371E-06	5.08371E-06	1.22951E-06	5.08371E-06	0	0*	0	0*	0	0*	0	0*	0	0	Sulfur Dioxid	9
	Argon	0.000470178	0.000470178	0.000470179	0.35036E-10	0.35036E-10	4.21516E-06	0.000470178	0	0*	0	0*	0	0*	0	0*	0		MIEA Argon	
	NO	1 88717E-07	1 88717E-07	1 88717F-07	1 88717F-07	1.88717E-07	8.52837E-11	1 88717E-07		0*	0	0*	0	0*	0	0*	0		NO	
NO2 6.38449E-07 6.38449E-07 6.38449E-07 6.38449E-07 9.86727E-07 6.38449E-07 9.86727E-07 6.38449E-07 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0	NO2	6.38449E-07	6.38449E-07	6.38449E-07	6.38449E-07	6.38449E-07	9.86727E-07	6.38449E-07	· 0	0*	0	0*	0	0*	0	0*	0	0	NO2	
NH3 3.55700E-06 3.55700E-06 3.55700E-06 3.55700E-06 3.55700E-06 7.62948E-05 3.55700E-06 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0	NH3	3.55700E-06	3.55700E-06	3.55700E-06	3.55700E-06	3.55700E-06	7.62948E-05	3.55700E-06	0	0*	0	0*	0	0*	0	0*	0	C	NH3	
Mass Flow kg/h kg/h kg/h kg/h kg/h kg/h kg/h kg/h	Mass Flow	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow	
Oxygen 7.20673 7.20673 7.20673 7.20673 7.20673 7.20673 6.15293E-05 7.20673 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0 Oxygen	Oxygen	7.20673	3 7.20673	7.20673	7.20673	7.20673	6.15293E-05	7.20673	0	0*	0	0*	0	0*	0	0*	0	C	Oxygen	
Nitrogen 19.7300 19.7300 19.7300 19.7300 19.7300 19.7300 8.36157E-05 19.7300 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0*	Nitrogen	19.7300	19.7300	19.7300	19.7300	19.7300	8.36157E-05	19.7300	0	0*	0	0*	0	0*	0	0*	0	C	Nitrogen	
Water 5.91152 5.91152 5.91152 5.91152 5.91152 5.91152 5.91152 3658.18 5.91152 95.6609 4.95548E+06* 4.95548E+06* 4.95548E+06 861801* 861801 4.95465E+06* 4.95465E+06 2742.90 Water	Water	5.91152	5.91152	5.91152	5.91152	5.91152	3658.18	5.91152	95.6609	4.95548E+06*	4.95548E+06	4.95548E+06*	4.95548E+06	861801*	861801	4.95465E+06*	4.95465E+06	2742.90	Water	
Carbon Dioxide 131228 131228 131228 131228 131228 131228 22.1030 131228 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0 Carbon Dioxide	Carbon Dioxide	131228	3 131228	131228	131228	131228	22.1030	131228	0	0*	0	0*	0	0*	0	0*	0	C	Carbon Dioxi	de
Sulfur Dioxide 0.00667296 0.00667296 0.00667296 0.00667296 0.00667296 4.52494E-05 0.00667296 0 0* 0 0* 0 0* 0 0* 0 0* 0 0 Sulfur Dioxide	Sulfur Dioxide	0.00667296	0.00667296	0.00667296	0.00667296	0.00667296	4.52494E-05	0.00667296	0	0*	0	0*	0	0*	0	0*	0	C	Sulfur Dioxid	e
MEA 8.33558E-07 8.33558E-07 8.33558E-07 8.33558E-07 0.000155130 8.33558E-07 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0	MEA	8.33558E-07	8.33558E-07	8.33558E-07	8.33558E-07	8.33558E-07	0.000155130	8.33558E-07	0	0*	0	0*	0	0*	0	0*	0	C	MEA	
Argon 0.628977 0.628977 0.628977 0.628977 0.628977 0.628977 0.628977 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0 0* 0 0* 0 0 0* 0 0* 0 0* 0 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0 0* 0*	Argon	0.628977	0.628977	0.628977	0.628977	0.628977	5.81952E-06	0.628977	0	0*	0	0*	0	0*	0	0*	0	0	Argon	
		0.000247713	0.000247713	0.000247713	0.000247713	0.000247713	3.13869E-09	0.000247713	0	0*	0	0*	0	0*	0	0*	0			
	NH3	0.000838038	0.000838038	0.000838038	0.000838038	0.000838038	0.00280787	0.000838038		0*	0	0*	0	0*	0	0*	0		NH3	
Process Streams 410 411 412 413 414 415 416 417 501 502 503 504 505 506 509 510 511 Process Streams	Process Streams	410	411	412	413	<b>414</b>	415	416	417	501	502	503	504	505	506	509	510	511	P	rocess Streams
Property Units I I I I I I I I I I I I I I I I I I I	Property Units																		Units P	roperty
Temperature C 25.9261 176.667* 129.444* 28* 48.2023 25.6326 27.9889 25.9261 11* 21 11* 21 11* 21 11* 21* 11* 21* 125.835 C Temperature	Temperature C	25.9261	176.667*	129.444*	28*	48.2023	25.6326	27.9889	25.9261	11*	21	11*	21	11*	21*	11*	21*	125.835	СΤе	mperature
Pressure bar 22.4181 93.5828 93.3070 92.9622 201.000* 1.79306 92.8933 22.4181 1.9999* 0.965686 1.9999* 1.31042 1.9999* 0.965686 2.37913 bar Pressure	Pressure bar	22.4181	93.5828	93.3070	92.9622	201.000*	1.79306	92.8933	22.4181	1.9999*	0.965686	1.9999*	0.965686	1.9999*	1.31042	1.9999*	0.965686	2.37913	bar P	ressure
Mole Fraction Vapor % 100 100 100 0 100 0.167175 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Mole Fraction Vapor %	100	100	100	0	100	0.167175	0	0	0	0	0	0	0	0	0	0	100*	% M	ole Fraction Vapor
Molecular Weight kg/kmol 44.0019 44.0019 44.0019 44.0019 44.0019 44.0019 18.0794 44.0019 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153 18.0153	Molecular Weight kg/kmol	44.0019	44.0019	44.0019	44.0019	44.0019	18.0794	44.0019	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	kg/kmol M	olecular Weight
Mass Density kg/m^3 45.5945 123.168 148.590 722.629? 778.532 440.987 722.521 996.481 1000.00 997.597 1000.00 997.597 1000.00 997.602 1000.00 997.597 1.31446 kg/m^3 Mass Density	Mass Density kg/m^3	45.5945	5 123.168	148.590	722.629?	778.532	440.987	722.521	996.481	1000.00	997.597	1000.00	997.597	1000.00	997.602	1000.00	997.597	1.31446	kg/m^3 M	ass Density
Molar Flow kmol/h 2983.09 2983.09 2983.09 2983.09 2983.09 2983.09 2983.09 203.562 2983.09 5.30999 275071 275071 275071 275071 47837.2 47837.2 275025 275025 152.254 kmol/h Molar Flow	Molar Flow kmol/h	2983.09	2983.09	2983.09	2983.09	2983.09	203.562	2983.09	5.30999	275071	275071	275071	275071	47837.2	47837.2	275025	275025	152.254	kmol/h M	olar Flow
Mass Flow kg/h 131262 131262 131262 131262 131262 131262 3680.29 131262 95.6609 4.95548E+06 4.95465E+06 4.95548E+06 4.95548E+0	Mass Flow kg/h	131262	131262	131262	131262	131262	3680.29	131262	95.6609	4.95548E+06	4.95548E+06	4.95548E+06	4.95548E+06	861801	861801	4.95465E+06	4.95465E+06	2742.90	kg/h M	ass Flow
Std Vapor Volumetric Flow m^3/h 70670.6 70670.6 70670.6 70670.6 70670.6 70670.6 125.796 6.51656E+06 6.51656E+06 6.51656E+06 6.51656E+06 6.51656E+06 6.51547E+06 6.51656E+06 6.51547E+06 6.51547E+06 6.51547E+06 6.51547E+06 6.51547E+06 6.51547E+06 6.51547E+06 6.51547E+06 6.51547E+06 6.51656E+06 6.5166E+06 6.5166E+06 6.5166E+06 6.5166E+06 6.51660E+06 6.5166	Std Vapor Volumetric Flow m^3/h	70670.6	5 70670.6	70670.6	70670.6	70670.6	4822.48	70670.6	125.796	6.51656E+06	6.51656E+06	6.51656E+06	6.51656E+06	1.13328E+06	1.13328E+06	6.51547E+06	6.51547E+06	3606.97	m^3/h S	d Vapor Volumetric Flow
Std Liquid Volumetric Flow m^3/h 159.834 159.834 159.834 159.834 159.834 159.834 159.834 0.0957550 4960.36 4960.36 4960.36 4960.36 862.649 862.649 4959.53 4959.53 2.74560 m^3/h Std Liquid Volumetric F	Std Liquid Volumetric Flow m^3/h	159.834	159.834	159.834	159.834	159.834	3.68870	159.834	0.0957550	4960.36	4960.36	4960.36	4960.36	862.649	862.649	4959.53	4959.53	2.74560	m^3/h Si	d Liquid Volumetric Flow
Opecinic Gravity         1.51988         1.51988         1.51988         0.723312 / 1.51988         0.723204 / 0.997422         1.00095         0.998540         1.00095         0.998544         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.00095         0.998540         1.000	Specific Gravity	1.51988	1.51988	1.51988	0.723312?	1.51988	15000.0	0.723204?	0.997422	1.00095	0.998540	1.00095	0.998540	1.00095	0.998544	1.00095	0.998540	0.622268	k l/ka	
Initiality Initiality CP 0.0159403 0.024204 0.0230638 0.0609532 0.0609271 0.870306 1.2003 0.087115 1.20002 0.087115 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.087145 1.20002 0.20002 0.20002 0.20002 0.20002 0.20002 0.20002 0.20002 0.20002 0.20002 0.20002 0.20002 0.20002 0.20002 0.20002 0.20002	Nass Entitalpy KJ/Kg	-0901.70	-8844.38	-0302.00	-9107.00	-9147.05 0.0602274	-10823.3	0 0600674	0.870206	-10921.7 1 20002	- 1000 1.2 0 097115	1 20002	-10001.2 0 097115	1 20002	- 10001.2 0 007105	1 20002	-10001.2	-13240.4		ass Ennalpy vnamic Viscosity
Dynamic viscosity Circle Conductivity W/(m*C) 0.0189 0.0342 0.0319 0.1073 0.0099 0.1073 0.6076 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.6006 0.5854 0.5854 0.6006 0.5854 0.5854 0.6006 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.5854 0.585	Thermal Conductivity W//(m*?)	0.0159403	0.0242104	0.0230638 0.0310	0.0009532	0.0092271		0.0009071	0.079290	0.5854	0.90115	0 5854	0.901110	0 5854	0.901 108.0	0 5854	0.90110	0.0100144	-υ- ₩/(m*℃) Τŀ	ermal Conductivity
Surface Tension dyne/cm 0.0000 72.6316 75.6475 73.6192 75.6475 73.6192 75.6475 73.6192 75.6475 73.6192 0.0000 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.0007 0.00	Surface Tension dvne/cm	0.0108	0.0042	0.0315	0.0000	0.0303		0.0000	72.6316	75.6475	73.6192	75.6475	73.6192	75.6475	73.6192	75.6475	73.6192	0.0270	dyne/cm S	urface Tension

Process Streams		512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527	Process Streams
		LP Condensate	LP Steam	LP Steam	SCW Supply	SCW Return	SCW Supply	SCW Return	Condenstate	Condenstate	Condenstate	SCW Supply	SCW Return	LP Steam	LP Steam	LP Condensate		
		from E-109	from E-114	to E-109	to E-113	From E-113	to E-115	From E-115	to E-112	to E-114	to E-116	to E-117	From E-117	from E-116	to E-110	from E-110	Vent Steam	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fraction
Oxygen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxygen
Nitrogen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen
Water		100	100	100	100*	100	100*	100	100*	100*	100*	100*	100	100	100*	100	100	Water
Carbon Dioxide		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Carbon Dioxide
Sulfur Dioxide		0	0	0	0^	0	0^	0	0*	0^	0^	0*	0	0	0^	0	0	
		0	0	0	0*	0	0*	0	0	0*	0*	0*	0	0	0*	0	0	MEA
Argon		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon
		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO2
NH3		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxvgen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxygen
Nitrogen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen
Water		487.823	150.833	485.819	28908.9*	28908.9	19043.1*	19043.1	152.254*	150.833*	182.732*	46982.0*	46982.0	182.732	11323.7*	11323.7	314.691	Water
Carbon Dioxide		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Carbon Dioxide
Sulfur Dioxide		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Dioxide
MEA		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	MEA
Argon		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon
NŐ		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO
NO2		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO2
NH3		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Fraction
Oxygen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxygen
Nitrogen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Nitrogen
Water		100	100	100	100*	100	100*	100	100*	100*	100*	100*	100	100	100*	100	100	Water
Carbon Dioxide		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Carbon Dioxide
Sulfur Dioxide		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Sulfur Dioxide
MEA		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	MEA
Argon		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon
NO		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO
NO2		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO2
NH3		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Oxygen
Nitrogen		0	0	0	0*	0	*0	0	0*	*0	0*	•0*	0	0	0*	0	0	Nitrogen
Water		8788.27	2/1/.29	8752.16	520803*	520803	343066*	343066	2742.90*	2/17.29*	3291.97*	846394*	846394	3291.97	204000^	204000	5669.24	Water
Carbon Dioxide		0	0	0	0*	0	0*	0	0*	0* 0*	0*	0*	0	0	0"	0	0	Carbon Dioxide
		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	
		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	Argon
NO		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO
		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NO2
NH3		0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0	NH3
Process Streams		512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527	Process Streams
Property	Units	0.2	0.0	•	0.0	0.0	•	0.0	0.0	020		022	020		010	010	02.	Units Property
Temperature	r.	125 835	125 835	125 835	16*	26*	16*	26*	98 8889*	98 8889*	98 8889*	16*	26*	125 835	135*	133 594	146 435	°C Temperature
Pressure	bar	2.37913	2.37913	2.37913	1.9999*	1.31042	1.9999*	1.31042	2.37913*	2.37913*	2.37913*	1.9999*	1.31042	2.37913	2.9999*	2,9999	2.3499*	bar Pressure
Mole Fraction Vapor	%	0*	100	100	0	0	0	0	0	0	0	0	0	100	100	0*	100	% Mole Fraction Vapor
Molecular Weight	kg/kmol	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	kg/kmol Molecular Weight
Mass Density	kg/m^3	938.857	1.31446	1.31446	998.879	996.185	998.879	996.185	959.505	959.505	959.505	998.879	996.185	1.31446	1.62556	932.265	1.23159	kg/m^3 Mass Density
Molar Flow	kmol/h	487.823	150.833	485.819	28908.9	28908.9	19043.1	19043.1	152.254	150.833	182.732	46982.0	46982.0	182.732	11323.7	11323.7	314.691	kmol/h Molar Flow
Mass Flow	kg/h	8788.27	2717.29	8752.16	520803	520803	343066	343066	2742.90	2717.29	3291.97	846394	846394	3291.97	204000*	204000	5669.24	kg/h Mass Flow
Std Vapor Volumetric Flow	m^3/h	11556.7	3573.29	11509.3	684866	684866	451138	451138	3606.97	3573.29	4329.00	1.11303E+06	1.11303E+06	4329.00	268264	268264	7455.16	m^3/h Std Vapor Volumetric Flow
Std Liquid Volumetric Flow	m^3/h	8.79692	2.71997	8.76077	521.315	521.315	343.404	343.404	2.74560	2.71997	3.29521	847.227	847.227	3.29521	204.201	204.201	5.67482	m^3/h Std Liquid Volumetric Flow
Specific Gravity		0.939745	0.622268	0.622268	0.999823	0.997127	0.999823	0.997127	0.960412	0.960412	0.960412	0.999823	0.997127	0.622268	0.622268	0.933146	0.622268	Specific Gravity
Mass Enthalpy	kJ/kg	-15448.2	-13240.4	-13240.4	-15904.0	-15862.9	-15904.0	-15862.9	-15561.8	-15561.8	-15561.8	-15904.0	-15862.9	-13240.4	-13224.7	-15390.4	-13200.2	kJ/kg Mass Enthalpy
Dynamic Viscosity	cP	0.219521	0.0106144	0.0106144	1.12405	0.874153	1.12405	0.874153	0.279294	0.279294	0.279294	1.12405	0.874153	0.0106144	0.0110023	0.206890	0.0114855	cP Dynamic Viscosity
Thermal Conductivity	W/(m*℃)	0.6847	0.0270	0.0270	0.5931	0.6077	0.5931	0.6077	0.6758	0.6758	0.6758	0.5931	0.6077	0.0270	0.0278	0.6856	0.0287	W/(m*°C) Thermal Conductivity
Surface Tension	dyne/cm	53.1489			74.6291	72.6168	74.6291	72.6168	58.4280	58.4280	58.4280	74.6291	72.6168			51.6045		dyne/cm Surface Tension

Process Streams		001	002	003	004	005	006	007	008	009	010	100	101	102	103	Process
		Flue Gas From	Flue Gas From	Process Water to	Process Water to	Process Water to	Abs 1. Flue Gas	Process Water to	Process Water to	Abs 2. Flue Gas	Softened	Cooled Flue	Warm Wash	Excess Water to	Off Gas to Atmosphere	
		CCPP	Common Fogger	Foggers	Common Fogger	Abs. 1 Fogger	Blower Discharge	Absorbers	Abs. 2 Fogger	Blower Discharge	Water	Gas to Abs. 1	Water (Abs. 1)	Absorbers	(Abs. 1)	
Mole Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fract
Oxygen		13.2199*	12.8362	2 1.02194E-08	1.02194E-08	1.02194E-08	12.8362	1.00791E-08*	1.02194E-08	12.8362	0	12.7523	0.000224200	0.000224200	13.5359	∂ Oxygen
Nitrogen		74.6917*	72.5237	8.80283E-09	8.80283E-09	8.80283E-09	72.5237	8.68876E-09*	8.80283E-09	72.5237	0	72.0497	0.000678671	0.000678671	76.4775	5 Nitrogen
Water		7.73242*	10.4081	99.9159	99.9159	99.9159	10.4081	99.9161*	99.9159	10.4081	100	10.9931	99.3508	99.3508	8.59823	3 Water
Carbon Dioxide		3.50117*	3.40120	0.0569770	0.0569770	0.0569770	3.40120	0.0567783*	0.0569770	3.40120	0	3.37934	0.166604	0.166604	0.512896	3 Carbon Dic
Sulfur Dioxide		9.98459E-06*	9.69702E-06	7.71650E-08	7.71650E-08	7.71650E-08	9.69702E-06	7.57268E-08*	7.71650E-08	9.69702E-06	0	9.63414E-06	1.13323E-07	1.13323E-07	1.01161E-05	5 Sulfur Diox
MEA		0*	0.000710082	0.0244640	0.0244640	0.0244640	0.000710082	0.0244914*	0.0244640	0.000710082	0	0.000865340	0.481486	0.481486	0.000304138	3 MEA
Argon		0.853978*	0.829190	7.85845E-10	7.85845E-10	7.85845E-10	0.829190	7.74769E-10*	7.85845E-10	0.829190	0	0.823771	1.53030E-05	1.53030E-05	0.874387	7 Argon
NO		0.000319287*	0.000310019	7.81744E-13	7.81744E-13	7.81744E-13	0.000310019	7.71094E-13*	7.81744E-13	0.000310019	0	0.000307993	8.00652E-09	8.00652E-09	0.000326915	5 NO
NO2		7.97150E-05*	7.74015E-05	6.82385E-09	6.82385E-09	6.82385E-09	7.74015E-05	6.70462E-09*	6.82385E-09	7.74015E-05	0	7.68956E-05	1.87616E-08	1.87616E-08	8.16024E-05	5 NO2
NH3		0.000398961*	0.000464497	0.00265682	0.00265682	0.00265682	0.000464497	0.00262444*	0.00265682	0.000464497	0	0.000478826	0.000235387	0.000235387	0.000408216	3 NH3
Molar Flow		kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flov
Oxygen		9192.55*	9192.55	2.60576E-07	2.12426E-07	2.40749E-08	4596.27	6.58886E-08*	2.40749E-08	4596.27	0	4596.27	0.167024	0.00696763	4596.19	) Oxygen
Nitrogen		51937.2*	51937.2	2.24455E-07	1.82980E-07	2.07377E-08	25968.6	5.67995E-08*	2.07377E-08	25968.6	0	25968.6	0.505594	0.0210916	25968.4	1 Nitrogen
Water		5376.77*	7453.67	2547.66	2076.90	235.382	3726.83	653.164*	235.382	3726.83	241.983	3962.22	74013.9	3087.60	2919.58	3 Water
Carbon Dioxide		2434.55*	2435.74	1.45280	1.18435	0.134226	1217.87	0.371167*	0.134226	1217.87	0	1218.00	124.116	5.17767	174.157	/ Carbon Dic
Sulfur Dioxide		0.00694283*	0.00694443	1.96756E-06	1.60399E-06	1.81785E-07	0.00347222	4.95035E-07*	1.81785E-07	0.00347222	0	0.00347240	8.44226E-05	3.52181E-06	0.00343497	7 Sulfur Diox
MEA		0*	0.508519	0.623783	0.508519	0.0576321	0.254259	0.160103*	0.0576321	0.254259	0	0.311891	358.696	14.9635	0.103272	2 MEA
Argon		593.817*	593.817	2.00375E-08	1.63349E-08	1.85129E-09	296.909	5.06476E-09*	1.85129E-09	296.909	0	296.909	0.0114004	0.000475583	296.903	3 Argon
NO		0.222017*	0.222017	1.99329E-11	1.62497E-11	1.84163E-12	0.111009	5.04073E-12*	1.84163E-12	0.111009	0	0.111009	5.96466E-06	2.48824E-07	0.111006	3 NO
NO2		0.0554302*	0.0554304	1.73995E-07	1.41844E-07	1.60756E-08	0.0277152	4.38289E-08*	1.60756E-08	0.0277152	0	0.0277152	1.39769E-05	5.83068E-07	0.0277086	3 NO2
NH3		0.277419*	0.332645	0.0677437	0.0552258	0.00625893	0.166323	0.0171563*	0.00625893	0.166323	0	0.172581	0.175357	0.00731528	0.138612	2 NH3
Mass Fraction		%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Frac
Oxygen		14.8799*	14.6029	1.81263E-08	1.81263E-08	1.81263E-08	14.6029	1.78775E-08*	1.81263E-08	14.6029	0	14.5415	0.000392758	0.000392758	15.5358	3 Oxygen
Nitrogen		73.5995*	72.2293	1.36690E-08	1.36690E-08	1.36690E-08	72.2293	1.34919E-08*	1.36690E-08	72.2293	0	71.9258	0.00104083	0.00104083	76.8443	3 Nitrogen
Water		4.89996*	6.66623	99.7757	99.7757	99.7757	6.66623	99.7761*	99.7757	6.66623	100	7.05748	97.9868	97.9868	5.55600	) Water
Carbon Dioxide		5.41996*	5.32165	0.138994	0.138994	0.138994	5.32165	0.138509*	0.138994	5.32165	0	5.29987	0.401409	0.401409	0.809633	3 Carbon Dic
Sulfur Dioxide		2.24998E-05*	2.20861E-05	2.74020E-07	2.74020E-07	2.74020E-07	2.20861E-05	2.68913E-07*	2.74020E-07	2.20861E-05	0	2.19944E-05	3.97452E-07	3.97452E-07	2.32454E-05	5 Sulfur Diox
MEA		0*	0.00154204	0.0828317	0.0828317	0.0828317	0.00154204	0.0829247*	0.0828317	0.00154204	0	0.00188363	1.61013	1.61013	0.000666352	2 MEA
Argon		1.19999*	1.17765	5 1.74013E-09	1.74013E-09	1.74013E-09	1.17765	1.71561E-09*	1.74013E-09	1.17765	0	1.17270	3.34678E-05	3.34678E-05	1.25288	3 Argon
NO		0.000336998*	0.000330724	1.30024E-12	1.30024E-12	1.30024E-12	0.000330724	1.28253E-12*	1.30024E-12	0.000330724	0	0.000329334	1.31525E-08	1.31525E-08	0.000351849	) NO
NO2		0.000128999*	0.000126598	1.74016E-08	1.74016E-08	1.74016E-08	0.000126598	1.70975E-08*	1.74016E-08	0.000126598	0	0.000126066	4.72536E-08	4.72536E-08	0.000134656	3 NO2
NH3		0.000238998*	0.000281241	0.00250806	0.00250806	0.00250806	0.000281241	0.00247750*	0.00250806	0.000281241	0	0.000290598	0.000219465	0.000219465	0.000249362	2 NH3
Mass Flow		kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen		294150*	294150	8.33811E-06	6.79737E-06	7.70369E-07	147075	2.10835E-06*	7.70369E-07	147075	0	147075	5.34456	0.222956	147073	3 Oxygen
Nitrogen		1.45494E+06*	1.45494E+06	6.28775E-06	5.12588E-06	5.80933E-07	727469	1.59115E-06*	5.80933E-07	727469	0	727469	14.1634	0.590846	727462	2 Nitrogen
Water		96864.1*	134280	45896.8	37415.9	4240.47	67140.0	11766.9*	4240.47	67140.0	4359.39	71380.4	1.33338E+06	55623.9	52597.0	) Water
Carbon Dioxide		107144*	107196	63.9371	52.1226	5.90723	53597.8	16.3349*	5.90723	53597.8	0	53603.7	5462.28	227.867	7664.55	5 Carbon Dic
Sulfur Dioxide		0.444784*	0.444887	0.000126049	0.000102757	1.16458E-05	0.222443	3.17138E-05*	1.16458E-05	0.222443	0	0.222455	0.00540843	0.000225620	0.220057	7 Sulfur Diox
MEA		0*	31.0619	38.1026	31.0619	3.52035	15.5309	9.77959*	3.52035	15.5309	0	19.0513	21910.2	914.016	6.30815	5 MEA
Argon		23721.8*	23721.8	8.00458E-07	6.52548E-07	7.39554E-08	11860.9	2.02327E-07*	7.39554E-08	11860.9	0	11860.9	0.455422	0.0189986	11860.7	7 Argon
NO		6.66188*	6.66188	5.98110E-10	4.87590E-10	5.52602E-11	3.33094	1.51253E-10*	5.52602E-11	3.33094	0	3.33094	0.000178976	7.46625E-06	3.33085	5 NO
NO2		2.55009*	2.55010	8.00472E-06	6.52558E-06	7.39566E-07	1.27505	2.01637E-06*	7.39566E-07	1.27505	0	1.27505	0.000643017	2.68243E-05	1.27475	5 NO2
NH3		4.72459*	5.66512	1.15371	0.940524	0.106593	2.83256	0.292180*	0.106593	2.83256	0	2.93915	2.98643	0.124583	2.36064	1 NH3
Process Streams		001	002	003	004	005	006	007	008	009	010	100	101	102	103	
Property	Units															Units
Temperature	C	90*	47.3510	48.1539	48.1539	48.1538	59.9094	45.9851*	48.1538	59.9094	20.0000	50.5250	52.0023	52.0023	43.1143	3 C
Pressure	bar	1.0017*	1.0017	138*	138	138	1.08857	4.13685*	138	1.08857	4.13685	1.08857	4.48079	4.48079	1.01273	3 bar
Mole Fraction Vapor	%	100	100	0 0	0	0	100	0	0	100	0	100	0	0	100	)%
Molecular Weight	kg/kmol	28.4291	28.1276	6 18.0406	18.0406	18.0406	28.1276	18.0406	18.0406	28.1276	18.0153	28.0617	18.2661	18.2661	27.8797	/ kg/kmol
Mass Density	kg/m^3	0.943296	1.05800	990.398	990.398	990.398	1.10630	989.418	990.398	1.10630	997.903	1.13587	988.288	988.288	1.07428	3 kg/m^3
Molar Flow	kmol/h	69535.5	71614.1	2549.80	2078.64	235.580	35807.1	653.712	235.580	35807.1	241.983	36042.6	74497.6	3107.77	33955.6	ک kmol/h
Mass Flow	kg/h	1.97683E+06*	2.01433E+06	6 46000	37500	4250	1.00717E+06	11793.3*	4250	1.00717E+06	4359.39	1.01142E+06	1.36078E+06	56766.7	946670	) kg/h
Std Vapor Volumetric Flow	m^3/h	1.64733E+06	1.69657E+06	60406.0	49244.0	5580.99	848285	15486.7	5580.99	848285	5732.69	853866	1.76488E+06	73624.5	804423	3 m^3/h
Std Liquid Volumetric Flow	m^3/h	2307.23	2344.77	46.0591	37.5481	4.25546	1172.39	11.8085	4.25546	1172.39	4.36368	1176.64	1362.85	56.8532	1101.88	3 m^3/h
Specific Gravity		0.981974	0.971558	0.991334	0.991334	0.991335	0.971558	0.990354	0.991335	0.971558	0.998846	0.969281	0.989222	0.989222	0.962995	5
Mass Enthalpy	kJ/kg	-1074.32	-1347.31	-15738.1	-15738.1	-15738.1	-1333.93	-15759.0	-15738.1	-1333.93	-15885.0	-1394.46	-15544.8	-15544.8	-799.333	3 kJ/kg
Dynamic Viscosity	сР	0.0205331	0.0186505	0.568716	0.568716	0.568717	0.0191922	0.576578	0.568717	0.0191922	1.01302	0.0187686	0.534003	0.534003	0.0186351	i cP
Thermal Conductivity	W/(m*℃)	0.0293	0.0266	0.6337	0.6337	0.6337	0.0274	0.6312	0.6337	0.0274	0.5991	0.0268	0.6265	0.6265	0.0266	პ W/(m*℃)
Surface Tension	dyne/cm			68.1959	68.1959	68.1960		68.6194	68.1960		73.8205		67.1773	67.1773		dyne/cm

Process Streams		s Streams	104	105	106	107	108	109	110	111	200	201	202	203	204	Process
			Lean Amine	Cooled Semi-Lean	Rich Amine	Process Water to	Cooled Wash Water to	Cooled Wash	Cooled Wash Water to	Combined Wash Water to	Cooled Flue	Warm Wash	Excess Water to	Off Gas to Atmosphere	Lean Amine	
			(Abs. 1)	Amine (Abs. 1)	(Abs. 1)	Upper Bed (Abs. 1)	Lower Bed (Abs. 1)	Water (Abs. 1)	Upper Bed (Abs. 1)	Upper Bed (Abs. 1)	Gas to Abs. 1	Water (Abs. 2)	Absorbers	(Abs. 2)	(Abs. 2)	
Mole Fraction		tion	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Frac
Oxygen			2.21328E-05	4.39524E-07	0.000211242	1.02194E-08	0.000224200	0.000224200	0.000224200	0.000179362	12.7523	0.000224200	0.000224200	13.5359	2.21328E-0	5 Oxygen
Nitrogen			6.69978E-05	9.04991E-07	0.000641773	8.80283E-09	0.000678671	0.000678671	0.000678671	0.000542939	72.0497	0.000678671	0.000678671	76.4775	6.69978E-0	5 Nitrogen
Water			82.4435	79.0891	78.7778	99.9159	99.3508	99.3508	99.3508	99.4638	10.9931	99.3508	99.3508	8.59823	82.443	5 Water
Carbon Dioxide		xide	3.21583	5.99973	6.53672	0.0569770	0.166604	0.166604	0.166604	0.144679	3.37934	0.166604	0.166604	0.512896	3.2158	3 Carbon Dic
Sulfur Dioxide		ide	1.11990E-08	3.11231E-08	1.04453E-07	7.71650E-08	1.13323E-07	1.13323E-07	1.13323E-07	1.06091E-07	9.63414E-06	1.13323E-07	1.13323E-07	1.01161E-05	1.11990E-0	8 Sulfur Diox
MEA			14.3404	14.9109	14.6843	0.0244640	0.481486	0.481486	0.481486	0.390082	0.000865340	0.481486	0.481486	0.000304138	14.340	4 MEA
Argon			1.51070E-06	2.87289E-08	1.43917E-05	7.85845E-10	1.53030E-05	1.53030E-05	1.53030E-05	1.22426E-05	0.823771	1.53030E-05	1.53030E-05	0.874387	1.51070E-0	5 Argon
NO			7.90396E-10	2.58195E-11	7.54724E-09	7.81744E-13	8.00652E-09	8.00652E-09	8.00652E-09	6.40537E-09	0.000307993	8.00652E-09	8.00652E-09	0.000326915	7.90396E-10	
			1.85318E-09	3.10785E-10	1.74434E-08	0.02385E-09	1.87010E-08	1.87010E-08	1.8/010E-08	0.000710672	7.08950E-05	1.87010E-08	0.000225297	8.16024E-05	1.85318E-0	
Molar Flow		v	0.000211307	0.000300284	0.000324430	0.00203082	6.000235387	6.000235387	0.000235387 kmol/h	6.000719073	kmol/h	kmol/h	0.000235387	0.000408210	kmol/h	Molar Flo
		-	0.00697299	3 31538E-05	0.0809127	3.06583E-08	0 16/333	0 167024	0.00269040	0.00269043	4596.27	0 167024	0.00696763	/596.19	0.0069729	
Nitrogen			0.00037233	6.82645E-05	0.245821	2.64085E-08	0.104355	0.505594	0.00203040	0.00203043	25968.6	0.107024	0.00030703	25968.4	0.0003123	8 Nitrogen
Water			25973.9	5965 78	30174 5	299 748	72821 7	74013.9	1192 21	1491.96	3962.22	74013 9	3087.60	2919 58	25973	9 Water
Carbon Dioxide		xide	1013 15	452 567	2503 78	0 170931	1202117	124 116	1 99925	2 17018	1218.00	124 116	5 17767	174 157	1013 1	5 Carbon Dic
Sulfur Dioxide		ide	3.52827E-06	2.34765E-06	4.00091E-05	2.31495E-07	8.30627E-05	8.44226E-05	1.35987E-06	1.59137E-06	0.00347240	8.44226E-05	3.52181E-06	0.00343497	3.52827E-0	6 Sulfur Diox
MEA			4517.97	1124.75	5624.56	0.0733919	352.918	358.696	5.77783	5.85123	0.311891	358.696	14.9635	0.103272	4517.9	7 MEA
Argon			0.000475948	2.16705E-06	0.00551249	2.35753E-09	0.0112167	0.0114004	0.000183636	0.000183638	296.909	0.0114004	0.000475583	296.903	0.00047594	8 Argon
NO			2.49016E-07	1.94760E-09	2.89085E-06	2.34523E-12	5.86859E-06	5.96466E-06	9.60782E-08	9.60806E-08	0.111009	5.96466E-06	2.48824E-07	0.111006	2.49016E-0	7 NO
NO2			5.83848E-07	2.38955E-08	6.68139E-06	2.04715E-08	1.37518E-05	1.39769E-05	2.25139E-07	2.45611E-07	0.0277152	1.39769E-05	5.83068E-07	0.0277086	5.83848E-0	7 NO2
NH3			0.0665916	0.0231034	0.124275	0.00797046	0.172533	0.175357	0.00282464	0.0107951	0.172581	0.175357	0.00731528	0.138612	0.066591	6 NH3
Mass Fraction		tion	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Frac
Oxygen			2.82981E-05	5.41002E-07	0.000259593	1.81263E-08	0.000392758	0.000392758	0.000392758	0.000314988	14.5415	0.000392758	0.000392758	15.5358	2.82981E-0	5 Oxygen
Nitrogen			7.49915E-05	9.75198E-07	0.000690443	1.36690E-08	0.00104083	0.00104083	0.00104083	0.000834729	71.9258	0.00104083	0.00104083	76.8443	7.49915E-0	5 Nitrogen
Water			59.3448	54.8075	54.5036	99.7757	97.9868	97.9868	97.9868	98.3410	7.05748	97.9868	97.9868	5.55600	59.344	8 Water
Carbon Dioxide		xide	5.65490	10.1569	11.0481	0.138994	0.401409	0.401409	0.401409	0.349445	5.29987	0.401409	0.401409	0.809633	5.6549	0 Carbon Did
Sulfur Dioxide		ide	2.86668E-08	7.66969E-08	2.56989E-07	2.74020E-07	3.97452E-07	3.97452E-07	3.97452E-07	3.73010E-07	2.19944E-05	3.97452E-07	3.97452E-07	2.32454E-05	2.86668E-0	8 Sulfur Diox
MEA			35	35.0354	34.4471	0.0828317	1.61013	1.61013	1.61013	1.30769	0.00188363	1.61013	1.61013	0.000666352	3	5 MEA
Argon			2.41134E-06	4.41465E-08	2.20794E-05	1.74013E-09	3.34678E-05	3.34678E-05	3.34678E-05	5 2.68408E-05	1.17270	3.34678E-05	3.34678E-05	1.25288	2.41134E-0	6 Argon
NO			9.47633E-10	2.98017E-11	8.69717E-09	1.30024E-12	1.31525E-08	1.31525E-08	1.31525E-08	3 1.05483E-08	0.000329334	1.31525E-08	1.31525E-08	0.000351849	9.47633E-1	0 NO
NO2			3.40654E-09	5.60606E-10	3.08191E-08	1.74016E-08	4.72536E-08	4.72536E-08	4.72536E-08	4.13423E-08	0.000126066	4.72536E-08	4.72536E-08	0.000134656	3.40654E-0	9 NO2
NH3			0.000143831	0.000200648	0.000212205	0.00250806	0.000219465	0.000219465	0.000219465	0.000672654	0.000290598	0.000219465	0.000219465	0.000249362	0.00014383	1 NH3
Mass Flow		/	kg/h	kg/n	kg/h	kg/n	kg/h	kg/h	kg/n	kg/h	kg/h	kg/h	kg/h	kg/n	kg/h	Mass Flow
Oxygen			0.223127	0.00106088	2.58911	9.81029E-07	5.25847	5.34456	0.0860897	0.0860907	147075	5.34456	0.222956	147073	0.22312	7 Oxygen
Nitrogen			0.591300	0.00191232	6.88627	7.39792E-07	13.9353	14.1634	0.228143	0.228143	727469	14.1634	0.590846	727462	0.59130	J Nitrogen
vvater			467928	10/4/5	543603	5400.04	1.31190E+06	1.33338E+06	21478.0	26878.0	71380.4	1.33338E+06	55623.9	52597.0	46792	3 Water
Carbon Dioxide		ido	44000.0	0.000150200	0.00256214	1 49204E 05	0.00522121	0.00540942	07.9008 9 711955 05	95.5065	0.222455	0.00540843	0.000225620	7004.55	44000.	5 Carbon Dic
		lue	0.000226035	0.000150599	0.00250514	1.40304E-03	0.00532131	0.00540643	0.71100E-00	0.000101949	0.222400	0.00540643	0.000225620	0.220057	0.00022603	
Argon			0.0190132	8 65694E-05	0 220213	4.40300 9.41788E-08	21557.5	21910.2	0.00733590	0 00733500	19.0513	0.455422	0.0180986	0.30015	27597	
			7 47199E-06	5.84398E-08	8 67430E-05	7.03713E-11	0.000176093	0.433422	2 88293E-06	2 88300E-06	3 33094	0.433422	7 46625E-06	3 33085	7 47199E-0	
NO2			2.68602E-05	1 09932F-06	0.000307381	9 41804F-07	0.000632659	0.000643017	1 03576F-05	1 12995E-05	1 27505	0.000643017	2.68243E-05	1 27475	2.68602F-0	5 NO2
NH3			1.13409	0.393463	2.11647	0.135741	2.93832	2.98643	0.0481051	0.183846	2.93915	2.98643	0.124583	2.36064	1.1340	9 NH3
Process Streams		Process Streams	104	105	106	107	108	109	110	111	200	201	202	203	204	
Property	Units	Property														Units
Temperature	C	Temperature	54.2565	59.2258	53.2964	45.9852	28.0000	28.0000	28.0000	31.6673	50.5250	52.0023	52.0023	43.1143	54.256	5 °C
Pressure	bar	Pressure	3.68912	5.15772	1.08857	4.13685	3.44658	3.44658	3.44658	3.44658	1.08857	4.48079	4.48079	1.01273	3.6891	2 bar
Mole Fraction Vapor	%	Mole Fraction Vapor	0	0	0	0	0	0	C	0	100	C	0	100		0 %
Molecular Weight	kg/kmol	Molecular Weight	25.0273	25.9967	26.0387	18.0406	18.2661	18.2661	18.2661	18.2210	28.0617	18.2661	18.2661	27.8797	25.027	3 kg/kmol
Mass Density	kg/m^3	Mass Density	1086.70	1141.77	1150.90	989.419	997.600	997.600	997.600	996.051	1.13587	988.288	988.288	1.07428	1086.7	0 kg/m^3
Molar Flow	kmol/h	Molar Flow	31505.2	7543.11	38303.3	300	73297.6	74497.6	1200	1500	36042.6	74497.6	3107.77	33955.6	31505.2	2 kmol/h
Mass Flow	kg/h	Mass Flow	788489	196096	997370	5412.18	1.33886E+06	1.36078E+06	21919.3	3 27331.4	1.01142E+06	1.36078E+06	56766.7	946670	78848	9 kg/h
Std Vapor Volumetric Flow	m^3/h	Std Vapor Volumetric Flow	746371	178700	907423	7107.13	1.73645E+06	1.76488E+06	28428.5	35535.7	853866	1.76488E+06	73624.5	804423	74637	1 m^3/h
Std Liquid Volumetric Flow	m^3/h	Std Liquid Volumetric Flow	793.218	199.184	1015.13	5.41913	1340.90	1362.85	21.9527	27.3718	1176.64	1362.85	56.8532	1101.88	793.21	8 m^3/h
Specific Gravity		Specific Gravity	1.08773	1.14285	1.15199	0.990354	0.998543	0.998543	0.998543	0.996992	0.969281	0.989222	0.989222	0.962995	1.0877	3
Mass Enthalpy	kJ/kg	Mass Enthalpy	-11409.8	-11158.3	-11200.2	-15758.9	-15644.5	-15644.5	-15644.5	-15667.1	-1394.46	-15544.8	-15544.8	-799.333	-11409.	8 kJ/kg
Dynamic Viscosity	сР	Dynamic Viscosity	1.74103	2.13328	2.57119	0.576570	0.864393	0.864393	0.864393	0.789799	0.0187686	0.534003	0.534003	0.0186351	1.7410	3 cP
Thermal Conductivity	W/(m*℃)	Thermal Conductivity	0.4180	0.3882	0.3822	0.6312	0.5983	0.5983	0.5983	0.6052	0.0268	0.6265	0.6265	0.0266	0.418	0 W/(m*℃)
Surface Tension	dyne/cm	Surface Tension	59.4102	92.6045	95.3224	68.6193	71.7937	71.7937	71.7937	71.1919		67.1773	67.1773		59.410	2 dyne/cm

Process Streams Strea		Streams	205	206	207	208	209	210	211	300	302	303	304	305	306	Process
			Cooled Semi-Lean	Rich Amine	Process Water to	Cooled Wash Water to	Cooled Wash	Cooled Wash Water to	Combined Wash Water to	Combined Cold	Hot Rich	Stripper Bottoms to	Rich Amine		Filtered Lean	1
			Amine (Abs. 2)	(Abs. 2)	Upper Bed (Abs. 2)	Lower Bed (Abs. 2)	Water (Abs. 2)	Upper Bed (Abs. 2)	Upper Bed (Abs. 2)	Rich Amine	Amine	E-108 Inlet	to E-103	Lean Amine	Amine	4
Mole Fraction		tion	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Frac
Oxygen			4.39524E-07	0.000211242	1.02194E-08	0.000224200	0.000224200	0.000224200	0.000179362	0.000211242	0.000211242	0	0.000211242	2.21328E-05	2.21328E-0	5 Oxygen
Nitrogen Water			9.04991E-07	0.000641773	8.80283E-09	0.000678671	0.000678671	0.000678671	0.000542939	0.000641773	0.000641773	0 80 5725	0.000641773	6.69978E-05	0.09978E-0	5 Nitrogen
Vvalei Carbon Dioxide		vide	79.0691	6 53672	99.9159	99.3508	99.3508	99.3500	99.4030 0 1 <i>44</i> 679	6 53672	6 53672	3 55319	6 53672	3 21583	3 2158	3 Carbon Di
Sulfur Dioxide		ide	3 11231F-08	1.04453E-07	7 71650E-08	1 13323E-07	1 13323E-07	1 13323E-07	1 06091E-07	1 04453E-07	1 04453E-07	0.00019	1.04453E-07	1 11990E-08	1 11990F-08	8 Sulfur Dio
MEA			14.9109	14.6843	0.0244640	0.481486	0.481486	0.481486	0.390082	14.6843	14.6843	15.8731	14.6843	14.3404	14.3404	4 MEA
Argon			2.87289E-08	1.43917E-05	7.85845E-10	1.53030E-05	1.53030E-05	1.53030E-05	1.22426E-05	1.43917E-05	1.43917E-05	0	1.43917E-05	1.51070E-06	1.51070E-06	6 Argon
NŐ			2.58195E-11	7.54724E-09	7.81744E-13	8.00652E-09	8.00652E-09	8.00652E-09	6.40537E-09	7.54724E-09	7.54724E-09	0	7.54724E-09	7.90396E-10	7.90396E-10	0 NO
NO2			3.16785E-10	1.74434E-08	6.82385E-09	1.87616E-08	1.87616E-08	1.87616E-08	1.63741E-08	1.74434E-08	1.74434E-08	0	1.74434E-08	1.85318E-09	1.85318E-09	9 NO2
NH3			0.000306284	0.000324450	0.00265682	0.000235387	0.000235387	0.000235387	0.000719673	0.000324450	0.000324450	0.000208479	0.000324450	0.000211367	0.000211367	7 NH3
Molar Flow		v	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen			3.31538E-05	0.0809127	3.06583E-08	0.164333	0.167024	0.00269040	0.00269043	0.161825	0.129460	0	0.0323651	0.00696763	0.00696763	3 Oxygen
Nitrogen			6.82645E-05	0.245821	2.64085E-08	0.497450	0.505594	0.00814406	0.00814408	0.491641	0.393313	0	0.0983282	0.0210916	0.0210916	6 Nitrogen
Water			5965.78	30174.5	299.748	72821.7	74013.9	1192.21	1491.96	60349.1	48279.3	45679.0	12069.8	25954.0	25954.0	0 Water
Carbon Dioxide		oxide	452.567	2503.78	0.170931	122.117	124.116	1.99925	2.17018	5007.56	4006.05	2014.39	1001.51	1012.37	1012.3	7 Carbon Die
Sulfur Dioxide		ide	2.34765E-06	4.00091E-05	2.31495E-07	8.30627E-05	8.44226E-05	1.35987E-06	5 1.59137E-06	8.00183E-05	6.40146E-05	0	1.60037E-05	3.52556E-06	3.52556E-06	6 Sulfur Dio
			1124.75	5624.56	0.0733919	352.918	358.696	5.77783	5.85123	11249.1	8999.30	8998.86	2249.82	4514.50	4514.50	
NO			2.10/UDE-UD	2 800855-06	2.30/032-09	5 26250E 06	5 964665.06	0.000183636		5 781605.06	4 625355-06	0	1.15634E-06	0.0004/0083	0.00047558 2.48824⊑ ∩	
NO2			2.38955E-08	6 68130F-06	2.34023E-12 2 NA715E-08	1.37518F-05	1.39769E-06	3.00702E-00 2.25130E-07	2 45611E-07	1.33628E-05	1.02000E-06	0	2 67256E-06	5 83400F-07	5 83400F-0	7 NO2
NH3			0.0231034	0.124275	0.00797046	0.172533	0.175357	0.00282464	0.0107951	0.248550	0.198840	0.118192	0.0497101	0.0665405	0.066540	5 NH3
Mass Fraction		tion	%	%	%	%	%	%	%	%	%	%	%	%	%	Mass Frac
Oxygen			5.41002E-07	0.000259593	1.81263E-08	0.000392758	0.000392758	0.000392758	0.000314988	0.000259593	0.000259593	0	0.000259593	2.82981E-05	2.82981E-0	5 Oxygen
Nitrogen			9.75198E-07	0.000690443	1.36690E-08	0.00104083	0.00104083	0.00104083	0.000834729	0.000690443	0.000690443	0	0.000690443	7.49915E-05	7.49915E-0	5 Nitrogen
Water			54.8075	54.5036	99.7757	97.9868	97.9868	97.9868	98.3410	54.5036	54.5036	56.3161	54.5036	59.3448	59.3448	8 Water
Carbon Dioxide		oxide	10.1569	11.0481	0.138994	0.401409	0.401409	0.401409	0.349445	11.0481	11.0481	6.06687	11.0481	5.65490	5.65490	0 Carbon Die
Sulfur Dioxide		ide	7.66969E-08	2.56989E-07	2.74020E-07	3.97452E-07	3.97452E-07	3.97452E-07	3.73010E-07	2.56989E-07	2.56989E-07	0	2.56989E-07	2.86668E-08	2.86668E-08	8 Sulfur Diox
MEA			35.0354	34.4471	0.0828317	1.61013	1.61013	1.61013	1.30769	34.4471	34.4471	37.6169	34.4471	35	35	5 MEA
Argon			4.41465E-08	2.20794E-05	1.74013E-09	3.34678E-05	3.34678E-05	3.34678E-05	2.68408E-05	2.20794E-05	2.20794E-05	0	2.20794E-05	2.41134E-06	2.41134E-06	6 Argon
NO			2.98017E-11	8.69717E-09	1.30024E-12	1.31525E-08	1.31525E-08	1.31525E-08	1.05483E-08	8.69717E-09	8.69717E-09	0	8.69717E-09	9.47633E-10	9.47633E-10	0 NO
NO2			5.60606E-10	3.08191E-08	1.74016E-08	4.72536E-08	4.72536E-08	4.72536E-08	4.13423E-08	3.08191E-08	3.08191E-08	0	3.08191E-08	3.40654E-09	3.40654E-09	9 NO2
NH3 Maaa Elow			0.000200648	0.000212205	0.00250806	0.000219465	0.000219465	0.000219465	0.000672654	0.000212205	0.000212205	0.000137749	0.000212205	0.000143831	0.00014383	1 NH3
			Kg/II	Kg/II	Kg/II	Kg/II	Kg/II	kg/II	kg/li	Kg/II	Kg/II	kg/n	Kg/II	Kg/II	Ky/II	
Oxygen			0.00106088	2.58911	9.81029E-07	0.20847	5.34450	0.0860897	0.0860907	5.17822 13.7725	4.14257	0	2 75451	0.222956	0.222950	6 Nitrogon
Mittogen Water			0.00191232	5/3603	7.39792E-07	1 31100E±06	14.1034 1 33338E±06	0.220143	26878.0	1.08721E±06	869765	822010	2.75451	0.590640	46756	S Millogen
Carbon Dioxide		vide	19917 2	110190	7 52259	5374 29	5462.28	87 9859	95 5085	220380	176304	88652.2	44076 1	44554 1	44554	1 Carbon Di
Sulfur Dioxide		ide	0.000150399	0.00256314	1.48304E-05	0.00532131	0.00540843	8.71185E-05	0.000101949	0.00512627	0.00410102	0	0.00102525	0.000225861	0.00022586	1 Sulfur Dio
MEA			68702.9	343566	4.48300	21557.3	21910.2	352.928	357.411	687131	549705	549678	137426	275759	275759	9 MEA
Argon			8.65694E-05	0.220213	9.41788E-08	0.448086	0.455422	0.00733590	0.00733599	0.440426	0.352341	0	0.0880852	0.0189986	0.0189986	6 Argon
NO			5.84398E-08	8.67430E-05	7.03713E-11	0.000176093	0.000178976	2.88293E-06	2.88300E-06	0.000173486	0.000138789	0	3.46972E-05	7.46625E-06	7.46625E-06	6 NO
NO2			1.09932E-06	0.000307381	9.41804E-07	0.000632659	0.000643017	1.03576E-05	5 1.12995E-05	0.000614762	0.000491809	0	0.000122952	2.68396E-05	2.68396E-0	5 NO2
NH3			0.393463	2.11647	0.135741	2.93832	2.98643	0.0481051	0.183846	4.23294	3.38635	2.01286	0.846588	1.13322	1.13322	2 NH3
Process Streams		Process Streams	205	206	207	208	209	210	211	300	302	303	304	305	306	
Property	Units	Property												-		Units
Temperature	C	Temperature	59.2258	53.2964	45.9852	28.0000	28.0000	28.0000	31.6673	53.4425	117*	126.527	53.4425	54.2565	54.256	5 °C
Pressure	bar	Pressure	5.15772	1.08857	4.13685	3.44658	3.44658	3.44658	3.44658	10.7412	9.70702	5.41280	10.7412	3.68912	3.68912	2 bar
Mole Fraction Vapor	%	Mole Fraction Vapor	0	0	0	0	0	C	0	0	0	0	0	0	(	0%
Molecular Weight	kg/kmol	Molecular Weight	25.9967	26.0387	18.0406	18.2661	18.2661	18.2661	18.2210	26.0387	26.0387	25.7751	26.0387	25.0273	25.0273	3 kg/kmol
Mass Density	kg/m^3	Mass Density	1141.77	1150.90	989.419	997.600	997.600	997.600	996.051	1150.98	1131.18	1065.65	1150.98	1086.70	1086.70	U kg/m^3
Noter Flow	kmol/h	Noos Flow	7543.11	38303.3	300	73297.6	74497.6	1200	1500	76606.7	61285.4	56692.3	15321.3	31481.0	31481.0	U KMOI/h
IVIASS FIOW	kg/n m∆2/h	IVIASS FIOW	196096	997370	5412.18	1.33886E+06	1.36078E+06	21919.3	2/331.4	1.994/4E+06	1.595/9E+06	1.46125E+06	398948	787884	78788	4 κg/n
Std Liquid Volumetric Flow	m^3/h	Std Liquid Volumetric Flow	1/8/00	907423 1015 12	7 107.13 5 41042	1.73043E+06	1262 PE	28428.5	30035.7 27 2710	1.01403E+Ub 2020.25	1.40100E+U0	1.34307 E+06 1/70 52	302909 406.050	792 610	702 611	0 m/3/h
Specific Gravity	nr 9/1	Specific Gravity	1 14295	1 15100	0 000354	0 008513	0 908543	21.9027 0 QQ85/3	0 006002	2030.25	1 13224.20	1470.53	1 15206	1 08773	1 0877	3
Mass Enthalpy	kJ/ka	Mass Enthalpy	-11158.3	-11200.2	-15758 9	-15644 5	-15644 5	-15644 5	-15667 1	-11198 9	-10971 1	-10821 4	-11198 9	-11409.8	-11409 8	8 kJ/ka
Dynamic Viscosity	cP	Dynamic Viscosity	2.13328	2.57119	0.576570	0.864393	0.864393	0.864393	0.789799	2.56530	0.684104	0.514774	2.56530	1.74103	1.74103	3 cP
Thermal Conductivity	W/(m*℃)	Thermal Conductivity	0.3882	0.3822	0.6312	0.5983	0.5983	0.5983	0.6052	0.3823	0.3954	0.4160	0.3823	0.4180	0.4180	0 W/(m*℃)
Surface Tension	dyne/cm	Surface Tension	92.6045	95.3224	68.6193	71.7937	71.7937	71.7937	71.1919	92.8018	86.8476	46.6289	92.8018	59.4102	59.4102	2 dyne/cm
			_													

Process Streams		Streams	307	309	310	311	312	313	314	315	316	317	318	319	320	322	323	324	Process
			Fresh Amine	Rich Amine to E-107	Rich Amine to E-109	Rich Amine to V-101	Flash Gas	Hot Semi- Lean Amine	Stripper Bottoms	Stripper Bottoms to E-107	Reclaimer Feed	Reclaimer Product	Stripper Reboiler Inlet	Stripper Reboiler Discharge	Stripper Overhead	Stripper Reflux	Reflux Purge	Cooled Stripper Overhead	
Mole Fraction		tion	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Fract
Oxygen			0	0.000211242	0.000211242	0.000211242	0.0137370	4.39523E-07	C	0	0	0	0	0	0.00301455	2.26180E-07	2.26180E-07	0.00301455	Oxygen
Nitrogen			0	0.000641773	0.000641773	0.000641773	0.0417620	9.04988E-07	C	0	0	0	0	0	0.00915969	3.64940E-07	3.64940E-07	0.00915969	Nitrogen
Water			0	78.7778	78.7778	78.7778	58.8108	79.0890	80.5735	80.5735	80.5735	95.7761	80.5735	80.5735	61.0520	99.8804	99.8804	61.0520	Water
Carbon Dioxide		xide	0	6.53672	6.53672	6.53672	40.9906	5.99974	3.55319	3.55319	3.55319	4.22361	3.55319	3.55319	38.9179	0.0891793	0.0891793	38.9179	Carbon Dic
Sulfur Dioxide		ide	0	1.04453E-07	1.04453E-07	1.04453E-07	4.80956E-06	3.11230E-08	45.0724	0	0	0	0	0	1.40791E-06	7.17026E-08	7.17026E-08	1.40791E-06	Sulfur Diox
Argon			100	1 42017E 05	14.0843	1 42017E 05	0.140694	14.9109	15.8731	15.8731	15.8731	0	15.8731	15.8731	0.0100055	0.0274058	1 62409E 09	0.0160055	Argon
NO			0	7.54724E-09	7.54724E-09	7.54724E-09	0.000935905 4 90146E-07	2.57266E-08		0	0	0	0	0	1.07676E-07	1.03490E-00	1 19379E-11	1.07676E-07	NO
NO2			0	1 74434E-08	1 74434F-08	1 74434E-08	1 11634E-06	3 16784E-10		0	0	0	0	0	2 48153E-07	2 63050E-10	2 63050E-10	2 48153E-07	NO2
NH3			0	0.000324450	0.000324450	0.000324450	0.00148991	0.000306286	0.000208479	0.000208479	0.000208479	0.000247815	0.000208479	0.000208479	0.00174182	0.00297231	0.00297231	0.00174182	NH3
Molar Flow		v	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flov
Oxygen			0	0.0323651	0.0323651	0.0323651	0.0322988	6.63073E-05	C	0	0	0	0	0	0.161760	7.08805E-07	6.37925E-06	0.161760	Oxygen
Nitrogen			0	0.0983282	0.0983282	0.0983282	0.0981917	0.000136528	C	0	0	0	0	0	0.491506	1.14365E-06	1.02929E-05	0.491506	Nitrogen
Water			0	12069.8	12069.8	12069.8	138.277	11931.5	45679.0	45679.0	0	0	30452.6	30452.6	3276.03	313.007	2817.06	3276.03	Water
Carbon Dioxide		xide	0	1001.51	1001.51	1001.51	96.3780	905.134	2014.39	2014.39	0	0	1342.93	1342.93	2088.32	0.279472	2.51524	2088.32	Carbon Dic
Sulfur Dioxide		ide	0	1.60037E-05	1.60037E-05	1.60037E-05	1.13084E-05	4.69529E-06	C	0	0	0	0	0	7.55477E-05	2.24703E-07	2.02232E-06	7.55477E-05	Sulfur Diox
MEA			0.211460	2249.82	2249.82	2249.82	0.330803	2249.49	8998.86	8998.86	0	0	5999.24	5999.24	0.858848	0.0858846	0.772962	0.858848	MEA
Argon			0	0.00220500	0.00220500	0.00220500	0.00220066	4.33409E-06	C	0	0	0	0	0	0.0110207	5.12373E-08	4.61135E-07	0.0110207	Argon
NO			0	1.15634E-06	1.15634E-06	1.15634E-06	1.15244E-06	3.89518E-09	0	0	0	0	0	0	5.77784E-06	3.74112E-11	3.36701E-10	5.77784E-06	NO
			0	2.67256E-06	2.67256E-06	2.67256E-06	2.62477E-06	4.77908E-08	0 119103	0 119102	0	0	0 0797043	0 0797043	1.33158E-05	8.24351E-10	7.41916E-09	1.33158E-05	
Mass Fraction		tion	%	0.0497101	%	%	0.00350312	0.0402009	%	%	%	%	%	0.0787943	0.0934033	0.00931400	0.0838321	0.0934033	Mass Frac
			<i>,</i> ,	0.000259593	0 000259593	0.000259593	0.0152960	5.41000E-07	,,, ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	,,	,,	,,	<i>,</i> ,,	<i>,</i> ,	0.00342794	4 00963E-07	4 00963E-07	0.00342794	Oxygen
Nitrogen			0	0.000239393	0.000233333	0.000239393	0.0407099	9 75194E-07	0	0	0	0	0	0	0.00911851	4.00305E-07	5.66375E-07	0.00911851	Nitrogen
Water			0	54.5036	54.5036	54.5036	36.8682	54.8074	56.3161	56.3161	56.3161	90.2746	56.3161	56.3161	39.0857	99.6870	99.6870	39.0857	Water
Carbon Dioxide		xide	0	11.0481	11.0481	11.0481	62.7746	10.1569	6.06687	6.06687	6.06687	9.72518	6.06687	6.06687	60.8657	0.217434	0.217434	60.8657	Carbon Dic
Sulfur Dioxide		ide	0	2.56989E-07	2.56989E-07	2.56989E-07	1.07219E-05	7.66968E-08	C	0	0	0	0	0	3.20526E-06	2.54486E-07	2.54486E-07	3.20526E-06	Sulfur Diox
MEA			100	34.4471	34.4471	34.4471	0.299054	35.0354	37.6169	37.6169	37.6169	0	37.6169	37.6169	0.0347429	0.0927428	0.0927428	0.0347429	MEA
Argon			0	2.20794E-05	2.20794E-05	2.20794E-05	0.00130109	4.41464E-08	C	0	0	0	0	0	0.000291564	3.61847E-08	3.61847E-08	0.000291564	Argon
NO			0	8.69717E-09	8.69717E-09	8.69717E-09	5.11786E-07	2.98016E-11	C	0	0	0	0	0	1.14816E-07	1.98452E-11	1.98452E-11	1.14816E-07	NO
NO2			0	3.08191E-08	3.08191E-08	3.08191E-08	1.78715E-06	5.60604E-10	C	0	0	0	0	0	4.05702E-07	6.70449E-10	6.70449E-10	4.05702E-07	NO2
NH3			0	0.000212205	0.000212205	0.000212205	0.000882962	0.000200649	0.000137749	0.000137749	0.000137749	0.000220812	0.000137749	0.000137749	0.00105416	0.00280440	0.00280440	0.00105416	NH3
Mass Flow		/	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flow
Oxygen			0	1.03564	1.03564	1.03564	1.03352	0.00212176	C	0	0	0	0	0	5.17612	2.26809E-05	0.000204128	5.17612	Oxygen
Nitrogen			0	2.75451	2.75451	2.75451	2.75068	0.00382463	0	0	0	0	0	0	13.7688	3.20376E-05	0.000288339	13.7688	Nitrogen
vvater			0	217441	21/441	217441	2491.11	214950	822919	822919	0	0	548613	548613	59018.6	5638.91	50750.2	59018.6	Water
Carbon Dioxide		ide	0	44076.1	44076.1	44076.1	4241.55	39834.5	88652.2	88052.2	0	0	59101.5	59101.5	91905.8	12.2994	0.000129558	91905.8	Carbon Dic
		iue	12 9166	137426	137426	137426	20 2065	137406	549678	549678	0	0	366452	366452	52 4611	1.43953⊑-05 5 24610	47 2149	52 4611	
Argon			12.3100	0.0880852	0.0880852	0.0880852	0.0879121	0 000173138	545070	0	0	0	000432	00432	0 440255	2 04683E-06	1 84214F-05	0 440255	Argon
NO			0	3.46972E-05	3.46972E-05	3.46972E-05	3.45803E-05	1.16879E-07	0	0	0	0	0	0	0.000173370	1.12256E-09	1.01031E-08	0.000173370	NO
NO2			0	0.000122952	0.000122952	0.000122952	0.000120754	2.19864E-06	C	0	0	0	0	0	0.000612601	3.79247E-08	3.41322E-07	0.000612601	NO2
NH3			0	0.846588	0.846588	0.846588	0.0596599	0.786928	2.01286	2.01286	0	0	1.34191	1.34191	1.59177	0.158634	1.42770	1.59177	NH3
Process Streams		Process Streams	307	309	310	311	312	313	314	315	316	317	318	319	320	322	323	324	
Property	Units	Property																	Units
Temperature	C	Temperature	20.0000	108*	112.778*	121.562	114.013	114.066	127.716	127.784			127.716	130.249	105.251	48.7494	48.7494	48.8889*	C
Pressure	bar	Pressure	4.13685	9.70702	8.67281	7.63859	2.39982*	5.84719	2.31016	6.10228	6.10228	6.10228	2.31016	2.31016	1.96543	5.24044	5.24044	1.82753	bar
Mole Fraction Vapor	%	Mole Fraction Vapor	0	0	0	0	100	0	C	0			0	19.7407	100	0	0	41.5715	%
Molecular Weight	kg/kmol	Molecular Weight	61.0831	26.0387	26.0387	26.0387	28.7373	25.9967	25.7751	25.7751	25.7751	19.1132	25.7751	25.7751	28.1399	18.0502	18.0502	28.1399	kg/kmol
Mass Density	kg/m^3	Mass Density	1021.42	1134.88	1132.93	1129.17	2.16649	1123.30	1064.88	1064.90			1064.88	9.06973	1.77565	988.425	988.425	4.65060	kg/m^3
Molar Flow	kmol/h	Molar Flow	0.211460	15321.3	15321.3	15321.3	235.122	15086.2	56692.3	56692.3	0	0	37794.9	37794.9	5365.96	313.382	2820.43	5365.96	kmol/h
Mass Flow	kg/h	Mass Flow	12.9166	398948	398948	398948	6756.79	392191	1.46125E+06	1.46125E+06	0	0	974168	974168	150998	5656.61	50909.5	150998	kg/h
Std Vapor Volumetric Flow	m^3/h	Std Vapor Volumetric Flow	5.00958	362969	362969	362969	5570.16	357399	1.34307E+06	1.34307E+06	0	0	895378	895378	127122	7424.15	66817.3	127122	m^3/h
Std Liquid Volumetric Flow	m^3/h	Std Liquid Volumetric Flow	0.0126621	406.050	406.050	406.050	7.68279	398.367	1470.53	1470.53	0	0	980.352	980.352	171.067	5.66483	50.9835	171.067	m^3/h
Specific Gravity	k 1/k~	Specific Gravity	1.02239	1.13595	1.13401	1.13024	0.992620	1.12436	1.06589	1.06591	40040 5		1.06589	40.400.0	0.971985	0.989360	0.989360	44550 7	k l/ka
wass Enmaipy	кJ/Kg сР	Iviass Enthalpy	-4445.34	-11005.4	-10987.4	-10953.5	-10463.2	-10961.5	-10817.0	-10816.5	-10816.5		-10817.0	-10493.6	-10590.8	-15/41.0	-15/41.0	-11553.7	кJ/Kg cP
Thermal Conductivity	UF \\\/(m*%)		20.01/4	0.708/11	0.730122	0.038957	0.0170053	086660.0	0.506255	0.506241			0.306259		0.0000	0.0480/8	0.0480/8		∪F \\//(m*°C)
Surface Tension	vv/(m°C) dvne/cm		0.2355	0.3950	0.3953	U.3954 86 72/2	0.0247	0.3990	0.4155 //6 //252	0.4159			0.4159 AG 4252		0.0240	0.0334	0.0334		dvne/cm
	uyne/Cm	Sunace TENSION	40.9301	00.0177	0100.10	00.7343		00.0206	40.4253	40.4067			40.4203			00.000	00.000		uyne/cm

Process Streams		s Streams	325	330	332	333	334	400	401	402	403	404	405	406	407	408	409 Process
			Stripper Overhead	Hot Semi-	Cold Rich Amine to Lean /	Process Water to	Lean Amine to		1st Stage	Hot 1st Stage	Cooled 1st Stage	Cold 1st Stage	2nd Stage	Hot 2nd Stage	Cooled 2nd Stage	Cold 2nd Stage	
			Liquid	Lean Amine	Rich Exchanger	Absorbers	E-102 Inlet	CO2	Suction	Discharge	Discharge	Discharge	Suction	Discharge	Discharge	Discharge	Dryer Inlet
Mole Fraction		tion	%	%	%	%	%	%	%	%	%	%	%	%	%	%	% Mole Fract
Oxygen			2.26180E-07	4.39523E-07	0.000211242	1.00791E-08*	0	0.00724650	0.00724656	0.00724656	0.00724656	0.00724656	0.00770337	0.00770337	0.00770337	0.00770337	0.00774011 Oxygen
Nitrogen			3.64940E-07	9.04988E-07	0.000641773	8.68876E-09*	0	0.0220189	0.0220191	0.0220191	0.0220191	0.0220191	0.0234072	0.0234072	0.0234072	0.0234072	0.0235189 Nitrogen
Water			99.8804	79.0890	78.7778	99.9161*	80.5735	6.53896	6.53819	6.53819	6.53819	6.53819	0.658045	0.658045	0.658045	0.658045	0.188672 Water
Carbon Dioxide		xide	0.0891793	5.99974	6.53672	0.0567783*	3.55319	93.4313	93.4320	93.4320	93.4320	93.4320	99.3103	99.3103	99.3103	99.3103	99.7795 Carbon Dic
Sulfur Dioxide		ide	7.17026E-08	3.11230E-08	1.04453E-07	7.57268E-08*	0	3.28386E-06	3.28389E-06	3.28389E-06	3.28389E-06	3.28389E-06	3.47321E-06	3.47321E-06	3.47321E-06	3.47321E-06	3.48396E-06 Sulfur Diox
MEA			0.0274058	14.9109	14.6843	0.0244914*	15.8731	8.54045E-08	8.53776E-08	8.53776E-08	8.53776E-08	8.53776E-08	3.02193E-09	3.02193E-09	3.02193E-09	3.02193E-09	4.87472E-10 MEA
Argon			1.63498E-08	2.87288E-08	1.43917E-05	7.74769E-10*	0	0.000493703	0.000493708	0.000493708	0.000493708	0.000493708	0.000524829	0.000524829	0.000524829	0.000524829	0.000527333 Argon
NO			1.19379E-11	2.58195E-11	7.54724E-09	7.71094E-13*	0	2.58830E-07	2.58832E-07	2.58832E-07	2.58832E-07	2.58832E-07	2.75147E-07	2.75147E-07	2.75147E-07	2.75147E-07	2.76459E-07 NO
NO2			2.63050E-10	3.16784E-10	1.74434E-08	6.70462E-09*	0	5.96178E-07	5.96183E-07	5.96183E-07	5.96183E-07	5.96183E-07	6.13746E-07	6.13746E-07	6.13746E-07	6.13746E-07	6.10352E-07 NO2
NH3			0.00297231	0.000306286	0.000324450	0.00262444*	0.000208479	1.42766E-05	1.42766E-05	1.42766E-05	1.42766E-05	1.42766E-05	1.07273E-05	1.07273E-05	1.07273E-05	1.07273E-05	9.52048E-06 NH3
Molar Flow		v	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h Molar Flow
Oxygen			7.08805E-06	6.63073E-05	0.129460	5.41359E-09*	0	0.161753	0.161753	0.161753	0.161753	0.161753	0.161752	0.161752	0.161752	0.161752	0.161751 Oxygen
Nitrogen			1.14365E-05	0.000136528	0.393313	4.66680E-09*	0	0.491494	0.491494	0.491494	0.491494	0.491494	0.491493	0.491493	0.491493	0.491493	0.491492 Nitrogen
Water			3130.07	11931.5	6 48279.3	53.6658*	45679.0	145.959	145.941	145.941	145.941	145.941	13.8173	13.8173	13.8173	13.8173	3.94282 Water
Carbon Dioxide		xide	2.79472	905.134	4006.05	0.0304961*	2014.39	2085.52	2085.52	2085.52	2085.52	2085.52	2085.27	2085.27	2085.27	2085.27	2085.17 Carbon Did
Sulfur Dioxide		ide	2.24703E-06	4.69529E-06	6.40146E-05	4.06735E-08*	0	7.33006E-05	7.33006E-05	7.33006E-05	7.33006E-05	7.33006E-05	7.29288E-05	7.29288E-05	7.29288E-05	7.29288E-05	7.28071E-05 Sulfur Diox
MEA			0.858846	2249.49	8999.30	0.0131545*	8998.86	1.90635E-06	1.90574E-06	1.90574E-06	1.90574E-06	1.90574E-06	6.34532E-08	6.34532E-08	6.34532E-08	6.34532E-08	1.01871E-08 MEA
Argon			5.12373E-07	4.33409E-06	0.00881999	4.16135E-10*	0	0.0110202	0.0110202	0.0110202	0.0110202	0.0110202	0.0110201	0.0110201	0.0110201	0.0110201	0.0110201 Argon
NO			3.74112E-10	3.89518E-09	4.62535E-06	4.14161E-13*	0	5.77746E-06	5.77746E-06	5.77746E-06	5.77746E-06	5.77746E-06	5.77741E-06	5.77741E-06	5.77741E-06	5.77741E-06	5.77739E-06 NO
NO2			8.24351E-09	4.77908E-08	1.06902E-05	3.60111E-09*	0	1.33076E-05	1.33076E-05	1.33076E-05	1.33076E-05	1.33076E-05	1.28872E-05	1.28872E-05	1.28872E-05	1.28872E-05	1.27550E-05 NO2
NH3			0.0931468	0.0462069	0.198840	0.00140961*	0.118192	0.000318676	0.000318673	0.000318673	0.000318673	0.000318673	0.000225246	0.000225246	0.000225246	0.000225246	0.000198957 NH3
Mass Fraction		tion	%	%	%	%	%	%	%	%	%	%	%	%	%	%	% Mass Frac
Oxygen			4.00963E-07	5.41000E-07	0.000259593	1.78775E-08*	0	0.00548109	0.00548111	0.00548111	0.00548111	0.00548111	0.00562349	0.00562349	0.00562349	0.00562349	0.00563463 Oxygen
Nitrogen			5.66375E-07	9.75194E-07	0.000690443	1.34919E-08*	0	0.0145803	0.0145803	0.0145803	0.0145803	0.0145803	0.0149591	0.0149591	0.0149591	0.0149591	0.0149888 Nitrogen
Water			99.6870	54.8074	54.5036	99.7761*	56.3161	2.78455	2.78420	2.78420	2.78420	2.78420	0.270450	0.270450	0.270450	0.270450	0.0773271 Water
Carbon Dioxide		xide	0.217434	10.1569	11.0481	0.138509*	6.06687	97.1949	97.1953	97.1953	97.1953	97.1953	99.7085	99.7085	99.7085	99.7085	99.9016 Carbon Dic
Sulfur Dioxide		ide	2.54486E-07	7.66968E-08	2.56989E-07	2.68913E-07*	0	4.97282E-06	4.97283E-06	4.97283E-06	4.97283E-06	4.97283E-06	5.07615E-06	5.07615E-06	5.07615E-06	5.07615E-06	5.07774E-06 Sulfur Diox
MEA			0.0927428	35.0354	34.4471	0.0829247*	37.6169	1.23312E-07	1.23273E-07	1.23273E-07	1.23273E-07	1.23273E-07	4.21112E-09	4.21112E-09	4.21112E-09	4.21112E-09	6.77415E-10 MEA
Argon			3.61847E-08	4.41464E-08	2.20794E-05	1.71561E-09*	0	0.000466193	0.000466195	0.000466195	0.000466195	0.000466195	0.000478304	0.000478304	0.000478304	0.000478304	0.000479252 Argon
NO			1.98452E-11	2.98016E-11	8.69717E-09	1.28253E-12*	0	1.83581E-07	1.83582E-07	1.83582E-07	1.83582E-07	1.83582E-07	1.88350E-07	1.88350E-07	1.88350E-07	1.88350E-07	1.88723E-07 NO
NO2			6.70449E-10	5.60604E-10	3.08191E-08	1.70975E-08*	0	6.48322E-07	6.48324E-07	6.48324E-07	6.48324E-07	6.48324E-07	6.44155E-07	6.44155E-07	6.44155E-07	6.44155E-07	6.38815E-07 NO2
NH3			0.00280440	0.000200649	0.000212205	0.00247750*	0.000137749	5.74723E-06	5.74720E-06	5.74720E-06	5.74720E-06	5.74720E-06	4.16782E-06	4.16782E-06	4.16782E-06	4.16782E-06	3.68868E-06 NH3
Mass Flow		/	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h Mass Flow
Oxygen			0.000226809	0.00212176	6 4.14257	1.73228E-07*	0	5.17589	5.17589	5.17589	5.17589	5.17589	5.17586	5.17586	5.17586	5.17586	5.17585 Oxygen
Nitrogen			0.000320376	0.00382463	11.0180	1.30733E-07*	0	13.7684	13.7684	13.7684	13.7684	13.7684	13.7684	13.7684	13.7684	13.7684	13.7684 Nitrogen
Water			56389.1	214950	869765	966.804*	822919	2629.50	2629.16	2629.16	2629.16	2629.16	248.923	248.923	248.923	248.923	71.0310 Water
Carbon Dioxide		xide	122.994	39834.5	5 176304	1.34212*	88652.2	91782.9	91782.9	91782.9	91782.9	91782.9	91771.8	91771.8	91771.8	91771.8	91767.4 Carbon Did
Sulfur Dioxide		ide	0.000143953	0.000300798	0.00410102	2.60570E-06*	0	0.00469592	0.00469592	0.00469592	0.00469592	0.00469592	0.00467210	0.00467210	0.00467210	0.00467210	0.00466430 Sulfur Diox
MEA			52.4610	137406	549705	0.803518*	549678	0.000116446	0.000116408	0.000116408	0.000116408	0.000116408	3.87591E-06	3.87591E-06	3.87591E-06	3.87591E-06	6.22259E-07 MEA
Argon			2.04683E-05	0.000173138	0.352341	1.66238E-08*	0	0.440235	0.440235	0.440235	0.440235	0.440235	0.440232	0.440232	0.440232	0.440232	0.440230 Argon
NO			1.12256E-08	1.16879E-07	0.000138789	1.24274E-11*	0	0.000173359	0.000173359	0.000173359	0.000173359	0.000173359	0.000173358	0.000173358	0.000173358	0.000173358	0.000173357 NO
NO2			3.79247E-07	2.19864E-06	0.000491809	1.65671E-07*	0	0.000612222	0.000612221	0.000612221	0.000612221	0.000612221	0.000592880	0.000592880	0.000592880	0.000592880	0.000586801 NO2
NH3			1.58634	0.786928	3.38635	0.0240064*	2.01286	0.00542721	0.00542717	0.00542717	0.00542717	0.00542717	0.00383606	0.00383606	0.00383606	0.00383606	0.00338834 NH3
Process Streams		Process Streams	325	330	332	333	334	400	401	402	403	404	405	406	407	408	409
Property	Units	Property															Units
Temperature	C	Temperature	48.6934	114.013	53.4425	45.9852*	58.8405	48.7032	48.7032	176.667*	129.444*	26*	25.8867	176.667*	129.444*	26*	25.9261 °C
Pressure	bar	Pressure	1.79306	2.39982	10.7412	4.13685*	4.72333	1.79306	1.79306	6.03537	5.75958	5.41484	5.34589	23.1069	22.8311	22.4864	22.4174 bar
Mole Fraction Vapor	%	Mole Fraction Vapor	0	C	0	0	0	99.9992	100	100	100	94.0626	100	100	100	99.5254	100 %
Molecular Weight	kg/kmol	Molecular Weight	18.0502	25.9967	26.0387	18.0406	25.7751	42.3053	42.3055	42.3055	42.3055	42.3055	43.8338	43.8338	43.8338	43.8338	43.9557 kg/kmol
Mass Density	kg/m^3	Mass Density	988.400	1123.28	1150.98	989.418	1098.16	2.85803	2.85802	6.88482	7.37019	10.0900	9.71118	27.9160	31.3450	45.7879	45.5558 kg/m^3
Molar Flow	kmol/h	Molar Flow	3133.82	15086.2	61285.4	53.7108	56692.3	2232.15	2232.13	2232.13	2232.13	2232.13	2099.75	2099.75	2099.75	2099.75	2089.78 kmol/h
Mass Flow	kg/h	Mass Flow	56566.1	392191	1.59579E+06	968.973*	1.46125E+06	94431.7	94431.4	94431.4	94431.4	94431.4	92040.1	92040.1	92040.1	92040.1	91857.8 kg/h
Std Vapor Volumetric Flow	m^3/h	Std Vapor Volumetric Flow	74241.5	357399	1.45188E+06	1272.43	1.34307E+06	52880.6	52880.1	52880.1	52880.1	52880.1	49744.1	49744.1	49744.1	49744.1	49507.8 m^3/h
Std Liquid Volumetric Flow	m^3/h	Std Liquid Volumetric Flow	56.6483	398.367	1624.20	0.970216	1470.53	114.418	114.418	114.418	114.418	114.418	112.022	112.022	112.022	112.022	111.838 m^3/h
Specific Gravity		Specific Gravity	0.989334	1.12434	1.15206	0.990354	1.09920		1.46128	1.46128	1.46128		1.51407	1.51407	1.51407		1.51828
Mass Enthalpy	kJ/kg	Mass Enthalpy	-15741.5	-10962.0	-11198.9	-15759.0	-11070.2	-9045.10	-9045.08	-8924.50	-8971.66	-9130.17	-8956.03	-8823.37	-8871.29	-8978.41	-8965.07 kJ/kg
Dynamic Viscosity	cP	Dynamic Viscosity	0.548226	0.699454	2.56530	0.576577	1.83764		0.0161455	0.0216019	0.0197044		0.0152834	0.0220095	0.0201805		0.0159385 cP
Thermal Conductivity	W/(m*℃)	Thermal Conductivity	0.6334	0.3990	0.3823	0.6312	0.4060		0.0187	0.0287	0.0251		0.0172	0.0296	0.0261		0.0189 W/(m*℃ )
Surface Tension	dyne/cm	Surface Tension	68.0675	87.4090	92.8018	68.6194	57.9601										dyne/cm

Process Streams		Streams	410	411	412	413	414	415	416	417	501	502	503	504	505	506	509	510	511	Process
			3rd Stage Suction	Hot 3rd Stage Discharge	Cooled 3rd Stage Discharge	Cold 3rd Stage Discharge	CO2 Product	Inter-stage Liquid	Liquefied CO2	Dryer Water	SCW Supply to E-101	SCW Return From E-101	SCW Supply to E-104	SCW Return From E-104	SCW Supply to E-102	SCW Return From E-102	SCW Supply to E-111	SCW Return From E-111	LP Steam from E-112	
Mole Fraction		tion	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	Mole Frac
Oxygen			0.00775389	0.00775389	0.00775389	0.00775389	0.00775389	9.70204E-07	0.00775389	0	0*	* 0	0*	0	0*	0	0*	0	(	) Oxygen
Nitrogen			0.0235607	0.0235607	0.0235607	0.0235607	0.0235607	1.46335E-06	0.0235607	0	0*	• 0	0*	0	0*	0	0*	0	(	) Nitrogen
Water			0.0110002	0.0110002	0.0110002	0.0110002	0.0110002	99.7532	0.0110002	100	100*	100	100*	100	100*	100	100*	100	100	Water
Carbon Dioxide		oxide	99.9571	99.9571	99.9571	99.9571	99.9571	0.246741	99.9571	0	0*	· 0	0*	0	0*	0	0*	0	(	Carbon Di
Sulfur Dioxide		ide	3.49016E-06	3.49016E-06	3.49016E-06	3.49016E-06	3.49016E-06	3.46852E-07	3.49016E-06	0	0*	· 0	0*	0	0*	0	0*	0	(	Sulfur Diox
MEA			4.88340E-10	4.88340E-10	4.88340E-10	4.88340E-10	4.88340E-10	1.33156E-06	4.88340E-10	0	0*	• 0	0*	0	0*	0	0*	0	(	MEA
Argon			0.000528271	0.000528271	0.000528271	0.000528271	0.000528271	7.16324E-08	0.000528271	0	0*	• 0	0*	0	0*	0	0*	0	(	) Argon
NO			2.76951E-07	2.76951E-07	2.76951E-07	2.76951E-07	2.76951E-07	5.14283E-11	2.76951E-07	. 0	0*	• 0	0*	0	0*	0	0*	0	(	NO
NO2			6.11439E-07	6.11439E-07	6.11439E-07	6.11439E-07	6.11439E-07	3.88307E-07	6.11439E-07	0	0*	· 0	0*	0	0*	0	0*	0	(	NO2
NH3			9.53742E-06	9.53742E-06	9.53742E-06	9.53742E-06	9.53742E-06	8.40604E-05	9.53742E-06	0	0*	• 0	0*	0	0*	0	0*	0	(	NH3
Molar Flow		v	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	Molar Flow
Oxygen			0.161751	0.161751	0.161751	0.161751	0.161751	1.38105E-06	0.161751	0	0*	· 0	0*	0	0*	0	0*	0	(	) Oxygen
Nitrogen			0.491492	0.491492	0.491492	0.491492	0.491492	2.08303E-06	0.491492	0	0*	· 0	0*	0	0*	0	0*	0	(	) Nitrogen
Water			0.229472	0.229472	0.229472	0.229472	0.229472	141.995	0.229472	3.71335	246262*	* 246262	246262*	246262	30912.8*	30912.8	199161*	199161	106.472	2 Water
Carbon Dioxide		oxide	2085.17	2085.17	2085.17	2085.17	2085.17	0.351227	2085.17	0	0*	· 0	0*	0	0*	0	0*	0	(	Carbon Di
Sulfur Dioxide		ide	7.28071E-05	7.28071E-05	7.28071E-05	7.28071E-05	7.28071E-05	4.93732E-07	7.28071E-05	0	0*	· 0	0*	0	0*	0	0*	0	(	) Sulfur Diox
MEA			1.01871E-08	1.01871E-08	1.01871E-08	1.01871E-08	1.01871E-08	1.89543E-06	1.01871E-08	0	0*	0	0*	0	0*	0	0*	0	(	MEA
Argon			0.0110201	0.0110201	0.0110201	0.0110201	0.0110201	1.01966E-07	0.0110201	0	0*	0	0*	0	0*	0	0*	0	(	) Argon
NO			5.77739E-06	5.77739E-06	5.77739E-06	5.77739E-06	5.77739E-06	7.32066E-11	5.77739E-06	0	0*	0	0*	0	0*	0	0*	0	(	NO
NO2			1.27550E-05	1.27550E-05	1.27550E-05	1.27550E-05	1.27550E-05	5.52743E-07	1.27550E-05	0	0*	0	0*	0	0*	0	0*	0	(	NO2
NH3 Maga Frantian		tion	0.000198957	0.000198957	0.000198957	0.000198957	0.000198957	0.000119657	0.000198957	0	0*	0	U^	0	U^	0	U^	0		Maga Fra
		tion	%	70	%	%	%	%	%	%	%	%	%	%	70	%	%	%	%	
Oxygen			0.00563873	0.00563873	0.00563873	0.00563873	0.00563873	1.71717E-06	0.00563873	0	0*	0	0*	0	0*	0	0*	0	(	Oxygen
Nitrogen			0.0149997	0.0149997	0.0149997	0.0149997	0.0149997	2.26741E-06	0.0149997	100	100	0	0	0	0	0	0	0	100	Nitrogen
water Corbon Diovido		vida	0.00450372	0.00450372	0.00450372	0.00450372	0.00450372	99.3993	0.00450372	100	100	100	100*	100	100*	100	100*	100	100	Vvater
Carbon Dioxide		ido	5 09144	5 09144	5 09144	5 09144	5 09144		5 09144	. 0	0*	· 0	0	0	0*	0	0*	0		
		lue	6 77909E-10	6 77909E-10	6.77909E-10	6 77909E-10	6 77909E-10	1.22900E-00	6 77909E-10		0*		0*	0	0*	0	0*	0		
			0.000479601	0.000479601	0.000479601	0.000479601	0.000479601	1 58278E-07	0.000479601	0	0*	. 0	0*	0	0*	0	0*	0		
NO			1 88861E-07	1 88861E-07	1 88861E-07	1 88861E-07	1 88861E-07	8 53547E-11	1 88861E-07	· 0	0*	• 0	0*	0	0*	0	0*	0	(	
NO2			6.39280E-07	6.39280E-07	6.39280E-07	6.39280E-07	6.39280E-07	9.88100E-07	6.39280E-07	· 0	0*	* 0	0*	0	0*	0	0*	0	(	NO2
NH3			3.69137E-06	3.69137E-06	3.69137E-06	3.69137E-06	3.69137E-06	7.91836E-05	3.69137E-06	0	0*	. 0	0*	0	0*	0	0*	0	(	NH3
Mass Flow		/	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	Mass Flov
Oxvaen			5.17585	5.17585	5.17585	5.17585	5.17585	4.41921E-05	5.17585	0	0*	· 0	0*	0	0*	0	0*	0	(	) Oxvaen
Nitrogen			13.7684	13.7684	13.7684	13.7684	13.7684	5.83528E-05	13.7684	. 0	0*	. 0	0*	0	0*	0	0*	0	(	) Nitrogen
Water			4.13400	4.13400	4.13400	4.13400	4.13400	2558.09	4.13400	66.8970	4.43647E+06*	4.43647E+06	4.43647E+06*	4.43647E+06	556903*	556903	3.58794E+06*	3.58794E+06	1918.12	2 Water
Carbon Dioxide		xide	91767.4	91767.4	91767.4	91767.4	91767.4	15.4573	91767.4	. 0	0*	· 0	0*	0	0*	0	0*	0	0	Carbon Di
Sulfur Dioxide		ide	0.00466430	0.00466430	0.00466430	0.00466430	0.00466430	3.16304E-05	0.00466430	0	0*	· 0	0*	0	0*	0	0*	0	(	) Sulfur Diox
MEA			6.22259E-07	6.22259E-07	6.22259E-07	6.22259E-07	6.22259E-07	0.000115779	6.22259E-07	. 0	0*	· 0	0*	0	0*	0	0*	0	(	MEA
Argon			0.440230	0.440230	0.440230	0.440230	0.440230	4.07335E-06	0.440230	0	0*	• 0	0*	0	0*	0	0*	0	C	) Argon
NO			0.000173357	0.000173357	0.000173357	0.000173357	0.000173357	2.19664E-09	0.000173357	0	0*	• 0	0*	0	0*	0	0*	0	C	NO
NO2			0.000586801	0.000586801	0.000586801	0.000586801	0.000586801	2.54292E-05	0.000586801	0	0*	· 0	0*	0	0*	0	0*	0	(	NO2
NH3			0.00338834	0.00338834	0.00338834	0.00338834	0.00338834	0.00203783	0.00338834	. 0	0*	• 0	0*	0	0*	0	0*	0	(	NH3
Process Streams		Process Streams	410	411	412	413	414	415	416	417	501	502	503	504	505	506	509	510	511	
Property	Units	Property																		Units
Temperature	C	Temperature	25.9261	176.667*	129.444*	28*	48.2035	25.8867	27.9889	25.9261	11*	° 21	11*	21	11*	21*	11*	21*	125.835	3 C
Pressure	bar	Pressure	22.4174	93.5800	93.3042	92.9595	201.000*	5.34589	92.8905	22.4174	1.9999*	0.965686	1.9999*	0.965686	1.9999*	1.31042	1.9999*	0.965686	2.37913	3 bar
Mole Fraction Vapor	%	Mole Fraction Vapor	100	100	100	0	100	0	0	0	0	0 0	0	0	0	0	0	0	100	* %
Molecular Weight	kg/kmol	Molecular Weight	44.0019	44.0019	44.0019	44.0019	44.0019	18.0794	44.0019	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	3 kg/kmol
Mass Density	kg/m^3	Mass Density	45.5929	123.164	148.585	722.616?	778.522	997.558	722.508	996.481	1000.00	997.597	1000.00	997.597	1000.00	997.602	1000.00	997.597	1.31446	6 kg/m^3
Molar Flow	kmol/h	Molar Flow	2086.07	2086.07	2086.07	2086.07	2086.07	142.347	2086.07	3.71335	246262	246262	246262	246262	30912.8	30912.8	199161	199161	106.472	2 kmol/h
Mass Flow	kg/h	Mass Flow	91790.9	91790.9	91790.9	91790.9	91790.9	2573.55	91790.9	66.8970	4.43647E+06	4.43647E+06	4.43647E+06	4.43647E+06	556903	556903	3.58794E+06	3.58794E+06	1918.12	2 kg/h
Std Vapor Volumetric Flow	m^3/h	Std Vapor Volumetric Flow	49419.8	49419.8	49419.8	49419.8	49419.8	3372.26	49419.8	87.9708	5.83405E+06	5.83405E+06	5.83405E+06	5.83405E+06	732339	732339	4.71821E+06	4.71821E+06	2522.36	5 m^3/h
Sta Liquid Volumetric Flow	m^3/h	Sta Liquid Volumetric Flow	111.771	111.771	111.771	111.771	111.771	2.57943	111.771	0.0669628	4440.84	4440.84	4440.84	4440.84	557.451	557.451	3591.47	3591.47	1.92000	/m/3/h
Specific Gravity	1/1/1-	Specific Gravity	1.51988	1.51988	1.51988	0.723299?	1.51988	0.998500	0.723191?	0.997422	1.00095	0.998540	1.00095	0.998540	1.00095	0.998544	1.00095	0.998540	0.622268	5 1  c  /!-~
	кJ/Kg оР		-8961.75	-8844.37	-8902.59	-9167.59	-9147.64	-15823.4	-9167.59	-15861.2	-15921.7	-15881.2	-15921.7	-15881.2	-15921.7	-15881.2	-15921.7	-15881.2	-13240.4	+ KJ/Kg
			0.0159403	0.0242103	0.0230636	0.0609529	0.0692256	0.865915	0.0609668	0.879295	1.29092	0.987115	1.29092	0.987115	1.29092	0.987185	1.29092	0.987115	0.0106144	+ CP
Surface Tonsion	dvno/cm	Surface Tension	0.0189	0.0342	0.0319	0.1073	0.0909	0.6021	0.1073	0.60/6	U.5854	0.6006	U.5854	0.6006	U.5854	0.6006	U.5854	0.6006	0.0270	dvno/cm
	uyne/Cm					0.0000		12.3392	0.0000	12.0310	/ 0.04/ 5	/ 3.0192	10.04/5	13.0192	/ 5.64/5	13.0192	10.04/5	13.0192		uyne/cm

Process Streams		s Streams	512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	527 Pr	ocess Streams
			LP Condensate from E-109	LP Steam from E-114	LP Steam to E-109	SCW Supply to E-113	SCW Return From E-113	SCW Supply to E-115	SCW Return From E-115	Condenstate to E-112	Condenstate	Condenstate to E-116	SCW Supply to E-117	SCW Return From E-117	LP Steam from E-116	LP Steam to E-110	LP Condensate from E-110	Vent Steam	
Mole Fraction		tion	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	% Mc	ble Fraction
Oxygen			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Ox	ygen
Nitrogen			0	0	0	0*	0	0*	0	0*	• 0*	0*	0*	0	0	0*	0	0 Nit	rogen
Water			100	100	100	100*	100	100*	100	100*	* 100*	100*	100*	100	100	100*	100	100 Wa	ater
Carbon Dioxide		oxide	0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Ca	rbon Dioxide
Sulfur Dioxide		ide	0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Su	lfur Dioxide
MEA			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 ME	EA
Argon			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Arg	gon
NO			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 NC	)
NO2			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 NC	02
NH3			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 NH	13
Molar Flow		v	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h	kmol/h Mo	olar Flow
Oxygen			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Ox	ygen
Nitrogen			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Nit	rogen
Water			339.640	105.477	339.731	20217.0*	20217.0	13316.7*	13316.7	106.472*	105.477*	127.783*	32854.4*	32854.4	127.783	8076.48*	8076.48	224.436 Wa	ater
Carbon Dioxide		oxide	0	0	0	0*	0	0*	0	0*	• 0*	0*	0*	0	0	0*	0	0 Ca	rbon Dioxide
Sulfur Dioxide		ide	0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Su	lfur Dioxide
MEA			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 ME	EA
Argon			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Arg	gon
NO			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 NC	)
NO2			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 NC	02
NH3			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 NH	13
Mass Fraction		tion	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	% Ma	ass Fraction
Oxygen			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Ox	ygen
Nitrogen			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Nit	rogen
Water			100	100	100	100*	100	100*	100	100*	* 100*	100*	100*	100	100	100*	100	100 Wa	ater
Carbon Dioxide		oxide	0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Ca	rbon Dioxide
Sulfur Dioxide		ide	0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Su	lfur Dioxide
MEA			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 ME	ĒA
Argon			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Arg	gon
NO			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 NC	)
NO2			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 NC	02
NH3			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 NF	13
Mass Flow		<u> </u>	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h Ma	ass Flow
Oxygen			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Ox	ygen
Nitrogen			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 Nit	rogen
Water			6118.71	1900.19	6120.36	364215*	364215	239905*	239905	1918.12*	* 1900.19*	2302.05*	591880*	591880	2302.05	145500*	145500	4043.28 Wa	ater
Carbon Dioxide		xide	0	0	0	0*	0	0*	0	0*	• 0*	0*	0*	0	0	0*	0	0 Ca	rbon Dioxide
Sulfur Dioxide		ide	0	0	0	0*	0	0*	0	0*	• 0*	0*	0*	0	0	0*	0	0 Su	lfur Dioxide
MEA			0	0	0	0*	0	0*	0	0*	* 0*	0*	0*	0	0	0*	0	0 ME	EA
Argon			0	0	0	0*	0	0*	0	0*	• 0*	0*	0*	0	0	0*	0	0 Arg	gon
NO			0	0	0	0*	0	0*	0	0*	• 0*	0*	0*	0	0	0*	0	0 NC	)
NO2			0	0	0	0*	0	0*	0	0*	0*	0*	0*	0	0	0*	0	0 NC	02
		Dragona Stragman	640	0	0	0*	640	0*	0	0*	0*	0*	0*	0	0	0*	0	0 NF	
Frocess Streams	11. 2	Process Streams	512	513	514	515	516	517	518	519	520	521	522	523	524	525	526	<b>52</b> /	Process Streams
Property	Units	Property												_				Un	Its Property
l emperature	C.	l emperature	125.835	125.835	125.835	16*	26*	16*	26*	98.8889*	98.8889*	98.8889*	16*	26*	125.835	135*	133.594	146.435 ℃	T emperature
Pressure	bar	Pressure	2.37913	2.37913	2.37913	1.9999*	1.31042	1.9999*	1.31042	2.37913*	2.37913*	2.37913*	1.9999*	1.31042	2.37913	2.9999*	2.9999	2.3499* ba	r Pressure
Mole Fraction Vapor	%	Mole Fraction Vapor	0*	100	100	0	0	0	0	0	0	0	0	0	100	100	0*	100 %	Mole Fraction Vapor
Molecular Weight	kg/kmol	Molecular Weight	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153	18.0153 kg	Molecular Weight
wass Density	кg/m^3	Malar Flow	938.857	1.31446	1.31446	998.879	996.185	998.879	996.185	959.505	959.505	959.505	998.879	996.185	1.31446	1.62556	932.265	1.23159 kg/	mrv3 Mass Density
IVIOIAT Flow	kmol/h	Notar Flow	339.640	105.477	339.731	20217.0	20217.0	13316.7	13316.7	106.472	105.477	127.783	32854.4	32854.4	127.783	8076.48	8076.48	224.436 km	
Mass Flow	kg/h	Mass Flow	6118.71	1900.19	6120.36	364215	364215	239905	239905	1918.12	1900.19	2302.05	591880	591880	2302.05	145500*	145500	4043.28 kg	m Mass Flow
Std Vapor Volumetric Flow	m^3/h	Std Vapor Volumetric Flow	8046.22	2498.79	8048.39	478950	478950	315480	315480	2522.36	2498.79	3027.24	778334	778334	3027.24	191335	191335	5317.00 m ²	3/n Std Vapor Volumetric Flow
Sta Liquia Volumetric Flow	m^3/h	Sta Liquid Volumetric Flow	6.12473	1.90206	6.12638	364.574	364.574	240.141	240.141	1.92000	1.90206	2.30431	592.463	592.463	2.30431	145.643	145.643	4.04726 m ²	S/n Sta Liquid Volumetric Flow
Specific Gravity	1, 1/1	Specific Gravity	0.939745	0.622268	0.622268	0.999823	0.997127	0.999823	0.997127	0.960412	0.960412	0.960412	0.999823	0.997127	0.622268	0.622268	0.933146	0.622268	Specific Gravity
Iviass Enthalpy	кJ/кg	Iviass Enthalpy	-15448.2	-13240.4	-13240.4	-15904.0	-15862.9	-15904.0	-15862.9	-15561.8	-15561.8	-15561.8	-15904.0	-15862.9	-13240.4	-13224.7	-15390.4	-13200.2 kJ/	
			0.219521	0.0106144	0.0106144	1.12405	0.8/4153	1.12405	0.8/4153	0.279294	0.279294	0.279294	1.12405	0.874153	0.0106144	0.0110023	0.206890	0.0114855 CP	
Surface Tension	w/(m^C)	Surface Tension	0.6847	0.0270	0.0270	0.5931	0.6077	0.5931	0.6077	0.6758	0.6758	0.6758	0.5931	0.6077	0.0270	0.0278	0.6856	0.0287 W/	(m C) I nermal Conductivity
Surface Tension	ayne/cm	Surface Tension	53.1489			74.6291	72.6168	/4.6291	/2.6168	JØ.4280	58.4280	JS.4280	74.6291	72.6168			51.6045	dyi	Surface Lension

6.0-CO₂ Drying and Compression

# 6.0 CO₂ Drying and Compression ____

The  $CO_2$  drying and compression process for the Kårstø  $CO_2$  Carbon Capture and Compression (CCC) Plant is described in this section.

## 6.1 Drying

The CO₂ leaving the stripper is saturated with water. The compression and cooling cycles of the first two stages of the compression system remove much of the water carried over from the stripper. However, to meet requirement for a final CO₂ water content of less than 50 ppmw, the CO₂ stream must be dried using desiccant dryers. The dryers are provided as a vendor package, with the vendor supplying the vessels, valving, instrumentation, and other associated equipment. The two vessels are operated in parallel—one in regeneration mode and one in operation. The dryers are located between the second and third compression stages. The regeneration method is extremely efficient because the dryer vessel is not depressurized and virtually no CO₂ is vented or recycled.

## 6.2 Compressor and Cooling_

The  $CO_2$  compressor consists of three compression stages in series. This arrangement provides the most cost-effective means of compression. Cooling the gas between compression stages lowers the electric power consumption. The  $CO_2$  is compressed to about 5 bara in the first stage and then cooled; in the second stage, it is compressed to about 22 bara and recooled; in the third stage, it is compressed to about 93 bara and cooled again. The inter-stage cooling is achieved via three low-pressure-(LP)-steam-generating heat exchangers and three seawater-cooled heat exchangers. The LP steam generated, which is a form of heat recovery, is used to heat the amine. The three stages of compression take the  $CO_2$ -rich stream from 1.8 bara to 93 bara.

#### 6.3 Compressor Driver_

The CO₂ gas compressor is driven by an induction motor coupled through two gear boxes – one to meet the speed requirement of the LP compression stage and the second to meet the speed requirement of the medium/high pressure compression stage. The motor is powered by a variable frequency drive (VFD) that permits the motor to be softstarted to avoid significant electrical power system inrush loading. The CO₂ compressor/motor is expected to run at 100% speed under most operating conditions. As directed by Gassnova/Fichtner, no alternate driver types or systems were studied.

#### 6.4 Drying and Compression Performance _____

The desiccant dryers remove more than 92% of the inlet water to achieve the  $CO_2$  water specification of < 50 ppmvw.

The compression system performance is enhanced by generating LP steam with inter-stage heat exchangers.

### 6.5 Liquids Storage and Handling _____

The desiccant drying process selected precludes the need to store and handle any liquids for drying.

Lubrication oil is required for the compressor and must be stored in a suitable location.

#### 6.6 Waste Discharge _____

Water generated in the regeneration cycle of the desiccant dryers is shown as a discharged stream. Vendor information shows that the water released from the regeneration operations can be recovered. A small amount of  $CO_2$  remains dissolved in this water.

Each dryer is charged with a total of 3,835 kg of activated alumina desiccant with a running lifetime of 3 to 5 years.

#### 6.7 Conclusions and Recommendations

The compressor pressurizes the CO₂ from 1.8 bara to over 93 bara. The compression energy heat is recovered via LP steam generators located in the discharge stream of each stage. The recovery of process water generated during the regeneration of the desiccant dryers is to be specified with the engineering, procurement, construction, and installation (EPCI) design.

7.0-Mechanical Utility Systems
# 7.0 Mechanical Utility Systems _____

# 7.1 Utilities—Consumptions and Equipment Handling _____

The mechanical utilities for the Kårstø  $CO_2$  Capture and Compression (CCC) Plant are as follows:

- Steam and condensate
- Cooling (seawater)
- Potable water
- Fire protection water
- Fuel gas (natural)
- Compressed air
- Inerting gases (nitrogen)
- Desalination water

The requirements for these utilities are summarized in Table 7.1-1. The estimated demands are based on using 35% monoethanolamine (MEA) solvent, the heat and mass balances in document 10112936-PB-P-HMB-0001 (25474-000-M4-CN-00001), and other design factors. These utilities support the plant's main amine process for capturing CO₂.

Commodity	Demand	Units	Comments
LP Steam	200	tonnes/hr	See 7.2
HP Steam	12	tonnes/hr	See 7.2; during reclaimer operation
LP Condensate	153	tonnes/hr	See 7.2, returned to CCPP
Cooling Water	17,340	m³/hr	See 7.3
(Seawater)			
Potable Water	35	m³/hr	See 7.4; intermittent
Fire Water	340	m³/hr	See 7.5; intermittent
Fuel Gas	1500	kg/hr	Continuous
Compressed Air			See 7.7
Instrument Air	185	Nm³/hr	Continuous
			(400 Nm ³ /hr intermittent)
Plant Air	85	Nm³/hr	Intermittent
			(maintenance tools)
Inerting Gases	85	Nm³/hr	See 7.8; intermittent
Desalination Water	10	m³/hr	See 7.9; intermittent

 Table 7.1-1. Utility Requirements

Some of the major equipment associated with the amine process is very large and requires special attention to installation and shipping. Table 7.1-2 lists the major equipment that requires special handling because it does not fit on a standard trailer truck.

Equipment	Tag No.	Length (Mm)	Width (Mm)	Weight (Kg)	Remarks
CO ₂ Absorber	T-101 / T-102	11,800	dia.	507,000	Updated weight
Stripper	T-103	6,670	dia	271,000	Updated weight
Flue Gas Blower	MA-101 / MA-102	7,890	7,290	71,000	Fan only
CO ₂ Compressor	MC-103A-C	21,500	4,000	149,700	Total for all three stages
CO ₂ Gas Drying Skid	X-104	5,100	5,000	139,250	
Concentrated Amine Storage Tank	MT-101	7,000	4,000 dia.	3,800	
Process Water Surge Tank	MT-104	7,300	4,300 dia.	4,000	
Transformer – Step-Down/Reserve 15 MVA	1ESETP03	4,850	3,650	20,000	
Transformer – Step-Down/Reserve 3 MVA	1ESETP02	3,650	3,100	7,000	
Stripper Reflux Drum	MV-202	5,500	3,700 dia.	2,500	
CO ₂ Compressor Suction Drum	MV-203	6,000	4,000 dia.	3,000	
Flue Gas Guillotine Damper	MD-008A/B	7,000 x 7,000	1,500	20,000	Each damper
Flue Gas Guillotine Damper	MD-034A/B & MD-060A/B	7,000 x 3,500	1,500	15,000	Each damper
Seawater Cooling Pumps	MP-115A/B	3,850	1,800	15,200	

Table 7.1-2	. Equipment	Requiring	<b>Special</b>	Handling
-------------	-------------	-----------	----------------	----------

## 7.2 Steam and Condensate_

The CCC Plant design includes low pressure (LP) steam, auxiliary boiler steam, high pressure (HP) steam, and LP and HP condensate systems for plant operations.

The LP steam supply is from the adjacent NaturKraft combined cycle power plant (CCPP) LP steam turbine crossover piping to an interface at the CCC Plant battery limit (B/L). The LP steam conditions at the B/L are 2.2 barg and 270 °C, and the maximum quantity of steam available from the CCPP is 165 tonnes/hr. The LP steam is desuperheated using LP condensate to reduce its temperature to approximately 135 °C for use in the reboilers and at the seven CCC Plant utility stations, thereby increasing its volume by about 20 tonnes.

During certain CCC Plant operating scenarios, the quantity of LP steam required exceeds the 165 tonnes/hr available from the CCPP. During these operating scenarios, the CCC Plant auxiliary boiler is used to supplement the LP steam demands to the stripper reboilers. The auxiliary boiler is sized for approximately 20 tonnes/hr of saturated steam to meet the LP steam conditions. LP steam flow control valves are provided on the inlet piping to each reboiler. Steam line drains are provided throughout the system as required and routed to the LP condensate blowdown tank.

HP steam supply is from the CCPP auxiliary boiler to an interface at the CCC Plant B/L. The HP steam conditions at the B/L are 7 barg at approximately 165 °C (saturated). The quantity of HP steam available from the CCPP auxiliary boiler is approximately 12 tonnes/hr and is available only when not required by the CCPP internal use. HP steam is used for amine reclamation in the CCC Plant's thermal reclaimer. Because amine reclamation is not a continuous process, it is expected that steam from the CCPP auxiliary boiler will be available when needed. An HP steam flow control valve is provided on the inlet piping to the reclaimer. Steam line drains are provided throughout the system as required and are routed to the LP condensate blowdown tank. In addition, a manual globe valve is provided in the HP steam line near the reclaimer to facilitate cleaning or aid in reclaimer waste removal.

LP condensate is produced in the stripper reboilers and is piped to the LP condensate blowdown tank. Similarly, HP condensate is produced from the amine reclaimer and piped to the LP blowdown tank. In addition, small quantities of blowdown from the CO₂ compressor 1st-, 2nd-, and 3rd-stage steam generators are routed to the LP blowdown tank. Some of the LP and HP condensate flashes in the blowdown tank and is vented to the stripper column. The remaining condensate in the LP blowdown tank is used as follows:

- Spray water for the LP steam desuperheater
- LP condensate supply to the three CO₂ compressor steam generators
- LP condensate return to the B/L for return to the CCPP condenser
- Supply to the CCC Plant auxiliary boiler
- Reject to the process water surge tank, as required

The LP condensate system includes the blowdown tank and  $2 \times 100\%$  LP condensate pumps. The LP condensate is continuously sampled before it is returned to the CCPP. If the return condensate doesn't meet plant requirements, it is discharged to the CCC Plant surge water tank.

# 7.3 Cooling ____

Seawater is used as the cooling medium for the CCC Plant's heat exchangers via a once-through, direct-cooling water system. Seawater is also the supply source for the plant's desalination system. The cooling water system design includes an intake tunnel and pump structure pit, a discharge pit, and an outfall tunnel, all of which accommodate plant flow rates. The intake and discharge pits are outside the B/L. The design includes 2 x 100% seawater cooling pumps in the intake structure and the piping from the intake structure to the B/L. All other required intake structure equipment (i.e., traveling water screens, screen wash pumps, etc.) is outside the B/L. The design includes seawater return piping from the plant to a discharge pit outside the B/L. A backpressure control valve located in the common return line ensures that the various heat exchangers remain full during operation. This control valve is located in a dry pit within the B/L at the required elevation to preclude cavitation of the valve, and the water enters a weir to control the outfall. The seawater cooling system can be drained by a small bypass valve placed around the control valve to a drain point downstream of the weir, and the weir itself is selfdraining.

Seawater cooling booster pumps (2 x 100%) are provided to increase system pressure to the stripper overhead condensers, which are located at a higher elevation than the other system heat exchangers. The flow rate to these condensers is only approximately 30% of the total seawater cooling flow rate. Adding the booster pumps precludes the need to add approximately 8 m head to the main seawater cooling pumps, thereby reducing overall pumping power. The common return piping from the overhead stripper condensers has a control valve that aids in maintaining a backpressure on the condensers and keeps them full during operation. The control valve is located at grade to preclude cavitation.

The seawater cooling system design is based on traveling screens that filter the debris in the seawater to less than 2.5 mm in diameter to preclude plugging of the plant plate-and-frame heat exchangers. The design is also based on seawater supply and return temperatures of 11 °C and 21 °C, respectively. The plant permit limit for cooling water return temperature to the sea is 25 °C.

## 7.4 Potable Water

Potable water is supplied from outside the CCC Plant B/L to an interface at the B/L. At that point, it is in accordance with the Norwegian potable water quality standard and at 5.0 barg pressure and ambient temperature. Potable water is used for sanitary needs and emergency safety showers (ESSs) and at all utility stations. Potable water is not used for any process needs. A hose connection for potable water is provided at each of the seven utility stations. Eight temperature-controlled ESSs are located in the following areas:

- Amine storage tank area
- CO₂ compressor area
- Absorber 1 area
- Absorber 2 area
- Stripper area
- Reboiler/reclaimer area (upper level)
- Reboiler/reclaimer area (lower level)
- Electrical building area

Heated emergency eyewash stations (EWSs) are supplied by bottle water. There are nine EWSs; eight are located adjacent to each ESS, and one is in the analyzer building area. Total potable water demand is based on the simultaneous use of all sanitary water users and assuming two ESSs operating simultaneously.

## 7.5 Fire Protection Systems _

Fire water is supplied from outside the CCC Plant B/L to two separate interfaces at the B/L. The interface pressure and temperature conditions are 11.7 barg and ambient temperature. The design reflects two fire water supply lines from outside the B/L that feed the plant underground fire loop, which includes service branch lines to the CO₂ compressor area automatic wet pipe sprinkler system and the yard hydrants. Fire hydrants are spaced at approximately 250-foot (76 m) intervals around the fire loop. The hydrants are located in accordance with NFPA 24 and local fire codes. Hose houses are provided for each hydrant. The system supplies the design maximum water demand for any automatic suppression system plus 114 m³/hr of flow for fire hydrants, based on National Fire Protection Association (NFPA) requirements.

The fire protection system is augmented by portable fire extinguishers located throughout the plant.

The plant fire alarm system includes local fire alarms, automatic fire and gas detectors, and a fire- and gas-detection programmable logic controller (PLC), as required by design codes. The PLC interfaces with the plant distributed control system (DCS). For a description of the CCC Plant fire and gas monitoring and alarm system, refer to Section 9.4.3.

# 7.6 Fuel Gas

Fuel (natural) gas is required for use in the CCC Plant auxiliary boiler. The gas is supplied from outside the B/L to an interface at the B/L. Fuel gas conditions at the B/L are 4.9 bara and 20 °C. The gas piping routed from the interface point to the auxiliary boiler incorporates an emergency shutdown valve that closes on a burner trip or can be closed by the operator in case of an emergency.

# 7.7 Compressed Air _

The compressed air system (PA) supplies instrument air (IA) and service air (SA) for all consumers within CCC Plant. An air receiver is provided to knock out any water droplets and is of sufficient size to provide instrument air (IA) for 10 minutes at specified pressure in the event of a feed failure.

The PA system consists of 2 x 100% air-cooled compressors, 2 x 100% air dryers, and a single air receiver. The compressed air system supplies dry, oil-free air at 8.62 barg and a dew point of -40 °C and can operate at 100% humidity and maximum ambient temperature. Both IA and SA are supplied dry air. SA connections are provided in each of the seven utility stations located within the plant. A hose connection for SA is provided at each utility station. Also provided is a connection for a temporary portable compressor, which is outside the B/L. The maximum allowable discharge pressure from this portable compressor is 13.8 barg.

Low-priority users (e.g., SA) are automatically shut off in case of low IA system pressure. Both air compressors are connected to emergency power; however, only one runs on emergency power at a time. The continuous IA requirement is based on the modulating control valves being in service and the on/off valves not stroking. For the intermittent IA demand, the flow rate is based on typical sizing flow rate, assuming time-averaged stroking activity for the control valves, including dryer purge air, plus a 10% allowance. For plant air, the demand is based on an estimate of using a few pneumatic tools during maintenance.

# 7.8 Inerting Gases _

The CCC Plant inerting gases needs are supplied via nitrogen gas bottles. The nitrogen is used for system and equipment lay-up as needed. The amine (concentrated) storage tank and the 35% MEA storage tank have nitrogen blanketing. A nitrogen connection is provided in each of the plant's seven utility stations. The nitrogen gas system supply header pressure to the utility stations is controlled to approximately 5 barg. The nitrogen gas system supply header pressure to the storage tanks is controlled to approximately 2 barg.

# 7.9 Desalination System _____

The CCC Plant operates in a water-balanced mode requiring no process makeup water. During startup and transition periods where the plant may be out of water balance, process makeup is provided by the desalination system.

A branch connection from the seawater cooling system is used to supply water to the desalination system. This system includes the required filtration, pumps, two-pass reverse osmosis (RO), storage tank, chemical feed skids, clean-in-place (CIP) skid, piping, and instrumentation and controls to produce plant makeup water. The system is designed to produce 8 m³/hr of permeate, with approximately 9 m³/hr discharge to the wastewater sump.

# 7.10 Waste Collection and Drains _____

### 7.10.1 Amine Waste ____

The amine (35% MEA) solvent needs to be drained from the CCC Plant at shutdown and from individual equipment for maintenance activities.

For shutdown, MEA circulation continues without flue gas flow to ensure that the MEA solution is lean throughout all of the equipment. The equipment is pumped out to a minimum level directly, or through other vessels, to the lean amine solvent storage tank. The remaining MEA solution is drained by gravity though the amine waste piping to the amine waste sump. From the sump, the amine solution is pumped through filters to the amine solvent storage tank. Two 100% amine waste-forwarding pumps and two 100% amine waste filters are provided. The amine solvent storage tank has been sized to accommodate the MEA solution from all of the plant's equipment and piping. The amine waste sump provides the opportunity to test the drained amine to ensure that it is of acceptable quality before it is pumped to the storage tank. This sump has been sized to accommodate the entire contents of the largest vessel (one CO₂ absorber vessel). If the drained MEA solution is not acceptable, it can be pumped from the amine waste sump directly to road tankers for offsite disposal.

#### 7.10.2 Wastewater___

Any wastewater effluent from the CCC Plant area open drains is routed to the wastewater sump. Two 100% wastewater forwarding pumps are provided. The wastewater effluent may contain oil; therefore, all wastewater effluent pumped from this sump to the seawater cooling discharge pit is routed through an underground oil/water separator. This separator removes any oil to meet  $\leq$  1.5 ppm oil content. The oil collected in its reservoir is manually drained for offsite disposal.

The wastewater sump provides the opportunity to test the drained effluent and ensure that it is of acceptable quality before it is pumped to the discharge pit. This sump has been sized to accommodate the entire contents of the largest vessel (one CO₂ absorber vessel). If the drained effluent is not acceptable, it can be pumped from the wastewater sump directly to road tanks for offsite disposal

### 7.11 Wastewater Treatment _____

No wastewater treatment facility is provided. Amine-laden water from the process is recycled back into the process. Steam condensate is returned to the CCPP. Backwash water and dissolved solids from the desalinization system RO units are returned to the seawater discharge pipe. Clean service water runoff and stormwater are discharged to the seawater discharge pipe. Sewage (water closets) is sent outside the B/L for processing.

### 7.12 Piping and Insulation _____

#### 7.12.1 Piping _____

The CCC Plant piping design is governed by ASME B31.3, plumbing code, NFPA, and/or local codes as applicable. The piping material classes are given in the piping class selection document, 10112936-PB-L-TED-0001 (25474-000-3DS-P72G-00001).

Piping is designed to resist plant-specific loads. Typical loading for a piping system includes:

- Dead loads
- Live loads
- Wind loads
- Seismic loads
- Temperature and pressure loads
- Test loads

The plant is arranged to minimize the crossing of piping and electrical commodities.

Aboveground piping is routed as directly as possible to its destination, except for the addition of piping flex loops. Routings avoid areas designated as equipment or instrument maintenance space, vertical access hatches, and maintenance crane or monorail travel space. Piping routed overhead maintains a minimum 6-foot, 9-inch headroom clearance above main floor level and walkways. Pipe routed above stairways maintains a minimum 7-foot headroom clearance above the nearest tread. Except for sloped piping, a two-level scheme is maintained to allow pipes to clear each other when a change in direction occurs in the routing path. Piping is routed above lighting fixtures located over floor access aisles.

Pipe racks support pipe routings between structures for piping requiring inspection or maintenance. Pipe rack that crosses access ways or roadways maintains a 20-foot minimum clearance.

Buried piping is routed in a common corridor between structures to minimize construction and traffic crossings.

Piping systems generally include high point vents and low point drains. Piping in unheated areas is either heat traced or designed for draining. Where feasible, steam piping is sloped in the direction of steam flow, with a minimum slope of 1/8 inch per foot. This general design requirement may be modified if it becomes impractical to maintain strict adherence; however, piping is designed to drain properly.

### 7.12.2 Insulation _

Parts of the CCC Plant requiring insulation to reduce heat loss or afford safety to personnel are thermally insulated. Piping, ducts, and other hot surfaces within reach of personnel are limited to 60 °C

regardless of ambient conditions or have standoffs or other protection in combination with insulation to meet this standard.

Thermal insulation materials are calcium silicate, fiberglass, or mineral fiber. Asbestos materials are prohibited. A jacket or suitable coating is provided on the outside surface of the insulation. Where a hard-setting compound is used as an outer coating, it is nonabsorbent and non-cracking. Thermal insulation remains chemically inert even when saturated with water. Insulation system materials, including jacketing, have a flame spread rating of 25 or less when tested in accordance with ASTM E 84.

Insulation outside buildings and structures is weatherproofed through the use of longitudinal laps below pipe centerline, downward end laps on vertical piping, and mastic plastic cements at penetrations. Removable insulation is provided at flanged valves 2-1/2 inches and larger.

Antisweat insulation with a moisture-proof barrier is furnished only in occupied (finished) areas. A fluid temperature of less than 10 °C is the basis for using antisweat insulation.

Insulation at valves, pipe joints, and other points where maintenance access may be required is removable with minimal disturbance to the pipe insulation. At each flanged joint, the molded material terminates on the pipe at a distance from the flange equal to the overall length of the flange bolts to permit their removal without damaging the molded insulation. Aboveground insulated piping includes suitable material cladding. At joints, the sheets are sufficiently lapped to prevent moisture from penetrating the insulation.

Design temperature limits for thermal insulation are based on system operating temperature during normal operation.

## 7.13 External Utility and Piping Interfaces_

The CCC Plant external utility and piping interfaces are as follows:

- LP steam from CCPP
- HP steam from CCPP
- LP condensate to CCPP
- HP condensate to CCPP (combined with LP condensate)
- Fuel gas from CCPP
- Flue gas from CCPP
- Fire water from CCPP (two connections)

- Seawater cooling pump intake structure
- Seawater cooling discharge pit
- Potable water from CCPP
- Sewage effluent return to CCPP
- CCC Plant utilities (compressed air, nitrogen gas, water, LP steam) station at CO₂ transport area

The connections information for the above utility interfaces is shown on interface register document 10112936-FI-Z-LST-0004.

8.0-CCC Plant Electrical Distribution System

# 8.0 CCC Plant Electrical Distribution System_

# 8.1 General_

The Kårstø CO₂ Capture and Compression (CCC) Plant electrical distribution system is designed to comply with the front-end engineering and design (FEED) tender documents. The plant receives its power from a 50 MVA transformer located outside the battery limit (B/L) and inside the adjacent Naturkraft combined cycle power plant (CCPP) and is connected to the generator isophase bus. This transformer is connected to the CCC Plant 22 kV switchgear via an infeed cable installed in sand-filled cable culverts. The CCC Plant receives its backup power (for maintenance only) from the CCPP 6.6 kV switchgear through a dead-time transformer, which is provided inside the B/L and is connected to the 22 kV switchgear via a cable located in a sand-filled culvert.

The 22 kV switchgear is the primary power feeding source for all plant loads. The 22 kV system feeds adjustable speed drive systems for motor loads greater than 3,500 kW. Motors greater than 250 kW but less than or equal to 3,500 kW are fed from the 6.6 kV switchgear through a step-down transformer inside the B/L. The 22 kV system also feeds the 400/230 V loads through redundant load center transformers connected to redundant 400 V load centers for further power distribution.

In the event of a complete loss of in-feed power, critical loads required to safely shut down the plant are fed from the dc and ac uninterruptible power supply (UPS) system. This system has redundant batteries, battery chargers, and inverters.

In the event of an extended loss of in-feed power, the plant has a standby emergency diesel generator. The standby diesel generator is connected to the plant's essential motor control center (MCC), which distributes emergency power to the plant's critical and essential loads.

Power factor correction equipment is connected to the 22 kV switchgear. The power factor correction capacitors are designed with an automatic power factor controller to maintain the plant power factor at approximately 1.0.

The plant uses the following nominal distribution system voltages:

- 22 kV, 3-phase, 50 Hz, isolated neutral (IT)
- 6.6 kV, 3-phase, 50 Hz, IT

- 400/230 V ac, 3-phase, 50 Hz, TN-S (separate neutral and protective earth)
- 400/230 V ac UPS, 3-phase, 50 Hz
- 110 V dc UPS
- 24 V dc UPS

The main electrical distribution components are located in or adjacent to the plant electrical building, as shown in Figure 8.1-1.





# 8.2 Switchgear

The CCC Plant 22 kV and 6.6 kV switchgear is located indoors in the electrical building, is designed of metal-enclosed (sheet-steel) construction, and is sized for the nameplate rating of the connected transformers. The 22 kV switchgear uses manually initiated, load-limited, make-before-break transfer to transfer power between the maintenance source and the normal power source without service interruption. The 6.6 kV switchgear has a single in-feed.

The 400 V load centers and MCCs are located indoors in the electrical building, are designed of metal-enclosed (sheet-steel) construction, and are sized for the nameplate rating of the connected transformers. The load centers and MCCs have two bus-bar sections with a coupling breaker and two 100% in-feeds. An automatic fast bus-transfer provided with the load center closes the coupling breaker in the event of a loss of one of the in-feeds.

The plant also has a 400 V essential MCC with two 100% normal in-feeds and an emergency in-feed from the standby diesel generator. Interlocks are provided to ensure safe operation.

Low voltage (LV) panelboards are located throughout the plant to supply power to convenience receptacles, certain lighting, and heat tracing. Indoor panelboards are metal enclosed (sheet steel construction), and outdoor panelboards are of stainless steel construction, IP54, and rated for use per the hazardous area classification.

All switchgear is designed for future expandability, has electrical protection to isolate electrical faults as close as possible to the fault location, and communicates with safety and automation systems via digital bus.

# 8.3 Transformers ____

The CCC Plant's transformers have copper windings, are sized to feed the plant's worst-case operating loads plus contingency for future growth, and are designed per IEC standards. Main design features are summarized in Table 8.3-1.

Transformer	Rating	Feed Source (Input)	Feed Source (Output)	Location	Supplier
CCC Plant Transformer	50 MVA, 20 kV/ 23 kV, 0NAN YNd11, with on-load tap changer	CCPP isophase bus	CCC Plant 22 kV switchgear	CCPP	Outside B/L
Dead-Time Transformer	3 MVA, 6.6 kV/ 23 kV YNyn(d)0, ONAN, de- energized tap changer	CCPP 6.6 kV switchgear	CCC Plant 22 kV switchgear	Outdoors adjacent to electrical building	Inside B/L

 Table 8.3-1.
 Transformer Ratings and Design Features

Transformer	Rating	Feed Source (Input)	Feed Source (Output)	Location	Supplier
Step-Down Transformer	15 MVA, 22 kV/ 6.9 kV, Dyn1, ONAN, de- energized tap changer	CCC Plant 22 kV switchgear	CCC Plant 6.6 kV switchgear	Outdoors adjacent to electrical building	Inside B/L
Load Center Transformers	2,500 kVA, 22 kV/ 0.42 kV cast resin, Dyn1, de- energized tap changer	CCC Plant 22 kV switchgear	400 V load centers	Indoors in electrical building	Inside B/L

# 8.4 Power Factor Correction

The CCC Plant's medium voltage (MV) power factor correction equipment consists of a metal-enclosed, multistage, switched capacitor bank in the electrical building. The capacitor bank has a power controller that automatically switches the individual capacitors on or off to provide the required MVAR support to maintain the system power factor at the plant's B/L at a nominal 1.0 based on preliminary design calculations. A four-stage capacitor bank with a total of 20 MVAR support was selected to cover various operating scenarios. The selected capacitor stages are listed in Table 8.4-1.

### Table 8.4-1. Power Capacitor Stages

Stage	MVAr
А	0.5
В	2.5
С	5.0
D	12.0
Total	20.0

NOTE: Number of stages and MVAr values require adjustment during detailed design to suit final requirements.

## 8.5 Electrical Loads Summary ____

Electrical load summaries were performed to outline the expected CCC Plant loads during the operating scenarios summarized in Table 8.5-1. Please see document 10112936-PB-E-PAL-0001 (25474-000-30R-E21G-00001) for complete details.

Scenario (~ approximately)	Load (KW)
Maximum Operation (for system sizing)	~44,000
Continuous Operation (CO ₂ capture during full power plant output)	~32,000
Standby Operation (CO ₂ capture imminent)	~5,000
UPS Operation (initial plant shutdown during in-feed power loss)	~65
Essential Operation (standby diesel generator)	~470

#### Table 8.5-1. Electrical Loads Summary

NOTE: Values are conservatively estimated but are not to be construed as guarantees.

## 8.6 System Studies _____

Electrical system studies were performed to verify the adequacy of the CCC Plant's electrical system design and the suitability of the selected electrical equipment. These studies were performed based on the worst-case input parameters and indicated that the selected equipment provides stable, reliable, and expandable plant power. The system studies summaries are outlined in Table 8.6-1.

Table 8.6-1. Electrical System Studies Summary			
Study	Purpose	Result	
Short- Circuit Study	Performed to select the interrupting rating of the circuit breakers.	Selected equipment will safely withstand and interrupt the worst-case fault conditions and have suitable margin.	
Load Flow Study	Performed to validate that voltages are within required tolerances during different operating conditions and to validate that all equipment is properly rated for the electrical load.	Voltages remain within acceptable tolerances under each operating condition, and the on-load tap changer on the plant transformer provides suitable voltage regulation.	
Transient Stability Study	Performed to that validate the largest motors on each bus are capable of accelerating their loads and to determine power system response to simulated	All motors safely accelerate their loads, and the electrical system is able to fully recover after clearing system disturbances.	

_ _ _ ___ - - -_

	system response to simulated system disturbances (electrical faults).	
Harmonic	Performed to ensure that	Total harmonic distortion is
Distortion	harmonic distortion levels on the	within acceptable levels using
Analysis	electrical network are within	tuned harmonic filters provided
	acceptable tolerances.	with the adjustable speed drives.

# 8.7 Emergency and UPS Power

The CCC Plant has emergency power sources to provide power if both normal and backup power are unavailable. Emergency power is provided through the UPS system located indoors in the electrical building. The UPS system has  $2 \times 100\%$  fully redundant batteries, battery chargers, inverters, and two 100% in-feed breakers to all subswitchgear, as shown in Figure 8.7-1.

The plant also has a 600 kWe standby diesel generator to provide power during an extended loss of in-feed power. The standby diesel generator is connected to the plant's essential MCC and is automatically started upon loss of power on the 400 V system. Upon diesel generator startup, the electrical system is designed to automatically supply power to the plant emergency and essential loads such as the UPS system; essential lighting; essential heat tracing; and essential heating, ventilation, and air-conditioning (HVAC).



Figure 8.7-1. CCC Plant UPS System Diagram

## 8.8 Hazardous Areas Classification .

Electrical equipment and bulks are suitable for installation for their exposed hazards. Outdoor electrical equipment is designed for Zone 2, Group IIA T2, as a minimum. Indoor electrical equipment and bulks are classified as nonhazardous. See document 10112936-PB-S-HSE-0010 (25474-000-U5Y-0000-00001) for detailed hazardous classifications.

# 8.9 Cable and Raceway_____

MV and LV power and control cables use stranded copper conductors. MV power cables are cross-linked polyethylene (XLPE) insulated, with polyvinyl chloride (PVC) jackets, and are designed with insulation levels suitable for application in unearthed systems. LV power cables are XLPE insulated, copper screened, and PVC over-sheathed. LV control cables are PVC insulated, with PVC over-sheath. All cables are armored, using glands for termination.

Aboveground circuits are designed for installation in stainless steel cable ladder or cable tray when outdoors and rigid galvanized steel cable ladder or tray when indoors. Underground circuits are installed in precast, sand-filled, cable culverts.

# 8.10 Earthing and Lightning Protection_____

The earthing system consists of three subsystems: instrument earth (IE), protective earth (PE), and intrinsically safe earth (IS). The earthing system is designed to obtain low-impedance earth paths for earth faults, static discharges, and lightning protection, and to meet electromagnetic conductivity (EMC) requirements. The main earthing system consists of buried stranded copper conductors connected at four points to the CCPP earth grid.

A separate neutral and protective conductor is provided for the 400 V system. The MV system is earthed through surge arresters and acts as an ungrounded system.

Lightning protection is provided for the absorbers, strippers, and buildings.

# 8.11 Lighting _____

The plant has normal, emergency, and essential lighting. Dedicated lighting columns are used for street and flood lighting. Metal halide lighting is provided for normal outdoor lighting and in locations with large head rooms, such as compressor houses and process buildings. Outdoor lighting fixtures are suitable for Zone 2 hazardous area and are controlled with photocell-controlled switching circuits. Emergency lighting (escape way lighting) is provided by florescent lamps powered from the 400/230 V UPS system. In addition to emergency lighting, lighting required for emergency egress is automatically transferred to the standby diesel generator in the event of power loss.

# 8.12 External Electrical Interfaces _____

The CCC Plant electrical system design includes interfaces with other facilities as summarized in Table 8.12-1.

Plant	Interfaces
CCPP	Normal and backup electrical power feeds, protection, measuring, control cables, instrument cables, cable trenches and raceway, new flue gas dampers, and earthing system
Karsto Gas Terminal	Cables and required raceway for fire and gas detection system (F&GDS) interfaces
CO ₂ Transport Area	Power, control, and instrument cables and required trench and raceway to support the transport system
Seawater Cooling	Power, control, and instrument cables and required trench and raceway to support the seawater pump system

 Table 8.12-1.
 External Electrical Interfaces

9.0-Automation Systems

# 9.0 Automation Systems _____

# 9.1 Overall Control Systems Architecture _____

The Kårstø CO₂ Capture and Compression (CCC) Plant is operated from the central control room (CCR) in the control/workshop/stores building. An operator stationed in the CCR has access to the following systems via the operator stations:

- Distributed control system (DCS)
- Process shutdown (PSD) system
- Emergency shutdown (ESD) system
- Fire and gas (F&G) detection system

The operator also can access selected information from the following systems via the operator stations:

- Continuous gas monitoring system (CGMS)
- Auxiliary boiler burner management system (BMS)
- Vibration monitoring system (VMS)

The operator also has access to the following systems from the CCR:

- ESD action panel
- F&G action panel
- CGMS data acquisition and handling system (DAHS)
- Closed-circuit television (CCTV) system
- Public address (PA) system
- Phone and ultra-high-frequency (UHF) radios

## 9.2 Controls Philosophy and Approach (Human Factors)_____

### 9.2.1 General Control Philosophy _____

The general control philosophy allows for control of major CCC Plant functions, with priority placed on personnel safety and equipment protection, followed by plant availability.

A single qualified inside operator stationed in the CCR controls the plant with the support of one or more qualified outside plant operators as needed during different operational modes. The plant incorporates sequences that automatically start it and shut it down once it has been filled, vented, and lined up in accordance with detailed operating procedures.

Normal operation is controlled automatically, following the CO₂ master controller signals. Adjustable set points and manual control of devices outside the automatic control routines are incorporated where possible to maximize operating flexibility. Despite this, interlock logic prevents the operator from creating an undesirable operating condition that could endanger personnel safety or cause equipment damage.

#### 9.2.2 CO₂ Removal Control Master_

The CO₂ removal control master provides overall automatic control to achieve constant 85% CO₂ removal from the flue gas by controlling the lean amine flow into each absorber column based on the incoming flue gas mass flow and CO₂ concentration in a feed-forward control. The final control trim is accomplished by using the desired removal set point (85%) difference between the incoming flue gas CO₂ flow and off-gas CO₂ flow calculation. Each absorber has a CO₂ master controller. The concept is shown in Figure 9.2-1.



Figure 9.2-1 CO₂ Master Controller Concept

#### 9.2.3 Overview of Normal Operation

A detailed description of the plant controls is provided in the Control Philosophy, 10112936-PB-I-PAL-0001 (25474-000-J0Y-JD-00001). The following is a brief overview of the process controls.

Under normal operation, the CCC Plant takes 100% of the flue gas from the CCPP to the absorbers. The flue gas pressure at the heat recovery steam generator (HRSG) outlet is controlled by modulating the blower speed. To maintain a constant pressure, the DCS uses the combustion turbine exhaust gas flow, absorber inlet flow, and HRSG outlet pressure in a three-element control scheme. The three-element control provides higher overall pressure stability despite process disturbances such as combustion turbine load change or flue gas flow deviations.

The flue gas is cooled by water foggers in two stages prior to entering each absorber at 50 °C. In each cooling stage, a spray water control valve throttles the flow to the cooler to control the temperature of the flue gas downstream of the cooler. A feed-forward control scheme using flue gas flow and fogger inlet temperature reduces variability in the temperature leaving each cooler and the chance of excessive spray water due to time lag associated with temperature measurement.

The  $CO_2$  master determines the required amount of lean amine inlet flow to the absorber. Rich amine flow from the absorber to the stripper is controlled in proportion to the lean amine flow to maintain a constant level in the stripper. A portion of the rich amine flow is diverted, heated, and flashed to create semi-lean amine, which is returned directly to the absorbers. This system can be bypassed and the system run using only lean amine.

Wash water to remove entrained amines from the off-gas is controlled at a constant flow rate into each water wash bed in the absorber. The amine concentration in the wash water system increases over time. To keep the amine concentration in the water wash system at a low level, a continuous flow of fresh process water is added to the system in proportion to the lean amine flow. The level of the water wash chimney tray is controlled by the wash water bleed valve, which sends the excess water to the lean amine system through the bleed line.

Excess water that may be generated by condensation from the flue gas is dumped to the lean amine system. The excess water is boiled off in the stripper and then removed from the stripper overhead, where the level of amine concentration is lowest, to minimize waste production and loss of amine from the process. During times when water is needed, water is added to the water wash system from the process water system. The makeup water in the water wash system cascades via the bleed line to maintain the proper level in the absorber bottom. Low pressure (LP) steam flow rate to the reboiler is controlled in proportion to the rich amine flow rate entering the stripper column. The steam flow rate is modified as needed to maintain the proper amount of reflux in the stripper overhead system.

Gas leaving the stripper contains some water and solvent. It enters the stripper overhead cooler and is cooled by seawater, condensing the water and solvent. The gas and condensate then enter the stripper reflux drum, where they are separated.

The reflux liquid from the stripper reflux drum is pumped back to the top of the stripper reflux section and is maintained in proportion to the gas stream flow to control overhead solvent loss with the CO₂ product. Excess liquid is pumped back to the process water surge tank. The stripper reflux system is shown in Figure 9.2-2.



Figure 9.2-2 Stripper Reflux System

Gas leaving the stripper reflux drum goes to the CO₂ compression system. A constant backpressure in the stripper reflux drum (and consequently the stripper) is maintained by the compressor speed.

The inlet to each stage of the  $CO_2$  compressor has a knockout drum to remove condensed liquid from the gas stream. The liquid is recycled to the process water system in a sequential let-down scheme that minimizes any venting of  $CO_2$  gas from the storage tank.

The  $CO_2$  gas from each compressor stage passes through a steam generator, where it is cooled and used to heat LP condensate, creating

interstage steam. The interstage steam is used to generate the semi-lean amine. The steam generators are controlled at a constant level and pressure.

Intercoolers at the inlet of the second and third compressor stages maintain the required CO₂ temperature entering each stage.

Prior to entering the compressor third stage, the CO₂ gas enters the CO₂ dryers to remove moisture to <50 ppm (wt). The output from the dryers is monitored by redundant analyzers, and an alarm is activated if moisture levels approach the required product specification. The CO₂ product is also monitored by redundant moisture and O₂ analyzers. If the levels exceed the required product specification at either location, the CO₂ product send-out pumps are stopped and the CO₂ product shutdown and control valves are closed. The CO₂ is vented from the CO₂ surge drum until the product quality meets the required specification.

After leaving the final stage of the compressor, the  $CO_2$  product is cooled to a liquid in the  $CO_2$  cooler and sent to the  $CO_2$  surge drum. Noncondensable gases in the  $CO_2$  surge drum are vented to the top of the absorbers by the vent valve on high pressure in the drum.

The  $CO_2$  product send-out pumps forward the  $CO_2$  product to the battery limit as a supercritical fluid. The flow to the pipeline is controlled at a steady rate, with reset from the  $CO_2$  surge drum level.

The reclaiming process is initiated by the operator when it is determined by analysis that the amount of degradation products in the lean amine is too high. The process can be carried out via the DCS either manually or with an automatic sequence. High pressure (HP) steam and soda ash are used to recover water and amines, which are flashed off and sent back to the stripper as vapor.

### 9.2.4 Human Factors _

#### 9.2.4.1 Human Machine Interface

The DCS has a human-machine interface (HMI) in the CCR. Preliminary considerations for the CCR human factors include the following.

#### 9.2.4.1.1 Hardware

- Dual-screen operator station and engineering workstation (EWS)
- Single-screen historian and CGMS DAHS

# 9.2.4.1.2 Operational Control

- Automatic control of CCC Plant (Manual control is not normally required.)
- Unit startup and shutdown (intermittently) via automatic sequence. Manual control is not normally required.

# 9.2.4.1.3 Operational Functions

- Alarm monitoring and acknowledgement (including the ESD, PSD, and F&G detection systems)
- Historian/historical data retrieval, if required for operating purposes
- Log printing
- Primary fault finding
- Tagging out/coordinating permit recording functions (if assigned to the operator or shift supervisor)

# 9.2.4.1.4 Engineering Functions

- EWS software, including configuration (logics and graphics)
- Alarm setup and management
- Detailed fault finding
- Historian maintenance (including DVD and storage media replacement)
- Serial link and Ethernet link configuration
- Periodic updates of anti-virus software
- User account management
- Information management system (IMS) server configuration

## 9.2.4.2 Operations During Upset Conditions

The plant is designed for fully automatic control during normal operation. During an upset, automatic overrides attempt to correct the problem prior to reaching PSD conditions. Further, redundant backup pumps automatically start on loss of the primary pump. Manual control may also be possible.

In the event of a PSD, the affected process is isolated. In some cases, the plant may continue operating; in other cases, it shuts down. Activity falls to fault finding by the operator and Engineering.

## 9.2.4.3 CGMS Shelter and Compressor Building Analyzer Room

The CGMS shelter and compressor building analyzer room are normally unmanned. The two main activities in these locations include analyzer system maintenance and grab sampling.

## 9.2.4.3.1 Maintenance

- Troubleshooting failed calibration of O₂, H₂O, CO, and CO₂ analyzers (infrequent)
- Fourier transform infrared (FTIR) spectroscopy analyzer calibration (very rare)
- Periodic calibration of conductivity, pH, DO, and silica analyzers (weekly or monthly)
- Online gas chromatograph (OGC) maintenance (infrequent)
- Replacement of calibration gas cylinders (infrequent)

# 9.2.4.3.2 Centralized Grab Sampling

Infrequent grab sampling of centralized liquids and gases is anticipated because the required analyses for operation are automated with online analyzers. The sampling system's design provides centralized access in the compressor building analyzer room for the most commonly sampled streams. For a list of centrally analyzed streams and analyzers, refer to Subsection 9.6.2.

High temperature samples are cooled in the sample panel. Sampling is controlled in a fume hood with closed sampling points and sample bottles for hazardous samples, and open sampling points for nonhazardous samples. An example of a prepackaged closed loop sampler that may be used in the sample panel is the Dopak^{®1} DPM (see Figure 9.2-3).





Figure 9.2-3 Grab Sampling – Example of Closed Grab Sample Point (Dopak Model DPM)

¹ Dopak is a registered trademark of Dovianus BV

Centralized grab sampling reduces any variation between grab samples that results from plant fluctuations because the samples are taken over a shorter overall time frame than if the operator walks to each point locally. This also facilitates more frequent sampling if required for a particular operating scenario. The time required to take the samples and the potential exposure of the operator to hazards are also minimized because it is not necessary for the operator to climb the columns or be in direct contact with process equipment in the course of taking the samples.

### 9.2.4.3.3 Local Grab Sampling

Infrequent local grab sampling is anticipated. The primary sampling requirement comes from the amine waste and wastewater sumps.

Where local grab sampling is required and the sample is at a high temperature, cooling is necessary to prevent potential injury to the operator taking the sample. A sample cooler is included in the system design. An example of a prepackaged closed loop sampler with integrated cooling that may be used in the detailed design is the Dopak Model S23 (see Figure 9.2-4).



Figure 9.2-4 Grab Sampling – Example of Closed Grab Sample Point With Cooling (Dopak Model S23)

Local grab samples are provided at the points listed in Table 9.2-1.

Grab Sample Point Description	Grab Sample Point Type
Stripper Reflux Water	Standard grab point
Amine Waste Sump	Standard grab point
Reclaimer Vapor	Closed grab sample with cooling
Reclaimer Waste	Closed grab sample with cooling
CO ₂ Compressor 1 st Stage Inlet	Closed grab sample
CO ₂ Compressor 2 nd Stage Inlet	Closed grab sample

Table 9.2-1 Local Grab Sample Points

Grab Sample Point Description	Grab Sample Point Type
CO ₂ Compressor 3 rd Stage Inlet	Closed grab sample with heating
CO ₂ Surge Drum Vapor	Closed grab sample with heating
ME-101 Seawater Outlet	Standard grab point
ME-102 Seawater Outlet	Standard grab point
ME-104 Seawater Outlet	Standard grab point
ME-111A Seawater Outlet	Standard grab point
ME-111B Seawater Outlet	Standard grab point
ME-111C Seawater Outlet	Standard grab point
ME-111D Seawater Outlet	Standard grab point
ME-113 Seawater Outlet	Standard grab point
ME-115 Seawater Outlet	Standard grab point
ME-117 Seawater Outlet	Standard grab point
Process Water Surge Tank	Standard grab point
Wastewater Sump	Standard grab point
Wastewater Outfall	Standard grab point
ME-112 Blowdown	Standard grab point
ME-114 Blowdown	Standard grab point
ME-116 Blowdown	Standard grab point
Lean Amine Storage Tank	Standard grab point
Amine Storage Tank (Concentrated)	Closed grab sample

## 9.3 Plant Communication Systems _____

### 9.3.1 Telephone System _

The CCC Plant's telephone system is a modern, state-of-the-art, hybrid private automatic branch exchange (PABX) system. The system includes an integrated intercom system that allows direct two-way communication between the CCR and selected places in the plant, voice recording system, and public telephone interface. The conceptual block diagram is shown in Figure 9.3-1.

### 9.3.2 Public Address System____

The PA system allows audible broadcast of announcements and alarms throughout the plant. The system is a duplicated system that consists of handsets, speakers, and orange beacons (for high noise areas). The block diagram for each of the duplicated systems is shown in Figure 9.3-2.

### 9.3.3 Closed Circuit Television System _____

The CCTV system provides direct video monitoring within the plant at specific locations. The system is controlled by the operator from the

CCR. Video can be displayed on the CCTV control server or the largescreen video display unit (VDU). The system includes various fixed and pan-tilt-zoom (PTZ) cameras, digital video recorder (DVR), global positioning system (GPS) time server interface, and interfaces to control systems within the plant and neighboring facilities. The conceptual block diagram is shown in Figure 9.3-3.



Figure 9.3-1 Conceptual Block Diagram for Telephone System



Figure 9.3-2 Conceptual Block Diagram for PA System



Figure 9.3-3 Conceptual Block Diagram for CCTV System

### 9.3.4 Portable UHF Radio System _

The portable UHF radio system consists of a central unit located in the CCR, portable hand sets with shoulder-strap carrying cases, charging units at various locations such as the CCR, and repeater if needed to achieve complete radio coverage within the plant. The supply of this system is outside the plant battery limit (B/L) to facilitate obtaining the necessary frequency spectrum permits.
### 9.4 Safety and Shutdown Analysis and Provisions ____

The CCC Plant has an ESD system, a PSD system, and an F&G detection system.

#### 9.4.1 Emergency Shutdown System_

The ESD system essentially safely actuates the appropriate PSD sequence(s), de-energizes the necessary electrical equipment, and depressurizes the unit (e.g.,  $CO_2$  compression system). The ESD functions are manually initiated by the operator, usually as the result of a fire, major spill, combustible gas detection, etc.

The ESD system is safety-programmable logic controller (PLC) based. The system is designed to meet SIL 1, 2, or 3 (as determined for each control loop) according to IEC 61508 and IEC 61511.

For situations not requiring immediate action, an audible and visible alarm is given in the CCR and also locally. Alarms are sent to, handled by, and presented in the DCS alarm system.

For a detailed list of causes of ESD initiation and actions, refer to the ESD/PSD Cause & Effect Diagram, 10112936-PB-I-DGM-0001 (25474-000-J4-JD-00001).

### 9.4.2 Process Shutdown System ____

The PSD system ensures that process conditions do not exceed specified process safety limits. The PSD system is functionally independent of the process control function but is implemented in the same DCS hardware with dedicated controllers and input/output (I/O) cabinets (see above description of the DCS structure and function).

In the event of abnormal operating conditions that could cause permanent damage to the plant, endanger human safety, or exceed operating limits to the detriment of plant life, the PSD system automatically shuts down discrete equipment, a system, or the CCC Plant, in a safe and controlled manner.

For a detailed list of causes of PSD initiation and actions, refer to the ESD/PSD Cause & Effect Diagram, 10112936-PB-I-DGM-0001 (25474-000-J4-JD-00001).

### 9.4.3 Fire and Gas Dectection System.

The F&G detection system is largely an alarm system, but it is also able to take certain actions other than activating remote or local area alarms devices, such as shutting off heating, ventilating, and air-conditioning (HVAC) systems upon combustible/toxic gas detection; starting HVAC systems upon  $CO_2$  detection; etc., in case of fire or gas and spill detection. The system layout is shown in Figure 9.4-1.



Figure 9.4-1 Conceptual Block Diagram for F&G Detection System

The F&G detection system is safety-PLC based. The system is designed to meet SIL 2 according to IEC 61508 and IEC 61511.

The F&G detection system interfaces to the neighboring facilities for exchange of alarms throughout the Kårstø site.

For a detailed list of causes of fire and gas detections and actions to be taken, refer to the Fire & Gas System Cause & Effect Diagram, 10112936-PB-I-DGM-0002 (25474-000-J4-JD-00002).

# 9.5 Safety and Automation System

The purpose of the CCC Plant's DCS-based safety and automation system (SAS) is to safely and efficiently control and monitor plant equipment and processes.

The DCS provides integrated modulating control, sequential control, and data acquisition for both normal operation and the PSD system.

The DCS controls, monitors and records physical and electrical parameters associated with the CCC Plant. The system provides interface with the ESD, F&G, continuous emissions monitoring system (CEMS), CCTV, and PA systems and with existing installations. The DCS allows full operation from the CCR.

The DCS processors are centrally located in the CCR equipment room for safety and accessibility. Remote I/O is used for interface with field devices. The conceptual block diagram of the DCS is shown in Figure 9.5-1. Further details of the hardware are provided in Subsection 9.8.



Figure 9.5-1 Conceptual Block Diagram for DCS and PSD System

# 9.6 Gas and Emissions Monitoring and Metering

### 9.6.1 Continuous Gas Monitoring System .

The purpose of the CCC Plant's CGMS is to sample, measure and analyze incoming flue gas from the Naturkraft combined cycle power plant (CCPP), absorber off-gas emissions, and the CO₂ product stream, and then calculate, record, report, and archive these emissions for use by both the SAS and plant management in reporting environmental compliance to the competent Norwegian Pollution Control Authority (SFT).

The CGMS for the CCPP incoming flue gas and each absorber's off-gas is located between the absorbers in the CGMS shelter. The gas monitoring equipment for the  $CO_2$  product is located in cabinets in a separate analyzer room in the compressor building. The CGMS interfaces to the DCS for exchange of control and reporting data. The conceptual block diagram is shown in Figure 9.6-1.



Figure 9.6-1 Conceptual Block Diagram for CGMS System

Although no air permit specific to the CCC Plant has been issued to date, certification is to European Union (EU) regulations.

The CGMS is a direct-extractive sampling system. Separate, dedicated  $CO_2$  analyzers are included on the flue gas and absorber off-gas streams for the  $CO_2$  master control. Ammonia in the flue gas from the CCPP is measured in situ to avoid potential transport problems associated with the long sample line. Redundant H₂O analyzers are provided on both the  $CO_2$  dryer outlet and the  $CO_2$  product stream, and redundant  $O_2$  analyzers are provided on the  $CO_2$  product stream to ensure that the product meets the required quality. Table 9.6-1 lists the measured components and analysis method for each monitored process stream within the plant.

Component		Carbon	Carbon		Nitrogen			
$\rightarrow$ Sample $\downarrow$	Amine (MEA)	Dioxide (CO ₂ )	Monoxide (CO)	Ammonia (NH3)	Oxides (NO _x )	Water (H ₂ 0)	Oxygen (O ₂ )	Analyzer Type
		Х			Х	Х		FTIR
Flue Gas from	-	-		Х		-		IR or TDLAS (in situ)
ССРР	-	-		-	-	-	х	ZrO ₂ or Para- magnetic
	-	Х			-	-	-	NDIR
	Х	Х		Х	Х	Х	-	FTIR
Off Gas (each Absorber)		-	-	-			х	ZrO2 or Para- magnetic
		Х						NDIR
	Х	Х				Х		FTIR
						Х		IR
CO ₂ Product	-	-		-			х	ZrO ₂ or Para- magnetic
		-		-			х	ZrO2 or Para- magnetic
Auvilian		Х						NDIR
Boiler		-	Х	-				GFC or NDIR

Table 9.6-1 Gas Analysis Parameters and Analyzer Type

### 9.6.2 Liquid Emissions

Samples from throughout the plant are routed to the sample panel where they are conditioned and distributed to the required analyzers and grab sample points. The particular samples, measured variables, and analyzers are shown in Table 9.6-2.

 Table 9.6-2
 Online Liquid Analysis

Sample	Measured Variable	Analysis Method
Absorber #1 Wash Water	% MEA	Shared OGC
Absorber #2 Wash Water	% MEA	Shared OGC
Rich Amine	% MEA and % CO ₂	Shared OGC

Sample	Measured Variable	Analysis Method
Lean Amine	% MEA and % CO ₂	Shared OGC
Semi-Lean Amine	% MEA and $%$ CO ₂	Shared OGC
LP Steam Inlet	Cation conductivity	Online analyzer
	рН	Online analyzer
	Silica	Shared online analyzer
HP Steam Inlet	Cation conductivity	Online analyzer
	рН	Online analyzer
	Silica	Shared online analyzer
LP Condensate	Cation conductivity	Online analyzer
	рН	Online analyzer
	Silica	Shared online analyzer
	Dissolved O ₂	Online analyzer
Seawater Inlet	Cation conductivity	Online analyzer
	рН	Online analyzer
Seawater Discharge	Amine concentration	Online analyzer
	рН	Online analyzer

To minimize MEA and water loss from the system, all of the samples except the seawater samples are pumped back to the absorber after analysis. The seawater samples are sent back to the wastewater system, where they are returned to the seawater discharge.

The seawater discharge is monitored for the presence of amine in the event that a leak occurs in one of the heat exchangers. The exact method of monitoring is to be determined during detailed design once specific limits have been defined. On high amine concentration, an alarm is annunciated. At this point, grab samples from each heat exchanger outlet can be analyzed via the online gas chromatograph or other method to determine the exact source of the leak. On high-high concentration, another alarm is annunciated, the seawater pumps are tripped, and the heat exchanger discharge valves are automatically closed to avoid possible discharge of contaminants to the sea. This results in an overall plant shutdown due to lack of cooling water to the equipment.

The seawater return line from each heat exchanger and the plant discharge seawater line are also monitored for temperature and provided with high and high-high alarms.

The amine waste sump can be tested via grab sample for quality. If the quality is acceptable, the waste is recycled to either the lean amine solvent tank or either of the rich amine pump suctions.

The wastewater sump can likewise be tested via grab sample for quality. If the quality is acceptable, the waste can be pumped via the oil/water interceptor to the seawater discharge.

Reclaimer sludge liquid is drained to a tote for offsite disposal.

# 9.7 Startup and Shutdown Considerations ____

### 9.7.1 Startup____

#### 9.7.1.1 Startup Sequence

The CCC Plant can be started manually or via automatic sequence. If started automatically, the sequence is initiated by the operator, and the sequencer guides the system through unit startup up to admission of flue gas. The general sequence is as follows:

- Makeup is added to the absorber and stripper bottom levels, water wash chimney tray, condensate blowdown tank, and compressor steam generators as needed.
- Seawater pumps are started.
- The auxiliary boiler start sequence is initiated.
- The LP steam line is warmed via the drain line until the minimum required superheat is reached. Steam is then admitted to the reboiler, and the drain valve is closed.
- The reflux and stripper are brought to operating pressure, and reflux flow is established.
- The lean amine, rich amine, and flash drum pumps are started in recirculation mode.
- Minimum lean/rich amine flow is established. At this point, CO₂ loading in the rich amine flow is minimal due to zero flue gas flow through the absorbers.
- The wash water pump is started, and wash water flow is established.
- The compressor is started at minimum speed in recirculation mode.
- The CCC Plant isolation dampers are opened.
- The flue gas blower for the first absorber is started at minimum speed.
- The CO₂ master output gradually increases from zero, admitting flue gas to the first absorber.
  - At first, the blower damper controls flow until it reaches maximum throttling position, at which point it goes open and the blower speed increases to take more flue gas flow.
  - The HRSG stack damper is modulated to maintain steady pressure in the HRSG/CCC Plant duct.
  - Lean amine flow to the absorber is controlled by the CO₂ master.
  - Steam to the reboiler increases as amine flow increases.

- At first, the stripper reflux drum pressure control valve keeps constant pressure in the stripper. As CO₂ flow increases, the pressure control valve fully opens and the compressor speed is used to control constant stripper pressure.
- The CO₂ master output is fixed to a minimum load until the CO₂ product system has been filled and started and the pipeline has been filled and is in service.
  - As CO₂ begins to fill the surge drum, air vents from motoroperated valves located on the CO₂ product send-out pumps and piping upstream of the CO₂ product control valve.
  - Once the system is vented, the motor-operated valves close and a CO₂ product send-out pump starts.
  - Flow to the CO₂ pipeline is strictly controlled until the pressure in the pipeline approaches operating pressure (details to be determined during final design with input from outside the B/L).
- The CO₂ master output begins to increase again.
- After the first absorber takes approximately 50% of the combustion turbine exhaust flow, the second absorber is started in the same sequence as outlined above. The HRSG stack damper goes fully closed during this step.
- Once the unit has stabilized, the CO₂ master is released for fully automatic control.
- Flow is established through the carbon filter package after the system is fully stabilized.
- Semi-lean amine flow to the absorber is controlled in proportion to the rich amine flow.

### 9.7.1.2 First Startup

The first startup of the unit after the system is completely drained requires additional manual steps as follows:

- Operators must verify manual valve and equipment line-up.
- The seawater system piping may not be completely full if it was drained. The system should be filled in a controlled manner to preclude water hammer.
- A 35% amine solution may need to be created if insufficient level exists in the lean amine solvent storage tank. The tank is filled with process water and then concentrated amine added to make 35% MEA. A grab sample is taken and manually injected into the online gas chromatograph to confirm the proper amine concentration.

- The lean/semi-lean/rich amine system piping and pumps are filled and vented using the 35% amine and a lean amine solvent fill pump.
- The wash water system piping and pumps are filled and vented using process water and an absorber makeup water pump.
- The stripper reflux system piping and pumps are filled and vented using process water and an absorber makeup water pump.
- The CO₂ product send-out system piping and pumps are filled and vented as determined during final design with input from outside the B/L.

Additional considerations for the automatic sequencing tasks are as follows:

- The 35% amine makeup to the unit is more than normal. The condensate blowdown tank fills to ensure an adequate water supply for the LP steam desuperheater until the system reaches equilibrium. Condensate may be rejected until the initial fill from the process water system is rejected back to the process water surge tank.
- The auxiliary boiler drum may not be full. It is recommended that the operator fill the drum prior to starting; however, the automatic sequencer performs this task if not already done.

# 9.7.1.3 Startup After Short Downtime

After a short downtime (hot start where the CCPP is already running), the shutdown sequence outlined in Subsection 9.7.2 is normally executed, but equipment is already filled, vented, and ready for restart. Steps 1-8 and 13 of the automatic sequencer may already be satisfied, shortening the overall startup time. The startup sequencer checks each step in order and continues to the next step if already completed.

### 9.7.1.4 Startup After Long Downtime

After a long downtime (cold start where the CCPP is already running but the shutdown condition has crossed shift change), the shutdown sequence outlined in Subsection 9.7.2 is normally executed, but equipment is already filled, vented, and ready for restart. After an outside plant operator verifies the manual valve and equipment lineup checking, the control room operator initiates the normal startup sequence.

### 9.7.1.5 Restart Following Trip

After diagnosing and troubleshooting the cause of the trip, the operator can, in many cases, restart the unit using the startup

sequencer. Refer to the Control Philosophy, 10112936-PB-I-PAL-0001 (25474-000-J0Y-JD-00001), for detailed explanation of full and partial trip situations.

### 9.7.2 Shutdown _

#### 9.7.2.1 Normal Shutdown

The CCC Plant can be shut down manually or via automatic sequence. If shut down automatically, the sequence is initiated by the operator, and the sequencer guides the system through unit shutdown. The general sequence is as follows:

- CO₂ master automatic control is deactivated and flue gas flow is slowly reduced to zero, at first by reducing blower speed and then by the blower damper. One absorber is shut down at a time. The HRSG stack damper opens to maintain a stable pressure in the HRSG and CCC Plant duct.
- HP steam to the reclaimer is shut down (if in operation).
- The auxiliary boiler is shut down.
- LP steam to the reboiler is shut down after the CO₂ in the rich amine has been removed.
- Semi-lean amine flow is stopped.
- The reflux and stripper are slowly depressurized.
- The compressor is stopped several minutes after CO₂ production stops.
- Flow is circulated until the stripper bottom temperature drops below 65 °C.
- Flow through the carbon filter package is stopped.
- Absorber, flash drum, stripper bottom, and reflux drum levels are decreased to minimum level by rejecting amine to the lean amine solvent storage tank (TK-102).
- The wash water pump is stopped.
- The reflux pump is stopped.
- The lean and rich amine pumps are stopped.
- The CCC Plant isolation dampers are closed.

The seawater pumps are stopped manually after the operator confirms that all equipment is shut down and there are no further cooling requirements.

#### 9.7.2.2 Extended Shutdown

If the unit is to be shut down for an extended period of time (>24 hours), the amine is drained manually from the absorbers to the amine waste sump and forwarded to the lean amine storage tank to avoid oxygen degradation of the MEA.

#### 9.7.2.3 Emergency and Process Shutdown

A number of situations may result in an emergency or process shutdown. For a detailed list of causes of ESD and PSD initiation and actions, refer to the ESD/PSD Cause & Effect Diagram, 10112936-PB-I-DGM-0001 (25474-000-J4-JD-00001). For a description of the effects of these major upsets to the process, refer to the Control Philosophy, 10112936-PB-I-PAL-0001 (25474-000-J0Y-JD-00001).

### 9.8 Primary Control System and Equipment _____

The CCC Plant's primary control system is the DCS. The conceptual block diagram is shown in Subsection 9.5. For the detailed block diagram, refer to the SAS Architecture Diagram, 10112936-PB-I-DRW-0001 (25474-000-JD-00001), and for a detailed description of components refer to the Safety and Automation System Narrative, 10112936-PB-I-DRW-0002 (25474-000-3YD-J01G-00002).

The major components of the DCS are as follows:

- Operator stations (2)
- Large-screen VDU
- EWS
- Plant historian
- IMS server
- Domain controller and anti-virus server
- Interface server
- Controller cabinets
- Remote I/Os and remote I/O cabinets
- I/O cards
- Data highway
- GPS-based clock system
- Color laser printers

Redundant components include the data highway, controllers, power feeds, and power supplies.

# 9.9 Central Control Room Layout

Central operation of the CCC Plant is provided from the CCR located in the control/workshop/stores building. The conceptual layout for the CCR is shown in Figure 9.9-1.



### Figure 9.9-1 Conceptual Control Room Layout (not to scale) (Drawing 10112936-PB-I-DRW-0004 [25474-000-J0-3110-00001])

The CCR has a U-shaped console where the operator sits facing two operator stations on the console and a large-screen VDU and emergency system action panels against the back wall. The operator has access to all other required central control functions on the sides of the console.

Rooms with functions associated with central operations and the DCS are arranged around the perimeter of the CCR. The engineering room

contains the DCS and equipment associated with administering the system. The electrical room has processors and servers for the DCS, PSD, ESD, and F&G detection systems, along with the support equipment such as network switches and the plant GPS time server. The shift supervisor's office can also be accessed via the CCR.

### 9.10 Local Equipment/Instrument Room Layouts _

Analysis equipment is located in two local equipment/instrument rooms on the site. The CGMS shelter is centrally located between the two absorbers, and the compressor building analyzer room is located on the west side of the compressor building.

DCS, PSD, and F&G detection system equipment is also located in the electrical building. Refer to Subsection 8.1 for the electrical building layout.

#### 9.10.1 CGMS Shelter

The CGMS shelter is a prefabricated building that houses the gas analysis equipment for the flue gas, Absorber 1 off-gas, and Absorber 2 off-gas samples. The shelter includes analyzers as outlined in Subsection 9.6.1. A separate room is located at the west end of the shelter for calibration gas bottle storage. The conceptual layout is shown in Figure 9.10-1.



Figure 9.10-1 Conceptual CGMS Shelter Layout (not to scale) (Drawing 10112936-PB-I-DRW-0006 [25474-000-J0-4410-00001])

### 9.10.2 Compressor Building Analyzer Room_

The compressor building analyzer room contains equipment for sampling and analysis of the  $CO_2$  product stream, equipment for sampling and analysis of the liquid process streams throughout the plant, and DCS remote I/O cabinets. A separate room is located at the south end of the analyzer room for calibration gas bottle storage. The conceptual layout is shown in Figure 9.10-2.

The  $CO_2$  product stream equipment is located in the south end of the room and includes analyzers as outlined in Subsection 9.6.1. The liquid process analysis equipment is located in the north end of the room as outlined in Subsection 9.6.2.



Figure 9.10-2 Conceptual Compressor Building Analyzer Room Layout (not to scale) (Drawing 10112936-PB-I-DRW-0005 [25474-000-J0-4010-00001])

# 9.11 Packaged Equipment Controls Interface _

The DCS interfaces with packaged systems within the plant via redundant interface servers and managed Ethernet switches. This interface allows the operator in the CCR to monitor and/or control these systems. The DCS interfaces with the PLCs of the ESD, F&G detection, CGMS, and auxiliary boiler BMS systems. It also interfaces with the Bentley Nevada VMS processors.

# 9.12 Field Instruments and Devices_

Foundation Fieldbus digital bus instruments are used where practicable. HART smart, loop-powered, 4-20mA dc instruments are used where Fieldbus cannot be used due to speed of response, safety requirements, etc.

The signal transfer to the medium voltage switchgear and low voltage motor control centers is also by digital bus communication.

Field instrumentation that remain powered after gas is detected is intrinsically safe, certified for explosion group IIA, temperature class T2. Foundation Fieldbus instrumentation operates using FISCO (Fieldbus Intrinsically Safe Concept).

Vibration monitoring is provided on the flue gas blowers,  $CO_2$  compressor,  $CO_2$  product send-out pumps, and seawater pumps. X/Y radial vibration is monitored on each pump/blower, gearbox, and motor bearing; thrust bearing position is monitored on each thrust bearing; and a key phasor is installed for each different shaft speed.

### 9.13 External Controls Systems Interfaces _

The DCS interfaces with external controls systems via the redundant interface servers and managed Ethernet switches. The DCS interfaces include Kårstø Gas Plant, CCPP, and CO₂ transport and storage system. These signals are exchanged with the systems at the neighboring facilities for communication of critical alarms and/or process parameters that may affect the other facilities. The detailed Signal Exchange List, 10112936-PB-I-LST-0001 (25474-000-J0-JD-00002), lists the signals that are exchanged.

**10.0-Civil, Structural, and Architectural Features** 

# 10.0 Civil, Structural, and Architectural Features _____

### 10.1 Civil/Structural Design Criteria

#### 10.1.1 Site Work _____

Site preparation for the Kårstø CO₂ Capture and Compression (CCC) Plant is not within the study scope. Additional excavation complies with the requirements in Civil Specification 10112936–FI–B–CON–0244. Erosion control and sediment control are considered minimal due to the rock fill material used in finished grading; however, sediment control is considered in the development of drainage swales. Grading and pavement designs comply with the applicable codes and standards, national highway regulations, and requirements of the Design Philosophy and Acceptance Criteria for Civil Works 10112936–PB–C–TED–0002.

#### 10.1.2 Foundations _____

Reinforced concrete foundations are based on methods prescribed in EN 1992-1-1 and EN 1997-1. Reactions at the base of the superstructure are transferred directly to the supporting foundations. To withstand horizontal loads on the superstructure due to an accident (thermal, impact, explosion), connections at the base of the superstructure are fixed. The foundations are designed to resist the moment that develops at the base of the superstructure.

#### 10.1.3 Structural Steel Design _____

Structural and miscellaneous steel and accessories are in accordance with the requirements established in the Structural Steel and Aluminum Requirements 10112936–FI–B–CON–0245. Steel is used for the design and construction of structural members, connections, and "outfitting" structures or miscellaneous members. Aluminum is not used for these items. The structural steel design is based on methods prescribed in EN 1990 and EN 1993-1. Steel design conforms to EN 10025.

#### 10.1.4 Architectural Criteria

The CCC Plant is designed to accommodate staff for full plant operations. The plant consists mainly of equipment buildings and the control/workshop/stores building.

The design approach for the control/workshop/stores building considers flexibility of workspace, plant views from the building, and explosion-resistant design. This building continues its function even during emergency evacuation. The proposed building materials for this facility are compatible with and complement the existing Naturkraft buildings at the site. The building is designed with steel frames, precast concrete panels, and concrete roof meeting the explosion criteria requirements.

The equipment buildings are designed to enclose the equipment. These buildings are steel framed and enclosed with insulated metal panels and insulated metal roof, which is traditional material for an industrial building. The flooring for equipment buildings is sealed concrete with hardener.

# 10.2 Foundations and Geotechnical Features_____

### 10.2.1 Geotechnical Features_

Geotechnical Report 10112936–FI–B–CON–0121 and supplemental data to that report do not provide geotechnical information for the area denoted on the Appendix E2.1 plan as the CCC Plant B/L (Drawing 10112936–0078-GAD). An additional soil investigation is necessary during the project's engineering, procurement, and construction (EPC) phase.

# 10.2.1.1 General Site Information

The CCC Plant terrain is that of a fully leveled industrialized site and consists of leveled crushed rock with variable depth to bedrock. The existing site elevation, as provided from an independent source, is +6 meters above mean sea level (MSL). The base elevation of the site, or the finished ground/grade elevation, is set at an average of +7 meters. The reference level at Kårstø is 2.29 meters above MSL.

### 10.2.1.2 Groundwater Table

Based on the provided geotechnical report, groundwater is not a consideration in the design of structures and their foundations. The elevation of the groundwater table is taken to be approximately at sea level.

### 10.2.2 Foundations _

The major foundations bear on rock-fill or directly on rock. Based on site grading as indicated in the tender documents, the west side is in cut and the east is in fill. While there is no specific geotechnical data for the area inside the B/L, the adjacent profiles indicate that there is weathered rock at the ground surface.

The allowable bearing pressure for shallow foundations is 190 kN/m². For foundations on rock, it is  $380 \text{ kN/m^2}$ .

Materials used to support footings are compacted to a minimum of 95% of the modified Proctor (NS-EN 1997-1) maximum dry density.

The bottoms of all foundations supporting major equipment or piping are a minimum of 0.9 meter below finished grade for frost protection.

A detailed specific site investigation is required for the design phase, to refine design pressures.

### 10.3 Underground Utilities Considerations _

Table 10.3-1 summarizes CCC Plant underground utility considerations.

	Stan	lding		
System	Material	Design	Material	Design
Seawater Piping	Glass fiber reinforced epoxy resin	ASTM D2996 GR. RTRP-11FE	Sand or lean concrete*	EN 1997-1 and AWWA M45
CO ₂ Piping	Stainless steel	ASTM A312 GR. TP304	Compacted granular material	EN 1997-1
Cable Culverts	Pre-cast concrete	EN 1992-1-1	Compacted granular material	EN 1997-1
Storm water Piping	Pre-cast concrete	EN 1916	compacted granular material	EN 1997-1
Fire Water Piping	Glass fiber reinforced epoxy resin	ASTM D2996 GR. RTRP-11FE	Compacted granular material	EN 1997-1
Potable Water Piping	High density polyethylene	ASTM D3350	Compacted granular material	EN 1997-1

Table 10.3-1 Major Subsurface Utilities

*The seawater line is encased in lean concrete in the area beneath the pipe rack to protect the line during rack installation.

#### 10.3.1 Additional Considerations for Cable Culverts

Electrical and instrument cables are placed in concrete culverts. Sidewalls have blockouts for cable inlets and outlets. The number and positions of blockouts are to be specified. In offsite areas, direct-buried cable trenches may be considered. Culvert walls and top covers are designed to sustain the pressure from backfilling and imposed loads, if any. The culverts are completely filled with sand. Bottom slabs have adequate drainage holes to facilitate surface and ground water movement.

### 10.3.2 Additional Considerations for Piping _____

Underground piping systems are discussed in the mechanical section. If sleepers are required, the design is to be based on geometry and loads (pressure, thermal, etc.) provided by the discipline designing the piping system. Wind loading is a consideration for the sleeper design only if the bottom of the pipe is more than 1 meter above finished grade. Sleepers are to include an embedded steel profile (hot dip galvanized), as support for the pipes.

# 10.4 Structural Materials Selections _____

### 10.4.1 Concrete and Grout _____

Preferred concrete grades for the CCC Plant are shown in Table 10.4-1

 Table 10.4-1
 Concrete Materials

Minimum Grade	Usage	Durability Class	Chloride Class
B30	Blinding layers underneath foundations	M60	C1 1.0
B35	Concrete structures	M45	C1 0.1

#### 10.4.2 Reinforcing Steel ____

Reinforcing steel is deformed bars of billet steel, conforming to NS 3576-3/B500C. Reinforcing and accessories are in accordance with the requirements established in the Civil Specification for the CCC Plant.

### 10.4.3 Anchor Bolts and Embedments _____

Anchor bolts and embedments are cast-in-place. The anchor bolt assembly includes a square anchor plate fixed with bolt, square washer, and two nuts. Requirements and tolerances are listed in Tables 10.4-2 and 10.4-3, respectively.

	Anchor Bolts			Embedments			
Part	Standard	Coating	Part	Standard	Coating		
Bolt	NS-ISO 4014, Grade 8.8	Mechanically galvanized, NS-EN IS01461	Steel plate	NS-EN 10025-2- S235J0+N	One coat of two- pack inorganic zinc-silicate weldable primer		
Square Washer	NS 5277	Mechanically galvanized, NS-EN ISO1461					
Nut	NS-ISO 4032, Grade 10	Mechanically galvanized, NS-EN ISO1461					

Table 10.4-2	Requirements	for Anchor	^r Bolts and	Embedments
--------------	--------------	------------	------------------------	------------

Table 10.4-3	<b>Tolerances</b>	for Anchor	<b>Bolts and</b>	Embedments
--------------	-------------------	------------	------------------	------------

Anchor	Bolts	Embe	edments
Side deviation, complete bolt group	±3 mm	Side deviation	±10 mm
Side deviation between bolts in bolt group	±3 mm	Height deviation	0 mm to -6 mm
Side deviation, single bolt*	±3 mm	Slope deviation*	±3%
Height deviation	+15 mm to -2 mm	Deviation from plane (curvature)*	maximum (L/1000, 3 mm)
Side deviation, top bolt	Maximum (bolt height/250, 2 mm)		

* Note: The plate length/width gives the number of lines where slope deviation and deviation from plane are to be documented:

L = 0-500 mm2 places (both edges)L = 500-1500 mm3 places (edges plus centerline)L  $\geq 1500 \text{ mm}$ 4 places (edges plus two lines on plate)

### 10.4.4 Structural and Miscellaneous Steel _____

Preferred steel grades are shown in Table 10.4-4.

### Table 10.4-4 Steel Materials

Location	Grade
Main members in modules and lift beams	S355J2+N
Secondary steel, angle bracing Miscellaneous pipe supports; site-erected steelwork Outfitting structures (ladders, handrail, etc.)	S235JR
Square hollow sections	S355J2+N

# 10.5 Buildings and Enclosures Design Criteria

Proposed buildings are designed to house the needs of CCC Plant equipment and to accommodate staff for full plant operation. The plant consists of mainly equipment buildings, a control/workshop/stores building, and support structures for process piping and ductwork.

#### 10.5.1 Pre-Engineered Structures_

The continuous emissions monitoring system (CEMS) building, storage sheds, and equipment skids are miscellaneous unmanned steel structures and frames provided to house or support equipment and instrumentation and store nonchemical items. Buildings and structures are designed with regard to the need for inspection, maintenance, cleaning, and repair.

### 10.5.2 Support Structure for Modified HRSG Stack _

The CCC Plant's support structure for the modified heat recovery steam generator (HRSG) stack is an unmanned steel structure, as illustrated in Figure 10.5-1. This structure provides strength and stability for the existing HRSG stack as the stack is modified to introduce a new alternative flue gas duct path. The steel structure also supports the new ductwork plenum that is attached to the modified HRSG stack.

A three-dimensional frame structure is employed to support a large ductwork plenum and the upper portion of the HRSG steel stack. Moment-resisting trusses transfer gravity loads and overturning moments from the stack to the frame's columns.

Along with these trusses, a single braced bay is constructed on the southern side of the frame to transfer all lateral and longitudinal horizontal loads (from wind, temperature, etc.) into the existing foundation as well as additional footings for columns bearing outside the HRSG stack foundation mat.

#### 10.5.3 Ductwork_

The CCC Plant's ductwork is supported by an unmanned steel structure designed to support the flue gas ductwork extending from the modified HRSG stack to the blowers/flue gas absorbers as illustrated in Figure 10.5-2. The steel structure also supports two isolation dampers, a fogger injection system, small piping and instrumentation for the flue gas system, and electrical cable tray for multiple project purposes. Access is provided to the dampers and

fogger system by ladders, platforms, and walkways. Duct supports consist of long-span prefabricated bridges and support towers that allow the duct to span across existing buildings and roads while maintaining clearances.



Figure 10.5-1 Flue-Gas Tie-in



Figure 10.5-2 Ductwork Layout with Support Steel Structure



Figure 10.5-3 CO₂ Stripper Column with Supporting Steel

For the structural steel design, an analytical model is to be constructed using "beam" elements to represent beams/truss chords and columns and "truss" elements to represent vertical and horizontal bracing (members with axial load only).

Manufactured expansion joints are installed periodically to thermally isolate modular duct sections, and ducts are supported in a way that allows thermal movements without over-constrained loads.

#### 10.5.4 Pipe Rack _____

The CCC Plant's pipe rack is an unmanned steel structure designed to support multiple levels of piping along with electrical cable tray extending from the battery limit and servicing the test facility. The structure is stick built on site. In addition, access and egress for a catwalk located on the uppermost level are provided for personnel to access equipment, piping, and instrumentation. Structural arrangements, including locations of expansion joints and anchor bays in the superstructure, suit their locations in piping. Braced bays transfer all longitudinal horizontal loads from wind, temperature, pipe anchors, etc., to the foundations.

#### 10.5.5 Compressor Building_____

The compressor building is capable of housing equipment such as the compressor, storage drums, and pumps and is required for noise reduction. Acoustical walls, roof insulation, and acoustical louvers are provided for noise reduction. Laydown areas are provided to enable easy handling/transportation during maintenance and repair. Overhead cranes or hoists are provided as required for maintenance. Internal and external explosions are taken into account.

#### 10.5.6 Flue-Gas Blower Enclosures ____

The flue-gas blower enclosures are buildings with flat roofs capable of housing the blowers and ancillary equipment. The enclosures are intended for noise reduction.

#### 10.5.7 Control/Workshop/Stores Building _____

The control/workshop/stores building is a single-story structure with a flat roof that houses control equipment, offices, meeting room, consumable and spare part (nonchemical) storage items, document storage room, and mechanical and other workshop areas. The building also houses the central control room (CCR) and rest rooms, including the kitchen/canteen facilities. The CCR and other rooms for installation of electrical/instrumentation cabinets are designed with a false floor. The CCR is designed to withstand accidental loads from explosions and earthquakes.

#### 10.5.8 Electrical Building_

The electrical building is a two-story structure with a flat roof and an elevated concrete floor that houses the electrical switchgear. Switchgear and other electrical equipment are located on the elevated floor, and a cable spreading room occupies the ground floor.

Oil-filled transformers are supported on reinforced concrete foundations located outside the building and are separated by a fire wall. The foundation supporting the transformers incorporates transformer rails (when applicable) for ease of transportation and placement. Transformers are fixed to the foundations with anchor bolts. Each transformer foundation slopes and has raised borders that enclose an oil pit in which the oil content of the transformer can be carried in the event of an oil leak. Above the oil pit, a minimum 20 cm thick gravel layer on a steel grating is provided. The oil pits drain into a central oil-collecting pit with integrated oil separator. The oil collecting pit is sized to hold the oil capacity of the largest transformer.

#### 10.5.9 Tank Bund Area ___

The bund area is a reinforced concrete structure providing a diked area for chemical storage. The area is capable of collecting the larger of 110% of the inventory of the largest tank within the bund or 25% of the volumes of all the tanks within the bund.

### 10.6 Building and Enclosure Layouts_

The CCC Plant is laid out to accommodate the spaces required for equipment access and to maintain and operate the plant. Access aisles and clearances are provided to accommodate operations and maintenance and equipment removal. The plant includes paved roads to access the buildings. Roof access is provided for equipment maintenance purposes only.

Provisions are also made for personnel walkways to equipment (for routine maintenance only), doors, stairs/fixed ladders, and other access points. Vertical access hatches are located to facilitate moving equipment and materials. Fire separation walls and floors are provided in accordance with code requirements. Plant security and life safety features are also considered in the plant layout. Recommended building and enclosure sizes are listed in Table 10.6-1.

Building/	Dimensions			Exterior Envelope		
Enclosure	Length	Width	Height	Wall	Roof	
Control/ Workshop/ Stores	63.4 m	22.2 m	9.5 m/ 5.0 m	Pre-cast concrete/ concrete masonry	Membrane roofing with concrete roof deck	
Flue Gas Blower buildings	20.8 m	20.0 m	10.0 m	Insulated metal siding with interior liner panels	Membrane roofing over metal deck with insulation	
CO ₂ Compressor Building	45.0m	20.0 m	10.0 m	Insulated metal siding with interior liner panels	Insulated standing-seam metal panels	
Electrical building	27.0 m	20.0 m	6.0 m	Same as CO ₂	Same as CO ₂	

 Table 10.6.1 Buildings and Enclosure Sizes

# 10.7 Building Architectural Features _

The CCC Plant is located on a site surrounded by an industrial complex and in proximity to the ocean and hills. The proposed plant is to be built east of an existing plant. The design and selection of the exterior envelope, including texture and colors for the buildings, is to blend with the existing facility and surrounding nature. The new plant is to exhibit subtle differences to reflect its special characteristics.

The exterior color for the equipment buildings is shades of blue to complement the existing equipment buildings. For the control/ workshop/stores building, the pattern of precast concrete panels, with variance in textures and combination of horizontal and vertical bands of different color, enhances the visual aesthetics of the building and blend with existing buildings at the site.

The CCR and administration areas have wide corridors and clear exits designed in simple linear formation to make emergency evacuation easier. The control/workshop/stores building is designed in full compliance with accessibility requirements. The office spaces used by permanent staff are designed with permanent partitions, and open offices are designed with system furniture for plant employees and visitors. The office floor has carpet and tile, and the CCR has recessed access flooring. Kitchen, restrooms, showers, and lockers have ceramic tile flooring. The workshop and stores area and the mechanical room have sealed concrete flooring with hardener.

Table 10.7-1 indicates the recommended finishes for the main areas.

		W	/alls	Ceili	ng
Area	Floor	Material	Finish	Material	Height
Administration Area	Carpet	Drywall	Paint	Acoustical ceiling tile	2.75 m
Conference Room	Carpet	Drywall	Paint	Acoustical ceiling tile	2.75 m
Offices	Carpet	Drywall	Paint	Acoustical ceiling tile	2.75 m
CCR	Access Floor	Drywall	Paint	Acoustical ceiling tile	2.75 m
Canteen/Staff/ Social Room	Vinyl tile	Drywall	Paint	Acoustical ceiling tile	2.75 m
Kitchen	Unglazed Ceramic tile	Drywall	Ceramic tile/paint	Acoustical ceiling tile	2.75 m
Toilet/Shower/Lockers	Unglazed Ceramic Tile	Drywall	Ceramic tile	Drywall ceiling	2.75 m

Table 10.7-1 Interior Finishes

		Walls		Ceiling	
Mechanical/ Maintenance Area	Concrete Floor	CMU/ drywall	Paint	Exposed	-
Workshop/Store Area	Concrete Floor	CMU/ drywall	Paint	Exposed	-
Equipment Buildings	Concrete Floor	Interior line	Paint/ prefinished	Exposed	-

# 10.8 Building HVAC, Utilities, and Services ____

### 10.8.1 Ventilation and Heating_

#### 10.8.1.1 Compressor Building

The CCC Plant's  $CO_2$  compressor building has wall-mounted ventilation supply fans. Air is exhausted through the wall-mounted back-draft dampers. The air circulation is from an upper building elevation out through the exhaust dampers located near grade. Each supply fan assembly consists of an inlet hood, motorized intake louver, replaceable filter (if required), differential pressure switch, and thermostat. The fan automatically cycles from the thermostat setting.

Thermostatically controlled electric unit heaters are provided to maintain the indoor temperature at 10 °C during the winter.

In the event of a fire or combustible gas detection, the supply air fans automatically trip. Also, the electric unit heaters remain in their previous operating state. In the event of a CO₂ leak, the supply air fans continue to operate or are automatically started to aid in venting the building of CO₂. Reference the Fire and Gas System Cause and Effect Diagram 10112936-PB-I-DGM-0002 (25474-000-J4-JD-00002).

#### **10.8.1.2** Flue-Gas Blower Enclosures

The flue gas blower buildings have wall-mounted ventilation supply fans. Air is exhausted through wall-mounted back-draft dampers. Each supply fan assembly consists of an inlet hood, motorized intake louver, replaceable filter (if required), differential pressure switch, and thermostat. The fan automatically cycles from the thermostat setting.

Thermostatically controlled electric unit heaters are provided to maintain the indoor temperature at 10 °C during the winter.

In the event of a fire or combustible gas detection, the supply air fans automatically trip as noted in the Fire and Gas System Cause and Effect Diagram 10112936-PB-I-DGM-0002 (25474-000-J4-JD-00002). Also, the electric unit heaters remain in their previous operating state.

# 10.8.1.3 Control/Workshop/Stores Building

The workshop and stores areas of the control/workshop/stores building have wall-mounted ventilation supply fans. Air is exhausted through wall-mounted back-draft dampers. Each supply fan assembly consists of an inlet hood, motorized intake louver, replaceable filter (if required), differential pressure switch, and thermostat. The fan automatically cycles from the thermostat setting.

Thermostatically controlled electric unit heaters are provided to maintain the indoor temperature at 10 °C during the winter.

In the event of a fire or combustible gas detection, the supply air fans automatically trip as noted in the Fire and Gas System Cause and Effect Diagram 10112936-PB-I-DGM-0002 (25474-000-J4-JD-00002). Also, the electric unit heaters remain in their previous operating state.

# 10.8.2 Heating, Ventilating, and Air Conditioning_

# 10.8.2.1 Control/Workshop/Stores Building

The CCR and administrative areas of the control/workshop/stores building have 2 x 100%, thermostatically controlled, packaged heating, ventilating, and air-conditioning (HVAC) units. Each unit consists of a condensing unit, an air-handling unit, an electric heater, and an intake filter assembly. The conditioned air is supplied through a network of ductwork, dampers, and supply diffusers/registers grills. The return air from the CCR and offices is routed back to the HVAC unit through return air ductwork. Air from areas such as the locker rooms, toilets, kitchen, mechanical room, instrumentation and controls shop, etc., is not included in the return air ducting back to the HVAC units. The air-conditioned areas are maintained at 25 °C  $\pm$ 1.7 °C and 60% relative humidity (summer) and 21 °C 1.7 °C and 60% relative humidity (winter).

In the event of a fire, combustible gas, or CO₂ gas detection, the HVAC system automatically shuts down. Reference the Fire and Gas System Cause and Effect Diagram 10112936-PB-I-DGM-0002 (25474-000-J4-JD-00002).

# 10.8.2.2 Electrical Building

The electrical building has 2 x 100%, thermostatically controlled, packaged HVAC units. The air-conditioned areas are maintained at same conditions as stated in Subsection 10.8.2.1. The HVAC supply is ducted to the low and medium voltage equipment areas, uninterruptible power supply (UPS), and battery charger area, as well

as the adjacent battery room. The battery room also has  $2 \times 100\%$  exhaust fans. The entire supply air from the battery room is exhausted outside. The fans are sized to limit the hydrogen concentration below 2% by volume. A fan malfunction alarm is provided in the plant DCS.

In the event of a fire, combustible gas or CO₂ gas detection, the HVAC system automatically shuts down. Reference the Fire and Gas System Cause and Effect Diagram 10112936-PB-I-DGM-0002 (25474-000-J4-JD-00002).

### 10.9 Access, Paving, and Landscaping _____

#### 10.9.1 Access Roads and Paved Areas ____

The CCC Plant site is located at Kårstø in the municipality of Tysvær on the southwest coast of Norway. The CCC Plant B/L extends 221 meters by 100 meters, with the southwest corner of the plot located at N4900 and E20552 on the Kårstø site local coordinate system. There are four means of access and egress for the site, which are designated in the Access Road and Finish Grading Plan 10112936-PB-C-TED-0005.

Table 10.9-1 indicates the types of roads and paved surfaces within the B/L. The designs, cross-section(s), materials, and compaction requirements comply with recommendations contained in Section 5.2 of the Design Philosophy and Acceptance Criteria for Civil Works 10112936-PB-C-TED-0002.

Туре	Material	Description
Main Plant Access Road	Asphalt gravel	Main plant access roads serve as through roads as specified by the plant layout.
Main Service Road	Asphalt gravel	Main service roads provide primary access to the process areas, buildings, and equipment.
Module Road	Asphalt Concrete	Module roads provide transport for modules and other heavy equipment.
Service Road	Asphalt gravel	Service roads provide secondary access to the process areas, buildings, and equipment.
Walkways	Concrete	Walkways provide access, by foot, along all main plant access roads and between plant facilities.
Light-duty Paving	Concrete	These are paved areas subject to chemical spillage; they include retention curbs.
Parking Areas	Asphalt gravel	There are a minimum of 12 parking places within the CCC Plant area.

 Table 10.9-1
 Type of Roads and Paved Surfaces

#### 10.9.2 Landscaping_

The site is to be landscaped with trees, shrubbery, and bushes to enhance the plant appearance and improve building appearance from the road. The west elevation of the control/workshop/stores building is to have paved sidewalk and be landscaped with shrubs.

# 10.10 Painting and Coating Requirements_____

Table 10.10-1 summarizes CCC Plant painting and coating requirements.

Description	Primer	Finish Coat	Color
Outdoor structural and miscellaneous steel, including platforms, pipe racks, and support structure for ductwork	75–125 µm of ethyl silicate inorganic zinc	100 μm of epoxy and 75 μm of polyurethane	Shades of blue
Indoor structural and miscellaneous steel	75–125 μm of ethyl silicate inorganic zinc	N/A	Shades of gray
Outdoor carbon steel hangers and supports exposed to water immersion or splash and spillage <50 °C	150–200 μm of high-build catalyzed epoxy	150–200 µm of high-build catalyzed epoxy	Shades of blue
Control building: precast concrete wall panels	N/A	N/A	Shades of beige and blue
Control building: roof	N/A	N/A	Black
Equipment buildings: wall panels (prefinished PVDF2)	N/A	N/A	Shades of blue
Equipment buildings: roof panels (prefinished PVDF2)	N/A	N/A	Black
Doors and windows and trim	Tie coat of universal primer	Polyurethane finish	Shades of off white

 Table 10.10-1
 Painting/Coating Recommendations

**11.0-Overall Facility Performance**
# **11.0** Overall Facility Performance

# 11.1 CCC Plant Reliability, Availability, and Maintainability Analysis _

The methodology used to assess the reliability of the Kårstø CO₂ Capture and Compression (CCC) Plant is based on the traditional reliability, availability, and maintainability (RAM) analysis provided for power plants. The plant is first divided into systems, and a reliability block flow diagram is constructed to depict the system configuration. Each block is then further broken down into components. Figure 11.1-1 is the overall reliability block flow diagram for the proposed plant. The plant is divided into seven systems as follows:

- Direct contact cooler
- Flue gas blowers
- Absorber tower
- Stripper tower
- Compressor and dryer
- Send-out pumps
- Balance of plant



#### Figure 11.1-1. Overall Reliability Block Flow Diagram

The reliability of each system is calculated based on its configuration and component reliability data. The reliability of the entire plant is the aggregate of all seven systems.

Based on the RAM analysis, the single equipment item that has the largest potential reliability loss is the  $CO_2$  compressor. Due to the high cost of this equipment, a redundant compressor has not been provided. If the 1 week of scheduled outage every 2 years is scheduled to

coincide with the power plant scheduled outage, the overall  $CO_2$  plant reliability is 99.33%. This high reliability is the result of having 100% installed redundancy for all pumps, including the  $CO_2$  send-out pumps. If the scheduled outage is included in the availability losses, the availability is reduced to 98.39%.

# 11.2 Emissions_

The CCC Plant employs a 35% (wt) aqueous solution of monoethanolamine (MEA) to capture CO₂ gas from the diverted flue gas stream of a combined cycle, natural-gas-fired turbine power plant.

MEA and ammonia emissions from the absorber outlet are 2.99 and 4 ppm, respectively, which are less than the 5 ppm limit stipulated in the owner's design basis. The process configuration could be modified to reduce these emissions further with some additional capital expenditure. These options are to be pursued in the engineering, procurement, construction, and installation (EPCI) phase.

The plant is expected to generate airborne, liquid, and solid wastes under normal operating conditions. The amine system emissions are summarized in Table 11.2-1.

Emission	Flow Rate	Flow Type	Annually Emitted Quantity	
Airborne				
Oxygen	182,472 kg/h	Continuous	3.197E+09 kg	
Nitrogen	932,643 kg/h	Continuous	1.634E+10 kg	
Water	65,918 kg/h	Continuous	1.155E+09 kg	
Carbon Dioxide	10,961 kg/h	Continuous	1.920E+07 kg	
Sulfur Dioxide	0.28 kg/h	Continuous	4.872E+03 kg	
MEA	7.79 kg/h	Continuous	1.364E+05 kg	
Argon	15,206 kg/h	Continuous	2.664E+08 kg	
NO	4.23 kg/h	Continuous	7.406E+04 kg	
NO ₂	1.06 kg/h	Continuous	1.851E+04 kg	
Ammonia	2.99 kg/h	Continuous	5.246E+04 kg	
Liquid				
Lubricating Oil	To be determined in EPCI	Intermittent	To be determined in	
	phase		EPCI phase	
Solid				
Reclaimer Waste (3)	225 kg/h	Intermittent	1.971E+06 kg	
F-101 Filter Cartridges (4)	14 elements/change	Intermittent	28 elements	
F-102 Filter	57 elements/change	Intermittent	114 elements	
Cartridges (4)				
F-105 Filter Cartridges (4)	57 elements/change	Intermittent	114 elements	
Activated Carbon	21,736 kg/month	Intermittent	2.608E+05 kg	

 Table 11.2-1
 Exhaust and Emissions Summary

Emission	Flow Rate	Flow Type	Annually Emitted Quantity
Desiccant (5)	3,835 kg total for both vessels	Intermittent	(5)

Notes:

- Emissions from the absorber towers are expected to contain small amounts (< 1 ppmv per component) each of piperazine, formaldehyde, and acetaldehyde. These are decomposition products of amine degradation reactions that occur in the circulating process streams over time.
- 2. Annually emitted quantity is based on 8,760 hours per year operation for continuous operations.
- 3. Figure is based on 170.5 kg/hr of sludge on a dry basis. Additional quantity includes flushing water. Annually emitted quantity is based on 8,760 hours per year operation for continuous operations. Waste is emitted intermittently.
- 4. Filters are changed semi-annually.
- 5. Desiccant run length is between 3 and 5 years.

#### 11.3 Noise _____

#### 11.3.1 Plant Noise Requirements _____

The environmental noise emissions from the CCC Plant comply with an overall A-weighted sound power level of 113 dBA. During nighttime operation, the noise emissions comply with a sound pressure level of 40 dBA at the nearest residential property, which is located approximately 700 meters toward the northeast from the CCC Plant.

Noise exposure limits are based on a LAeq8  $\leq$  85 dB(A). The working environment area noise limits are assessed based on NORSOK standard S-002 recommended values.

#### 11.3.2 Noise Assessment ____

The noise emission solely from the CCC Plant at the nearest residential property (700 meters toward the northeast from the CCC Plant) was assessed based on the contribution from major noise producing equipment. See the Coarse Noise Evaluation Report document number 10112936-PB-S-HSE-0012 (25474-000-U0Y-0000-00004). The following major noise sources were identified and are considered in the noise study:

- Heat recovery steam generator (HRSG) outlet
- Flue gas blowers
- CO₂ compressors
- Building ventilation
- Seawater pumps

The following noise transmission paths are also identified and accounted for in the noise assessment:

- In-duct noise from the HRSG outlet and flue gas blowers transmitted through the flue gas ductwork, absorber shells, and absorber stack exits
- Casing-radiated acoustic energy from blowers and compressors transmitted though building walls, roofs, and ventilation openings

#### 11.3.3 Noise Mitigation _____

To meet the sound power level of 113 dBA for the CCC Plant, the following noise mitigation requirements are identified for the major noise emitting equipment:

- Acoustic lagging of flue gas ductwork
- Acoustic lagging of absorber shells
- Acoustic silencer on absorber stack exit
- Acoustical wall and roof assemblies for blower buildings
- Acoustical wall and roof assemblies for compressor building
- Low noise ventilation fans
- Acoustical building ventilation louvers
- Low noise emergency diesel generator
- Low noise auxiliary boiler

# 11.4 Guarantees on Key Parameters_____

#### 11.4.1 Limits by Design_

The following limits by design are identified:

- There is an emission limit of 5 ppmvd amine from the absorbers, and trace amounts of other constituents are permitted. No permit limits have been established since the Owner is in process of preparing the permit application.
- Design complies with the limit for a maximum seawater discharge temperature of 21°C.
- Far-field noise limit for the CCC Plant only is 40 dBA at 700 meters from the nearest receptor. Near-field equipment design limit is 85 dBA at 1 meter.

#### 11.4.2 Guarantees—Expected for EPCI Phase_

No performance guarantees are provided. These can be addressed after the contract terms and liquidated damage (LD) levels are established.

- Availability (currently a minimum of 97% by contract)
- CO₂ capture rate (currently a minimum of 85% by contract)
- CO₂ purity (currently a minimum of 99.6% by contract)
- Overall solvent loss
- Steam consumption
- Electric power consumption
- Sea water consumption
- Emissions to air
- Emissions to sea water
- Hazardous waste level and quantity
- Liquid effluent discharges

No  $NO_x$ ,  $SO_x$ , CO,  $CO_2$ , or any other CCPP exhaust gas emission limits are expected to be imposed on the CCC Plant.

**12.0-Materials Technology** 

# 12.0 Materials Technology _____

# 12.1 Corrosion Evaluations ____

The purposes of the corrosion evaluations are to determine the corrosivity of the fluids in the Kårstø  $CO_2$  Capture and Compression (CCC) Plant's main process systems and to indicate the materials of construction and the paints and coatings to be specified for items of equipment and piping in these systems to mitigate against the effects of corrosion. The systems addressed are:

- Amine service
- CO₂ service
- Utility services

#### 12.1.1 Amine Service_

#### 12.1.1.1 Pressure Boundaries, Internals, Piping, and Valves

Due to the corrosivity of amines, particularly the rich amine streams containing a high loading of CO₂, solid Type 304L stainless steel (SS) is recommended for all pressure-boundary and internals materials for all vessels, drums, heat exchangers, and pumps exposed to amines. This recommendation also applies to all amine service piping and valves. However, depending on vessel, drum, or heat exchanger shell thickness, it may be more cost-effective to use carbon steel clad with 1/8 inch of Type 304L SS. For non-welded internals or other non-welded components, Type 304 SS is acceptable and may be used. Substituting Type 316L/316 SS for Type 304L/304 SS is acceptable because of the superior corrosion resistance of Type 316L/316 SS.

#### 12.1.1.2 Heat Exchangers

Plate heat exchangers in amine service cooled with seawater must be fabricated from titanium plate materials. Due to the high chloride content of seawater, the use of any of the 300 Series stainless steels is unacceptable. These materials are susceptible to pitting, crevice corrosion, and chloride stress corrosion cracking in chloride-bearing media like seawater.

Plate exchangers that are strictly in amine service, such as the rich/ lean exchangers, may be fabricated from Type 304 or 316 SS.

#### 12.1.1.4 Pumps

Amines, and particularly rich amine, are corrosive and become even more corrosive as fluid velocity increases. Therefore, amine service pumps and piping must be constructed of stainless steel materials. Cast material shall conform to grade CF8 or CF8M (CF3 or CF3M if welded and not solution-annealed after weld repair), and wrought material shall conform to Type 304 or 316 SS (Type 304L or 316L SS if welded).

#### 12.1.1.5 Towers

Towers like the  $CO_2$  stripper are in very corrosive service because the rich amine is flashed as it enters the tower and the amine is further stripped by steam. The released  $CO_2$  is free to combine with water vapor as it moves up the tower, and it forms carbonic acid in the tower and overhead system. The tower and all equipment and piping in the overhead system are exposed to carbonic acid and must be fabricated from Type 304L SS.

#### 12.1.1.6 Absorber

The lean amine stream from the  $CO_2$  stripper is recycled back to the absorber. While most of the  $CO_2$  has been removed from this stream, the lean amine still contains some  $CO_2$  and amine degradation compounds and thus is corrosive; consequently the absorbers must be fabricated from Type 304L SS. The lean amine that is recycled back to the absorber combines with the  $CO_2$  from the flue gas to form a corrosive rich amine in the absorber. Both the absorber tower and the equipment and piping handling the rich amine stream that leaves the tower for the  $CO_2$  stripper must be fabricated from Type 304L SS.

#### 12.1.2 CO₂ Service

#### 12.1.2.1 Vessels, Drums, Shells, and Piping

When saturated  $CO_2$  condenses in the overhead system, it forms carbonic acid. Carbonic acid is very corrosive toward carbon steel. Therefore, vessels, drums, exchanger and condenser shells, and piping in  $CO_2$  service, such as the overhead system of the  $CO_2$  stripper, are fabricated from Type 304L SS.

#### 12.1.2.2 $CO_2$ Compression Section

To combat carbonic acid in the CO₂ compression section, carbon steel is recommended for the shell-side of the steam generators, with stainless steel for the tube-side materials. In the seawater-cooled intercoolers, titanium, Sea-Cure, or AL6XN alloy is recommended for the tubes to resist seawater corrosion, and stainless steel (Type 304L SS) is recommended for the shell-side materials for carbonic acid resistance. Piping and drums in the compression section in contact with saturated  $CO_2$  or carbonic acid are fabricated from stainless steel to resist carbonic acid corrosion.

#### 12.1.2.3 Drying and Compression Section

In the drying and compression section, the recommended materials of construction for the steam generators, seawater-cooled intercooler, drums, and piping are the same as specified above. Because the gas has been dried in this portion of the system, stainless steel is specified for low-temperature service due to the potential for depressurization and auto-refrigeration should the system develop a leak.

#### 12.1.3 Utility Services ____

#### 12.1.3.1 Steam, Condensate, and Nitrogen Service Piping

Steam, condensate, and nitrogen service piping is recommended to be ASTM A106 Gr. B or ASTM A53 Gr. B, with 1.2 mm (0.050 inch) corrosion allowance. Valves must have a cast steel body, ASTM A216 WCB, with F6 valve trim.

# **12.1.3.2** Compressed Air, Process Water, Amine Waste, and Wastewater Piping

The material for compressed air, process water, amine waste, and wastewater piping is recommended to be ASTM A106 Gr. B or ASTM A53 Gr. B, with a corrosion allowance of 3 mm (1/8 inch). Instrument air piping must be Type 304/304L SS.

# 12.1.3.3 Fire Water, Seawater Cooling Water, and Potable Water Piping

Fire water and seawater cooling water piping is recommended to be glass-reinforced plastic (GRP). Potable water piping is recommended to be polyvinyl chloride (PVC) or chlorinated PVC (CPVC). For outdoor exposure, ultraviolet (UV)-resistant grades are used.

#### 12.1.4 Paints and Coatings_

Description	Surface Preparation	Primer	Finish Coat
1.0 Structural and Miscellaneous Steel			
1.1 Platform steel, pipe, and cable racks – indoor	SP 10/SA 2.5	75–125 µm of ethyl silicate inorganic zinc	N/A

#### Table 12.1-1 Paintings and Coatings

	Surface		
Description	Preparation	Primer	Finish Coat
1.2 Platform steel, pipe, and cable racks – outdoor	SP 10/SA 2.5	75–125 µm of ethyl silicate inorganic zinc	100 µm of epoxy and 75 µm of polyurethane
1.3 High strength (A-490) nuts and bolts – indoor	N/A	100 µm epoxy mastic	N/A
1.4 High strength (A-490) nuts and bolts – indoor	N/A	75 μm epoxy mastic	75 μm of epoxy and 75 μm of polyurethane
1.5 Miscellaneous nuts and bolts other than A-490 – indoor	N/A	hot-dip galvanized ASTM A 123, or mechanically galvanized per ASTM B695	N/A
1.6 Miscellaneous nuts and bolts other than A-490 –outdoor	N/A	mechanically galvanized per ASTM B695	75 μm of epoxy and 75 μm of polyurethane
1.7 Carbon steel surfaces exposed to splash and spillage <50 °C – indoor or outdoor	SP 10/SA 2.5	150–200 µm of high-build catalyzed epoxy	150-200 μm high- build catalyzed epoxy
1.7 Carbon steel surfaces exposed to water immersion <60 °C	SP 5/SA 3	250–375 μm of high-build catalyzed epoxy	250–375 μm high- build catalyzed epoxy
2.0 Piping and Valves			
2.1 Non-insulated carbon steel piping and valves, including hangers and supports, <400 °C – indoor	SP10/SA 2.5	silicate inorganic zinc	N/A
2.2 Non-insulated carbon steel piping and valves, including hangers and supports, <104 °C – outdoor	SP10/SA 2.5	75-125 μm of ethyl silicate inorganic zinc	75 μm of epoxy and 75 μm of polyurethane
2.3 Non-insulated carbon steel piping and valves, including hangers and supports, >104 °C to <400 °C – indoor/outdoor	SP10/SA 2.5	75-125 μm of ethyl silicate inorganic zinc	two coats, 25– 40 µm per coat, of high-temperature silicone
2.3 Non-insulated stainless steel piping and valves <104 °C – outdoor (hangers and supports per 2.1)	sweep blast (SP 7)	150-200 µm of high-build catalyzed epoxy	optional 75 µm of polyurethane
2.4 Non-insulated stainless steel piping and valves <104 °C – indoor (hangers and supports per 2.1)	SP10/SA 2.5	N/A	N/A
2.5 Insulated stainless steel piping and valves <121 °C – outdoor (hangers and supports per 2.1)	sweep blast (SP 7)	150–200 µm of high-build catalyzed epoxy	N/A
2.6 Insulated stainless steel piping and valves <121 °C – indoor (hangers and supports per 2.1)	N/A	N/A	N/A
2.6 Insulated carbon steel piping and valves >121 °C to <400 °C - indoor (hangers and supports per 2.1 or 2.2)	mfr std	mfr std	N/A
2.7 Insulated carbon steel piping and valves <121 °C – outdoor (hangers and supports per 2.1 or 2.2)	SP10/SA 2.5	150-200 µm of high-build catalyzed epoxy	N/A

	Surface				
Description	Preparation	Primer	Finish Coat		
2.8 Insulated carbon steel piping	SP10/SA 2.5	75–125 µm of ethyl	N/A		
and valves >121 °C to		silicate inorganic			
<400 °C – outdoor (hangers		ZINC			
and supports per 2.1 or 2.2)					
3.1 Non-insulated large (>5 m ² )	SP10/SA 2.5	100-15 0 µm rust-	75-100 microns of		
carbon steel mechanical	,	inhibitive catalyzed	epoxy intermediate		
equipment and associated		epoxy primer	and 75–125 µm of		
components, including			polyurethane		
or outdoor					
3.2 Non-insulated large (>5 m ² )	SP10/SA 2.5	75-125 µm of ethyl	two coats, 25-40		
carbon steel mechanical		silicate inorganic	µm per coat, of high-		
equipment and associated		zinc	temperature silicone		
components, including					
$<400 \ ^{\circ}C$ – indoor or outdoor					
3.3 Non-insulated stainless steel	SP 10/SA 2.5	150-200 µm of	optional 75 µm of		
mechanical equipment and		high-build catalyzed	polyurethane		
associated components,		ероху			
including supports, <104 °C					
3.4 Non-insulated stainless steel	N/A	N/A	N/A		
mechanical equipment and	,	,	,		
associated components,					
Including supports – Indoor	mfretd	mfr.ctd.cuitable.for	mfrietd cuitable for		
carbon steel mechanical	iiiii stu	exposure conditions	exposure conditions		
equipment and associated					
components, including					
supports, to <400 °C –					
3.6 Non-insulated amine and	SP 10/SA 2 5	250-300 um of	250-300 um of		
other chemical skid steel –	01 10/0/12:0	chemical-resistant	chemical-resistant		
indoor/outdoor		coatings	coatings		
3.7 Insulated carbon or stainless	mfr std	mfr std	mfr std		
and associated components					
including supports, to					
<400 °C – indoor					
3.8 Insulated carbon or stainless	SP 10/SA 2.5	150-200 µm of	N/A		
steel mechanical equipment		high-build catalyzed			
including supports <121 °C		ероху			
- outdoor					
3.9 Insulated carbon or stainless	mfr std	mfr std	mfr std		
steel mechanical equipment					
and associated components,					
to <400 °C – outdoor					
4.0 Tanks and Vessels	1		1		
4.1 Non-insulated shop	SP10/SA 2.5	100-150 µm rust-	75-100 microns of		
fabricated carbon steel tanks		inhibitive catalyzed	epoxy intermediate		
and vessels <104 °C -		epoxy primer	olvurethane		
4.2 Non-insulated shop	SP10/SA 2.5	100-150 um rust-	75-125 µm of		
fabricated carbon steel tanks	,	inhibitive catalyzed	polyurethane		
and vessels <104 °C -indoor		epoxy primer			
4.3 Non-insulated field erected	SP10/SA 2.5	100–150 µm rust-	75–100 microns of		
carbon steel tanks and		enoxy primer	and 75-125 up of		
VESSEIS \104 C - UUUUUI			polyurethane		

	Surface			
Description	Preparation	Primer	Finish Coat	
4.4 Non-insulated shop	sweep blast	150-200 µm high-	optional 75 µm of	
fabricated stainless steel	(SP 7)	build catalyzed	polyurethane	
tanks and vessels <104 °C -		epoxy		
4.5 Non-insulated shon-	N/A	N/A	N/A	
fabricated stainless steel	1.97	1.97	Ny / Y	
tanks and vessels – indoor				
4.4 Insulated shop-fabricated	mfr std	mfr std	mfr std	
carbon steel tanks and				
Vessels <121 °C - Indoor		150, 200 um high	NI / A	
carbon steel tanks and	3F 10/3A 2.5	build catalyzed	N/A	
vessels <121 °C – outdoor		epoxy		
4.6 Insulated shop-fabricated	SP 10/SA 2.5	150–200 µm high-	N/A	
stainless steel tanks and		build catalyzed		
vessels <121 °C – outdoor		ероху		
4.7 Insulated shop-fabricated	SP10/SA 2.5	75–125 µm of ethyl	N/A	
$x = x^{2}$		zinc		
- outdoor		200		
4.8 Interior of carbon steel tanks	corrosion-resista	ant coating materials or a	alloy materials	
and vessels	suitable for the	design conditions		
5.0 Pumps and Motors	0040/0405	75 400	75 400 6	
5.1 Non-insulated pumps,	SP10/SA 2.5	75–100 µm rust-	75-100 µm of	
$<104 ^{\circ}\text{C}$ – outdoor		epoxy primer	and 75–125 um of	
		open, primer	polyurethane	
5.2 Non-insulated pumps,	mfr std	mfr std	mfr. std	
motors, and supports				
<400 °C –indoor		450,000	NI / A	
5.3 Insulated pumps <121 °C -	SP10/SA 2.5	150-200 µm mgn- build catalyzed	N/A	
		epoxy		
6.0 Electrical and Control	I			
6.1 Switchgear, motor control	mfr std	manufacturer's standa	ard primer and finish	
centers, chargers, inverters,		or 125–175 µm powder coatings suitable		
Switchboards, local devices,		for service and enviror	nmental conditions	
cabinets, etc.				
6.2 Boards/consoles and other	mfr std	manufacturer's standa	ard primer and finish	
associated components		or 125–175 µm powder coatings suitabl		
	6	for service and enviror	nmental conditions	
6.3 Miscellaneous electrical and	mfr std	manufacturer's standa	ard primer and finish	
control instruments		environmental conditions		
6.4 Power transformers,	SP10/SA 2.5	75–100 µm rust-	75–100 µm of	
enclosure/modules, and		inhibitive catalyzed	epoxy intermediate	
large (>5 m ² ) electrical		epoxy primer	and 75–125 µm of	
equipment		dolugoized with start	polyurethane	
5.5 Cable trays, cable tray	N/A	coating or optional FR	P or PVC (conduits	
conduits		and pull boxes)		
6.6 Electrical motors – indoor or	mfr std	epoxy primer and epox	ky or polyurethane	
outdoor		topcoat		
7.0 Miscellaneous Steel	7.0 Miscellaneous Steel			
r.⊥ Outdoor platform grating,	per code	not-up gaivanized to	IN/A	
- indoor or outdoor		705 g/m ² per ASTM		
		A123 or equivalent		
		ISO standard		

	Surface		
Description	Preparation	Primer	Finish Coat
7.2 Platform handrails, stair steel, and ladders – indoor	SP10/SA 2.5	hot-dip galvanized to a minimum of 705 g/m ² per ASTM A123 or equivalent ISO standard	N/A
7.3 Platform handrails, stair steel, and ladders – outdoor	SP10/SA 2.5	hot-dip galvanized to a minimum of 705 g/m ² per ASTM Aa123 or 75–100 µm rust-inhibitive catalyzed epoxy primer	75–100 μm of epoxy intermediate and 75–125 μm of polyurethane
7.4 Grating for chemical trench and sump (non-vehicular traffic)	FRP		

#### 12.2 Durability Report

This section outlines the philosophy employed in specifying metallic materials of construction and paint/coating materials for equipment and piping for the CCC Plant.

#### 12.2.1 Materials of Construction

#### 12.2.1.1 Amine Service

The specific metallic materials of construction for equipment and piping in amine service depends on the specific amine chosen to selectively remove  $CO_2$  and the design temperature/pressure conditions necessary in the process to optimize amine performance.

For this particular project, Type 304/304L SS was selected as the minimum required material of construction for all items of equipment and piping in amine service. Depending on the specific amine, for example monoethanolamine (MEA) or diethanolamine (DEA), carbon steel materials with post-weld heat treatment (PWHT) and specified corrosion allowances can also be used. But even with these amines, stainless steel material is often required for the rich-amine service portion of the process, depending on temperature and amine loading. To provide maximum flexibility and the ability to accommodate the use of any amine package, stainless steel materials of construction have been recommended. It is important to note that in welded applications, Type 304L SS is required. The use of L-grade material minimizes sensitization of the weld heat-affected zone (HAZ) during fabrication, resulting in welds that maintain the required corrosion resistance.

#### 12.2.1.2 Seawater Cooling Water Service

For seawater, using the standard 300 Series stainless steels is not viable because these materials are susceptible to severe pitting and crevice corrosion in the marine environment. These materials are also susceptible to chloride stress corrosion cracking when temperatures exceed 50 °C. Numerous duplex and super-austenitic stainless steel materials exhibit excellent resistance to pitting and stress corrosion cracking in the marine environment, but these alloys are expensive. It is proposed that GRP piping be used in firewater and cooling water service. An epoxy-resin-based material with an epoxy-rich internal chemical-resistance barrier should provide adequate resistance for the life of the plant.

Where metallic materials must be used, for example in the seawatercooled plate exchangers, titanium is recommended. It is resistant to stress corrosion cracking, pitting, and crevice corrosion and provides superior performance in service.

#### 12.2.1.3 Steam Condensate and Utility Services

Standard carbon steel materials of construction are suitable for equipment and piping in steam and condensate services. Carbon steel is also suitable for plant air, nitrogen, and process water service. Instrument air piping is usually specified to be stainless steel or copper piping. These materials are specified to eliminate the risk of having corrosion product adversely affect instrumentation performance.

# 12.2.1.4 Carbon Dioxide Service

The recommended material of construction for vessels and piping in  $CO_2$  service at the saturation temperature is Type 304L SS. Any subsequent condensation from the saturated vapor results in the formation of carbonic acid, which is very corrosive toward carbon steel.

#### 12.2.1.5 Demineralized and Potable Water Services

Demineralized water that contains dissolved oxygen is very aggressive and corrodes carbon steel. Consequently, Type 304L SS materials are recommended and routinely used in demineralized water service.

Depending on water quality, carbon steel is suitable for potable water service. However, plastic materials such as PVC and CPVC have been found to be suitable for a wide range of potable water qualities, are relatively simple to install, and provide satisfactory performance. Consequently PVC and CPVC are recommended. UV-resistant grades are required for outdoor exposure.

#### 12.2.2 Paints and Coatings Selection .

Coatings are selected based on their ability to provide sustained corrosion protection for the design life of the plant, as well as an aesthetically appealing facility. Refer to Table 12.1-1 for specific applications.

#### 12.2.2.1 Surface Preparation

SSPC SP10 was chosen for surface preparation because it is recommended by paint manufacturers. It is an industry standard practice for seacoast environments because it increases the long-term efficiency, sustainable performance, and protection of the coating, yielding a life expectancy of at least 20 years with routine maintenance as required.

#### 12.2.2.2 Stainless Steel

To coat the outside diameter (OD) surfaces of stainless steel exposed to the marine environment, 150–200  $\mu$ m of catalyzed epoxy with an optional 75  $\mu$ m polyurethane topcoat is recommended. The coating acts as a barrier and minimizes the risk of chloride stress corrosion cracking and pitting of stainless steel on OD surfaces due to external chloride contamination. Note that inorganic zinc silicate or galvanized coatings are prohibited on stainless steel.

# 12.2.2.3 Insulated Steel Outdoors (Carbon and Stainless Steel)

Both carbon and stainless steel surfaces having a surface temperature less than 121 °C (250 °F) are coated with 150–200  $\mu$ m of catalyzed epoxy to prevent corrosion (pitting, rust, etc.) under the insulation and to prevent stress corrosion cracking of stainless steel.

# 12.2.2.4 Insulated Steel Indoors (Carbon and Stainless Steel)

Manufacturers' standard coatings are specified for carbon and lowalloy steel equipment and piping to provide sufficient corrosion protection during transport to and storage at the site prior to use. Insulated and uninsulated stainless steel surfaces located indoors are not coated.

# 12.2.2.5 Uninsulated Outdoor Exposure

The marine environment is very harsh and causes severe corrosion of uninsulated carbon and low-alloy steel equipment, tanks/vessels, piping, valves, and structural and miscellaneous steel exposed to the very humid, chloride-bearing environment. The coating systems for these components were selected to maximize their corrosion protection. The prime coat shall consist of 75–125 µm of ethyl silicate

inorganic zinc or rust-inhibitive epoxy, followed by 100  $\mu$ m of epoxy top-coated with 75  $\mu$ m of polyurethane. Note that the external coating requirements for stainless steel exposed to the marine environment are covered separately above.

#### 12.2.2.6 Indoor Structural Steel

Inorganic zinc silicate coating is selected based on its outstanding protective properties, which include its sacrificial corrosion protection properties in combination with its barrier properties and physical characteristics. For indoor exposure, this coating should last for the design life of the plant. It is unaffected by weather, sunlight, UV radiation, rain, dew, bacteria, and temperature and does not chalk. It has a very good chemical resistance to pH levels between 5 and 9.

Hot-dipped galvanized coatings are also suitable for structural elements for indoor service. The minimum and maximum coating weights provided by a typical hot-dip galvanizing specification are  $320 \text{ g/m}^2$  ( $1 \text{ oz/ft}^2$ ) to  $705 \text{ g/m}^2$  ( $2.3 \text{ oz/ft}^2$ ), which translates into a maximum coating thickness of about  $100 \mu$ m. This coating weight range per m² is sufficient to provide corrosion protection for the design life of the plant. Hot-dip galvanized coating was chosen for bolts, nuts, gratings, ladders, handrails, etc., because hot-dip galvanizing is an economical process for efficiently coating fasteners and small structural components.

**13.0-Occupational Health and Safety** 

# 13.0 Occupational Health and Safety _____

# 13.1 Occupational Health Assessment _____

NORSOK S-002 standards and health, safety, and environmental (HSE) requirements outside the Kårstø CO₂ Capture and Compression (CCC) Plant battery limit (B/L) mandate that the working environment (WE) be assessed and analyzed during the engineering project development life cycle. The overall purpose of assessing occupational health in the WE is to ensure that the design of the installation promotes a quality WE during a facility's operational phase. This is consistent with the overall HSE philosophy of providing a "zero harm" WE for all personnel working at the facilities.

NORSOK S-002, Clause 4.4.2.0-1, Working Environment, establishes the normal review cycle expectations for revising a "concept Working Environment Impact Assessment (WEIA)." A WEIA is normally prepared during the concept selection phase (pre-front-end engineering and design [FEED]), and updated as the project progresses through FEED. The concept selection phase WEIA was not available as an input to the FEED Study update.

On this basis, a concept WEIA was completed during the FEED Study as a new document in compliance with the requirements of NORSOK S-002, Section 4.4.2. It includes the following impact assessment areas:

- Job hazard/risk of occupational injuries
- Ergonomics/prevention of musculoskeletal strains and injuries
- Ergonomics/human factors in work systems
- Hazardous chemicals
- Noise and vibration control
- Illumination
- Outdoor operations cold stress
- Outdoor operations precipitation and shelters
- Outdoor operations flaring
- Constructability

While not a specific NORSOK S-002 WEIA FEED stage requirement, chemical risk assessment is a fundamental requirement for the CCC Plant. Therefore, the supplied documentation includes an appendix section entitled Framework Chemical Health Risk Assessment. This

document serves as input to the detailed engineering phase WE risk analysis, which is a requirement of NORSOK S-002.

In support of the FEED stage WE assessment, worker exposure to hazards and working environment area limits for occupational settings were evaluated. Detailed working environment area charts (WEACs) were prepared for specific work areas (FEED stage) to address reasonable and foreseeable WEs. The form depicted in NORSOK S-002, Annex E, Working Environment Area Chart, was used as the template.

This information is available in document 10112936-PB-S-HSE-0007, Occupational Health Area Charts.

# 13.2 Fire and Explosion Strategy _____

A fire and explosion strategy (FES) was developed in accordance with ISO 13702 to examine fire and explosion hazards associated with the CCC Plant. The design objectives of the FES are to:

- Provide direction to project management in controlling fire and explosion (F&E) hazards associated with this project
- Establish a strategy to ensure that the identified F&E hazards associated with the operational development phases are addressed

#### 13.2.1 Fire and Explosion Hazards _____

The CCC Plant is considered to consist of three main zones for the development of the FES:

- Flue gas tie-in area (blower and quench section)
- CO₂ compression and drying section
- Amine process and storage areas

#### 13.2.1.1 Flue Gas Tie-in Area

The potential for F&E in the blower and quench section is minimal due to the nature of the process materials (water and flue gas).

# 13.2.1.2 CO₂ Compression and Drying Section

The potential for F&E in the  $CO_2$  compression and drying section is minimal due to the nature of the process and the materials handled. However, there is a potential for a fire involving the  $CO_2$  compressor and flue gas blower lube oil skids. Lube oil fires are considered a hazard that is addressed in a hazard and operability (HAZOP) study for consideration in the design. Available research indicates that a boiling liquid/expanding vapor explosion (BLEVE) is unlikely to occur with the supercritical  $CO_2$  present in the CCC Plant. While there may be a rapid release with some pressure rise, such an event is not followed by a vapor cloud explosion, as could be the case with flammable liquids.

#### 13.2.1.3 Amine Process and Storage Areas

The main CCC Plant fire hazards involve the amine processing and storage areas, which can be subdivided into the following process sections:

- CO₂ absorption
- Heat integration
- CO₂ stripping
- Amine reclamation
- Amine storage

For FEED, amine solutions in water are treated as combustible mixtures in the compositions used in the design. Further study of aqueous amine solutions to confirm flammability could result in an optimized design in which reduced flammability is verified.

# 13.2.2 Ignition Source Control _

The potential for ignition is minimized since all outdoor equipment is suitable for Zone 2, Group IIA, and temperature Class T2 hazardous area classification as a minimum. Equipment and piping surface temperatures are well below the air inlet temperature of monoethanolamine (MEA) (410  $^{\circ}$ C).

Other plant areas are non-classified by design or spatial separation.

Hot surface, electrostatic, lightning, and hot work ignition sources are well controlled due to features incorporated into the design.

#### 13.2.3 Fire and Gas Detection _

The fire and gas (F&G) detection system has various detectors within the CCC Plant B/L to detect the presence of CO₂, combustible gas, smoke, and fire.

The F&G detection system status is shown and alarms are annunciated at the distributed control system (DCS) operator stations.

A manual operator response is required for F&G alarms. Some automatic actions are taken by the system, such as shutting down ventilation inside a building on combustible gas detection, discharging extinguishing agent, etc. Automatic actions in response to F&G detection are described in the cause and effect charts.

F&G detection philosophy, detector location, and alarm levels comply with provisions described in document 10112936-FI-B-CON-0140-05, Exhibit E8.1–HSE Requirements.

The F&G system complies with the requirements of document 10112936-FI-B-CON-0094-01, Exhibit E4.4—General Technical Requirements, Fire and Gas Monitoring and Alarm System.

#### 13.2.4 Depressurizing_

The CCC Plant contains  $CO_2$  at supercritical conditions. If a leak or equipment failure occurs, the released  $CO_2$  falls to extremely low temperatures, causing a hazard to surrounding equipment and personnel. Additionally, the  $CO_2$  concentrations in the local atmosphere may reach dangerous levels.

Depressurizing facilities are installed after the final stage of the compressor to ensure that the plant can be depressurized to mitigate the impact of containment loss. The depressurizing rate, valve, and piping need to be carefully designed to prevent excessively low temperatures and dry ice formation.

The plant depressurizing design basis is fully elaborated in the depressurizing philosophy narrative prepared during FEED.

#### 13.2.5 Active Fire Protection_

The existing fire water network at the Naturkraft combined cycle power plant (CCPP) site supplies fire water requirements for the CCC Plant.

The specification of system components for firefighting complies with document 10112936-FI-B-CON-0140-05, Exhibit E8.1 – HSE Requirements, Clause 3.8 (all sub-clauses).

CCC Plant workers do not approach structural fires. All buildings are fitted with full fire detection and alarming facilities and/or automatic suppression systems.

The CCC Plant design includes a full perimeter, underground fire ring main tied to the Kårstø site fire water system.

Further evaluation is needed during detailed engineering to consider the application of specialized, self-contained, high-momentum water mist extinguishing to provide fire suppression for specific hazards (e.g., lube oil systems, stationary diesel engine bays).

#### 13.2.6 Passive Fire Protection

The reduced combustibility of aqueous amine solutions limits the dimensioning of fire events under leakage conditions. Equipment survivability under foreseeable fire conditions determines the need for passive systems. Consistent with the specified functional requirements, active means of protection are to be sought and implemented in the design before passive protection schemes are applied (e.g., fireproofing with cementitious materials).

The FEED design considers passive fire protection on pipe rack structures and skirts for the absorber towers and stripper column.

#### 13.2.7 Emergency Power Systems_

Emergency power supply requirements are provided by a dedicated emergency diesel generator located within the CCC Plant B/L.

All critical systems (e.g. safety and automation system [SAS], emergency shutdown [ESD], process shutdown [PSD], F&G detection, alarms) are to be arranged to supply power from the emergency bus under primary power failure conditions to ensure control and monitoring integrity without interruption.

#### 13.2.8 Drainage Systems

The CCC Plant design employs both open and closed drainage systems and bunding in specific areas to contain potential spills of amine and required process chemicals to minimize the potential for dimensioning of a spill condition.

The open drain system is used primarily for rain and surface water runoff, which is normally processed through an oily water interceptor before it is discharged to the sea.

The closed drain system is used for amine processing area discharge and system drain-down. The design intent is to recycle amine discharges to the process to prevent effluent.

Pumps in amine service employ high integrity seal technology to minimize leakage risk.

# 13.3 Escape, Evacuation, and Rescue Strategy

The escape, evacuation, and rescue strategy (EERS) prepared for the project describes the provisions to be implemented for the escape and mustering of personnel from the CCC Plant plot space. The EERS documentation was developed in accordance with the requirements of the NORSOK S-001 and ISO-13702 standards.

The EERS addresses issues such as organization, procedures, information, training, and emergency response, which are necessary to achieve a successful EER process.

#### 13.3.1 Escape Strategy _

If a hazardous incident occurs, the FEED escape route arrangements ensure that personnel may leave areas using at least one safe route. FEED planning and development must ensure that personnel can reach the designated mustering area from any part of the plant.

Escape route planning and preparation consider the following plant and plant systems design elements and interfaces:

- Equipment layout
- Public address (PA), alarm, and emergency communication
- Emergency power and lighting
- Passive fire protection
- Structural integrity

The FEED design considers an appropriate temporary muster point for escaping workers to go to during a called emergency. For this purpose, the main stores area is designated as the temporary muster point, (designated as TR) to ensure that a complete head count of all personnel can be made.

Escape may be triggered by an escape call from the plant control room, from the site-wide central control room (CCR), or in response to a local fire or gas alarm annunciator.

The designated muster point is reflected on the applicable escape route drawings. All escape routes employ normally used paths of travel and are signed in accordance with all regulatory requirements. Permanently and intermittently manned areas are arranged with at least two means of egress.

Appropriate emergency lighting and alarm communication systems (including voice PA) are provided so that personnel can effectively

execute emergency duties. In the case of a site-wide escape call, a worker can escape to the site-wide muster point designated as M1.

#### 13.3.2 Evacuation Strategy_

The CCC Plant is an onshore facility. The design of the plant and process fluids do not present a credible risk for fire, toxic gas, or explosions that can escalate to the muster area under a single failure event, e.g., localized spill or leak.

Evacuation provisions do not need to be included for all facility personnel. Once the facility personnel have mustered in the designated temporary muster point (TR), they can escape to the designated Kårstø site-wide muster point (M1) under the direction of the site-wide CCR staff and/or emergency services personnel.

#### 13.3.3 Rescue Strategy __

The CCC Plant is an onshore facility that does not present a risk of fire, toxic gas, or explosions (see Subsection 13.4.2). Therefore, formal vehicle-based rescue provisions (as normally required for an offshore platform) are not required.

After the facility personnel arrive at the designated temporary muster point (TR), they can escape to the designated Kårstø site-wide muster point (M1) under the direction of the site-wide CCR staff and/or emergency services personnel.

Due to the operational requirement to perform field maintenance and intermittent work in confined spaces or above grade, rescue means need to be in place in the event of personnel injury. This emergency extrication planning is addressed in the job hazards analysis (JHA) process developed during detailed engineering.

The coordinated emergency response plan includes safety showers, safety cabinets, first-aid kits, and provisions to ensure that personnel can be safely removed for examination, first-aid, and transport to medical facilities.

#### 13.4 Observations and Recommendations

#### 13.4.1 Observations

HSE requirements for the overall Kårstø site, including requirements covering the owners of the gas plant and CCPP, have not been defined

to the degree possible for conditions common to process plant environments.

Routinely coordinating HSE planning activities benefits the overall risk profile of a site that has the complexities of Kårstø. Further definition of site-wide HSE practices must be a design absolute during the detailed engineering process.

Sufficiently detailed FEED-level hazard identification (HAZID) and process hazards analysis (PHA) (FEED stage HAZOP) studies have been completed. Design optimization of the proposed CCC Plant is possible through careful and considered implementation of the action items issued as a result of these risk analyses.

A fundamental conclusion of the assembled HAZID and FEED stage HAZOP teams is that, if the action items are implemented successfully, all identified risks can be mitigated to a level considered as low as reasonably practicable (ALARP).

Further study of the F&E properties of amine/water solutions is required at the outset of detailed engineering to conclusively determine their thermophysical characteristics. A determination of reduced combustibility may yield considerable opportunities to reduce active and passive fire protection requirements, extent of hazardous area classifications, and potential for additional unclassified areas.

Amine/water solutions under leakage conditions are not considered to present a credible explosion hazard or a potential for pool fire scenarios, except in concentrated form.

There is a significant risk to workers during a leakage in which CO₂ loss of containment occurs. Although extensive gas monitoring and PSD/ESD systems are employed, the CCC Plant represents a "first in kind" facility (in terms of size and scale) employing supercritical CO₂. The limited research available suggests that both thermal and toxic effects expose workers to potentially hazardous working conditions.

The CCC Plant FEED design includes features to monitor and manage emissions to the land, water, and air. The design considers the recycling of effluents to the process to minimize waste. Laboratory facilities need to be provided in the design to ensure that regulatory requirements documented in the Environmental Impact Assessment (EIA) and regulatory permits are adhered to.

#### 13.4.2 Recommendations_

FEED-stage recommendations offered for consideration during the detailed engineering stage are described in the following subsections.

#### 13.4.2.1 Working Environment (i.e., Occupational Health)

The following additional assessment and narratives should be performed during detailed engineering:

- Occupational health risk analyses (JHA, chemical health risk assessment, comparison risk analysis)
- Ergonomic analyses (task analysis, crisis intervention and operability, valve and instrument access and operability)
- Occupational health design review report
- Material handling (cranes, hoists, etc.) assessment
- Illumination design philosophy
- Alarm management narrative

A formal Working Environmental Risk Assessment (WERA) study is also required, including an update of all WEACs resulting from actions identified in the WERA.

A full chemical risk analysis study is a design absolute during the appropriate phase of detailed engineering. The presence of amine degradation products and hazardous wastes creates an exposure risk to workers that must be fully evaluated to establish the appropriate risk level and to document and validate the preliminary labeling requirements of various wastes anticipated in the operation of the CCC Plant.

#### 13.4.2.2 Noise and Vibration

Further detailed noise studies/assessments are needed during detailed engineering to model noise emissions that could endanger workers or the environment or affect permits for facility operations.

Established working environment area limits (WEALs) must be updated through the EPC phase and validated during the commissioning phase. Applicable limits for worker exposure are reflected on the FEED-stage WEACs.

# 13.4.2.3 Fire and Explosion Strategy

CCC Plant staffing is limited. Therefore, the FES does not envision plant employees serving in a firefighting role beyond providing incipient response or triggering manual call points located throughout the facilities.

Use of CCC Plant fire hydrants is restricted to the main Kårstø fire brigade, and all structural and large-scale firefighting activities must be coordinated through main site fire and emergency services.

Fire protection impairment management procedures and coordination with the main Kårstø site requirements require further definition during detailed engineering.

The response time and manpower from site-wide professional firefighting services must be further defined and documented in the FES when it is revised. For FEED, it is assumed that professional firefighting services are available for possible fire events and can respond with a trained fire brigade to a fire call in less than 5 minutes.

To address specific fire potentials (e.g., lube oil fire) consideration must be given to using prepackaged, skid-mounted fire suppression systems, such as high-momentum water mist for ordinary combustibles and liquid fires and inert gas systems for high-value concentration electronic equipment.

# 13.4.2.4 Escape, Evacuation, and Rescue Strategy/Escape Routes

The escape route arrangements for FEED must be validated with the site-wide EERS plans. This validation must ensure that the planning and development activities completed for FEED allow personnel to reach the designated mustering area from any part of the CCC Plant. Where gaps exist in this initial planning, corrections must be made.

Escape from elevated work surfaces requires further study during detailed engineering to establish the most effective and efficient means for workers to travel to grade and move to a safe distance from a developing event in a timely fashion. The overall philosophy should continue to employ the CCC Plant ring road as a primary egress path.

The coordination and triggering of a CCC Plant escape to the designated temporary muster point (TR) and a site-wide escape call from the CCR must be validated and documented.

The availability of emergency services (medical and extrication teams) must be confirmed during the initial stages of detailed engineering. The coordinated emergency response plan must include provisions to

ensure that personnel can be safely removed for examination, first-aid, and transport to medical facilities.

Escape directions are considered preliminary and must be validated. The availability of egress to the CCPP Plant and site-wide muster point M6 must be ascertained and documented as soon as practicable during detailed engineering.

Due to operational requirements to perform field maintenance and intermittent work in confined spaces or above grade, rescue means need to be in place in the event of personnel injury. This emergency extrication planning is addressed in the JHA process developed during detailed engineering.

#### 13.4.2.5 HAZID and FEED HAZOP (PHA)

All actions and recommendations entered into the recommendation registers for the HAZID and FEED HAZOP studies must be reviewed during the initial stages of detailed engineering to confirm that FEED recommendations have been closed out. Outstanding items on both registers must receive prompt attention for closure as soon as practicable.

#### 13.4.2.6 Layout Safety (Issue for FEED Plot Plan)

Additional optimization of the layout should focus on further segregation of hazardous (i.e., amine/CO₂) process areas from unclassified (e.g., electrical building, control/workshop/stores building) and permanently/intermittently manned areas (e.g., control/workshop/stores building).

#### **13.4.2.7** Hazardous Area Classification/Ignition Source Control

The likelihood of fire within the battery limits of the CCC Plant is greatly limited due to the limited combustibility of the MEA, concentrations present in the amine sections of the plant.

The plant preliminary area classification is based on application of classified equipment to gas Group IIA, temperature Class T2, specifications for all outdoor equipment. This classification needs to be validated during detailed engineering when absorption solvent thermophysical properties at process concentrations are confirmed.

The auxiliary boiler envisioned in the FEED design is considered a strong ignition source in the context of area classification. The availability of an additional steam supply (as a commodity) from a source outside the B/L and design optimization for when the boiler is no longer required must be studied to reduce the release level ignition probability to Level I per IP15, 3rd edition.

# 13.4.2.8 Emissions and Discharge

Feedback is required from the EIA conclusions to further define emissions and discharge limitations for CCC Plant operations.

Due to the plant's scale, additional process modeling of amine degradation products and wastes needs to be completed during the early stage of detailed engineering to more accurately determine the expected amine waste composition and quantities.

Additional emissions modeling is required to determine the effects of absorber exhaust stack emissions and fugitive sources to ensure that levels are below regulatory limits covering both the environment and worker exposure.

Open and closed drainage systems for spill and precipitation management must be validated during detailed engineering to ensure that the sizing requirements and treatment levels permit discharge to the seawater return point.

The site-wide disposal procedures (per Statoil Hydro document WR1839) must be coordinated to ensure that nonhazardous wastes are handled in a manner consistent with site requirements.

**14.0-Operations and Maintenance** 

# 14.0 Operations and Maintenance

# 14.1 Operations Philosophy _____

The Kårstø CO₂ Capture and Compression (CCC) Plant system controls are accessible through the distributed control system (DCS) workstations located in the central control room (CCR). The control system design includes automatic control, with interlock functions to minimize operator actions. Operators are able to manually perform startup, operation, and shutdown functions, with sufficient interlocks to prevent unsafe operation. Abnormal or unsafe operating conditions initiate appropriate alarms, followed by subsequent plant shutdown. Restart requires operator initiation.

Plant operations are controlled from the CCR. The following key operator actions are required:

- System line-up and verification that equipment is ready for service prior to system start
- Line-up of off-line equipment
- Verification of manual valve (non-actuated) positions
- Verification of tank and vessel levels via sight glass or level gauge
- Operator initiation of plant start after trip or from standby condition
- Operator initiation of plant shutdown for standby (other than permissive/interlock condition)

The control room operator (CRO) operates the plant from the CCR. The CRO's duty station is normally at the main CCR control console. Shift operators assist in verifying system line-ups and equipment conditions as required and directed by the CRO.

# 14.2 Operations Training and Staffing

#### 14.2.1 Training ____

The CCC Plant training program addresses the operation of the supplied equipment, including applicable theory. The training program is all-inclusive, addressing all plant systems and equipment, and provides the operating personnel with the required knowledge to operate the systems and the maintenance personnel with the required knowledge to properly maintain them. Personnel selected to participate in the program are generally limited to those who need such training to

perform their duties. The typical training duration is approximately 4 weeks.

#### 14.2.2 Operating Staff_

CCC Plant operations are handled by shift operators, the CRO, the shift supervisor, and backup operators (shift positions). Additionally, the operations staff is complemented by a support staff (non-shift positions) handling plant administrative activities such as engineering; laboratory services; warehousing; accounting; human resources; and environmental, safety, and health.

The shift operators operate the physical plant equipment, including lining up systems (verifying valve positions for operation), verifying readiness of equipment, placing local control equipment in and out of service, and taking direction from the CRO for placing large equipment and systems in and out of service. Additionally, the shift operators assist in collecting data, administering the clearance program, doing light equipment maintenance (lubrication, strainer cleaning, general cleaning), and performing overall housekeeping.

The CRO operates and controls the overall plant, placing equipment and systems in and out of service via the DCS, directing shift operators with regard to systems operation, maintaining the detailed operations log, coordinating CCC Plant operation with the Naturkraft combined cycle power plant (CCPP), advising the CCPP of CCC Plant conditions, logging CCC Plant conditions, taking appropriate actions as necessary, administering the lock-out/tag-out (LOTO) and safety system, and issuing work authorizations and lockout tags and locks (clearances).

The shift supervisor manages the CRO and the operator mechanics, along with managing and administering day-to-day plant activities, including managing the schedule, procuring materials, preparing daily reports, approving logs, and so forth. The shift supervisor must be capable of performing the duties of the CRO and the shift operators and filling in on such duties when the need arises.

The plant engineer is a degreed chemical engineer who assists in interpreting supplier information, specifications, operating procedures, and additional instructions to the operators if deficiencies in such are found, as well as providing technical guidance in resolving identified problems. The plant engineer also provides guidance with respect to process details such as required chemicals, solvent conditions, and information on handling various chemicals and materials.

Refer to Figure 14.2-1, Kårstø Plant Staffing Chart.






## 14.3 Operations Particular Requirements

CCC Plant operational prerequisites are discussed in this subsection.

A LOTO and safety system for issuing system lockout tags and locks (clearances), work authorizations, and administration thereof, must be in place. The exact nature of the system is worked out by the parties involved, both inside and outside the plant battery limit (B/L).

Additional required administrative control procedures specific to operations and maintenance include:

- *Confined space entry*—This procedure covers monitoring hazardous materials and atmospheres in combined spaces, controlling and accounting for persons entering, and the safety measures that are to be in place.
- *Job hazard analysis* This procedure covers the step-by-step analysis of potential hazardous tasks and the step-by-step mitigating measures to be taken.
- *Materials handling plan* This procedure covers the measures to be in place to prevent spill or uncontrolled escape to the environment when handing chemicals, oils, waste, etc.

Experienced plant personnel who are outside the B/L must be trained in the plant-specific theory and operation of the equipment.

Plant equipment must be ready for operation, including turnover records documenting equipment commissioning. Monitoring equipment condition and maintaining equipment in a ready-to-operate condition are functions of personnel outside the B/L.

The CCPP and CCC Plant operations must be coordinated; this is an activity for personnel outside the B/L. Also, status data must be transmitted via link to the Naturkraft facility and the offshore injection wells.

## **14.4** Maintenance Philosophy

In general, planned CCC Plant maintenance is scheduled in accordance with original equipment manufacturer (OEM) recommendations. These recommendations are transferred from the supplier documentation to the maintenance list. The plant engineer is responsible for maintaining and updating the list with requirements as deemed appropriate by experience gained during operation. In addition to their operations duties, the shift operators perform lightduty equipment maintenance (e.g., lubrication, cleaning, gasket replacement).

The personnel who perform routine maintenance are a mechanical technician for mechanical equipment and an instrumentation/ controls/electrical (ICE) technician for instrumentation and electrical items. Shift operators assist these technicians.

## 14.5 Maintenance Training and Staffing ____

Refer to Subsection 14.2.1 for a description of CCC Plant training.

The maintenance staff consists of the mechanical technician, the ICE technician, and the shift operators, who provide light maintenance and assist the technicians. Refer to Figure 14.2-1, Kårstø Plant Staffing Chart.

## 14.6 Maintenance Program Overview _

In general, planned CCC Plant maintenance is scheduled in accordance with OEM recommendations. These recommendations are transferred from the supplier documentation to the maintenance list. The plant engineer is responsible for maintaining and updating the list with requirements as deemed appropriate by experience gained during operation. Refer to the sample maintenance template in Figure 14.6-1.

## 14.7 Spare Parts _

Lists of recommended spare and wear parts for the CCC Plant are provided by the equipment suppliers within the B/L and are submitted for consideration of warehouse stock to be maintained outside the B/L. The exact format of the spare parts information collected is worked out by the parties involved, both inside and outside the B/L. Review of the recommended spare parts lists and purchase of parts in accordance with plant operation philosophy are outside the B/L.

Startup and commissioning spare parts necessary to commission the plant are provided inside the B/L through turnover to outside the B/L. In the project's interest, parts procured outside the B/L are generally made available for purchase or replacement in kind inside the B/L to supplement commissioning spares already available within the B/L.

#### Startup and Operations - Operating Maintenance Template

Beohtel Tag ≢	Seller Part ID, Serial, Mark #	Component Description	Subcomponent Decoription	Maintenance Action	Maintenance Frequency	Lubricant Spece	Lubricant Qty	Storage Category	Space Heater (WkW/Φ)	Special Inst / Remarks

#### **Operating Maintenance - Template Completion Instructions**

Seller to complete the attached template in order to communicate their site operating maintenance requirements to the Buyer. Data inputs shall be complete and specific as stipulated below for all equipment provided by the Seller which requires storage maintenance. Columns which are not applicable shall be populated with "N/A." Entries such as "See IOM Manual" or email references are NOT acceptable and will be rejected. Any deviation from these requirements must be approved by the Project Startup Manager or Representative. Data inputs to this template will be uploaded electronically into Buyer's Equipment Storage and Maintenance Database for program management on the jobsite.

#### Bechtel Tag # Column

Per equipment list and associated P&IDs, the Buyer's tag number assigned to each piece of equipment.

#### Seller Part ID, Serial, Mark # Column - Instructions

The characters in this column will be the Selier's unique identifier for the equipment or skid. It **IEEQUIRED** that the characters in this column MATCH the characters isted at line item detail on the Selier's Shippable Bill of Materials (SBCM) and Packing list (as included in the Buyer's P.O.). Buyer will use this numbericharacter string to link the technical storage and maintenance requirements to the physical equipment received on the Jobste.

#### Component Description Column

Description of the tagged Item (e.g. Boller Feed Pump, Air Preheater, Coal Conveyor, Filter Separator) consistent with the Supplier's Equipment List.

#### Subcomponent(s) Description Column

Subcomponent (requiring storage and maintenance) of the above equipment to be listed by the Seller individually.

#### For example:

Component – Boller Feed Pump Component – Troughed Belt Conveyor Subcomponent: Motor Subcomponent: Gearbox Subcomponent: Drive Motor Subcomponent: Belt

#### Maintenance Action / Maintenance Frequency Columns

Description of storage maintenance or operating maintenance action (e.g. grease bearings, rotate shaft, check space heater) and the frequencin <u>daws</u>, which the maintenance action is to occur. However, if action is to occur upon receipt, selfer shall indicate "OR" in the frequency column. If action is to occur before commissioning, Selfer to indicate "SU" in the frequency column.

#### Examples:

"Rotate shaft several revolutions once a month" Maintenance Action: Rotate shaft several revolutions Maintenance Frequency: 30 days "Fill Gearbox with Oil Upon Receipt" Maintenance Action: Fill Gearbox With Oil Maintenance Frequency: OR Lubricant Specs / Quantity Columns:

#### Lubricant Specs Column:

If applicable, Selier to provide the recommended lubricant type and manufacturer associated with each maintenance action (ISO # only NOT acceptable, must name recommended mitr). Selier shall provide approved equivalent if the parent technical specification or PO documents request a specific manufacturer. Examples: Mobil Gear 632 Paik LTG Lubriplate HO-2 Hydraulic OI Shell Turbo J32 Degol GS 1500

Quantity Column: Input required quantity and unit of measure (e.g. 10 gallons, 20 oz).

#### Storage Category Column - Instructions

Selier to input 1-5 for the required storage category for each piece of equipment requiring special storage maintenance.

Storage Category 1 – Outside Storage
Equipment will be stored as received. Pallets or cribbing as necessary.
Storage Category 2 - Outside Storage, Covered
Ecuipment will be stored outside Storage, Covered
Ecuipment will be stored outside stored, covered with a tarpaulin or equivalent method to prevent exposure to elements. Pallets or cribbing
as necessary.
Storage Category 3 - Outside Storage, Covered with a tarpaulin or equivalent method to prevent exposure to elements. Pallets or cribbing
as necessary.
Storage Category 3 - Outside Storage
Ecuipment will be stored outstors as received, covered with a tarpaulin or equivalent method to prevent exposure to elements and space heater
energized to avoid condensation. Pallets or cribbing as necessary.
Storage Category 4 - Inside Storage
Ecuipment will be stored as received indoors. Epace Heaters will be energized as required.
Storage Category 5 - Inside with Controlled Climate
Equipment will be stored as received indoors. Epace Heaters will be energized as required.
Storage Category 5 - Inside with Controlled Climate
Equipment will be stored as received indoors with controls to maintain temperature and humidity as specified.

#### Space Heater (V/W/Φ) Column

If space heater is required, Seller to indicate the votage (V), Wattage (NW), and number of phases required for connection. This information is required for temporary power supply management on site.

#### Figure 14.6-1 Sample Maintenance Template

Spare parts are categorized into four classes:

- *Startup/commissioning spare parts* may be required at any time during equipment installation, precommissioning, commissioning, startup, and testing.
- *Operating spare parts* are required to maintain continuous operation of the supplied equipment and/or system and to replace those parts and components that fail due to operation. The operating spare parts cover the range of parts required to be on hand and available to effect highly reliable equipment operation for a period of 3 years.
- *Capital spare parts* are major parts and equipment components and subsystems required to provide reliable equipment operation throughout the plant life and have a significant lead time for manufacture and delivery. Capital spare parts are major replacement parts or complete units or sets of equipment essential to the continuity of operations. Capital spare parts are considered long-term investments and are not required to be available during the commissioning period. Capital spare parts are acquired outside the B/L on a case-by-case basis based on economic considerations.
- *Special tools* are tools, instruments, devices, human machine interfaces (HMIs), and software necessary to calibrate, set up, precommission, commission, start up, operate, and maintain the equipment within the scope of supply. Special tools do not include items found in a normal maintenance facility.

## 14.8 Consumables

The CCC Plant consumables listed in Table 14.8-1 include utilities and major materials. Not included is a breakdown of minor lubricants (such as for hinges, rollup doors, etc.), machining oils, incidental cleaning agents and solvents, rags, fasteners, gaskets, grinding disks, etc. The values in the table are preliminary pending detailed design after frontend engineering and design (FEED). The types, material specifications, condition specifications, additional requirements, etc., are also preliminary pending detailed design after FEED.

Description Consumable	Unit of Measurement	Estimated Consumption Rate	Intermittent/ Continuous	Remarks
Electrical Power	kW	~44,000	Continuous	Full production, maximum operation
Steam	tonnes/hr	200 LP	Continuous	165 LP from CCPP and 15 LP from CCC Plant auxiliary boiler

 Table 14.8-1
 List of Consumables

		Estimated		
Description	Unit of	Consumption	Intermittent/	
Consumable	Measurement	Rate	Continuous	Remarks
Steam	tonnes/hr	12 HP	Intermittent	from CCPP
			-	auxiliary boiler
Seawater Cooling	m ³ /hr	17,340	Continuous	
Fuel Gas	kg/hr	1,500	Continuous	
Compressed Air	Nm ³ /hr	185	Continuous	Produced by onsite
•	,			compressor
Amine Process	m ³ /year	1,400	Continuous	Makeup for
Solvent				emission losses via
				makeup metering
				pump and storage
Amine Cartridge	each/vear	300	Intermittent	Change once per 3
Filter Element	cuony your			to 6 months
Activated Carbon	tonnes/month	< 40	Intermittent	500 kg/m³ bulk
Nitrogen Gas	Nm ³ /hr	85	Continuous	
Soda-Ash Solution	kg per reclaim	1700	Intermittent	When reclaimer is
(106 G/Mole)	batch		<b>A</b>	operated
Reverse Osmosis	kg/month	< 100	Continuous	For process
Antiscalant				demineralized
				from seawater
Reverse Osmosis	each/3 vears	approx 30	Intermittent	48-in SWR0
Membrane				elements
Elements				
Reverse Osmosis	each/year	30	Intermittent	Change once per
Cartridge Filter				6 months
Elements	lite a fear	< 1000		Declara dependentes
Diesei Fuei	inter/yr	< 1000	Intermittent	Backup generator
				consumption =
				monthly testing
Blower Fan	liters/yr	< 500	Intermittent	
Lubricant				
CO ₂ Compressor	liters/yr	< 1000	Intermittent	
Lubricant	lite up (		last a sure it to set	
Centrifugal Pump	liters/yr	< 500	Intermittent	
Lubricant				
Bearing/Joint	kg/month	< 10	Intermittent	Several types
Lubrication Grease				required
Miscellaneous	kg/month	< 1	Intermittent	Several types
Lubricant/Grease				required
Potable Water	m ³ /day	5 to 10	Continuous	Potable users
Analyzer Reagents	lot	during	Intermittent	
		design		
Test Lab Reagents	lot	during	Intermittent	
		detailed		
		design		

15.0-Cost Estimate

# COST INFORMATION REFERENCED IN THE EXHIBITS NOTED IN THIS SECTION CAN BE FOUND IN APPENDICES A, B, & C AT THE END OF THIS REPORT

# 15.0 Cost Estimate_____

#### 15.1 CAPEX Estimate _____

#### 15.1.1 General_____

The Capital Cost Estimate (CAPEX) is provided in document Number 10112936-PB-G-CRE-0001.

The estimate has been prepared in accordance with the requirements of the following Contract Documents:

- Exhibit E1.1: Requirements for Cost Estimates and Capture Cost Calculation
- Exhibit E1.2: Cost Breakdown Structure

The CAPEX has been prepared to an accuracy of  $\pm 20\%$  as required in the Contract documents. The Cost Breakdown Structure (CBS) described in document E1.2 was used.

A cost risk analysis was performed, and the summary is provided in the referenced document.

The following sections provide additional information on the CAPEX and risk analysis.

#### 15.1.2 Pricing Basis _____

The estimate costs are based on 4th Quarter 2008 prices. Escalation through commercial operation is included.

#### 15.1.3 Exchange Rate_____

The currency exchange rate used for the estimate is 1 USD = 5.3 NOK, which is in accordance with the requirements of Exhibits E1.1 and E1.2.

#### 15.1.4 Contingency _____

Contingency is not included in the Contractors Cost. The Contingency analysis was undertaken as part of the risk analysis.

#### 15.1.5 Qualifications and Assumptions for CAPEX

The following qualifications and assumptions apply to the CAPEX estimate:

- The site is clean, free of hazardous materials, level, and free of any obstructions above or below grade.
- The estimate is only for material within the plant battery limits (B/L) shown on the general arrangement drawing, except for the flue gas duct, electrical power tie-ins, seawater cooling pumps, and cooling water pipe.
- Since the site is an existing operating plant with a wharf, it is possible to receive shop-fabricated, large-diameter tanks and vessels. Access to the project site is possible without any modifications to the route.
- The existing stack can accept the modifications to support the CCC Plant flue duct and stack damper.
- The seawater pump structure accommodates the selected pumps, and the cooling water pipe connection design and routing can be accommodated.
- Construction power and water are to be provided by the Owner.
- Soils conditions allow for spread footing design.
- Adequate construction access is available on all sides of the proposed site except the west side.
- CCC Plant lighting and small power distribution are limited to the B/L.
- All pre-existing hazardous materials are to Owner's account.

#### 15.1.6 Exclusions from CAPEX_

The following items are excluded from the CAPEX cost estimate:

- Contingency
- Escalation
- Liquidated damages (LD) insurance
- Builders risk and marine cargo insurance
- Required payment securities
- Environmental wetland and endangered species protection is excluded.
- All construction and environmental permits (to be obtained by Owner)

- Camp costs
- Value-added taxes (VATs) and import duties, where applicable, which are pass throughs
- Licensing or royalty fees associated with proprietary processes/ equipment/chemicals (none identified for base case)
- Capital spare parts
- Work associated with demolition at the site
- Furniture or laboratory equipment
- Duties, permits, and taxes
- Modifications to existing utilities, equipment, and facilities
- Onsite accommodations for craft housing

#### 15.1.7 CAPEX Cost Contingency and Risk Analysis _____

The Bechtel Risk Analysis Contingency (BecRAC) software was used for the contingency and risk analysis. The summary sheet of the results from the analysis is provided in document Number 10112936-P-G-CRE-0001.

The Contingency derived from the analysis is not included in the overall CAPEX estimate for the project.

## 15.2 OPEX Estimate_____

#### 15.2.1 General_____

The OPEX estimate is provided in document Number 10112936-PB-G-CRE-0002.

The OPEX estimate was prepared in accordance with the requirements of the following Contract Documents:

- Exhibit E1.1: Requirements for Cost Estimates and Capture Cost Calculation
- Exhibit E1.2: Cost Breakdown Structure

The Operating Expenditure (OPEX) Cost Estimates has been prepared to an accuracy of  $\pm 20\%$  as required in the Contract documents.

#### 15.2.1 Data used in developing OPEX

The following is a summary of the basis of the data used in the OPEX estimate:

• Average use time

The average use time for utility consumption is estimated at 8105 hours per year. This includes allowances for CCPP outages and the 97% capacity factor for the CCC plant.

• Utility consumption

Usage rates are based on the base case open-art design.

Unit prices are provided from Gassnova except for the price of condensate, which is estimated based on our past experience.

• Consumables

Usage rates are based on the base case open-art design.

Unit prices are obtained from Bechtel pricing database.

• Staff

Staffing levels are as outlined in the Bechtel document submittal 10112936-PB-O-DOC-0004 (Operating Staff Concept).

• Maintenance cost

This is estimated as a percentage of capital costs, as is typical for a FEED estimate.

• Spare and wear parts

This is estimated as a percentage of equipment costs, except for absorber packing, which is estimated separately based on input from packing suppliers.

• Service cost to Gassco

A cost of 8000,000 NOK/y is input per Section 2.0 of Exhibit E1.1.

• Special waste

Usage for activated carbon and reclaimer sludge is based on the base case open-art design. Unit price is based on vendor pricing data.

• Service agreement with Naturkraft

This cost is to be determined by Gassnova per Clause E2.2 of Exhibit E1.2.

• Taxes

This cost is to be determined by Gassnova per Clause E2.2 of Exhibit E1.2.

• Land leasing cost

This cost is to be determined by Gassnova per Clause E2.2 of Exhibit E1.2.

• Other costs

An administration cost of 10,000,000 NOK/y is input per Section 2.0 of Exhibit E1.1.

#### 15.2.2 OPEX Sensitivity/Risk Analysis_____

The data on the OPEX Sensitivity/risk analysis is included in the CO₂ Capture Cost Calculation, document Number 10112936-PB-G-CRE-0003

#### 15.3 Input to CO₂ Capture Cost Estimate _____

#### 15.3.1 General

The CO₂ Capture Cost Calculation is not a required deliverable in the Exhibit A1 contract documents. However, we believe it would be useful to Gassnova and have therefore prepared the calculation and issued it under document Number 10112936-PB-G-CRE-0003.

The CO₂ Capture Cost Calculation was undertaken using our own financial model. It uses an approach similar to the provisional calculation model provided by Gassnova as an attachment to Exhibit E1.1.

The calculation is undertaken for the base case open-art MEA design.

#### 15.3.2 Information Included and Excluded from the Model ____

The model calculates the  $CO_2$  capture cost (NOK/tCO₂) based on data from the following cost estimates for the CCC Plant:

- Capital cost (CAPEX)—See document Number 10112936-PB-G-CRE-0001
- Operating costs (OPEX)—See document Number 10112936-PB-G-CRE-0002

The following information is not included in the calculation:

• Gassnova's OPEX costs which are defined as "By Gassnova" in Exhibit E1.2

- Capital cost contingency and all other items excluded from the CAPEX estimate
- Insurance
- Capital or operating costs for any work to be performed outside of the B/L by Gassnova

#### 15.3.3 Assumptions Used in Model_

The following assumptions were used in creating the model:

- Project lifetime of 25 years
- Data provided in Exhibit E1.1 to determine the level of planned and unplanned outages for the Naturkraft CCPP. These vary year by year, and this is reflected in the model (for information, the availability averages 95.4% over the 25 year period).
- A capture plant on-stream factor of 97% for the design case (100% load of power plant) relative to the CCPP availability
- A production year of 8760 hours. Actual operation hours are calculated using CCPP availability and the CCC Plant on-stream factor for each year.
- Exchange rate of NOK/USD: 5.3 (per Exhibit E1.1)
- Discount rate (NPV) of 8%
- For simplicity, a construction schedule done on an annual basis. Because the NPV calculation is done on an annual basis, little is gained by splitting construction numbers into a monthly level of detail.
- Changes in working capital added to operating expenses to get a more accurate representation of cash flows. Working capital includes changes in operating cash and changes in accounts payable.

#### 15.3.4 Sensitivity Analysis

Sensitivity analyses were performed for the NPV unit cost (NOK/t) and the NPV of total cost. The output is presented in terms of a "tornado" chart, with the higher impacts shown at the top of the chart.

The parameters listed in section 6 of Exhibit E1.1 were assessed along with other parameters identified by the Contractor.

16.0-Construction, Commissioning, and Execution

# 16.0 Construction, Commissioning, and Execution_

## 16.1 Construction Approach and Overview _

The overall construction methodology for the Kårstø  $CO_2$  Capture and Compression (CCC) Plant can be described largely as a modularization approach with some preassembly and stick-built construction. Most of the plant equipment is a prime candidate for modularization. The approach for the tie-in work within the Naturkraft combined cycle power plant (CCPP)—a combination of preassembly and stick-built construction—is driven by the need to perform pre-outage work during CCPP operation.

Construction management services provide oversight of all construction operations. At peak, the management staff is composed of non-manuals who are a mix of expatriates and local resources. Qualified subcontractors execute the construction under the direction of the construction management team. This team and subcontractor personnel are housed in camp accommodations.

At notice to proceed, the site is assigned for initial civil earthwork activities. Clearing/grubbing and mass earthwork for the site are performed prior to mobilization. Although the site is provided at a designated elevation, the existing terrain requires rock blasting to excavate for the deep underground utilities. As blasting operations are completed and underground utilities are installed, the foundation form, rebar, embeds, and concrete placement (FREP) activities commence.

Pre-cast concrete cable trenches, manholes, and catch basins are used to the extent possible to minimize the amount of poured-in-place concrete required for these items. A mud mat of lean concrete is placed on the bottom of excavations for large foundations to provide protection from the weather and groundwater seepage, to provide a good working surface for anchoring formwork, and to provide a bearing surface for chairs to support the reinforcement steel. Enclosures such as tents are used for protection during winter weather concrete placements. A multi-use concrete forming system is used for all cast-in-place concrete. Anchor bolts, metal embeds, and reinforcement steel are detailed and prefabricated by vendors off site. In a preassembly area, rebar mats and cages are pre-tied and the formwork pre-ganged into the largest sections that can be safely handled and brought to the foundation for installation. A temporary concrete batch plant is used for concrete supply. The bulk of ready-mix concrete is placed by chute directly from trucks and supplemented by the use of buckets and/or concrete pumps for large or elevated placements. Admixtures such as fly ash,

plasticizers, accelerators, and retarders are included in the mix designs to improve the workability of the concrete.

Prior to starting detail design, the Engineering and Construction groups assess the potential areas for modularization, along with the associated cost and schedule benefits. Long-lead critical path items such as the absorber and stripper columns are fabricated at an offsite manufacturing facility, then shipped to the Kårstø Gas Plant Anleggsdai Jetty. Each column arrives preassembled to the extent possible to minimize field erection time and permit immediate setting. The columns are offloaded using heavy shipping vessel cranes and delivered to the site via the designated module transport road. These large vertical columns are then dressed out with ladders, platforms, piping, instruments, lighting fixtures, and raceways to the extent possible at grade and set using heavy lift cranes.

Pipe racks are designed and procured in modularized sections. These modular units are delivered with piping, valves, hangers, and cable tray installed on the rack. The modules are shipped to the Anleggskai Jetty for transport along the module transport road via a self-propelled motorized transporter.

Miscellaneous structural steel is fabricated and painted at the steel supplier's fabrication facility. Structural steel requiring fireproofing is coated at the fabrication facilities, and touchup is performed after installation. Structural steel walkways and ladders are shipped with the steel to aid in erection.

The compressor building and flue gas blower enclosures are preengineered structures, whereas the electrical/switchgear and control buildings are design/install structures. These buildings require a stickbuild construction approach.

The major mechanical equipment (reboiler, reclaimer, pumps, heat exchangers, tanks, filters) are designed and procured and issued to the construction subcontractor. Interconnecting piping, valves, hangers, electrical components, instruments, and other components are freeissued to the construction subcontractor. Installation of these components is sequenced in conjunction with the delivery of the absorber and stripper columns.

The tanks and analyzer building are also manufactured off site. The analyzer building is a prefabricated structure manufactured with all of its internal equipment installed at the manufacturing facility. The analyzer building and tanks are shipped to the Karsto Gas Plant Anleggskai Jetty for offloading and transporting to the site. All equipment, including heat exchangers, pumps, compressors, motors, lube oil skids, and filters, is delivered to the jobsite, then assigned to the construction subcontractor to perform required preventive maintenance.

Large-bore-diameter welded piping is shop-fabricated, including welded attachments such as shoes and dummy legs, and, if required, finish painting is performed off site. The individual spools are preassembled at grade into the largest subassemblies that can be safely and efficiently handled. Most of the field welding of carbon steel and stainless piping uses the shielded metal arc welding (SMAW) process. The field welding of thin-wall and stainless steel piping uses the tungsten inert gas (TIG) process, supplemented by a flux-cored arc welding (FCAW) process for large-bore pipe. FCAW and/or SMAW are used for structural welding requirements. Welders are qualified in accordance with applicable codes. Nondestructive examination (NDE) work is coordinated with other activities to use breaks, lunch, and shift changes whenever possible. However, most of this work is performed during off hours, i.e., nights and weekends.

Electrical work, including final calibration and testing of the equipment, is performed at the jobsite. The plant lighting system is installed early and uses temporary power to provide lighting during construction. Inline instruments, such as control valves, orifice flanges, sight glasses, instrument bridles, and heat tracing, are installed with the piping. Instruments are factory calibrated by the vendor, have certification papers shipped with the instrument, and do not require field bench testing.

To minimize the use of scaffolding, manlifts are used to the extent possible. In addition, preassembly at grade is performed to the extent possible prior to equipment erection. Subcontractors are responsible for supplying and erecting their own scaffolding.

When construction is approximately 70% complete, the focus changes from construction by area to completion by system. The civil and structural work are substantially complete, the equipment is set, and most of the large-bore piping is installed. The project schedule is driven by the mechanical completion and precommissioning requirements. The startup coordinator, assisted by the project field engineer, defines, scopes, and assembles the system completion and turnover packages.

As the piping installation, hydrotesting, and equipment erection are completed and the density of craft personnel and construction equipment is reduced within each area, the balance of the painting and insulation work is completed. The pipe racks are completed first, followed by the process and utility areas. After the installation of the equipment and piping has been completed, the final road paving, site grading, and cleanup are done. The temporary construction facilities are demobilized progressively as they are no longer needed.

Startup and commissioning activities are performed with the assistance of subcontractor construction craft and/or specialized technicians. Design-related problems discovered during the mechanical completion, startup, and commissioning processes are resolved by the Engineering group. Subcontractors perform any required field modifications arising from the technical resolution of design-related problems.

## 16.2 Constructability Reviews_

A construction representative was assigned to the CCC Plant FEED Study during preliminary design, and constructability reviews were initiated. The construction representative provides early detailed construction planning in coordination with engineering design and procurement activities. Front-end construction planning is the start of the constructability program that addresses and incorporates the following:

- Safety
- Quality
- Timely completion
- Productivity
- Environmental
- Cost-effectiveness
- Operability
- Maintainability
- Reliability
- Special project concerns

This front-end planning and integration of construction knowledge and experience into the planning, design, and engineering process are the greatest benefits of the constructability program.

Constructability reviews performed for the heat recovery steam generator (HRSG) stack tie-in determined that the limited 4-week outage window is not sufficient to complete the tie-in scope of work. Further reviews determined which construction activities can be performed prior to the outage. These are detailed in Constructability Study 10112936-PB-O-DOC-0001 (25474-000-4CR-T01G-00001).

Constructability reviews performed to ensure that no operational disruptions occur from working within the operating CCPP during pre-outage construction led to the decision to use a stick-build and preassembly approach as the preferred construction method.

Another key constructability issue related to the stack tie-in is the ability to isolate the flue gas ductwork system upstream of the absorber towers. An evaluation of the potential impacts to construction led to the decision to ensure that the guillotine dampers are installed during the pre-outage scope of work. The dampers are installed and tested pre-outage to ensure that the flue gas can be isolated once the tie-in is made. This permits construction and testing activities to continue on all equipment downstream of the dampers.

As preliminary design for the amine and compression portions of the plant proceeded, the Construction and Engineering groups jointly performed constructability reviews for these areas. Delivery dates have been established for the long-lead equipment, and the construction sequence is designed with the late deliveries in mind.

A significant activity during the civil phase of work is the removal of rock for seawater piping, foundations, and underground utilities. Rock blasting is a critical path activity. Constructability reviews of the seawater cooling line installation revealed the need to avoid planning for the use of heavy rigging cranes on top of these lines. Consequently, the heavy lift sequences have been modified to avoid the seawater lines.

The identification of delivery dates for the absorber and stripper towers allowed the rigging sequence for related ductwork and pipe racks to be established. Reviews of the ductwork and pipe racks confirmed that modularizing to the extent possible minimizes congestion within the construction area. Therefore, the rigging plans developed ensure that sufficient space is available to set each heavy lift. The constructability reviews also identified the need to install temporary haul roads along the north side of the site. These temporary modifications are required beyond the designated site boundary.

After the absorbers and stripper towers are set, the installation of large bore pipe commences. An important constructability issue is crane access around the towers during pipe installation. Therefore, areas with restricted access are a primary focus early in the piping phase. Piping around the absorber and stripper towers is sequenced prior to setting the pipe racks.

Through constructability reviews, a sequencing plan has been prepared for installing the modularized pipe racks once the platform,

ladders, and down-comer piping are installed around the towers. The rack pipe and electrical commodities are interconnected as soon as the modules are set.

The modularized construction approach helps minimize the number of construction craft workers required on this restricted construction site. While the towers and racks are being modularized and shipped, the balance of plant facilities can be constructed. This includes the electrical switchgear building, control/workshop/stores building, and compressor building. The equipment is placed within each facility, and piping and cable pulling begins once the buildings are sufficiently enclosed.

The compressors are long-lead critical equipment. Constructability reviews revealed that the building design needs to accommodate late delivery of the compressors. Plant construction is complete before this equipment arrives. Compressor sections are transported into the building through the roll-up door and rigged onto the foundation. This approach permits the bulk of the building to be constructed without the compressors.

The final construction phase is construction testing of the various systems. A system turnover plan is developed early in the project, and the construction plan incorporates this turnover plan.

## 16.3 Commissioning Approach _____

#### 16.3.1 Cold Commissioning ____

Once a system is mechanically complete, the Construction group turns it over to the Startup group to begin cold commissioning. A system's acceptance by Startup constitutes its mechanical completion and indicates that it is ready to be commissioned.

Once a system has been accepted by Startup, it is green-tagged, and cold commissioning activities then begin, followed by commissioning and startup (hot commissioning phase). This is also generally known as the startup phase.

The Project Startup Manual describes the startup process, including, but not limited to, administrative and technical procedures, detailed commissioning schedule, organization chart, and definition of the subdivision of the plant into discrete portions to facilitate phased turnover from Construction to Startup. Standard test and commissioning procedures (STCPs) are used to perform cold commissioning, which is carried out in a manner compliant with NORSOK Z007 standard. Refer to Mechanical Testing and Completion Schedule 28474-000-583-U07G-00001.

Permanent plant operations personnel assist with cold commissioning activities, which provides them their initial on-the-job training (OJT).

In addition to planning and scheduling, Startup performs the following tasks during this phase:

- Monitor precommissioning activities
- Inspect construction records
- Check equipment/systems and prepare preliminary punch lists
- Verify that mechanical completion checks have been performed
- Prepare all necessary inspection records and test certificates; ensure that all documentation is in place to allow systems to progress to the commissioning phase
- Generally expedite the transition from precommissioning to commissioning
- Monitor vendor representative activities so that personnel are used efficiently and contribute effectively to the vendor training program, both in the classroom and in the field
- Perform final inspection of vessels and other equipment internals on a selected basis and close and leak test such vessels and equipment where applicable (Final inspection of some vessels may take place in the initial stage of the commissioning phase.)
- Perform final cleanliness inspection prior to closing key piping

Plant equipment is accepted from Construction on a system-by-system basis for start of cold commissioning. Figure 16.3-1, Systems Turnover, depicts a representative series of turnovers from Construction to Startup for the Kårstø project. Durations shown are rough approximations of the duration of all aggregate commissioning activity for a given system.

Figure 16.3-2, Cold Commissioning Activities, lists typical activities undertaken during cold commissioning, along with the applicable STCPs.

					l	Karsto CO2	Capture Plan	t		
		Days resolution in schedule graph Milestone Summary Schedule D	7 ates DAY		F	Project Name	Karsto			
		Start Checkout	1		C	Driginator	rkress			
		Energize First Domin Water	31	ASSUMPTION	S:					
		First Amine	117							
		First CO2	134	NOTES:	d Otrion on T	euron Deeking i	natallation comm	ata hu duna	alı aftar tura	
		Target Complete	182	1) Absorber an	a stripper i	ower Packing I	nstallation compl	ete by 1 we	ek atter turno	over
				2) Potable wate	er available	for flushing				
		NOTE: Durtations are representat	ive and not meant to be							
		guarrantee commitments. Refer to	applicapble MSS	3) Flush waste	of quality th	at it can be dis	charged			
		schedule documents for proposed	milestones.	4) Performance	e Test: Proje	ect Specific				
				5) Functional T	ests: Proje	ct Specific				
							8			
				ckow			e Ne			mptop
				gi Cow			Amin	8		8
				Shart			Rise Res	19 19		Tar
				• • • • •			• • • • •	• • •		•
				1	2	3	4	5	0	2
Prereq		System	Duration Adj							
	EG01	Grounding	7	<b>1</b> = =						
	VB01	HVAC (control room)	7							
	ED01 EU01	125/220 VDC	5 5							
	EM01	Protection & metering	30							
	ZA01	Main and Aux transformers	30							
	PF01	Fire protection	30							
	JD01	DCS	183							•
	ES01 EK01	Load centers	30							
	EC01	Low voltage MCC	30							
		Energize	0	•						
	PA01	Instrument & Service Air	14			_				
	WR01 WD01	Raw water Demineralized Water	28				- I			
	XW01	Waste Water	14				-			
	PW01	Potable Water	14							
	XN01	Sanitarty Waste	14					_		
	EHU1 CN01	Freeze Protection Amine Absorber	90							
	CN02	Amine Wash Water	90							
	CN03	Rich Amine	90							
	CN04	Lean Amine	90							
	CN05 CN06	Flash Feed Amine Stripper Tower	90							
	CN07	Amine Reclaim	100							
	CN08	Amine Chem Feeds	60		-			-		
	BA01	Flue Gas and Water Injection	100							
	QG01 SB01	CO2 Compression	75		'					
	QG02	CO2 Drving	+2 21							
	AB01	LP Steam	30			1		•		
	SC01	LP Condensate	30					•		
	WL01	Sea Water Cooling	42							
	FE01	Communications	10							
	JQ01	Security and CCTV	14							
	EL01	Lighting	21						•	
	AN01	Emergency Diesel Gen	21							
	EQ01	Cathodic protection	10							
	EWUI	werding receptacies	10					-	-	

Figure 10.3-1. Systems furnover	Figure	16.3-1.	<b>Systems</b>	Turnover
---------------------------------	--------	---------	----------------	----------

	5	6	7	8	9
A		Install temporary commissioning test equipment as required	Complete preparations for flushing, chemical cleaning, steam and blows	Perform flushing, chemical cleaning, steam and air blows	Install all orifice plates
В	Calibrate and test instruments	Initially energize and test control loops		Stroke control valves/dampers, etc.	
с	Install temporary pipe for flushing and cleaning	Perform API valve tightness test		Inspect temporary strainers and differential gauges	Perform equipment oil flushes
D	Schedule vendors for functional testing	Load catalyst and chemicals and close up	Provide chemistry consulting services	Load initial charge of resins, filter media, chemicals, etc.	Make all support utilities available
E	Calibrate/test meters, relays, CTs, PTs, and secondary circuits	Perform additional cable and equipment hi- pot/megger tests as required	Test power transformers and major electrical equipment	Initially energize major power supply systems, including phase checks	
F			Bump motors for rotation	Run-in and vibration test motors uncoupled	Couple rotating equipment
G	Check out and perform in-service test of control room HVAC	Power up DCS	Complete preparations for process system high pressure leak tests		
н	Set MOV torque switches and adjust limit switches	Electrically operate MOVs	Remove and set safety relief devices	Perform required maintenance on equipment and systems	Complete the data sheets and test records
J		Manage the clearance and safety tagging program	Complete insulation and painting	Identify design problems to engineering for resolution	Remove all scaffolding and combustible materials

The phase where component testing occurs. This phase is sometimes referred to as "precommissioning," "cold commissioning," "construction completion," or "pre-op." Typically, this phase of execution follows system/component turnover from Construction but may vary depending on contract requirements. Activities in this phase are typically executed by Startup personnel; however, some may be executed in the Construction Completion Phase by other experienced testing personnel trained and knowledgeable of Startup processes and procedures. Support labor for these activities may be subcontractors, Construction, or Startup direct, depending on project execution plan.

Pre-commissioning Phase (Cold Commissioning), from Figure 16.3-2, Project Completion Phases, Mechanical Testing and Completion Schedule, 10112936-PB-0-DOC-0005 (25474–000–583–U07G–00001)

#### Figure 16.3-2. Cold Commissioning Activities

#### 16.3.2 Hot Commissioning ____

Once cold commissioning is finished, plant startup enters the hot commissioning phase. Carried out by the Startup group, hot commissioning is essentially a seamless phase transition in the plant's startup with respect to administration of the safety lock-out program and the care, custody, and control of the equipment and systems. Refer to Cold Commissioning Schedule 10112936-PB-O-DOC-0006 (25474-000-512-U07G-00001) for a description of activities leading to hot commissioning.

STCPs are used to perform cold commissioning, which is carried out in a manner compliant with NORSOK Z007 standard. Refer to Mechanical Testing and Completion Schedule 10112936-PB-O-DOC-0006 (28474-000-583-U07G-00001).

Permanent plant operations personnel assist with hot commissioning activities, which provides them the primary part of their OJT. During this time, these operators are expected to operate plant systems safely and efficiently as directed. Responsibility for hot commissioning rests with the Startup group, augmented by field engineering, safety, and maintenance personnel, as well as permanent plant operations personnel.

Plant equipment and systems are made ready to receive combined heat and power,  $CO_2$  amine solvent, and other chemicals, to process flue gas during hot commissioning. Arranging for vendor service/startup representatives for major equipment at the appropriate times is a critical function during this phase. These activities also include:

- Performing initial charging of solvents and chemicals
- Performing system functional checkout
- Cleaning and checking temporary strainers during initial circulation or fluid flow operations
- Checking and testing hazard detection, firefighting, and other lossprevention systems and equipment
- Ensuring that documentation is in place to allow a system to progress to the operation phase
- Supervising and directing permanent plant personnel in startup, testing, maintenance, and operation activities until turnover (These personnel are used only in ways consistent with staff position and responsibility.)
- Performing formal system walkdowns before startup, with appropriate prior notifications
- Preparing and submitting system turnover packages as scheduled. As a minimum, these packages consist of the following:
  - General
    - Turnover package and section indices

- * Copy of not-yet-incorporated Design Change Notices (DCNs)
- * Punchlist
- * Copy of system and specialty commissioning procedures that contain recorded data or sign-off
- Mechanical
  - * Current red-line, as-built, approved boundary piping and instrumentation diagrams (P&IDs)
  - * Hydrostatic test records
  - * Pipe cleaning records (flush, blow, chemical cleaning, etc.)
  - * Safety/relief valve field setting record
  - * Coupling alignment records (with and without pipe attachment)
  - * Driven equipment data sheets
  - * Vibration data sheets
  - * Drive turbine data sheets
- Electrical
  - * Approved, highlighted schematic wiring diagrams or cable schedule indicating completion of proper cable checkout
  - Block diagram(s)
  - * Bus bar torque data
  - * Electrical scheme test data sheet
  - * Termination/continuity record
  - * Cable test record
  - Motor data sheets
  - * Motor-operated valve (MOV) data sheets
  - * Battery data sheets
  - * Megger data sheets
  - * High-potential test data sheets
  - Switchgear test records (EL)
  - * Transformer test records
  - * MCC test records (EL)
  - * Earth loop impedance test records (EL)
- Instrumentation and Control
  - Calibration sheets
  - Loop test records
  - * Control logics/ diagrams
  - * DCS interface drawing
  - * DCS configuration diagram
  - * As-built set points, alarms, and trips
  - * level setting drawings
  - * DCS input/output (I/O) list highlighted to reflect verified I/Os
  - * Instrument Index

- Operation and Maintenance
  - * Lubrication records
  - Construction-storage-phase maintenance/lubrication/heating records
  - * Startup-phase maintenance and lubrication records
  - * Vendor service engineer's reports
- Administering and conducting system walkdowns in preparation for turnover

Before the scheduled turnover date, and allowing sufficient time for review, the Startup-to-Customer Turnover Package is submitted for acceptance. The turnover package typically includes those items listed above plus the Startup-to-Customer System/Facility Turnover Form, identifying the items being turned over. This form is completed and properly signed by the responsible personnel. Signatures indicate the following:

- The project startup manager's signature signifies that the system/facility testing is complete to the extent that it is ready for operation, and that exceptions are listed on the punchlist.
- The Customer's, or Customer designee's, signature indicates turnover acceptance of the system/facility, including any exceptions noted.

Punchlists are updated to show the current status of turnover exceptions. Each exception item that has been completed before turnover is signed as complete by the responsible personnel. Each exception that is not completed before turnover has an estimated completion date and responsible party entered on the form. The form is included in the turnover package.

The Customer reviews the turnover package for completeness, accuracy, and exception status. If the turnover is acceptable, the Facility Manager indicates acceptance by signing the Startup-to-Customer System/Facility Turnover Form transmitted with the package and distributes a signed copy to the project startup manager. If a turnover is not acceptable, the turnover package is returned to the project startup manager with a detailed written explanation of why the turnover was rejected.

Upon receiving the signed copy of the Startup-to-Customer Turnover Form, Startup proceeds to remove green turnover tags and replace them with blue tags if the blue tag process is being used by the project. If the blue tag process is not being used, the green tags remain in place until the Customer takes care, custody, and control of the facility. Figure 16.3-3, Hot Commissioning Activities, lists typical activities undertaken during hot commissioning, along with the applicable SCTPs. Figure 16.3-4, High Level Schedule of Commissioning Activities, provides a basic schedule of aggregate commissioning and startup activities.

	10	11	12		13	14	-
A	Set all process blinds as per blind list		Operate & monitor permanent plant equipment & systems		Lineup systems for operation	Unit line out	
в		Verify digital & analog control circuits & interlocks	Functionally test/operate instruments & controls as systems		Gas in & pressure up to the facility working pressure	Fine tune process variables	
С	Perform final HVAC testing	Check & set boiler safety valves	N ₂ purge of the flare & fuel gas systems			Introduce feedstock	
D	Conduct steam boiler functional tests	Perform vacuum leak tests as required	(C) Remove temporary piping & equipment as required		Cold circulation operation	Lab tests of all samples	
E	♦ Schedule Vendors for initial equip. operation		Perform steam line blows (boiler operation)	Systems testing complete and facility ready for	Hot circulation operation	Route product to storage	Facility ready for Acceptance/ Performance
F	Run-in & vibration test rotating equipment	Perform in-service leak tests	Process system N ₂ purge	integrated startup & process operation.	Re-torque bolting as required	Perform transient tests	Test and Turnover to Owner.
G	Perform process System high pressure leak tests	Adjust pipe hangers to operational settings	Perform hot alignment checks on rotating equipment		Setup for performance testing	Establish normal operation	
н	Supply chemicals, fluids & spare parts as required	Complete data sheets & test records				Complete data sheets & test records	
J	Identify design problems to engineering for resolution		Turnover to owner walkdown		Touchup insulation, painting, etc. as required	Feed rate to design conditions	

#### HOT COMMISSIONING

#### **Commissioning Phase**

Occurs after completion of component testing and system turnover to Startup or others as defined by contract. System testing and integrated system testing on safe fluids are performed in this phase and systems are placed in service to support overall plant startup. Performance of activities in this phase are typically executed by Startup personnel.

#### Startup/Operations Phase

The phase where final system tests are performed, feedstocks are introduced, and the facility is made ready for performance/ acceptance testing. Activities in this phase are typically executed by Startup or Facility Operations personnel.

Commissioning and Startup/Operations Phase, from Figure 1, Project Completion Phases, Mechanical Testing and Completion Schedule, 10112936-PB-O-DOC-0005 (25474 - 000 - 583 - U07G - 00001)

#### Figure 16.3-3. Hot Commissioning Activities

		5 6 LOAD AMINE
		TARGET 🚹
Resolution	/	COMPLETE
PHASE System Duration		
	┥┛┥╸┥╸	
	╢┛╢┛╢┛╢┛╢	╸┥╺┤╺┤╺┤╺┤╺┤╸ <mark>╴</mark>
COLD Checkout High Voltage 30		
COLD DCS Control System Checkout 183	++++	
	++++	┽┼┼┼┼┼┼┼┼
COLD Checkout Medium and Low Voltage Distribution 60	++++	
COLD I/O and Loop Continuity Check 124		
COLD Panel Checks 30 30 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4		
	╢┛╢┛╢┛╢┛╢	┺┤┻┤╺┤╶┤╶┤╶┤╶ <mark>┥╶</mark>
COLD Motor Runsy Pump Checks 42	++++	┽┼┼┼┼┼┼┼┼
COLD Priping System Flush	++++	┼┼┼┼┼┼┼┼┼
COLD Fan and Compressor Lube OII Flush 30		┽┼┼┼┼┼┼┼┼
COLD Alkaline Flush of Amine Path 30 30 10 10 10 10 10 10 10 10 10 10 10 10 10		┽┼┼┼┼┼┼┼┼
	┼╾┼╾┼═┼═┼	┽┼┼┼┼┼┼┝╋
	┤┻┤┻┤┻┤┻┤	
HOT Recirculate Amine Loop on water /	++++=+	
HOT ID Fan Run on Cold Gas / Open Damper 14	┼┼┼┼╤┼╸	╕╕┥┥┥┥┝
HOT Initial Fump Runs 30 1 1 1	++++=+	
NOT Initial CO2 Compressor Run on Air 5	<del>┥┥┥╹</del>	┼ <u></u> ╡┼┼┼┼┼┼┝ <mark>╷</mark>
NOT     File CCFF in the aneady operating       NOT     Load Amino to System (Pacigraphica)	<del>│                                    </del>	
NOT     Load Anime to System/reductable       JOT     First Flux Gas to Tower	++++	┼┼┼┼┼┼┝┝
IVOT Prisciple Gas to Towers 1	+++++	
NOT Steam to nA and Annie warmup / /	+++++	
Invite         14           UOT         Tupe and Test Pariod           20         20	++++	┼┼╤┼╤┼╤┼╤┼╤┼╤┝┯┥╴
	<del>┥┥┥╻</del> ┇	
	<del>╷╷╷╹</del> ╹	<del>╸╷╺╷╺╷╺╷╸╷╸╷╸╷╸<mark>╴</mark>╸</del>
	++++	<del>┼┼┼┼┼┼<mark>╹</mark>╴</del>

Figure 16.3-4. High Level Schedule of Commissioning Activities

## 16.4 Schedule Overview (Level II with Storyboard)_____

#### 16.4.1 Critical Path Activities_____

The critical path begins with initial system engineering. This leads to preparing the specification for the columns of the flue gas absorber and amine stripper and continues with bidding, evaluating, and awarding the columns. These columns are the long lead time items in today's market. The path continues with fabricating, delivering, and setting the columns and installing the column internals. The path then follows through precommissioning and concludes with project completion at the end of hot commissioning.

#### 16.4.2 Key Schedule Durations _____

Key schedule durations are as follows:

Milestone Description	Months from NTP
NTP	0
Site mobilization	9
First concrete	12
Absorber column delivery	18
Energization	23
Project completion	28

## 16.5 Schedule Assumptions and Risks _____

#### 16.5.1 Schedule Basis and Assumptions _____

Schedule is based on modular approach to installing the pipe rack and associated pipes and cable trays. Equipment lead times are based on budgetary quotes. Construction schedule development was based on detailed storyboard analysis.

#### 16.5.2 Schedule Risks _____

Schedule risks include the following:

- Early design support is required to support procurement of major commodities.
- The compressor lead time is 18 months.

- Early design support is required for release of bulk pipe in support of offsite pipe rack modularization.
- Crane access and installation sequencing must take pipe rack layout into consideration.
- Winter weather is a factor.
- Owner support is required for the power plant outage.
- Overseas shipment is scheduled for all major equipment.

## 16.6 Owner Milestones (Required by Schedule)

0	1 2
Milestone Description	Months from NTP
Geotechnical investigation complete	(-) 2
EPC Contract Award	(-) 2
Notice to Proceed	0
All required permits received	8
Site free and clear	9
Tie-in outage starts	17
Tie-in outage completes	18
Seawater intake completed	22
22 kV power available	22
Seawater available	24
Naturkraft CCPP in operation	25
Natural gas available	25
HP and LP steam available	25.5
CCC Plant in operation	30

The following Owner milestones are required by schedule:

## Attachments _

16.1 Project Level II Schedule

16.2 Project Construction Story Boards

- Months 10 to 22, starting at Notice to Proceed (NTP) as shown on the Schedule
- Pipe Rack Sequence

Page 1 of 3

						09	_										10												11		_
DESCRIPTION	WBS	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	Мау	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Se
		-5	4	-3	-2	<u>  -1</u>	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24 NATURKI	2 R4
OWNER MILESTONE DATES				EPC		.CT	NTP								P PERM	ITS (ALL) E FREE /	AND CLEAR	       R								SE	EA WATE OMPLETE 22K AV/	R INTAKE	م م	SEA WA	• •Ti
PLANT MILESTONES				ENG.	A DSN STAF								8 8 8 8 8 8		MOBIL				▲ FIRST		         								ENE	RGIZE	GA
ERECT BATCH PLANT	1					     							PEC	[₿]	I EA I	]3		EREC		KE I E	     										19
FINAL SOIL BORINGS	2		     		(			OIL BOR							!     			!     			l     	     		     	     						
SITE PREP & EARTHWORK	3		1						¢—	SPEC		<b>ф</b>	BEA				PREP	þ—	CRAN	E PAD		þ		1	1		1				
BLASTING	3.1		1	1						1		1	 		 		STING	5			   	1		1							
SITE WORK & TEMP SERVICES S/C	3.2		1						<u> </u>	SPEC		<u> </u>	BEA	-	ż	<b>∕</b> Р мов		   													
TEMP POWER, WATER AND OFFICE AREA	3.3		i i	i		i			i				 				AND PAF		rup )		   	i i		i i			i I	i			
FENCING S/C	3.4		1						$\leftarrow$	SPEC		<b> </b>	BEA	F	-	Амов		   				1		1							
BARGE UNLOADING CRANE PAD	3.5		 	   						1		   	 		 			¦ C	PILES			VE SETUR	Þ	1	I I I						
COOLING WATER PIPE	4							BEA				FAB / DE			19 D					CIRC PIPE		5									
UNDERGROUND SERVICES	5								<u> </u>	SPEC		O BEA		FAB &	DEL D	^{el} 7	(	 	NSTALL U	G (	)	CC			ries	(					
CONCRETE & UNDERGROUND SERVICES S/C	5.1								<u> </u>	SPEC			BEA				Амов	-     			,     				   				1		
U/G P&ID'S (FG,PF,PW,WD, WL, XN, XW)	5.2									EP & ISSU	IE U/G	0	     					   			   			   							
U/G PIPING ROUTING / DESIGN	5.3								C	) SP	EC	BE		FAB /		^{el} 7	(		ALL U/G P		5										
U/G ELECTRICAL DUCT BANK	5.4								(		EC			FAB /	DEL D	el 7	(		L U/G ELE		5			   							
TIE IN TO EXISTING STACK	6									<u> </u>	DSN			FAB/DEL		-c )						1			N READY	FOR OUT/	AGE			Ą	Б
RELOCATED EXISTING EQUIPMENT	6.1																ATE EXIS		IPMENT												
INSTALL NEW FND	6.2											(		DSN			C				     			     							
STEEL STRUCTURE	6.3										DSN	     			 	FAB & D	EL	     		ERECT		)		   	 						
NEW DUCT & DAMPERS @ STACK	6.4														     				7	7	{		DUCT AT		STACK						
ABBSORBER FND	7												(	<u> </u>		, (	FC 		(		FREP	FND	#2	#1 0 -							
ABSORBERS	8		   		(		I/SPEC		BEA							FAB	/ DEL							T			ERECT	ABSORBER	S EQUIP.	& PIPES	z
HEAVY LIFT & CRANE SERVICES S/C	8.1												(		<u>}</u>	BEA		 			   				Y LIFT CF	ANE ON	SITE				
ABSORBER #1	8.2				(		I/SPEC		BEA	, ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			, ,,,,,,,		 	F	АВ					s 7777	,     	7				ECTION AB	SORBER E	QUIP. & PIP	ES Z
ABSORBER #2	8.3				(		WSPEC		BEA							F	ав					s Trine	, 	\				SORBER E	QUIP. & PIP	èes	Z
ABSORBER INTERNAL	8.4		 						BEA	; 	 	-				m	FA	в 11111				; 7777		SH	)   P		; 7777		INSTALL		Z

					12		
ер	Oct	Nov	Dec	Jan	Feb	Mar	CO2 KARSTO PROJECT
25	26	27	28	29	30	31	
-		1	1				
AFT P	LANT OPE	I RATION	l I		1	1	
HP	& LP STF	AM AVAII	I				✓ [−] SCHEDULE MILESTONE EVENT
	P	1	1	CCC PL OPER/	ANT IN	A	
ſER						1	
			 5 AV/A II A II			1	P.O. OR SUBCONTRACT AWARD
	IN/AT	URAL GAS				i i	<u>^</u>
		1	1			1	C RELEASE FOR FABRICATION
		I	1		T	I I	
		Α	1	COWP			
S PA	MEC TH COM	HANICAL PI FTION	l I				C SCHEDULED ACTIVITY
τ		1					
		1	1		1	i.	
		I	 			1	CRITICAL ACTIVITY
_							
						i.	SECOND SHIFT
		 	I I				
			1		1		
			1				ABBREVIATIONS:
						i i	BEA BID, EVALUATE, AWARD BLDG BUILDING
			I.				CONS CONSTRUCTION COMP. COMPLETE
			1				DEL DELIVER DSN DESIGN
						Ì	EPC ENGINEERING, PROCUREMENT, CONSTRUCTION
		l I	I.				EQUIP EQUIPMENT FAB FABRICATE
		1	1		1		FDN FOUNDATION
						i.	GPC GAS PATH COMPLETE
		1	l			i.	IFC ISSUE FOR CONSTRUCTION
		1	1		1	1	INST INSTALL LNTP LIMITED NOTICE TO PROCEED
		——					LP LOW PRESSURE MOB MOBILIZATION
		l I	1			i.	NTP NOTICE TO PROCEED SPEC SPECIFICATION
			 			1	U/G UNDERGROUND UTIL UTILITIES
			1			1	
		1	1			1	
			1			1	
		i i				i i	
		1				1	
			1		1	1	
						i i	
		1	1		1		
			1			1	
		1	 		1	1	
		1	1		1		
TIE-IN	NEEDS T	o				i.	
BE CO	MPLETE	1	1				
			1				
		1	1		1		
			1		1		
			I			i.	
		1	I.		1	1	
			1				
						i.	
		I I	I.		1	I.	
		 	I 			-	
			1				
			I.				
			1			1	
77	2		1			i.	
		1	I I		1	I.	
			1		1		
			1				BECHTEL
s	Ļ		I.		1		FREDERICK, MD
	٦		1				
	)		1				
			1		1		
Z		i	I			i i	
~		1	1		1	1	

Page 2 of 3

				09 10												11							—										
DESCRIPTION		Apr	Ma	y Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ja	n Feb	Mar	Apr	Мау	Jun	Jul	Aug	Sep	0	ct N	ov	Dec	Jan	Feb	Ma	r Ap	or	Мау	Jun	Jul	Aug	5
		-5	-4	-3	-2	-1	1	2	3	4	5	6	7	8	9	10	11 DSN FND	12	13 IFC	1	4 1 REP FNC	5	16	17	18	19	20		21	22	23	24	_
STRIPPER FND															(			[	0	$\dot{-}$			)					1	1			1	
STRIPPER EQUIPMENT						SIGN		<b> </b>	BEA	<u></u>	¢zz					F/	и				m		SI 7772)(	не С					ERECT	STRIPP	ER EQUIF	2. & PIPE	
FLUE GAS BLOWERS - FND															(		DSN F	FND	     			C	FREP	BASE SL	AB O								-
FLUE GAS BLOWER EQUIPMENT							SI 	PEC / BEA			-			-			FAB & DE	EL		-								-	·	INSTALL	EQUIPME	NT	Ū U
FLUE GAS EQUIPMENT #1	12.1																													L R #1			& BU
FLUE GAS EQUIPMENT #2															-     													INS BLC	WER #2		STALL DU		JLKS
FLUE GAS BLOWER VFD'S							<u> </u>	SPEC / BE			-		1	-			FAB / DEL	-	 			-								ISTALL V	/FD'S	þ	
FLUE GAS BUILDINGS	12.4								       																		$\leftarrow$			NSTALL			Ó
FLUE GAS DUCTS - SEE 6.4	12.5							<u>↓</u>	DESIGN		$\leftarrow$	BEA		┢══ ┼──		F	AB							+			DE	EL & IN	NSTALL			 	
COMPRESSOR AREA FND	13												     				0	]					)		<u> </u>		<b>-</b>		i i			   	   
COMPRESSOR EQUIPMENT	14						(	;	SPEC / BE		ф=		1						FAE	B & DEL		-								4			
CO2 COMPRESSOR- 26,000 HP	14.1							ф <u> </u>	SPEC / BE		ф <u> </u>		1		 			FAB 8	& DEL			-							!.	5	7	INSTAL	+
COMPRESSOR VFD'S												<u>с</u>	SPEC / BE		- 			545		F	AB & DEL	-							, .				
CO2 PRODUCT SENDOUT PUMPS - 250 HP							(	<u>}</u>	SPEC / BE		<u>†</u>							FAB	& DEL			-	540								7		+
COMPRESSOR BUILDING	14.4													<u> </u>	SPEC			BEA		╞			FAB	/ DEL			<u> </u>		RECT		>	   	
PIPE RACK - FND	15								     				   		(		DSN FND	(	⊇ 		-0		FREP		ф 				1			   	
MODULES	16					- -	DESIGN/ E	BÉA	- 			   	FAB		   			DEL 7	   	+					AB & INS	STÀLL						 	ņ
STRIPPER AREA STEEL MODULES													   		   	1			1		AB MODUL	LES R	REBOILE	Ř-SEE 2	0.6	φ		- + .		CT STEE	EL AT STR		
STEEL, RACK PIPE, VALVES, FITTINGS & CABLE TRAYS						<u> </u>	DESIGN/ E	BEA PR		   	-		FAB		   	1 1 1		del 7	   						FIN							1	
SOUTH SIDE PIPE RACK MODULES	16.3														   	C		FA	B MODU		E RACK			þ	_		TALL PIPE	ERÁCI		.ES & BU		1	
MIDDLE PIPE RACK MODULES	16.4															1	q		F 	AB MO	DULE PIP	PERAC	СК		ф	·		TALL I	PIPE RAG	XK MODU	JLES & BL	ILKS C	
EAST SIDE PIPE RACK MODULES						   							   					(	╞		FAB MC		PIPE R			ф		-7		PIPE RA		JLES & E	логк Ф
AMINE - EQUIPMENT	17						þ	DESIGN			BE				   				DS	SN / FAB					   	 		_√			STALL EQ		+
AMINE AREA - FND'S	17.1								   				   		   	1	Ċ	)	DSN					þ	FREP	Þ						1	
AMINE EQUIPMENT	17.2		   	   			<u> </u>	SPEC		<u> </u>	BEA		<u> </u>					DSN	/ FAB										   		ALL EQUIF		
ELECTRICAL SWGR BUILDING							¢		SPEC / D	SN			I BEA		-			AB / DE	L   				11	NSTALL I	ELECT E							1	
ELECTRICAL BUILDING FND									   				 		   (		SN IFC	; ) -  -  -(		FREP												1	
ELECTRICAL BUILDING								5	PEC / DS		-		BEA				FAB & DE	ELIVER	 						   	ERECT						1	
MV SWGR IN ELECTRICAL ROOM									$\overline{\mathbf{c}}$	SPEC	;		BEA		<u> </u>				F	FAB & D	ELIVER				 				LL   R   			]	
CONTROL ROOM / WORKSHOP / STORES		1				1		<u> </u>	SPE	d	÷	B	ÉA	ļ_		DES	SIGN		FREP	, t		FA	AB					E	RECT	INSTALL		]	

					12		
ер	Oct	Nov	Dec	Jan	Feb	Mar	CO2 KARSTO PROJECT
25	26	27	28	29	30	31	
					-   		
					<u>                                      </u>	 	SCHEDULE MILESTONE EVENT
	) 				 	 	
					   		P.O. OR SUBCONTRACT AWARD
_					1		C RELEASE FOR FABRICATION
					1 	   	
кs							
					 	i I	
					 	1	
					   		SECOND SHIFT
					 		ABBREVIATIONS: BEA BID, EVALUATE, AWARD
					   		BLDG BUILDING CONS CONSTRUCTION COMP. COMPLETE
							DEL DELIVER DSN DESIGN EPC ENGINEERING PROCUREMENT
л							CONSTRUCTION EQUIP EQUIPMENT FAB FABRICATE
	þ						FDN FOUNDATION FREP FORM, REBAR, EMBEDS, PLACE
_	7				 	i I	HP HIGH PRESSURE
п	ſ				1		LNTP LIMITED NOTICE TO PROCEED LP LOW PRESSURE
Ξ	>					1	NTP NOTICE TO PROCEED SPEC SPECIFICATION
	5				 	1	U/G UNDERGROUND UTIL UTILITIES
_	ĺ						
					 	1	
					l   	-	
					 	1	
					 	i I	
					-   	I.	
					1		
	5				 	 	
_					 		
					1		
					 		KARSTO
					 		2 UNIT CO2 PROJECT
Page 3 of 3

		Γ				09												10													11		
DESCRIPTION	WBS	Apr	May	Jun	Jul	Aug	Sep	Oc	t Nov	v De	c Ja	an Fe	eb	Mar	Apr	May	Jun	Jul	Aug	J Sep	5 C	oct N	ov	Dec	Jan	Feb	Mar	Apr	May	Jur	Jul	A	.g ε
ADMIN BUILDING - PIT & FND	19.1	-5	-4	-3	-2	<u>  -1</u>	1	2	3	4			6	· (		9	10 DESIGI	11 N	12	13		FREP	15 	16 )	17	18	19	20	21	22	23	2	4
	19.2					1									Ī				- - -		Ĭ		- - -		BUILDIN	GISTEEL	RECTIO	N	- -	- - -			
	10.2					i I I			SPE	; c		BE	BEA							FAB	& DELIN	/ER	- 							s s		i	i
DCS EQUIPMENT	19.3		1			1	1		1	1	$\rightarrow$	1		L		1		-	1	1		1				1	1	¥	1	<u> </u>			
MECHANICAL EQUIPMENT	20						<u>þ</u>	SPEC /	BEA		-		DESI	IGN / SPI	EC / PRO				<u> </u>	-	FAB & I	DELIVER		1ST		 	1	-	 		+		VSTALL
MECH & PIPING S/C	20.1					   							¢		SPEC	; ;(		E	BÉA	_		P	мов										
AIR COMPRESSER / DRYER	20.2					1		SPEC		- - -	В	EA								FÁB & DE							I DEL	<u></u>	1	1	INSTALL		ENT
	20.2					   	T   		1				Is	SPEC		¦ 	BEA					FAB &	DELIVE	ER		DE	L/MOB					-	
FIRE PROTECTION STSTEM	20.3										SPE	ц с і			BEA	γ <u> </u>					FA	B & DELIN	/ER				-V	DEL MOB	1		ERE		IKS
FIELD ERECTED TANKS S/C	20.4									<u>с</u>	epr		=c ¦		DEA				1					'n				Υ					
EMERGENCY GENERTOR	20.5		i I I			i I I			i I I	Ò I	GrL		=Ò		BLA	-	<b>-</b>			-	+						   	-	Υ <del>΄΄</del>		-		$\exists \phi$
REBOILER	20.6						<u> </u>	BEA		÷	_					FAB & DEI			1	-	+		DI	EL - SEE	16.1 V								
OVERHEAD CONDENSER	20.7					   	<u> </u>	BEA		÷	_					FAB & D	ELIVER		     	-	+		-	DEI	<u>ι</u> γ	ERE		_		     	-	þ	
HEAT EXCHANGER	20.8		1					BEA								   FAB & D			1	-		-		DEI	 7	ERE			1			P	
			<u> </u>	<u> </u>		   		-	DES	IGN / SPE	EC	BE	EA			 				F	-AB & C	EL					    		 	 		INSTA PUMF	
	21		 	 		i i			<u> </u>							   				_						-	   				¥		
PIPING & INSTRUMENTATION	22									$\dot{\frown}$	SPE		=0	)	BEA	[	0 H			-	E	AB				<u> </u>		-	 		INSTALL	& INSUL	ATION
LARGE BORE PIPE	22.1					   				- 	SPI	EC	=	)	BEA	; [	<u> </u>		   	 	FAB &	DELIVER						-	   	   	+		INSTAL
PIPING & MECH EQUIP INSULATION S/C	22.2														t		SF	PEC	   	<u> </u>	ВЕ	A	╧			FAB 8	DEL			EL / OB			
ELECTRICAL EQUIPMENT	23										SPI	EC		)	E	BEA					FAB	& DEL			[	DEL IN:	STALL E	QUIPMEN'	 0				
	00.4										SPE	EC			в	ĖA					FAB & I	DELIVER				<u>Ė</u> INS	TALL EQ	UPMENT					
MCC/LOAD CENTERS	23.1		1							Ļ		1				1							1			Y	1		ļ				
UPS / BATTERIES	23.2		   							- -	SPE		<u> </u>		B	iÉA 		<u> </u>	   		FAB &	DELIVER				V INS	TALL EC	UIPMENT	φ				
RACEWAY & CABLE	24		1			1				IGN / SPE	EC			В	EA		<u> </u>		FA	B & DEL				L 7	INS		EWAY			PULL & TE			
	24.1									I I I SPE	EC .	-		BE	EA		<u> </u>		   FA	B & DEL				L		1	 		1	1	INSTAL		
CABLE THAT AND CONDULT	24.1									SPE	EC			В	BEA				   	FAB & I	DEL		¥	D	EL	1	1		1	1			
POWER AND CONTROL CABLE	24.2			1		1		-			-		REA					-				FAB	& DEI	\	$\square$	1	   	DEI	1				
MAIN TRANSFORMERS	25					   	(	╞						[	<u></u>	   				-	+					1		Ŷ—	1	   		Ď	
TRANSFORMER - FND	25.1													C	┝──	DSN			<b>_</b>	FREP	FND												
MAIN TRANSFORMER EQUIPMENT	25.2									-	SP	EC	=¢		BEA		H				-	FA	B & DE	LIVER		 	 		 		ISTALL	Ď	
STARTUP / COMMISSIONING (ENTIRE PLANT)	26																					1						5	TART CH	ЕСКОИТ			

					12		
бер	Oct	Nov	Dec	Jan	Feb	Mar	CO2 KARSTO PROJECT
25	26	27	28	29	30	31	
MECH	ANICAL E	QUIPMEN	T 1 1 1 1 1 1 1 1 1 1				SCHEDULE MILESTONE EVENT C ACTIVITY NODE P.O. OR SUBCONTRACT AWARD RELEASE FOR FABRICATION SITE DELIVERY C C SCHEDULED ACTIVITY
						1	
IN	STALL	5					
							ABBREVIATIONS: BEA BID, EVALUATE, AWARD BLDG BUILDING CONS CONSTRUCTION COMP. COMPLETE DEL DELIVER DSN DESIGN EPC ENGINEERING, PROCUREMENT, CONSTRUCTION EQUIP EQUIPMENT FAB FABRICATE FDN FOUNDATION FREP FORM, REBAR, EMBEDS, PLACE GPC GAS PATH COMPLETE HP HIGH PRESSURE HP HIGH PRESSURE HP LIMITED NOTICE TO PROCEED LNTP LOW PRESSURE MOBIL VATION
							NTP NOTICE TO PROCEED SPEC SPECIFICATION
				)		 	UTIL UTILITIES
L	)						
	INST	ALL/ INSU		)			
1ST D WATI		MINE 1ST CO2	2	FINISH	CHECKO		BECHTEL FREDERICK, MD
						• 	KARSTO 2 UNIT CO2 PROJECT



# Month 10

#### **Construction Activities**

- Site Mobilization
- Blasting Plan
- → Setup Site Offices
- Establish Laydown
- Establish Parking Lots
- → Start Site Grading





# Month 11

#### **Construction Activities**

- Site Mobilization
- Blasting Plan
- → Setup Site Offices
- Establish Laydown
- Establish Parking Lots
- → Start Site Grading





### Month 12

#### **Construction Activities**

- Start Installation at Processor Area for Circulating Water Pipe
- Install Underground Utilities.





### Month 13

#### **Construction Activities**

- Continue Installation of Circulating Water Pipe
- Continue Installation of Underground Utilities
- → Start Concrete for Transformer





### Month 14

#### **Construction Activities**

- > Install Circulating Water Pipe
- → Install Underground Utilities
- → Install CO2 Lines
- Start Electrical Building Concrete
- Continue Transformer Foundation





## Month 15

#### **Construction Activities**

- Start Stripper Concrete
- Start Electrical Building Steel Work
- Concrete work for the Control, Workshop, Store building
- > Finish Concrete Work for the Transformer





# Month 16

#### **Construction Activities**

- → Absorber #2 Concrete
- → FREP Rack Footings
- Start Steel work for the Control/ Workshop Building
- Place Area Slab (Area around the stripper
- Continue Electrical Building Steel work





### Month 17

#### **Construction Activities**

- Continue Electrical Building Steel work
- Concrete for Flue Gas Blower #1 & 2
- Continue Control Building / Workshop steel erection
- Continue Area Concrete to Allow Rack Setting
- Concrete for the Absorber #1





# Month 18

#### **Construction Activities**

- Continue steel work for the CWSB & Electrical Building
- Concrete foundation for the Duct Towers
- Concrete for the Amine Building





### Month 19

#### **Construction Activities**

- Start Pipe Rack Steel (South Side)
- → Set south side Ductwork
- > Finish Electrical Building Steel Work
- Continue Control Room / Workshop Building Steel
- Set the Absorber #2
- Set The Stripper
- Concrete for the Compressor Building





### Month 20

#### **Construction Activities**

- → Set Miscellaneous Pumps
- Relocate the 888 Crane from the East side
- Start Erect Compressor Building
- DCS & Electrical Equipment for Control Room / Workshop Building
- > Finish Steel Work for the CWSB
- Start Pipe Rack Steel (Middle Side)
- Set Ductworks
- Set The Absorber #1
- Setting Absorbers Equipments & Pipes





# Month 21

#### **Construction Activities**

- → Start Cable Pulling
- Finish Setting Electrical Equipment for Control Room / Workshop Building
- Set Equipment for the Amine Building
- → Start Pipe Rack Steel (East Side)
- → Set The Blower #2
- Continue Setting the Ducts
- Continue Setting Absorbers Equipments & Pipes
- Start Stripper Steel work





### Month 22

#### **Construction Activities**

- → Start Set the Transformer
- → Relocate the 4100 Crane
- → Continue Pipe Rack Steel.
- Continue Setting Absorbers Equipments & Pipes
- Setting the Ducts
- Continue Setting the Equipments for the Amine Building
- Setting The Duct Between The Blower And Absorber #2
- → Setting The VFD for the Blower #2
- Continue Stripper Steel work





# Pipe Rack Sequence

#### Notes:

→ Go to Month 19 for Rack Sequencing

Rack Module Sequence:

- 1) SR1
- 2) SR2
- 3) SR3
- MR1 4)
- 5) MR2
- 6) MR3
- 7) MR4
- ER1
- 8)
- ER2 9)

**17.0-Optional Functionalities** 

### 17.0 Optional Functionalities_

The following items represent possible options and opportunities that could be implemented in the engineering, procurement, construction, and installation (EPCI) phase of the Kårstø CO₂ Carbon Capture and Compression (CCC) Plant project:

- 1. Add a spray header under the absorber demister to increase its efficiency by keeping it wet, and delete the upper absorber packing bed.
- 2. Delete the individual pump minimum flow recirculation lines and use only a single recirculation system for the redundant pumps.
- 3. Move pump P-105A/B downstream of heat exchanger E-107 to reduce pump exposure to the hot amine from the stripper; pump NPSH will not be an issue.
- 4. Move all of the stream flows 102/202/333 (pumps P-102/ P-104/P-109) to Tank TK-102 to blend the streams before returning to the absorber as stream 104/204.
- 5. Move out-feed from carbon filter F-107 to tank TK-102 to blend this stream in the tank prior to returning to the process. This makes F-107 an atmospheric vessel and facilitates changing the filter beds. Make the filter dual in-line to permit on-line filter media change out.
- 6. Add a CO₂ compressor 1st stage inlet cooler in the recycle line to save motive power demand, which would reduce total compression HP and handle any 1st stage spillback flow without combining the spillback with the stripper overhead condenser. This scheme would simplify compressor startup since it isolates the compressor from stripper operation.
- 7. Provide each stripper reboiler with its own column connection for better symmetry and subsequent flow.
- 8. Move dual filters to the pump skids, with one filter per pump, since the pumps and their filters are redundant.
- 9. Change to caustic soda (NaOH) for the reclaimer as this is easier and safer to handle than soda ash.
- 10. Provide for a bunkered shelter under the flue gas duct or around the west end of the CCC Plant to reduce the travel distance for the operator in case of a site alarm.

- 11. Design the stack tie-in as a reinforced rib/plate steel template attached to the east side of the heat recovery steam generator (HRSG) stack with hole penetrations the same as the present HRSG breeching penetration, to eliminate the need for the external structural steel frame.
- 12. Steam generators (E-112, E-114, and E-116) are all single-pass tubular exchangers. Provide them as double-ended kettle type for steam collection and disengagement, plus a steam dome with demister to further reduce water carryover.
- 13. Remove the steam generators from the interstage compressor cooling arrangement to reduce capital cost.
- 14. Produce all low-pressure (LP) steam onsite using natural gas to avoid derating the Naturkraft plant steam turbine. This will avoid the cost of steam and condensate piping and preclude any possibility of condensate contamination.
- 15. Produce steam on site at a higher pressure (4 barg) to improve the overall amine plant efficiency.
- 16. Incorporate amine degradation byproducts into the simulation model when these products are determined by theoretical study.
- 17. Develop a blinding and isolation philosophy to possibly remove some of the piping blinds.
- 18. Assess the efficiency of a three-stage compressor versus a compressor with more stages.
- 19. Optimize the flow rate through the carbon filter package to reduce waste generation.
- 20. Investigate minimum flue gas vent temperature to recover more water. Dispersion modeling will need to be done to ascertain minimum flue gas temperature.
- 21. Investigate the opportunity to recover heat from the condensate before returning to the offsite battery limit (OSB/L).
- 22. Reassess the bypass requirements for the heat exchangers given their built in over-capacity.
- 23. Investigate recovering of the water generated during dryer regeneration operations.

- 24. If required based on emissions dispersion modeling being completed by the Owner, provide an absorber tower discharge stack that is larger in diameter.
- 25. Remove the split flow amine equipment (E-103/E-107/E-109, V-101, and P-106A/B) to reduce capital cost.
- 26. Consider higher MEA concentrations.



**18.0-References** 

#### 18.0 References ______

#### 18.1 Attached Documents _____

The following documents are attached to this FEED Study:

- 10112936-PB-P-DGM-0001 (25474-000-M6-BA-00001) Ducting and Instrument Diagram, Flue Gas System
- 10112936-PB-P-DGM-0002 (25474-000-M6-BA-00002) Ducting and Instrument Diagram, Flue Gas System
- 10112936-PB-R-PAL-0001 (25474-000-M0X-0000-00001) Mechanical Equipment List
- 10112936-PB-G-DRW-0001 (25474-000-P1-0010-00001) General Arrangement Plan
- 10112936-PB-G-DRW-0002 (25474-000-P1-0310-00001) Main Plant Layout, Flue Gas Blower/Absorber Area
- 10112936-PB-G-DRW-0003 (25474-000-P1-0310-00002) Main Plant Layout, Stripper Area/CO₂ Compressor Building
- 10112936-PB-G-DRW-0004 (25474-000-P1-0310-00003) Main Plant Layout, Control/Workshop/Stores Building, Switchgear Building & Tank Farm
- 10112936-PB-G-DRW-0007 (25474-000-P1-0010-00002) Plant Interface Tie-Point Plan
- 10112936-PB-C-TED-0005 (25474-000-CS-0000-00001) Access Roads and Finish Grading Plan
- 10112936-PB-C-PLN-0005 (25474-000-A1-3110-00001) Conceptual Plan, Control/Workshop/Stores Building
- 10112936-PB-E-DGM-0001 (25474-000-E1-0000-00001) [Electrical] Main Single line Diagram
- 10112936-PB-E- DGM-0002 (25474-000-E1-0000-00002) [Electrical] DC and UPS Single line Diagram
- 10112936-PB-C-DRW-0003 (25474-000-C0-0000-00001) Construction Facilities Plan

#### 18.2 Supplementary Lists

The following provide a comprehensive list of documents submitted as part of the FEED Study and that are available from PKM:

- FEED Study Document List From Bechtel's *InfoWorks* document control system
- Fichtner Review Sheets List –A list of the Review Sheets and the completion status of contractor responses





Kårstø CO₂ Capture and Compression Plant

Kårstø, Norway

Mechanical Equipment List (25474-000-MOX-0000-00001)

for Front-End Engineering and Design (FEED) Study Report

<u> </u>														
Mech	anical I	Equipment I	_ist			····-		<u> </u>						
CO2 :	Karsto I	Project												
Job N	o: 254′	74						<u> </u>						
Docu	nent No	o.: 25474-00	10-M0X-0000-00001										-	
Rev. 1	Ňo.: 1													
						· · · · ·								
	İ													
Projec	System			Canacity Per				Units		Martin				
t Qty	Code	Tag No.	Item Description	Component	Type	P&ID	Nominal	(Each)	Diff.	(Rated)	LD./W	H/T-T	Surf Area	Metallurgy / Remarks
<u> </u>	1	_					or Rated		bar	kW	ш	m	m ²	ą, ·
[				1x100% per										Stainless Steel Housing and
[ ,	BA	MA-101	Fine gas blower (Absorber 1)	Train (50%	Horizontal Centrifical	M6 RA 00001	1 757 895	m ³ /h	0.1	6140	NI/A	<b>N/A</b>	NI/A	Internals; Includes 2x100% lube
		101-101		1x100% per	Horizontal Celia liugai	M0-DA-00001	1,232,003	<u> </u>	0.1	0340	N/A	IVA	IN/A	Stainless Steel Housing and
[	ł			Train (50%										Internals; Includes 2x100% habe
1	BA	MA-102	Flue gas blower (Absorber 2)	per Unit)	Horizontal Centrifugal	M6-BA-00001	1,252,885	m³/h	0.1	6340	N/A	N/A	<u>N/A</u>	oil pumps
					Saturated steam boiler									
					with 2x100% feedwater									
		-			w/storage tank.									
					blowdown tank,								1	
1	SB	MB-101	Auxiliary Boiler	lx100%	chemical feed skid, etc.	M6-SB-00001	20	Tonnes/hr	N/A	7.5	N/A	N/A	N/A	
					Horizontal Rotary						10(00)			
2	PA	MC-101A/B	Instrument/Service Air Compressor	2x100%	Acoustical Enclosure	M6-PA-00001	500	m ³ /h	N/A	55	1.0 (w) x 2.6 (L)	18	N/A	1600 kg
<u> </u>						M6-OG-00020, -			14/12	35	4.0 (W) x	1.0	1.1/11	1000 xg
1	QG	MC-103	CO2 Compressor	1x100%	Centrifugal; 3 Stage	00050 & -00090	74684	m ³ /h	92.7	20,000	21.4 (L)	4.1	N/A	Including 2x100% lube oil pumps.
				2x50% per							1.95 (W) x			
2	CN	ME-101	Wash Water Cooler (Absorber 1)	Train	Plate and Frame	M6-CN-00030	30.7	MW	N/A	N/A	3.8 (L)	3.8	743	Titanium.
Ι.	-													Titanium. Alfa Laval Compabloc
	CN	ME-102	Lean Amine Cooler	1x100%	Welded Plate and Frame	M6-CN-00080	10.7	MW	N/A	N/A	TBD	TBD	TBD	type
<b>,</b>	CN	ME 103A/R	Sami Laan / Dich Haat Exchanger	2~50%	Waldad Blats and Emma	M6 CNI 00095	15.4	MIN	NIA	NT/A	TED	TRD	TDD	Stainless steel. Alfa Laval
	CIN	IVEL-TUS/US	Semi-Lean / Kich Heat Exchanger	2x50% per	weided riale and rialite	MO-CIN-00083	13,4	101.00	. IVA	IN/A	1.95 (W) x			Сотравлос туре
2	CN	ME-104	Wash Water Cooler (Absorber 2)	Train	Plate and Frame	M6-CN-00070	30.7	MW	N/A	N/A	3.8 (L)	3.8	743	Titanium
														Stainless steel. Alfa Laval
μ	CN	ME-107	Flash Feed Heat Exchanger	1x100%	Welded Plate and Frame	M6-CN-00100	2.9	MW	N/A	N/A	TBD	TBD	TBD	Compabloc type
				1		244 022 00000								
l s	CN	ME-1084/1	Lean/Rich Amine Heat Exchanger	8+12 504	Welded Plate and Froms	M6-CN-00080	10 1	MW	NI/A		1.2 (W) x	2.2	\$202.0	Stamless steel. Alfa Laval
	0.17	-100/5/H	Loan root ronne meat excitatiget	5A12.370	wence riace and riance	anougu -00064	10,1	TAT AA	IN/A	IN/A.	4.0 (L)	3.4	6392.0	
														Stainless steel, Alfa Laval
1	CN	ME-109	Flash Feed Heater	1x100%	Welded Plate and Frame	M6-CN-00100	5.4	MW	N/A	N/A	TBD	TBD	TBD	Compabloc type
	CN	LOT 110 4 /1*		0.15-57	W2 11 1 1 1 -	M6-CN-00150 & -					1.75 (W) x			Stainless steel. Alfa Laval
8	UN	ME-110A/H	Stripper Reboiler	8x12.5%	Welded Plate and Frame	00160	15.3	MW	N/A	N/A	1.75 (L)	3.5	534.0	Compabloc type

Mech	nical l	Equipment I	list											
CO2 I	arsto	Project											· · ·	
Job N	1: 254	74												
Docur	ient N	.: 25474_N	IA-MAX-0000-00001	· · ·										
Rev. N	o.: 1													
Projec Qty	System Code	Tag No.	Item Description	Capacity Per Component	Туре	P&ID	Nominal	Units (Each)	Diff.	Motor (Rated)	LD./W	<u>H/T-T</u>	Surf Area	Metallurgy / Remarks
							or realed		Uar	A IV	<u> </u>	ш	<u> </u>	
4	CN	ME-111A/D	Overhead Stripper Condenser	4x25%	Plate and Frame	M6-CN-00130	61.3	MW	N/A	N/A	TBD	TBD	TBD	Titanium.
	~~		CO2 Compressor 1st Stage Steam	1 1000							1.3 (W) x			CO2 Side - SS Tubes.
1	ŲG			1x100%	Sneu & Tube	M6-QG-00030	1.8	MW	N/A	N/A	2.9 (L)	TBD	426	Steam/Cond Side - CS Shell
1	QG	ME-113	CO2 Compressor 1st Stage Intercooler	1x100%	Shell & Tube	M6-QG-00030	6.5	MW	N/A	N/A	1.3 (W) x 6.6 (L)	TBD	510	CO2 Side - 304LSS Shell. Sea Water Side - Titanium or SeaCure Tubes.
1	06	ME 114	CO2 Compressor 2nd Stage Steam	1=1000/	Chall & Take	M6 0/2 00060	1.0	MU	NI(A	27/4	1.2 (W) x	700		CO2 Side - SS Tubes.
	~~	ME-114	CO2 Compressor 2nd Stage	1100%		M8-Q3-00000	1.8	MW		N/A	3.8 (L)	TBD	262	CO2 Side - 304LSS Shell Sea Water Side - Titanium or SeaCure
<u> </u>	<u>Vu</u>	ME-115	CO2 Compressor 3rd Stage Steam	IX100%	Shell & Tube	M6-QG-00060	4.3	MW	N/A	N/A	7.2 (L)	TBD	392	Tubes.
1	QG	ME-116	Generator	lx100%	Shell & Tube	M6-QG-00100	2.1	MW	N/A	N/A	4.5 (L)	TBD	279	Steam/Cond Side - CS Shell
1	QG	ME-117	CO2 Cooler	1x100%	Shell & Tube	M6-QG-00100	10.6	MW	N/A	N/A	1.1 (W) x 7.2 (L)	TBD	463	CO2 Side - 304LSS Shell. Sea Water Side - Titanium or SeaCure Tubes.
1	CY	ME-118	Amine Storage Tank Heater	1x100%	Electric Bayonet	M6-CY-00010	11	KW	N/A	N/A	N/A	<u>N/A</u>	N/A	
1	CY	ME-119	Lean Amine Solvent Storage Tank Heater	1x100%	Electric Bayonet	M6-CY-00010	150	KW	N/A	N/A	N/A	N/A	N/A	-
1	WP	ME-123	Heater	1x100%	Electric Bayonet	M6-WP-00010	11	<u>K</u> W	N/A	N/A	N/A	N/A	N/A	
1	ĊN	MF-101	Lean Amine Side Stream Carbon Filter	1x100%	Carbon	M6-CN-00090	420	m³/h	1	N/A	N/A	N/A	N/A	Stainless steel housing. Packaged skid w/pre-filter and after-filter
2	ĈN	MF-102A/B	Rich Amine Mechanical Filter	2x100%	Cartridge	M6-CN-00040	2500	m³/h	0.5	N/A	N/A	N/A	N/A	10 micron absolute filter. Stainless steel housing & Polypropylene cartridge.
2	<u>CN</u>	MF-105A/B	Lean Amine Mechanical Filter	2x100%	Cartridge	M6-CN-00170	2000	m³/h	0.5	<u>N/A</u>	N/A	N/A	N/A	10 micron absolute filter. Stainless steel housing & Polypropylene cartridge.
1	CN	MF-106	Lean Amine Side Stream Pre-Filter	<u>1x100%</u>	Cartridge	M6-CN-00090	420	m³/h_	0.5	N/A	N/A	N/A	N/A	5 micron absolute filter. Stainless steel housing & Polypropylene cartridge. Packaged skid with carbon filter.
1	CN	MF-107	Lean Amine Side Stream After-Filter	1x100%	Cartridge	M6-CN-00090	420	m³/h	0.5	N/A	N/A	N/A	N/A	10 micron absolute filter. Stainless steel housing & Polypropylene cartridge. Packaged skid with carbon filter.
2	xw	MF-108A/B	Amine Return Filter	2x100%	Cartridge	M6-XW-00001	125	_m³/h	1	N/A	N/A	N/A	N/A	10 micron absolute filter. Stainless steel housing & Polypropylene cartridge.

Mach	aniaalU	Cauinmont I	let											
COT		Duciosé											1	
	Narsto I	PT0ject 74	¶											·····
JOD T	0: 204	/4 	0 MOV 0000 00001											
Rev	No.: 1	5.: <u>25474-0</u> 0	-1410X-0000-08001	1										
<u>ACT</u>														
Projec t Qty	System Code	Tag No.	Item Description	Capacity Per Component	Туре	P&ID	Nominal or Rated	Units (Each)	Diff.	Motor (Rated) kW	I.D./W m	H/T-T m	Surf Area	Metaliurgy / Remarks
1	AN	MG-101	Standby diesel generator	1x100%	Diesel driven	N/A	600	ĸw	N/A	N/A	N/A	N/A	N/A	Fuel oil storage tank integral with generator.
2	CN	MP-101A/B	Rich Amine Pump (Absorber 1)	2x100% per Absorber	Horizontal Centrifugal	M6-CN-00040	1361	m³/h	16.1	900	N/A	N/A	N/A	API 610 design. Stainless Steel.
2	CN	MP-102A/B	Wash Water Recirculation Pump (Absorber 1)	2x100%	Horizontal Centrifugal	M6-CN-00030	1811	m³/h	4.9	370	N/A	N/A	N/A	Constant speed motor. Stainless steel. ANSI design
2	CN	MP-104A/B	Wash Water Recirculation Pump (Absorber 2)	2x100%	Horizontal Centrifugal	M6-CN-00070	1811	m³/h	4.9	373	N/A	N/A	N/A	Constant speed motor. Stainless steel. ANSI design
2	CN	MP-105A/B	Lean Amine Pump	2x100%	Horizontal Centrifugal	M6-CN-00170	2175	<u>m³/h</u>	10.4	900	N/A	N/A	N/A	API 610 design. Stainless Steel.
2	CN	MP-106A/B	Flash Drum Pump	2x100%	Horizontal Centrifugal	M6-CN-00110	548	ma³/b	5	107	N/A	N/A	N/A	API 610 design. Stainless Steel.
2		MD 107478	Peflux Dump	2~100%	Horizontal Centrifugal	M6 CN 00140	05	m ³ /h	5.4	45	NJ/A	N/A	N/A	Capacity includes an assumed constant recirc flow. Constant speed motor. Stainless steel. ANSL design
2	06	MP-108A/B	CO2 Product Sendout Pupp	2×100%	Horizontal Centrifugal	M6-0G-00100	194		118	960	N/A	N/A	N/A	API 610 design Stainless Steel
2	BA	MP-109A/B	Flue Gas Fogger Water Supply Pump	2x100%	Horizontal Centrifugal	M6-BA-00002	65	m³/h	30	93	N/A	N/A	N/A	Supplied with fogger skid package. Constant speed motor. Stainless steel. ANSI design
2	CY	MP-110A/B	Fresh Amine Metering Pump	2x100%	Positive Displacement	M6-CY-00010	0.2	m³/h	8	1	N/A	N/A	N/A	Constant speed motor. Stainless steel. ANSI design
2	CY	MP-111A/B	Lean Amine Solvent Fill Pump	2x100%	Horizontal Centrifugal	M6-CY-00010	91	m³/h	7.6	45	N/A	N/A	N/A	Stainless steel. ANSI design.
2	xw	MP-112A/B	Amine Waste Sump Pump	2x100%	Vertical Centrifugal	M6-XW-00001	55	m³/h	3.5	11	N/A	N/A	N/A	Constant speed motor. Stainless steel. ANSI design. Located in concrete sump. Constant speed motor. Stainless
2	xw	MP-113A/B	Wastewater Forwarding Pump	2x100%	Vertical Centrifugal	M6-XW-00002	35	m ³ /h	1	7.5	N/A	N/A	N/A	steel. ANSI design. Located in concrete sump.
2	sc	MP-114A/B	LP Condensate Return Pump	2x100%	Vertical Centrifugal	M6-SC-00001	225	m³/h	8	75	N/A	N/A	N/A	Constant speed motor. SS impeller, ANSI design
2	WL	MP115A/B	Sea Water Cooling Pump	2x100%	Vertical Centrifugal	M6-WL-00001	17340	m ³ /h	2.1	1500	N/A	N/A	<u>N/A</u>	Single speed motor. Duplex stainless steel. ANSI design. Located in Owner's intake dry pit.
2	CY	MP-116A/B	Chemical Additive Metering Pump	2x100%	Positive Displacement	N/A	I	m³/h	7	0.37	N/A	N/A	N/A	Constant speed motor. Stainless steel. ANSI design
2	CY	MP-117A/B	Caustic Metering Pump	2x100%	Positive Displacement	N/A	0.2	m³/h	3.1		N/A	N/A	N/A	Constant speed motor. Stainless steel. ANSI design

			<u> </u>		· · · ·			1					1	
Mech	anical F	lquipment L	ist											
CO2	Karsto	Project												
Job N	o: 254	74			· · ·									
Docu	nent No	.: 25474-00	0-M0X-0000-00001											
Rev.	No.: 1													
						_				_			ļ	
Projec t Qty	System Code	Tag No.	Item Description	Capacity Per Component	Туре	P&ID	Nominal or Rated	Units (Each)	Diff. bar	Motor (Rated) kW	LD./W	H/T-T m	Surf Area	Metallurgy / Remarks
			· · ·											
2	WP	MP-119A/B	Absorber makeup water pumps	2x100%	Horizontal Centrifugal	M6-WP-00010	15	m³/h	2	1.5	N/A	N/A	N/A	Common pumps feed both absorbers. Constant speed motor. SS impeller. ANSI design Constant speed motor. Duplex
2	WL	MP-121A/B	Sea Water Cooling Booster Pump	2x100%	Horizontal Centrifugal	M6-WL-00001	5124	m ³ /h	0.84	224	N/A	<u>N/A</u>	N/A	SS. ANSI design
2	WR	MP-122A/B	Raw (Softened) Water Supply Pumps	2x100%	Horizontal Centrifugal	M6-WR-00001	9	ш ³ /ћ	1.17	1	N/A	N/A	N/A	Constant speed motor. SS impeller. ANSI design
,		MP-124A/B	Rich Amine Punp (Absorber 2)	2x100% per Absorber	Horizontal Centrifugal	M6-CN-00040	1361	m ³ /h	16.1	900	N/A	N/A	N/A	API 610 design. Stainless Steel.
2	WD	MP-125A/B	Demineralized Water Pumps	2x100%	Horizontal Centrifugal	M6-WD-00001	1	m³/h	7	1	N/A	<u>N/A</u>	N/A	Constant speed motor. SS. ANSI design
<u> </u>						00020 00050. & -							·	
2	CN	T-101, 102	CO2 Absorber	2x50%	Vertical Column	00060	N/A	N/A	N/A	N/A	11.8	44.3	N/A	Stainless steel
1	CN	T-103	Stripper	1x100%	Vertical Column	M6-CN-00120 & - 00130	N/A	<u>N/A</u>	N/A	N/A	6.7	43.6	<u>N/A</u>	Stainless steel
	CY	MT-101	Amine Storage Tank (Concentrated)	1x100%	Horizontal	M6-CY-00010	85	m ³		N/A	TBD	TBD	N/A	Fiberglass w/Electric Heater
			Lean Amine Solvent (35% MEA)	T				3		27/4	TDD	mp	214	Paula la se stand su Ælastala Haston
	CY	MT-102	Storage Tank	Ix100%	Vertical	M6-CY-00010	1038	î	N/A	N/A N/A		TBD		Stattless steel w/Electric Heater
<u>⊢</u> +	wP	MT-104	Process Water Surge Tank	Ix100%	Vertical	M6-WP-00010	104	m ³	N/A N/A	N/A	TBD	TBD	N/A	Fiberglass
⊢÷-	CN	MT 109	Reclaimer Waste Storage Tank	1x100%		N/A		 	N/A	N/A	TBD	TBD	N/A	Carbon steel
	DA	MT-100	Instrument Air Receiver	1x100%	Vertical ASME VIII	M6-PA-00001	40	 	N/A	N/A	TBD	TBD	N/A	Carbon steel
	WD	MT-110	Demineralized Water Storage Tank	1x100%	Vertical	M6-PA-00001	2	m ³	N/A	N/A	TBD	TBD	N/A	Fiberglass
Ê		201 201	Sami Lass Flash Dawn	1=1009/	Vertical ASME VIII	M6 CN 00110	70	)	N/A	N/A	31	91	N/A	Stainless steel
	ICN CN	MIV-201	Seimer Poffue Deum	1x100%	Vertical ASME VIII	M6_CN_00140	60	m ³	N/A	N/A	3.2	5.5	N/A	Stainless steel
<u></u> <u> </u> <u> </u>		WV 202	CO2 Compressor Suction Dram	1x100%	Vertical ASME VIII	M6-0G-00010	75	 	N/A	N/A	4.0	6.0	N/A	Stainless steel
	IOG	MV-104	CO2 Compressor 1st Interstage Knockout Drum	Ix100%	Vertical, ASME VIII	M6-QG-00040	23	m ³	N/A	N/A	2.7	4,1	N/A	Stainless steel
			CO2 Compressor 2nd Interstage	1 1000/		N/C 0.0 00070	-	3		N/A		27	NIA	Stainlass staal
$\downarrow$	QG	MV-105	Knockout Drum	1x100%	Vertical, ASME VIII	M6-QG-00070	7		N/A N/A	N/A	1.0	2.7	N/A	Stainless steel
$\vdash$	QG	MV-100	L B. Condensate Blowdown Tank	1x100%	Vertical ASME VIII	M6-SC-90001	25	 	N/A N/A	N/A	2.4	6.0	N/A	Carbon steel
	BA	MS-101A/C	Flue Gas Water Fogger System	1x100%		M6-BA-00001 & - 00002	N/A		N/A		.N/A	N/A	N/A	Package includes pumps, 3 foggers (1 common duct and 1 in each blower disch to absorber) and 2x100% water supply pumps.
,	CN	MS-102	Amine Reclaimer	1,100%	Shell & Tube	M6-CN-00180	TBD	TBD	N/A	N/A	TBD	TBD	N/A	instrumentation.
⊢÷-	CY	MS-102 MS-103	Reclaimer Chemical Feed Package	1x100%	Language 1 yps	M6-CN-00190	TBD	TBD	N/A	N/A	N/A	N/A	N/A	

Mecl	anical H	Cauinment I	.ist					l						
<u> </u>	V	D											1	
02	Aarsto .	rroject												
Jop I	No: 254	74	<u> </u>										<u> </u>	
Docu	ment No	p.: 25474-00	0-M0X-0000-00001											
Rev.	<u>No.: 1</u>													
Denia	Eventer			Caracity De-				T In ite						
t Qty	Code	Tag No.	Item Description	Component	Туре	P&ID	Nominal	(Each)	Diff.	Motor (Rated)	LD./W	H/T-T	Surf Area	Metallurgy / Remarks
		8					or Rated		bar	kW	m	m	m ²	
							-							
Ι.					Regenerative, Closed						5.5 (W) x			
	QG	MS-104	CUZ Drying Package	1x100%	Loop blower type	M6-QG-00080	71078	m3/br	N/A	N/A	5.5 (L)	5.2	N/A	304 SS piping, valves and vesssel.
2	DA	MS 1054/B	Instrument Air Dever	2~100%	Desiccant; Dual Columns Nonrefrigerent with Prefilters After	M6 DA 00001	500		DI/A	λτ/A	TDD	TBD	NI/A	
8	PW	1445-1057010	Emergency Shower	1x100%	Heated	M6-PW-00001		N/A	N/A	N/A	N/A	N/A	N/A	Lises notable water
			Common Flue Gas Duct Isolation		Motor Actuated Guillotine Type. Each									Damper package includes seal air fan skid containing 1x100% fan. Damper and damper housing
2	BA	MD-008A/B	Damper	2x100%	6.2m x 6.2m	M6-BA-00001	N/A	N/A	N/A	TBD	N/A	N/A	N/A	material is carbon steel.
			Flue Gas Duct Isolation Damper		Motor Actuated Guillotine Type. Each									Ine two-damper package for each blower includes a seal air fan skid containing 1x100% fan. Damper and housing material is stainless
2	BA	MD-034A/B	(Absorber I)	2x100%	6.2m x 3.1m	M6-BA-00001	N/A	. N/A	<u>N/A</u>	TBD	N/A	N/A	N/A	steel.
2	BA	እሙ ሰሩስ ለ ም	Flue Gas Duct Isolation Damper	2~100%	Motor Actuated Guillotine Type. Each	M6 BA 00001	NIA	N1/A	DI/A	TPD		DI/A	NIA	Ine two-damper package for each blower includes a seal air fan skid containing 1x100% fan. Damper and housing material is stainless
		WID-000ATB	Flue Gas Expansion Joint (Common	2810076	0.2m X 3.1m	M0-DA-0001	IN/A	IV/A	IV/A	עפו	IN/A	_ N/A	IN/A	Damner and housing material is
4	BA		Duct)		Each 6.2m x 6.2m	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Carbon Steel.
			Flue Gas Expansion Joint (Common							-				Damper and housing material is
4	BA		Duct)		Each 6.2m x 6.2m	N/A	<u>N/A</u>	N/A	N/A	N/A	N/A	N/A	N/A	Stainless Steel.
6	24		Flue Gas Expansion Joint (Blower		E 1 6 2 2 1	77/4		31/4			37/4		3714	Damper and housing material is
V	<u></u>				Add paeumatic actuator to existing damper located in the CCPP 7m dia stack. Also add local volume air tank for two full strokes and wich screen in a clerotic	N/A.	N(A		NA		<u>N/A</u>	<u>N/A</u>	N/A	Stamless Steel.
1	ва	PV-002	Stack Damper Actuator	1x100%	(<1 sec opening solenoid	M6-BA-00001	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Stainless steel air tank
<u> </u>	1	PV-035 & -	Control Damper at Inlet of Each	101/0/0	Pneumatic. Each 6.2m			IV/A	N/PL	IN/PA	IN/A	11/21	IUA	STANIGOS SIGGI AU Idilk.
2	BA	061	Blower		x 3.1m	M6-BA-00001	N/A	N/A	N/A	<u>N/A</u>	N/A	N/A	<u>N/</u> A	Stainless Steel.
8	PF		Fire Hydrants and Hose Houses			M6-PF-00001	TBD	TBD	N/A	N/A	N/A	N/A	N/A	
10	PF		Fire Extinguishers	1x100%	Handheld (ABC Dry Powder)	N/A	TBD	TBD	N/A	N/A	N/A	N/A	N/A	Quantity as required.
_1	PF		Fire Extinguishers	Ix100%	Powder)	N/A	TBD	TBD	N/A	N/A	N/A	N/A	N/A	Quantity as required.

Mech	anical H	Zquipment ]	List											
CO2	Karsto	Project				1								
Lah N	- 754	74				-							· · ·	
2001	0: 234	/4				+			· .					
Docu	nent No	D.: 25474-0	00-M0X-0000-00001											
Rev.	No.: 1													
							-							
Projec t Qty	System Code	Tag No.	Item Description	Capacity Per Component	Туре	P&ID	Nominal or Rated	Units (Each)	Diff. bar	Motor (Rated) kW	I.D./W	H/T-T m	Surf Area	Metailurgy / Remarks
10	PF		Fire Extinguishers	Ix100%	Handheld (CO2)	N/A	TBD	TBD	N/A	N/A	N/A	N/A	N/A	Quantity as required.
9	PW		Emergency Eyewash	1x100%	Heated	M6-PW-00001			N/A	N/A	N/A	N/A	N/A	Uses bottled water
1	DE		Compressor Area	1~100%	Automatic	M6-PE-00001	TRD	TRD	N/A	NIA	NI/A	N/A	NIA	
	PF		Fire and Gas Detection System	Lx100%		N/A	TBD	TBD	N/A	N/A	<u></u> N/Δ	N/A		
			Control/Workshop/Stores Bldg HVAC				122	100				1021	1.021	
2	VB		Units (Control & Admin Areas Only)	2x100%	32 Tons	N/A	110	kW	N/A	N/A	N/A	N/A	N/A	
			Control/Workshop/Stores Bldg Vent											
4	VB		Fans (Workshop & Stores Areas Only)	4x25%	21,000 m3/hr	N/A	3.7	kW	N/A	N/A	N/A	N/A	N/A	
6	VB		Control/Workshop/Stores Bldg Electric Unit Heaters (Workshop & Stores Areas Only)	6x17%		N/A	15	kW	N/A	N/A	N/A	N/A	N/A	
5	VВ		Fans (Compressor Bidg Ventilation Fans (Compressor area)	5X25%	26,000 m3/hr	N/A	3.5	kW	N/A	N/A	<u>N/A</u>	N/A	N/A	
2	VB		CO2 Compressor Bldg Ventilation Fans (VFD Area)	2x100%	24,500 m3/hr	N/A	2.2	kW_	N/A	N/A	N/A	N/A	N/A	
2	VВ		CO2 Compressor Bldg Ventilation Fans (Water Treatment Area)	2x100%	10,000 m3/hr	N/A	1.1	kW	N/A	N/A	N/A	N/A	N/A	
			CO2 Compressor Bldg Electric Unit											
8	VB		Heaters (Compressor Area)	8x14.5%		N/A	15	kW	N/A	N/A	N/A	N/A	N/A	
2	VB		CO2 Compressor Bldg Electric Unit Heaters (VFD Area)	2X50%		N/A	15	kW	N/A	N/A	N/A	N/A	N/A	
1	VВ		CO2 Compressor Bldg Electric Unit Heaters (Water Treatment Area)	1x100%		N/A	15	kW	N/A	N/A	N/A	N/A	N/A	
3	VB		Blower Bldg Ventilation Fans (Absorber 1)	3x33%	22,000 m3/hr	N/A	2.2	kW	N/A	N/A	N/A	N/A	N/A	
4	VB		Blower Bldg Electric Unit Heaters (Absorber 1)	4x25%		N/A	15	kW	N/A	N/A	N/A	N/A	N/A	
			Blower Bldg Ventilation Fans					1						
3	VB		(Absorber 2)	3x33%	22,000 m3/hr	N/A	2.2	kW	N/A	N/A	N/A	N/A	N/A	
4	VB		Blower Bldg Electric Unit Heaters (Absorber 2)	4x25%		N/A	15	kW	N/A	N/A	N/A	N/A	N/A	
1	VB		Lube Oil Storage Bldg Ventilation Fan	ix100%	1.500 m3/hr	N/A	0.2	kW	N/A	N/A	N/A	N/A	N/A	
1	VB		Lube Oil Storage Bldg Unit Heater	1x100%		N/A	1	kW	N/A	N/A	N/A	N/A	N/A	
2	VB		CO2 Compressor Bldg HVAC Units (Analyzer Room)	2x100%	1.5 Tons	N/A	5	kW	N/A	N/A	N/A	N/A	N/A	
2	VВ		Electrical Bldg HVAC Units	2x100%	25 Tons	N/A	80	kW	N/A	N/A	N/A	N/A	N/A	· · ·
2	VB		Battery Room Exhaust Fans	2x100%	Explosion proof	N/A	0.2	kW	N/A	N/A	N/A	N/A	N/A	
2	VB	1	CGMS Shelter HVAC Units	2x100%	1 Ton	N/A	3	kW	N/A	N/A	N/A	N/A	N/A	
Mech	anical I	quipment	List											
-----------------	----------------	-----------------------------	----------------------------------------	---------------------------	------------------------------	------------------------	------------------	-----------------	-------	------------------	--------	-------	----------	----------------------------------------------------------------------------------------------------
CO2	Karsto	Project												
Job N	io: 254	4												
Docu	ment No	.: 25474-0	00-M0X-0000-00001											
Rev.	No.: 1	···, ·· <b>_</b> · <b>_</b>												
	1													
Projec t Qty	System Code	Tag No.	Item Description	Capacity Per Component	Туре	P&ID	Nominal	Units (Each)	Diff.	Motor (Rated)	I.D./W	н/т-т	Surf Are	a Metallurgy / Remarks
							or Rated		bar	kW	m	Ţ,	m²	
								34						FRP Housing; Packaged unit complete with filters, pumps, chemical feed skids, clean in place
2	ĮWD		Desalimation Equipment	2x100%	2-Pass Reverse Osmosis	M6-WD-00001	8	m²/h	N/A	N/A		TBD	N/A	skad, etc.
Note:	This med	anical equip	ment list provides preliminary data, s	cope, and quantiti	es that may be subject to cl	bange during final eng	zineering design	L.						

¥.



	1	1			
7	8	9	10	11	12
					• <del>-</del>

-



010	20	30	40
 11		12	



	14		15	16	
			LEGEND		
ID NO	EQUIPMENT	ALTERNATE	DESCRIPTION	··· ··· ··· ··· ··· ··· ··· ···	
1	MA-101	K-101	FUEL GAS BLOWER (ABSORE	RER 1)	
2	MA-102	K-102	FUEL GAS BLOWER (ABSORE	RFR 2)	
3	MC-101A/B	N/A	INSTRUMENT/SERVICE AIR CO	DMPRESSOR	V
4	MC-103A/C	K-103A/C	CO2 COMPRESSOR		
5	ME-101	E-101	WASH WATER COOLER (ABS)	ORBER 1)	
6	ME-102	E-102	LEAN AMINE COOLER		1
7	ME-103A/B	E-103A/B	SEMI-LEAN/RICH HEAT EXCH	ANGER	⊢
8	ME-104	E-104	WASH WATER COOLER (ABS)	DRBER 2)	
<u>g</u>	ME-107	E-107	FLASH FEED HEAT EXCHANG	ER	
10	ME-108A/H	E-108A/H	LEAN/RICH AMINE HEAT EXC	HANGER	
10	ME-109	E~109	FLASH FEED HEALER		
17	ME-11UA/H	E-IIUA/H	STRIPPER REBUILER		╎┖
14	ME-112	E 111A/D	CO2 COMPRESSOR 1ST STAC		
15	ME-113	F-11.3	CO2 COMPRESSOR IST STAC		
16	ME-114	E-114	CO2 COMPRESSOR 2ND STA	GE STEAM GENERATOR	
17	ME-115	E-115	CO2 COMPRESSOR 2ND STA	GE INTERCOOLER	
18	ME-116	E-116	CO2 COMPRESSOR 3RD STA	GE STEAM GENERATOR	
19	ME-117	E-117	CO2 COOLER		
20	ME-118	N/A	AMINE STORAGE TANK HEATE	R	
21	ME-119	N/A	LEAN AMINE SOLVENT STOR	AGE TANK HEATER	K
22	ME-122	N/A	SOFTENED WATER STORAGE	TANK HEATER	
23	ME-123	N/A	PROCESS WATER SURGE STO	DRAGE TANK HEATER	
24			LEAN AMINE SIDE STREAM C	AKBUN FILTEK	
20 26		P-101A/B	RICH AMINE DUMPS (ADSOUD		
27	MP-1024/R	P-1024/R	WASH WATER RECIRCUL ATION	LIN 17	
28	MP-104A/R	P-104A/R	WASH WATER RECIRCINATION	V PUMPS (ARSORBER 2)	
29	MP-105A/B	P-105A/B	LEAN AMINE PUMPS		
30	MP-106A/B	P-106A/B	FLASH DRUM PUMPS		
31	MP-107A/B	P-107A/B	REFLUX PUMPS		J
32	MP-108A/B	P-108A/B	CO2 PRODUCT SENDOUT PU	MPS	
33	MP-109A/B	P-109A/B	FLUE GAS FOGGER WATER S	SUPPLY PUMPS	
34	MP-110A/B	P-110A/B	FRESH AMINE METERING PUM	PS	
35	MP-111A/B	P-111A/B	LEAN AMINE SOLVENT FILL F	PUMPS	
30 77	MP-11ZA/B	P-112A/B	AMINE WASTE SUMP PUMPS		
32 38	MP-113A/B	P-113	WASTEWATER FORWARDING F		
39	MP-115A/8	P-115A/R	SEA WATER COOLING PLIMPS		
40	MP-116A/B	P-116A/B	CHEMICAL ADDITIVE METERING	S PUMPS	
41	MP-117A/B	P-117A/B	CAUSTIC METERING PUMPS		Η
42	MP-119A/B	N/A	ABSORBER MAKEUP WATER F	PUMPS	
43	MP-121A/B	N/A	SEA WATER COOLING BOOST	ER PUMPS	
44	MP-122A/B	N/A	SOFTENED WATER SUPPLY F	PUMPS	
45	MP-123A/B	N/A	COMPRESSOR 1ST STAGE CO	NDENSATE BOOSTER PUMPS	
46	MP-124A/B	P-124A/B	RICH AMINE PUMPS (ABSORBI	ER 2)	
4/	MV-101	T-101	CO2 ABSORBER NO.1		
+0 40	MV-103	T-102	STRIPPER		
 50	MV-104	V-104	CO2 COMPRESSOR 1ST INTER	STAGE KNOCKOUT DRUM	G
51	MV-105	V-105	CO2 COMPRESSOR 2ND INTE	RSTAGE KNOCKOLIT DRUM	
52	MV-106	V-106	CO2 SURGE DRUM		
53	MV-107	N/A	LP CONDENSATE BLOWDOWN	TANK	
54	MV-201	V-101	SEMI-LEAN FLASH DRUM		
55	MV-202	V-102	STRIPPER REFLUX DRUM	·	
56	MV-203	V-103	CO2 COMPRESSOR SUCTION	DRUM	
57	MT-101	TK-101	AMINE STORAGE TANK (CONC	ENTRATED)	
58	MT-102	IK-102	LEAN AMINE SOLVENT (35%	MEA) STORAGE TANK	
<u>99</u>	MT-107	IK~104	PROCESS WATER SURGE TAN		F
0U 61	MT-100	N/A	SUFTENED WATER STORAGE	I ANK	,
62	MS-1014/C	<u>χ-101Δ/C</u>	FILLE GAS WATER FORCER S	YSTEM	
6.3	MS-1017/0	X-1017/C	AMINE RECLAIMER	I J I L IVI	
64	MS-103	X-103	RECLAIMER CHEMICAL FFFD F	ACKAGE	
65	MS-104	X-104	CO2 DRYING PACKAGE		_
66	MS-105A/B	N/A	INSTRUMENT AIR DRYER		
1					
					E
$\nabla$	///////////////////////////////////////				
V	[]/]/]/]/				
Ľ	77 <u>77</u> 777	<u> </u>			
Ø	\$\$17777				
1		EXA X	▋		П
		₩A¥A			υ
1		//X/&			
H	#X///x				
		E D			
11/	1/18/11	<u>44///</u>			
< y/	74 Y V / / / /				
	<u> </u>	<u>      </u>			

MATCH LINE "C" MATCH LINE "C"



	REVISED PER 10112936- MAIN ELECTRICAL EQUIPM	VISED PER 10112936-S-FIPB-G-0188 TO INCORPORATE IN ELECTRICAL EQUIPMENT DESIGNATIONS						f	20	\$E1	]
0 19/	11/08 ISSUED FOR APPROVAL	APPROVAL							BTR	AJG	
NO. D	ATE	REVISIONS	BY	снк	DES	ENGR.	PROJ	APPR	1		
Owner	GASSNOVA		C02	KARSTO	PR	OJE	ECT			·	
Owner Drow 101129 Contractor	36-PB-G-DRW-0002	,	MAIN	FOUIPME	NT	1 4 1	/011	т			
		FLU	E GAS	BLOWER/	ABS	SOR	BEF	κ Α	REA	1	
AT PH	BECHIEL POWER		x841 "A1"	Scale: 1:200							1
BE			I NO.	DR	AWIN	G NC	).		R	EV.	
	FREDERICK, MARYLAND	25	25474		P1-0310-00001					1	
	14			15				16			

25M



	13		14		15	16	
		٦					
Image: The information of the informati						I	
						,	
Image: Second							
LUCk U     U   Bit Terminal Hitting Terminal State Hitting Termina			[				
				ALTERNATE			
Sector   Sector   Sector   Sector   Sector     Sector   Sector   Sector   Sector   Sector   Sector   Sector     Sector   Sector   Sector   Sector   Sector   Sector   Sector   Sector   Sector   Sector   Sector   Sector   Sector   Sector   Sector   Sector   Sector </td <td></td> <td></td> <td>1 MA-101</td> <td>K-101 K-102</td> <td>FUEL GAS BLOWER (ABSORBER</td> <td>1)</td> <td></td>			1 MA-101	K-101 K-102	FUEL GAS BLOWER (ABSORBER	1)	
			3 MC-101A/B	N/A K-1030/C	INSTRUMENT/SERVICE AIR COM	IPRESSOR	-
Image: Stand			5 ME-101 6 ME-102	E-101 E-102	WASH WATER COOLER (ABSORB	ER 1)	
Image: Second			7 ME-103A/B 8 ME-104	E-103A/B E-104	SEMI-LEAN/RICH HEAT EXCHAN	IGER ER 2)	
III.   III. <thiii.< th="">   III.   III.   <thi< td=""><td></td><td></td><td>9 ME-107 10 ME-108A/H</td><td>E-107 E-108A/H</td><td>FLASH FEED HEAT EXCHANGER</td><td>ANGER</td><td></td></thi<></thiii.<>			9 ME-107 10 ME-108A/H	E-107 E-108A/H	FLASH FEED HEAT EXCHANGER	ANGER	
13   ••••••••••••••••••••••••••••••••••••			11 ME-1Ø9 12 ME-11ØA/H	E-109 E-110A/H	FLASH FEED HEATER STRIPPER REBOILER		
Image: Provide State St			13 ME-111A/D 14 ME-112	E-111A/D E-112	OVERHEAD STRIPPER CONDENSE CO2 COMPRESSOR 1ST STAGE	ER STEAM GENERATOR	
Image: state in the state is and state is and state is an interval in the state is an interval in the state is an interval in the state is an interval			15 ME-113 16 ME-114	E-113 E-114	CO2 COMPRESSOR 1ST STAGE CO2 COMPRESSOR 2ND STAGE	INTERCOOLER STEAM GENERATOR	
HART   F-17   CC2   COULLB   F-17   CC2   COULLB     25   M2   M4   Server Sturger Sturger Sturger Stark - Earls   Server Sturger Sturger Stark - Earls   Server Sturger Sturger Sturger Stark - Earls     21   M2   M2   M4   Server Sturger Sturger Stark - Earls   Server Sturger Stark - Earls     M132   M33   M2   M2   M4   Server Sturger Stark - Earls   Server Sturger Stark - Earls     M132   M34   M2   M2   M2   M2   Server Sturger Stark - Earls   Server Sturger Stark - Earls   Server Sturger Stur			17   ME-115     18   ME-116	E-115 E-116	CO2 COMPRESSOR 2ND STAGE CO2 COMPRESSOR 3RD STAGE	INTERCOOLER STEAM GENERATOR	
High   High   High   High   High   High     High   High   High   High   High   High   High     High   High   High   High   High   High   High   High   High     High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High   High <td></td> <td></td> <td>19 ME-117 20 ME-118</td> <td>E-117 N/A</td> <td>CO2 COOLER AMINE STORAGE TANK HEATER</td> <td></td> <td></td>			19 ME-117 20 ME-118	E-117 N/A	CO2 COOLER AMINE STORAGE TANK HEATER		
Ministry Control of the control of			ZI   ME-119     22   ME-122     23   ME-100	N/A N/A	LEAN AMINE SOLVENT STORAGE	L TANK HEATER	-
1333 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	<u>N4932</u> (4 4)		23 ME-123 24 MF-101 25 ME-1026/B	F-101 F-1020/B	LEAN AMINE SIDE STREAM CAP	RBON FILTER	
H+926 60/27 Image: Amage:	<u>N4930</u> (44)		26 MP-101A/B 27 MP-102A/B	P-101A/B P-102A/B	RICH AMINE PUMPS (ABSORBER WASH WATER RECIRCULATION F	1) 2UMPS (ABSORBER 1)	
14333 State 2 PLIARAD			28 MP-104A/B 29 MP-105A/B	P-104A/B P-105A/B	WASH WATER RECIRCULATION F	PUMPS (ABSORBER 2)	
22   M* 128A/3   P-128A/3   PL24A/3   PL24A/3 <thpl24a 3<="" th="">   PL24A/3   P</thpl24a>	<u>N4928</u> 6022	)	30   MP-106A/B     31   MP-107A/B	P-106A/B P-107A/B	FLASH DRUM PUMPS REFLUX PUMPS		
Image: Second		=	32   MP-108A/B     33   MP-109A/B	P-108A/B P-109A/B	CO2 PRODUCT SENDOUT PUMPS FLUE GAS FOGGER WATER SUP	PLY PUMPS	
→ 0.1 PPI 124/26 PP		- INF	34 MP-11ØA/B 35 MP-111A/B	P-110A/B P-111A/B	FRESH AMINE METERING PUMPS	S JMPS	
Str   No.   Lissue   Pillazie   Pillazi		Ξ	36 MP-112478 37 MP-113A/B	P-112A/B P-113	WASTEWATER FORWARDING PUM	PS	
Image: State		1AT(	39 MP-115A/B 40 MP-116A/B	P-115A/B	SEA WATER COOLING PUMPS		
43 MP-122A/8 N/A GAS AFTER CORCE BOSTER PLAYS   44 MP-122A/8 N/A COMPRESSOR IST STATE COUCHAGE BODSTER PLAYS   45 MP-122A/8 N/A COMPRESSOR IST STATE COUCHAGE BODSTER PLAYS   45 MP-122A/8 PLA/A/A COMPRESSOR IST STATE COUCHAGE BODSTER PLAYS   46 MP-124A/8 CO2 ABSORDER N.0.2 PLAY   47 MP-10 T-142 CO2 ABSORDER N.0.2   48 MP-10 T-142 CO2 ABSORDER N.0.2   49 MP-10 T-142 CO2 ABSORDER N.0.2   49 MP-108 T-142 CO2 ABSORDER N.0.2   49 MP-108 T-142 CO2 ABSORDER N.0.2   49 MP-108 T-142 CO2 ABSORDER N.0.2   51 MP-108 T-143 CO2 COMPRESSOR IST INTERSTATE KNOCKOUT DRUM   52 MP-108 T-136 CO2 COMPRESSOR SUCTION DRUM TANK   54 MP-202 V-13 SEMI-ENDARCE TAKK EM   55 MP-202 V-13 SEMICE SURCE COMENTATED EM   56 MP-202 V-13 SEMICHARICOL COMENTATED EM			41 MP-117A/B 42 MP-119A/B	P-117A/B	CAUSTIC METERING PUMPS	IPS	
4:   MP-124A/B   P124A/B   P124A/B   P124A/B     4:   MP-124A/B   P124A/B   P124A/B   P124A/B   P124A/B     4:   MP-124A/B   P124A/B   CD2 ABSCREEN N2_1   P124A/B     4:   MP-124A/B   T142   CD2 ABSCREEN N2_1   P124A/B     4:   MP-124A/B   CD2 COPRESSOR 1ST INTERSTACE KNOCKOUT DRUM   P14A     4:   MP-124A/B   CD2 COPRESSOR 1ST INTERSTACE KNOCKOUT DRUM     5:   MP-126   V-26   CD2 COPRESSOR 1ST INTERSTACE KNOCKOUT DRUM     5:   MP-126   V-26   CD2 COPRESSOR 1ST INTERSTACE KNOCKOUT DRUM     5:   MP-126   V-26   CD2 COPRESSOR 1ST INTERSTACE KNOCKOUT DRUM     5:   MP-20   V-12   STEPPER RELIX GRUM     5:   MP-20   V-12   STERPER RELIX GRUM     5:   MP-20   MP-20   MP-20 <td< td=""><td></td><td></td><td>43 MP-121A/B 44 MP-122A/B</td><td>N/A N/A</td><td>SEA WATER COOLING BOOSTER SOFTENED WATER SUPPLY PUM</td><td>PUMPS PS</td><td></td></td<>			43 MP-121A/B 44 MP-122A/B	N/A N/A	SEA WATER COOLING BOOSTER SOFTENED WATER SUPPLY PUM	PUMPS PS	
47   MY-182   1-182   CO2 ABSORBER NO.2     49   MY-183   T-123   STRIPPER     58   MY-184   V-186   CO2 COMPRESSOR SMC INTERSTACE KNOCKOUT ORUM     51   MY-186   V-186   CO2 COMPRESSOR SMC INTERSTACE KNOCKOUT, DRUM     52   MY-186   V-186   CO2 COMPRESSOR SMC INTERSTACE KNOCKOUT, DRUM     52   MY-187   V-186   CO2 COMPRESSOR SMC UNTON TANK     54   MY-282   V-186   CO2 COMPRESSOR SMC UNTON TANK     54   MY-282   V-183   CO2 COMPRESSOR SMC UNTON DRUM     55   MY-282   V-183   CO2 COMPRESSOR SMC UNTON DRUM     56   MY-282   V-183   CO2 COMPRESSOR SMC UNTON DRUM     57   MT-184   IK-182   ARM SMC SMC TANK COMPONATE     58   MT-187   MARA ANTE SOLVANT CR2X Reads TANK   GA STRIPER     60   MT-187   MARA RECLARMENT ANT CR2X REAds TANK   GA STRIPER     61   MT-187   MARA RECLARMENT CR2X REAds TANK   GA STRIPER     62   MS-184/C   FUB ANT RECLARMENT CR2X REAds TANK   GA STRIPER ANT RECLAREA <td></td> <td></td> <td>45 MP-123A/B 46 MP-124A/B</td> <td>N/A P-124A/B</td> <td>COMPRESSOR 1ST STAGE CONDE RICH AMINE PUMPS (ABSORBER</td> <td>ENSATE BOOSTER PUMPS 2)</td> <td></td>			45 MP-123A/B 46 MP-124A/B	N/A P-124A/B	COMPRESSOR 1ST STAGE CONDE RICH AMINE PUMPS (ABSORBER	ENSATE BOOSTER PUMPS 2)	
49   MY-183   T-183   STRIPPER     32   MY-184   Y-285   C02 COMPRESSOR IST INTERSTACE KNOCKOUT DRUM     32   MY-186   Y-185   C02 COMPRESSOR IST INTERSTACE KNOCKOUT DRUM     33   MY-187   N/A   LP CONDENSATE BLOWDOWN TAWK     34   MY-187   N/A   LP CONDENSATE BLOWDOWN TAWK     35   MY-187   N/A   LP CONDENSATE BLOWDOWN TAWK     36   MY-282   Y-183   CO2 COMPRESSOR SUCTION ORUM     36   MY-187   N/A   LP CONDENSATE BLOWDOWN TAWK     36   MY-187   N/A   LP CONDENSATE BLOWDOWN TAWK     36   MY-187   N/A   LSTERMENT AIR RED.     37   MT-180   TK-180   AMINE STRAPE TAK (CONDENTATE DURING ATAKK CONCENTRATED)     39   MT-187   N/A   STRIPPER REFLUX DRUM   ASTART CONCENTRATE DURING ATAKK CONCENTRATED)     39   MT-187   N/A   STRIPER REFLUX DRUM   MARCENTRATESTARE     39   MT-187   N/A   STRIPER REFLUX DRUM   MAKENT CONCENTRATESTARE     39   MT-187   N/A			47 MV-1Ø1 48 MV-1Ø2	T-101 T-102	CO2 ABSORBER NO.1 CO2 ABSORBER NO.2		-
S1   MV-106   V-126   C02   CORPRESSOR 2/MC INTERSTAGE KNOCKOUT, DRUM     S3   MV-107   N/A   L/P   CONUENSATE BLOWDWN TANK     S4   MV-202   V-123   SEM_LEAN FLACH URUM   SEM_LEAN FLACH URUM     S5   MV-202   V-122   SEM_LEAN FLACH URUM   SEM_LEAN FLACH URUM     S5   MV-202   V-122   SEM_LEAN FLACH URUM   SEM_LEAN FLACH URUM     S6   MV-202   V-122   SEM_LEAN FLACH URUM   SEM_LEAN FLACH URUM     S6   MV-202   V-123   CO2   COMPRESSOR SUCTION DRIM     S6   MV-202   V-122   SEM_LEN SURGE TANK   SEM_LEN SURGE TANK     S6   MT-122   TK-142   LEAN ANTE SOURCE TANK   SEM_LEN SURGE TANK     S6   MT-123   TK-122   LEAN ANTE SOURCE TANK   SEM_LEN SURGE TANK     S6   MT-123   TK-142   LEAN ANTE SOURCE TANK   SEM_LEN SURGE TANK     S6   MT-128   N/A   INSTRUMENT AIR RECEIVER   SEM_LEAN ANTE     S6   MS-102   X-104   C02   DRYING PACKAGE   SEM		_	49 MV-103 50 MV-104	T-1Ø3 V-1Ø4	STRIPPER CO2 COMPRESSOR 1ST INTERST	AGE KNOCKOUT DRUM	
S.3   WH/2   IVA   LP   UDURING IN BUILDING INK     55   WH-201   SERUPER REFLUX DRUM   55     55   WH-202   V-103   SERUPER REFLUX DRUM     56   WH-201   SERUPER REFLUX DRUM     57   WH-101   STRUPPER REFLUX DRUM     58   WH-201   Y-103   CO2     59   WH-201   Y-103   SERUPER TAK (CORCENTATED)     58   WH-101   TK-102   LEAN ANNE SOLVENT GROWERTATED)     58   WH-102   TK-102   LEAN ANNE SOLVENT GROWERTATED)     59   MT 102   TK-102   LEAN ANNE SOLVENT GROWERTATED)     59   MT 104   TK-102   LEAN ANNE SOLVENT GROWERTATED)     60   MT-109   N/A   INSTRUMENT AIR RECEIVER     61   MT-109   N/A   INSTRUMENT AIR RECEIVER     62   MS-105A/B   N/A   INSTRUMENT AIR RECEIVER     63   MS-105A/B   N/A   INSTRUMENT AIR DRYER     64   MS-105A/B   N/A   INSTRUMENT AIR DRYER     65   MS-105A/B </td <td></td> <td></td> <td>51 MV-105 52 MV-106</td> <td>V-105 V-106</td> <td>CO2 COMPRESSOR 2ND INTERS</td> <td>TAGE KNOCKOUT DRUM</td> <td></td>			51 MV-105 52 MV-106	V-105 V-106	CO2 COMPRESSOR 2ND INTERS	TAGE KNOCKOUT DRUM	
33 NV-202 V-182 SIM_PER HELLUX DRUM   56 NV-202 V-182 CO2 COPERSOR SUCTION DRUM   57 NT-101 TK-101 AMINE STORAGE TANK (CONCENTRATED)   58 MT-102 TK-102 LEAN ANINE STORAGE TANK (CONCENTRATED)   59 MT-102 TK-102 LEAN ANINE SCUPENT (352 MEA) STORAGE TANK   60 MT-107 N/A SOFTENED WATER SURGE TANK   61 MT-107 N/A SOFTENED WATER SURGE TANK   62 MS-102 X-102 AWINE RECLEIVER   63 MS-102 X-103 RECLAIMER CHEMICAL FEEL PACKAGE   64 MS-103 X-103 RECLAIMER CHEMICAL FEEL PACKAGE   65 MS-105A/B N/A INSTRUMENT AIR DRYER   66 MS-105A/B N/A INSTRUMENT AIR DRYER   61 MAIN EQUIPMENT LAYOUT   63 MAIN EQUIPMENT LAYOUT			53 MV-107 54 MV-201	V-101	SEMI-LEAN FLASH DRUM	NK	
Image: Strategy and S			55 MV-202 56 MV-203	V-102 V-103	CO2 COMPRESSOR SUCTION DRU		
Image: Second			58 MT-102 59 MT-104	TK-101 TK-102	LEAN AMINE SOLVENT (35% ME PROCESS WATER SUBGE TANK	A) STORAGE TANK	
62   MS-10/A/C   FLUE GAS WATER FOGGER SYSTEM     63   MS-102   X-102   AMINE RECLAIMER     64   MS-102   X-102   RECLAIMER     64   MS-102   X-102   RECLAIMER     64   MS-102   X-102   RECLAIMER     65   MS-104   C02   REVISED PER 10112936-S-FIP9-0-0208   TO INCORPORATE     66   MS-1075A/B   N/A   INSTRUMENT AIR DRYER   DO AX     66   MS-1075A/B   N/A   INSTRUMENT AIR DRYER			60   MT-107     61   MT-109	N/A N/A	SOFTENED WATER STORAGE TA	NK	
64   MS-103   X-103   RECLAIMER CHEMICAL FEED PACKAGE     65   MS-104   X-104   CO2 DRYING PACKAGE     66   MS-105A/B   N/A   INSTRUMENT AIR DRYER     67   MAIN ELECTRICAL EQUIPMENT DESIGNATION   RPT   RPT   BTR     66   Idv1/dm   ISSUED FOR APPROVAL   IkLI   RPT   BTR   A/G     6   Idv1/dm   ISSUED FOR APPROVAL   RCO2   KARSTO PROJECT   Issue State			62 MS-101A/C 63 MS-102	X-101A/C X-102	FLUE GAS WATER FOGGER SYS	TEM	
66   MS-105A/B   N/A   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER   INSTRUMENT AIR DRYER     INSUED FOR AREA A A CO2 COMPRESSOR B	•		64 MS-103 65 MS-104	X-1Ø3 X-1Ø4	RECLAIMER CHEMICAL FEED PA CO2 DRYING PACKAGE	CKAGE	
Image: State of the state			66 MS-105A/B	N/A	INSTRUMENT AIR DRYER		
Image: State Stat							
Image: Solution of the state of the sta							
Image: Second State of the		_					
Image: State of the state							
Image: Substant State Revised per 10112936-S-FIPB-G-0208 TO INCORPORATE RPT Image: Substant State Image: Substant State RPT Image: Substant State Image: Substant State RPT Image: Substant State Ima	<b>_</b>	~					
Image: Contractor active ac		A KAM	REVISED PER 101129	36-S-FIPB-G-	0208 TO INCORPORATE	RPT BB FF AD A	
NO. DATE PEVISIONS BY OHK DES ENGR. PROJ APPR   Owner GASSNOVA CO2 KARSTO PROJECT Intervision of the second		0 14/11/	ISSUED FOR APPROVA			KLJ RPT RPT BTR AJ	;
GASSNOVA CO2 KARSTO PROJECT Owner Drawing No. 10112936-PB-G-DRW-0003 Contractor BECHTEL POWER CO2 COMPRESSOR BUILDING Sheet Stare 594x841 "A1" Staller 1:125 JOB NO. DRAWING NO. REV.		NO. DATE		REVIS	IONS	BY CHK DES ENGR. PROJ APPI	
Owner Drawing No.   10112936-PB-G-DRW-0003   Contractor   Contractor   BECHTEL POWER CORPORATION   Stheet Stare 594x841 "A1"   Scale: 1:125   DRAWING NO.		÷. (	GASSNOV	4	CO2 KARSTO	PROJECT	
Contractor BECHTEL POWER CORPORATION DB NO. COMPRESSOR BUILDING Street Stze 594x841 "A1" Scale: 1:125 DRAWING NO. REV.	- 1	ner Drawing 011293	6-PB-G-DRW-OC	)03	MAIN EQUIPMEI	NT_LAYOUT	1
BECHTEL POWER CORPORATION JOB NO. DRAWING NO. REV.	×   [	ntractor		]	STRIPPER A	AREA & DR BUILDING	
CORPORATION JOB NO. DRAWING NO. REV.		CHI	BECHTEL POWER	Sheet Size	594x841 "A1" Scale: 1:125		_ '
			CORPORATIC	)N  j ⊳	DB NO. DRA	AWING NO. REV.	_





7 8 9 10	11	12

DOINTS	

DESCRIPTION
NE ROAD
SE ROAD
NW ROAD
SW ROAD
PIPE RACK FOR STEAM AND CONDENSATE FROM
LP STEAM FROM CCPP
LP CONDENSATE TO CCPP
HP STEAM FROM CCPP
HP CONDENSATE TO CCPP
FUEL GAS TO CCC PLANT
FLARE FROM CCC PLANT
GAS (INCLUDING STACK MODS AND FLUE GAS TO
22 kV ELECTRICAL POWER CABLES, ALTERNAT
6 KV ELECTRICAL POWER CABLES
UNDERGROUND FIREWATER (WEST)
UNDERGROUND COOLING WATER SUPPLY
UNDERGROUND COOLING WATER SUPPLY
UNDERGROUND COOLING WATER SUPPLY
ELECTRICAL POWER CABLES TO COOLING WATE
PROTECTION, MEASURING AND CONTROL PUR CABELING TO/FROM COOLING WATER PUN
UNDERGROUND COOLING WATER RETURI
UNDERGROUND FIREWATER (EAST)
POTABLE WATER
SEWAGE WATER
PIPE RACK TO CO2 TRANSPORT AREA
PIPLINE CO2 EXPORT
VENT LINE FROM CO2 TRANSPORT ARE
FRESH WATER TO CO2 TRANSPORT AREA (UTILIT
COMPRESSED AIR TO CO2 TRANSPORT AREA (UTILI
NITROCEN TO CO2 TRANSPORT AREA (UTILITY
LP STEAM TO CO2 TRANSPORT AREA (UTILITY
INSTRUMENT CABLES TO/FROM CO2 TRANSPOR
ELECTRICAL POWER CABLES TO CO2 TRANSPO
INSTRUMENT CABLES TO/FROM NATURKRAFT
INSTRUMENT CABLES TO/FROM KARSTO GAS T
ABELING FOR PROTECTION, MEASURING AND CONTR
POWER CABELING INTERFACE FOR NEW F.G. DAM
EARTHING SYSTEM CONNECTION POINT
NT

		FOR	CONNECTION INFORMATION, ET	C. REFER TO E-17	10 20	R 10112936-FI-Z-LST-0004. ) 30
7	8	9	10		11	12





5	6	7	8	9	10	11
U				· · · · · · · · · · · · · · · · · · ·		



					10	
 7	8	9	10	11	IZ	
/			<u> </u>			



13	14	15	16	

NOTES			   M
	EMENT AND BYPASS SWITCH DOCITION		
ON THE GRA	PHICAL DISPLAY.	TO BE READ	
2. A COMMON COMBINATION FOR REMOTE	ROUBLE SIGNAL OUTPUT (OPEN ON TR OF DRY CONTACTS AS REQUIRED)WILL ALARM AND DISCONNECTION.	OUBLE i.e. SERIES BE PROVIDED	
3. MAGNETIC BI RATINGS.	REAKERS WITH ADJUSTABLE MAGNETIC	TRIP	
4. NEUTRAL OF NEUTRAL SH TRANSFORME	UPS SHALL BE EARTHED AT ONE POIN NLL BE ISOLATED FROM EARTH AT THE R/ DISTRIBUTION PANEL SIDE.	T AT INVERTIER.	-
5. EARTH NEUT	RAL AT INVERTER OUTPUT.		ΪL
6. A CONTACT AS WELL AS	WILL BE PROVIDED EACH FOR COMMON FOR LOCAL OPEN INDICATION FOR EAC	REMOTE ALARM CH FEEDER BREAKER.	
7. EACH BATTE	RY CHARGER AND BATTERY IS SIZED T	O FEED 100% OF LOAD.	
8. EQUIPMENT A	ND BREAKER SIZING TO BE CONFIRMED	(LATER).	
9. SYSTEM VC 110V D 230V 24V D	LTAGE VARIATIONS ARE AS FOLLOW C +10%, -15% AC +/- 10% C (20V TO 30V)	S:	
10. CABLES FROM FAULT CURRI	A BATTERIES SHALL BE SIZED TO CARE	RY FULL	
11. ALL SWITCHB WITH 30% SF	OARDS AND PANELBOARDS WILL BE PRO ARE SPACE.	DVIDED	K
12. DURING NORM TO THE LOAI AUTOMATICAL	AL OPERATION, THE INVERTER SHALL S >S. UPON LOSS OF DC POWER, THE ST/ _Y TRANSFER LOADS TO ISOLATION TH	UPPY POWER ATIC SWITCH WILL MANSFORMER.	-
13. NEGATIVE OF	24V DC SYSTEM TO BE SOLIDLY EAR	RTHED.	ĺ
14. LOCAL AND F	EMOTE ALARM INDICATION SHALL BE PF		<u> </u>
15. DURING NORM NO AUTOMATI	AL OPERATION, THE TIE BREAKER SHALI C TRANSFER IS PROVIDED.	BE OPEN.	
16. CONSUMERS LOCAL TO CO	VILL BE DOUBLE FED WITH DIODE DC-C	OUPLING CIRCUITS	
			J
REFERENC	E DRAWINGS:		
1. MAIN SINGLE		000-00001	
			н

LE(	<u>GEND:</u>
$\langle \mathbf{x} \rangle$	CIRCUIT BREAKER
4	LOAD BREAK DISCONNECT (LBD)
•	SHUNT
	FUSE
2	DC TO DC CONVERTER
<u>~</u>	DC TO AC CONVERTER
AVS	AUTOMATIC VOLTAGE STABILIZER
2P 4P	2 POLE 4 POLE
27	UNDERVOLTAGE
59	OVERVOLTAGE
64	EARTH FAULT SUPERVISION
MCB	MINIATURE CIRCUIT BREAKER
NO	MOULDED CASE CIRCUIT BREAKER NORMALLY OPEN
NC	NORMALLY CLOSED
$\odot$	VOLTMETER
(A)	AMMETER
	PRELIMINARY

$\square$							<u> </u>	<u> </u>	Ţ			
$\triangle$						1			<u>+</u>	<u> </u>		
	6 10V 08	REVISED PER 10112936-S-P-FIPB-E-0067				Sme	RP		Bre.	WE	 	
$\mathbb{A}$	67/8	REVISED PER 101129	36-S-P	-FIPB-E-0022 AN	DREDRAWN	ss	RP	-	BR	WRE		1
	⁷ 10/8	ISSUED FOR APPROV	ISSUED FOR APPROVAL			ss	РК	—	BR	WRE	· ·	В
	ÛATE		At	EVESTORS		87	СНК	DES	ENGR.	PROJ	APPR	1
	GASSNOVA CO2 KARSTO P				PR	DJE	ECT				 	
101129 Contractor	1 <u>36</u> -1	PB-E-DGM-0002	DC AND SINGLE LINE				S AG	RA	M	<u>.</u>		
		BECHTEL	Chart Corr									A
ar CH		POWER		594 X 841 'A1'	1:500				_			
Li L	Ŋ	CURPORATION		JOB NO.	DRA	WING	NO.			RE	/.	
FREDERICK, MARYLAND		25	6474-000	E1-00	00-0	000	02			2		
		14		1	5				- <u></u>	_!	—–	<u> </u>



### Sorted by Client Document Number

Client Document Number	Bechtel Document Number	Title	Revision	Date on Document
10112936-FI-Z-LST-0004	25474-000-3IC-G01G-00001	Interface Register CO2 Karsto	0	11/7/2008 0:00
10112936-PB-A-GEA-0001	25474-001-2RM-R01G-00001	Karsto - Risk Management System	1	10/24/2008 0:00
10112936-PB-A-HSE-0001	25474-001-2HS-G01G-00001	Karsto - HSE Plan	1	10/2/2008 0:00
10112936-PB-A-PPR-0002	25474-001-GPP-GAM-00002	General Project Procecdure for Communication Control	2	10/24/2008 0:00
10112936-PB-A-QAP-0001	25474-001-GQP-GAQ-00001	Karsto - Quality Plan	2	11/4/2008 0:00
10112936-PB-A-QAR-0001	25474-001-GQP-GAQ-00002	Karsto - Plan for Quality Audits and Surveillance	0	9/16/2008 0:00
10112936-PB-C-DOC-0001	25474-000-3YD-A01G-00001	Architectural Descriptions and Design Reports	0	11/20/2008 0:00
10112936-PB-C-DOC-0002	25474-000-3YD-A01G-00002	Relevant Architectural Analysis	0	11/20/2008 0:00
10112936-PB-C-DRW-0001	25474-000-30Y-C01G-00003	Plant Area Drawings Surrounding Infrastructure and Security		
		Fencing	0	12/5/2008 0:00
10112936-PB-C-DRW-0002	25474-000-30Y-C01G-00004	Site Preparation and Leveling Drawings	0	12/6/2008 0:00
10112936-PB-C-DRW-0003	25474-000-C0-0000-00001	Construction Facilities	0	12/5/2008 0:00
10112936-PB-C-PAL-0001	25474-000-30X-C15G-00002	Preliminary List of Equipment and Piping	0	11/26/2008 0:00
10112936-PB-C-PLN-0001	25474-000-AL-1000-00001	Landscape Plan	1	12/5/2008 0:00
10112936-PB-C-PLN-0002	25474-000-A1-4810-00001	Conceptual Plan - Flue Gas Blower Building	0	11/20/2008 0:00
10112936-PB-C-PLN-0003	25474-000-A1-6310-00001	Conceptual Plan - CO2 Compressor Building	0	11/20/2008 0:00
10112936-PB-C-PLN-0004	25474-000-A1-6110-00001	Conceptual Plan - Electrical Switchgear Building	0	11/20/2008 0:00
10112936-PB-C-PLN-0005	25474-000-A1-3110-00001	Conceptual Plan - Control/Workshop/Store Building	1	12/11/2008 0:00
10112936-PB-C-PLN-0006	25474-000-A2-3190-00001	Conceptual Elevations - Control/Workshop/Store Building	0	11/20/2008 0:00
10112936-PB-C-PLN-0007	25474-000-A1-0310-00001	Main Area Plans	0	11/21/2008 0:00
10112936-PB-C-TED-0001	25474-000-30Y-A01G-00001	Architectural Design Premises/Criteria	1	11/11/2008 0:00
10112936-PB-C-TED-0002	25474-000-30Y-C01G-00001	Design Philosophy and Acceptance Criteria for Civil Works	1	11/7/2008 0:00
10112936-PB-C-TED-0003	25474-000-CG-0000-00001	Rough Grading Plan	1	11/26/2008 0:00
10112936-PB-C-TED-0004	25474-000-CD-0000-00001	Site Drainage Plan	0	11/26/2008 0:00
10112936-PB-C-TED-0005	25474-000-CS-0000-00001	Access Roads and Finished Grading Plan	1	12/22/2008 0:00
10112936-PB-C-TED-0006	25474-000-DB-0100-00001	Ductwork Foundation Plan W/Typical Sections & Details		
		Sheet 1 Of 3	0	11/19/2008 0:00
10112936-PB-C-TED-0007	25474-000-DB-0100-00002	Ductwork Foundation Plan W/Typical Sections & Details		
		Sheet 2 Of 3	0	11/19/2008 0:00
10112936-PB-C-TED-0008	25474-000-DB-0100-00003	Ductwork Foundation Plan W/Typical Sections & Details		
		Sheet 3 Of 3	0	11/19/2008 0:00
10112936-PB-C-TED-0009	25474-000-DB-0200-00001	CCC Plant Foundation Plan with Typical Sections and Details		
		Sheet 1 of 4	0	11/20/2008 0:00
10112936-PB-C-TED-0010	25474-000-DB-0200-00002	CCC Plant Foundation Plan with Typical Sections and Details		
		Sheet 2 of 4	0	11/20/2008 0:00
10112936-PB-C-TED-0011	25474-000-DB-0200-00003	CCC Plant Foundation Plan with Typical Sections and Details		
		Sheet 3 of 4	0	11/20/2008 0:00

Client Document Number	Bechtel Document Number	Title	Revision	Date on Document
10112936-PB-C-TED-0012	25474-000-DB-0200-00004	CCC Plant Foundation Plan with Typical Sections and Details		
		Sheet 4 of 4	0	11/20/2008 0:00
10112936-PB-C-TED-0013	25474-000-CY-0000-00001	Site Subsurface Plan	0	11/19/2008 0:00
10112936-PB-C-TED-0014	25474-000-CY-0000-00002	Underground Structures Typical Sections & Details (Sheet 1		
		of 2)	0	11/19/2008 0:00
10112936-PB-C-TED-0015	25474-000-CY-0000-00003	Underground Structures Typical Sections & Details (Sheet2		
		of 2)	0	11/19/2008 0:00
10112936-PB-C-TED-0016	25474-000-30Y-S01G-00002	Building Structural Design Requirements	0	11/21/2008 0:00
10112936-PB-C-TED-0017	25474-000-30Y-C01G-00002	Required Infrastructure Improvements Outside Plant Battery		
		Limits	0	12/6/2008 0:00
10112936-PB-E-DAS-0001	25474-000-3SD-E000-00001	Data Sheets of Main Electrical Equipment	0	12/5/2008 0:00
10112936-PB-E-DGM-0001	25474-000-E1-0000-00001	Main Single Line Diagram	1	11/26/2008 0:00
10112936-PB-E-DGM-0002	25474-000-E1-0000-00002	DC and UPS Single Line Diagram	2	11/26/2008 0:00
10112936-PB-E-DRW-0001	25474-000-E4-0000-00001	Electrical Arrangement Drawings	0	11/19/2008 0:00
10112936-PB-E-PAL-0001	25474-000-E8-0000-00001	Electrical Consumers List	2	12/4/2008 0:00
10112936-PB-E-TDO-0001	25474-000-E0C-ES-00001	Load Flow Calculations	0	11/21/2008 0:00
10112936-PB-E-TDO-0002	25474-000-E0C-ES-00002	Short-Circuit Calculations	0	11/21/2008 0:00
10112936-PB-E-TDO-0003	25474-000-E0C-ES-00003	Transient Stability Calculations	1	11/21/2008 0:00
10112936-PB-E-TDO-0004	25474-000-E0C-ES-00004	Harmonic Distortion Study	0	11/21/2008 0:00
10112936-PB-E-TDO-0005	25474-000-30R-E21G-00001	Electrical Load Summary	0	11/20/2008 0:00
10112936-PB-E-TDO-0006	25474-000-E4-0310-00001	Equipment Location Plan - Electrical Switchgear Building	0	11/20/2008 0:00
10112936-PB-E-TDO-0007	25474-000-ER-0310-00001	Electrical Routing Plan - Cable Ladder - CCC Facility West		
		Side	0	11/20/2008 0:00
10112936-PB-E-TDO-0008	25474-000-ER-0310-00002	Electrical Routing Plan - Cable Ladder - CCC Facility East		
		Side	0	11/20/2008 0:00
10112936-PB-E-TDO-0009	25474-000-ER-0310-00003	Electrical Routing Plan - Electrical Switchgear Building	0	11/20/2008 0:00
10112936-PB-E-TDO-0010	25474-000-ER-0300-00001	Electrical Routing Plan - Cable Trench	0	11/20/2008 0:00
10112936-PB-E-TDO-0011	25474-000-EG-0300-00001	Electrical Earthing and Lightning Protection Plan	0	12/5/2008 0:00
10112936-PB-E-TED-0001	25474-000-3DR-E12G-00001	Electrical Power System Design Philosophy	2	12/1/2008 0:00
10112936-PB-E-TED-0002	25474-000-30Y-E01G-00001	Design Basis of Electrical Tie-Ins from External Facilities	0	10/7/2008 0:00
10112936-PB-E-TED-0003	25474-000-3BD-E12G-00001	Design Basis for Switchgear Protection and Control	1	11/26/2008 0:00
10112936-PB-E-TED-0004	25474-000-3BD-E12G-00002	Standy-by Emergency Diesel Generator Design Basis	0	11/19/2008 0:00
10112936-PB-E-TED-0005	25474-000-30R-E21G-00002	Electrical Equipment Sizes	0	11/20/2008 0:00
10112936-PB-E-TSP-0001	25474-000-3PS-E000-00001	Specifications of Main Electrical Equipment	0	12/4/2008 0:00
10112936-PB-G-CRE-0001	25474-000-G38-GAB-00001	CAPEX Cost Estimate	0	1/12/2009
10112936-PB-G-CRE-0002	25474-000-G38-GAB-00002	OPEX Cost Estimate	0	1/12/2009

#### Title Date on Document Client Document Number Bechtel Document Number Revision Karsto - Current CDR List with Status of Documents and 10112936-PB-G-DAL-0001 25474-001-30R-G01G-00002 Drawings 21 1/12/2009 0:00 Karsto - Owner's Engineering Document Form - Table of 10112936-PB-G-DOC-0001 25474-000-G27-GZC-00047 Content for Karsto FEED Study Report 0 10/17/2008 0:00 10112936-PB-G-DOC-0001 25474-001-30R-G01G-00001 Karsto - Table of Contents for Karsto FEED Study Report 10/2/2008 0:00 1 10112936-PB-G-DOC-0002 25474-000-M0X-0000-00006 Material Takeoff (MTO) Main Components 0 12/5/2008 0:00 Risk Management Document 0 1/12/2009 10112936-PB-G-DOC-0003 25474-000-2RM-R01G-00002 Guarantees on Key Parameters 10112936-PB-G-DOC-0004 25474-000-G67-GAX-00001 0 1/12/2009 FEED Study Report 1/12/2009 10112936-PB-G-DOC-0005 25474-000-30R-G04G-00001 0 10112936-PB-G-DRW-0001 25474-000-P1-0010-00001 General Arrangement Plan 0 11/19/2008 0:00 Main Equipment Lavout Flue Gas Blower/Absorber Area 10112936-PB-G-DRW-0002 25474-000-P1-0310-00001 1 12/4/2008 0:00 10112936-PB-G-DRW-0003 25474-000-P1-0310-00002 Main Equipment Layout - Stripper Area & CO2 Compressor Building 1 12/4/2008 0:00 Main Equipment Layout - Control/Workshop/Store Building, 10112936-PB-G-DRW-0004 25474-000-P1-0310-00003 Switchgear Building & Tank Farm 1 12/4/2008 0:00 3D Model Composite Extraction End View and Elevation 10112936-PB-G-DRW-0005 25474-000-P4-0010-00009 0 12/5/2008 0:00 3D Model Composite Extraction Isometric View 10112936-PB-G-DRW-0006 25474-000-P4-0010-00010 0 12/5/2008 0:00 10112936-PB-G-DRW-0007 25474-000-P1-0010-00002 CCCP Battery Limits Interface Tie -Point Plan 0 12/19/2008 0:00 10112936-PB-G-PAL-0001 25474-000-G07-GPX-00003 Preliminary Vendor-Subcontractor List for Main Components 0 12/22/2008 0:00 Karsto - Mobilization Plan 10112936-PB-G-PPL-0001 25474-001-GQP-GAQ-00004 1 10/23/2008 0:00 Procurement Milestones for Long Lead Items 10112936-PB-G-PPL-0002 25474-000-G07-GPX-00002 0 12/22/2008 0:00 10112936-PB-G-PPL-0003 Overall Time Schedule 0 1/12/2009 25474-000-GDS-GAM-00002 0 11/14/2008 0:00 10112936-PB-H-TED-0001 25474-000-30Y-M83G-00001 HVAC Design and Control Philosophy HVAC System Design and Description 10112936-PB-H-TED-0002 25474-000-3YD-M63G-00001 0 11/20/2008 0:00 ESD / PSD Cause & Effect Diagram 10112936-PB-I-DGM-0001 25474-000-J4-JD-00001 1 12/4/2008 0:00 Fire & Gas System Cause & Effect Diagram 10112936-PB-I-DGM-0002 25474-000-J4-JD-00002 1 12/4/2008 0:00 Narrative of Information Management System 10112936-PB-I-DOC-0001 25474-000-3YD-J01G-00005 0 12/4/2008 0:00 12/4/2008 0:00 10112936-PB-I-DOC-0002 25474-000-J0-0000-00001 Instrument Index for CO2 Capture Facility Karsto Norway 0 IO Estimation 0 12/4/2008 0:00 10112936-PB-I-DOC-0003 25474-000-J0-JD-00001 10112936-PB-I-DRW-0001 25474-000-JD-JD-00001 SAS Architecture Diagram 0 11/3/2008 0:00 10112936-PB-I-DRW-0002 25474-000-3YD-J01G-00002 Safety and Automation System Narrative 1 12/4/2008 0:00 Continuous Gas Monitoring System (CGMS) Description 12/22/2008 0:00 10112936-PB-I-DRW-0003 25474-000-3YD-J01G-00003 1 Central Control Room Conceptual Layout 12/22/2008 0:00 10112936-PB-I-DRW-0004 25474-000-J0-3110-00001 1 Compressor Building Analyzer Room Conceptual Layout 10112936-PB-I-DRW-0005 25474-000-J0-4010-00001 0 11/19/2008 0:00 CGMS Shelter Conceptual Layout 11/19/2008 0:00 10112936-PB-I-DRW-0006 25474-000-J0-4410-00001 0 11/20/2008 0:00 10112936-PB-I-DRW-0007 25474-000-E6-EEC-00001 CCTV Conceptual Block Diagram 0

Client Document Number	Bechtel Document Number	Title	Revision	Date on Document
10112936-PB-I-DRW-0008	25474-000-E6-EFP-00001	PA System Conceptual Block Diagram	0	11/20/2008 0:00
10112936-PB-I-DRW-0009	25474-000-E6-EFV-00001	Telephone System Conceptual Block Diagram	0	11/20/2008 0:00
10112936-PB-I-LST-0001	25474-000-G27-GZC-00327	Owner's Engineer Document Review Form -Signal exchange		
		list with external systems	0	12/22/2008 0:00
10112936-PB-I-LST-0001	25474-000-J0-JD-00002	Signal Exchange List	0	12/5/2008 0:00
10112936-PB-I-LST-0002	25474-000-J0-JD-00005	Instrument Air Consumption List	0	12/16/2008 0:00
10112936-PB-I-LST-0003	25474-000-J0-JD-00004	Automation Systems UPS/DC	0	12/16/2008 0:00
10112936-PB-I-PAL-0002	25474-000-J0-JD-00003	List of Open Loop Contorls	0	12/5/2008 0:00
10112936-PB-I-PAL-0003	25474-000-J0-0000-00002	List of Analog Instruments	0	12/5/2008 0:00
10112936-PB-I-PAL-0004	25474-000-J0-0000-00003	List of Control Valves	0	12/5/2008 0:00
10112936-PB-I-PAL-0005	25474-000-J0-0000-00004	List of Pneumatic On/Off Drives	0	12/5/2008 0:00
10112936-PB-I-PLN-0001	25474-000-J0-0010-00001	Conceptual Location Plan of Gas Analyzing and Monitoring		
		Equipment	0	12/4/2008 0:00
10112936-PB-I-TD0-0003	25474-000-EL-0310-00001	Control System Data Highway Routing Scheme	0	11/20/2008 0:00
10112936-PB-I-TDO-0001	25474-000-3YD-J01G-00001	SAS Design Philosophy	0	11/7/2008 0:00
10112936-PB-I-TDO-0002	25474-000-30Y-E44G-00001	Instrument Earthing Philosophy	0	11/20/2008 0:00
10112936-PB-I-TED-0001	25474-000-3YD-J01G-00004	Description of F&G Monitoring and Alarm System	0	11/19/2008 0:00
10112936-PB-L-DRW-0001	25474-000-P4-0010-00001	Piping Arrangement Overall Piping Plan	0	11/20/2008 0:00
10112936-PB-L-DRW-0002	25474-000-P4-0010-00002	Piping Arrangement Plan View at Grade (EL. +7.0M)	0	11/20/2008 0:00
10112936-PB-L-DRW-0003	25474-000-P4-0010-00003	Piping Arrangement Plan View at (EL. +16.95M)	0	11/20/2008 0:00
10112936-PB-L-DRW-0004	25474-000-P4-0010-00004	Piping Arrangement Sections and Elevations	0	11/20/2008 0:00
10112936-PB-L-DRW-0005	25474-000-P4-0010-00005	Piping Arrangement Sections and Elevations	0	11/20/2008 0:00
10112936-PB-L-DRW-0006	25474-000-P4-0010-00006	Piping Arrangement Sections and Elevations	0	11/20/2008 0:00
10112936-PB-L-DRW-0007	25474-000-P4-0010-00007	Piping Arrangement Sections and Elevations	0	11/20/2008 0:00
10112936-PB-L-DRW-0008	25474-000-P4-0010-00008	Piping Arrangement Sections and Elevations	0	11/20/2008 0:00
10112936-PB-L-LST-0002	25474-000-M0X-0000-00004	Storage and Transport Systems	0	11/12/2008 0:00
10112936-PB-L-TED-0001	25474-000-3DS-P72G-00001	Pipe Class Selection	0	11/13/2008 0:00
10112936-PB-L-TED-0002	25474-000-3DG-P70G-00001	Selection And Application of Valves	0	12/5/2008 0:00
10112936-PB-L-TED-0003	25474-000-30R-M90G-00001	LCC Pipe Design	0	12/7/2008 0:00
10112936-PB-M-TDO-0001	25474-000-G65-GEN-00001			
		Corrosion Evaluation for Main Systems CO2 Capture Facility	0	11/20/2008 0:00
10112936-PB-M-TDO-0002	25474-000-G65-GEN-00002	Durability Report (Material Selection Philosophy) CO2		
		Capture Facility	0	11/20/2008 0:00
10112936-PB-N-DRW-0001	25474-000-S0-0000-00001	Structural Steel Sheet Typical Sections and Details	0	10/24/2008 0:00
10112936-PB-N-DRW-0002	25474-000-S0-0000-00002	Structural Steel Sheet Typical Sections and Details	0	10/24/2008 0:00
10112936-PB-N-DRW-0003	25474-000-S0-0010-00003	Structural Steel Sheet Typical Sections and Details	0	10/24/2008 0:00
10112936-PB-N-DRW-0004	25474-000-S0-0010-00004	Structural Steel Sheet Typical Sections and Details	0	10/24/2008 0:00

Client Document Number	Bechtel Document Number	Title	Revision	Date on Document
10112936-PB-N-TDO-0002	25474-000-30X-C15G-00001	Foundation Loads	0	11/20/2008 0:00
10112936-PB-N-TED-0001	25474-000-30Y-S01G-00001	Structural Design Philosophy and Acceptance Criteria	1	11/26/2008 0:00
10112936-PB-O-DOC-0001	25474-000-4CR-T01G-00001	Constructability Report	0	11/14/2008 0:00
10112936-PB-O-DOC-0002	25474-000-4CY-T01G-00001	Material Preservation and Storage Philosophy	0	11/20/2008 0:00
10112936-PB-O-DOC-0003	25474-000-517-U07G-00001	Operating and Maintenance Philosophy	1	12/12/2008 0:00
10112936-PB-O-DOC-0004	25474-000-517-U07G-00002	Operating Staff Concept	1	12/12/2008 0:00
10112936-PB-O-DOC-0005	25474-000-583-U07G-00001	Mechanical Testing and Completion Schedule	0	12/6/2008 0:00
10112936-PB-O-DOC-0006	25474-000-512-U07G-00001	Cold Commissioning Schedule	0	12/6/2008 0:00
10112936-PB-O-DOC-0007	25474-000-512-U07G-00002	Hot Commissioning Schedule	0	12/6/2008 0:00
10112936-PB-O-DOC-0008	25474-000-586-U07G-00001	Performance Guarantee Test Procedure	0	12/7/2008 0:00
10112936-PB-O-DOC-0009	25474-000-552-U07G-00001	Recommended Spare and Wear Parts	0	12/6/2008 0:00
10112936-PB-O-LST-0001	25474-000-514-U07G-00001	List of Consumables	0	12/2/2008 0:00
10112936-PB-O-TDO-0001	25474-000-4CY-T01G-00002	Erection Concept and Access Requirements for Operation		
		and Maintenance	0	1/5/2009 0:00
10112936-PB-P-DAS-0001	25474-000-M5D-CN-00011	Vessel Data Sheet	1	11/19/2008 0:00
10112936-PB-P-DAS-0002	25474-000-M5D-CN-00012	Process Data Sheet Trays and Packing	1	11/19/2008 0:00
10112936-PB-P-DAS-0003	25474-000-M5D-CN-00031	Heat Exchanger (Plate) Data Sheet	1	11/19/2008 0:00
10112936-PB-P-DAS-0004	25474-000-M5D-CN-00051	Vessel Data Sheet	1	11/19/2008 0:00
10112936-PB-P-DAS-0005	25474-000-M5D-CN-00052	Process Data Sheet Trays and Packing	1	11/19/2008 0:00
10112936-PB-P-DAS-0006	25474-000-M5D-QG-00011	Process Data Sheet Compressors	0	10/7/2008 0:00
10112936-PB-P-DAS-0007	25474-000-M5D-BA-00011	Process Data Sheet Blowers	0	10/8/2008 0:00
10112936-PB-P-DAS-0008	25474-000-M5D-BA-00012	General Package Datasheet	0	10/7/2008 0:00
10112936-PB-P-DAS-0012	25474-000-M5D-CN-00013	Heat Exchanger (Plate) Dtat Sheet	0	11/14/2008 0:00
10112936-PB-P-DAS-0013	25474-000-3SD-M000-00001	Utility Data Sheet	0	12/5/2008 0:00
10112936-PB-P-DGM-0001	25474-000-M6-BA-00001	Flue Gas Duct System	0	11/13/2008 0:00
10112936-PB-P-DGM-0002	25474-000-M6-BA-00002	Flue Gas Duct System	0	11/13/2008 0:00
10112936-PB-P-FLD-0001	25474-000-M5-YA-00001	Block Flow Diagram	1	11/12/2008 0:00
10112936-PB-P-FLD-0002	25474-000-M5J-YA-00001	Symbols and Legends	0	10/10/2008 0:00
10112936-PB-P-FLD-0003	25474-000-M5-BA-00001	Process Flow Diagram - Blower and Quench Section	1	11/12/2008 0:00
10112936-PB-P-FLD-0004	25474-000-M5-CN-00001	Process Flow Diagram - Absorber T-101	1	11/12/2008 0:00
10112936-PB-P-FLD-0005	25474-000-M5-CN-00002	Process Flow Diagram - Absorber T-102	1	11/12/2008 0:00
10112936-PB-P-FLD-0006	25474-000-M5-CN-00003	Process Flow Diagram - Lean Amine Cooling Sheet 1 of 2	1	11/12/2008 0:00
10112936-PB-P-FLD-0007	25474-000-M5-CN-00004	Process Flow Diagram - Lean Amine Cooling Sheet 2 of 2	1	11/12/2008 0:00
10112936-PB-P-FLD-0008	25474-000-M5-CN-00005	Process Flow Diagram Stipper	1	11/12/2008 0:00
10112936-PB-P-FLD-0009	25474-000-M5-CY-00001	Process Flow Diagram - Fresh and Lean Amine Storage	1	11/12/2008 0:00
10112936-PB-P-FLD-0010	25474-000-M5-QG-00001	Process Flow Diagram - Compression & Drying Section -		
		Sheet 1 of 2	1	11/12/2008 0:00

Client Document Number	Bechtel Document Number	Title	Revision	Date on Document
10112936-PB-P-FLD-0011	25474-000-M5-QG-00002	Process Flow Diagram - Compression & Drying Section -		
		Sheet 2 of 2	1	11/12/2008 0:00
10112936-PB-P-FLD-0012	25474-000-M5-WP-00001	Process Flow Diagram - Process Water System	0	11/12/2008 0:00
10112936-PB-P-FLD-0013	25474-000-M5-WL-00001	Closed Cooling Water System	0	11/13/2008 0:00
10112936-PB-P-FLD-0014	25474-000-M5-SC-00001	LP Condensate Return System	0	11/13/2008 0:00
10112936-PB-P-HMB-0001	25474-000-M4-CN-00001	Heat and Mass Balance Diagrams	1	11/14/2008 0:00
10112936-PB-P-HMB-0002	25474-000-M4-CN-00002	Heat and Mass Balance Diagrams	1	11/14/2008 0:00
10112936-PB-P-LCL-0001	25474-000-M0X-0000-00002	Line List	0	11/14/2008 0:00
10112936-PB-P-LST-0001	25474-000-M0X-0000-00003	Utility Consumption List	0	11/14/2008 0:00
10112936-PB-P-PID-0001	25474-000-M6J-YA-00001	Symbols and Legends	0	11/13/2008 0:00
10112936-PB-P-PID-0002	25474-000-M6J-YA-00002	Symbols and Legends	0	11/13/2008 0:00
10112936-PB-P-PID-0003	25474-000-M6J-YA-00003	Symbols and Legends	0	11/13/2008 0:00
10112936-PB-P-PID-0004	25474-000-M6J-YA-00004	Symbols and Legends	0	11/13/2008 0:00
10112936-PB-P-PID-0005	25474-000-M6J-YA-00005	Symbols and Legends	0	11/13/2008 0:00
10112936-PB-P-PID-0006	25474-000-M6-CN-00010	Piping & Instrument Diagram CO2 Absorber T-101 (Amine		
		Section)	0	11/12/2008 0:00
10112936-PB-P-PID-0007	25474-000-M6-CN-00020	Piping & Instrument Diagram CO2 Absorber T-101 (Wash		
		Water Cooling Section)	0	11/12/2008 0:00
10112936-PB-P-PID-0008	25474-000-M6-CN-00030	Piping & Instrument Diagram Absorber 1 Wash Water		
		Cooling Syster	0	11/12/2008 0:00
10112936-PB-P-PID-0009	25474-000-M6-CN-00040	Piping & Instrumentation Diagram Absorber 1 Rich Amine		
		Pumpls	0	11/12/2008 0:00
10112936-PB-P-PID-0010	25474-000-M6-CN-00045	Piping & Instrumentation Diagram Absorber 2 Rich Amine		
		Pumps	0	11/13/2008 0:00
10112936-PB-P-PID-0011	25474-000-M6-CN-00050	Piping & Instrument Diagram CO2 Absorber T-102 (Amine		
		Section)	0	11/12/2008 0:00
10112936-PB-P-PID-0012	25474-000-M6-CN-00060	Piping & Instrument Diagram CO2 Absorber T-102 (Wash		
		Water Cooling Section)	0	11/12/2008 0:00
10112936-PB-P-PID-0013	25474-000-M6-CN-00070	Piping & Instrument Diagram Absorber 2 Wash Water		
		Cooling System	0	11/12/2008 0:00
10112936-PB-P-PID-0014	25474-000-M6-CN-00080			
		Piping & Instrument Diagram Lean Amine Cooling System	0	11/12/2008 0:00
10112936-PB-P-PID-0015	25474-000-M6-CN-00081	Piping & Instrument Diagram Lean Amine /Rich Amine Heat		
		Exchangers Shet 1 of 4	0	11/12/2008 0:00
10112936-PB-P-PID-0016	25474-000-M6-CN-00082	Piping & Instrument Diagram Lean Amine /Rich Amine Heat		
		Exchangers Sheet 2 of 4	0	11/12/2008 0:00

Client Document Number	Bechtel Document Number	Title	Revision	Date on Document
10112936-PB-P-PID-0017	25474-000-M6-CN-00083	Piping & Instrument Diagram Lean Amine /Rich Amine Heat		
		Exchangers Sheet 3 of 4	0	11/12/2008 0:00
10112936-PB-P-PID-0018	25474-000-M6-CN-00084	Piping & Instrument Diagram Lean Amine Piping &		
		Instrument Diagram Lean Amine /Rich Amine Heat		
		Exchangers Sheet 4 of 4	0	11/12/2008 0:00
10112936-PB-P-PID-0019	25474-000-M6-CN-00085	Piping & Instrument Diagram Semi-Lean Amine / Rich Amine		
		Heat Exchanger	0	11/13/2008 0:00
10112936-PB-P-PID-0020	25474-000-M6-CN-00090	Piping & Instrument Diagram Lean Amine System Side		
		Stream Filters	0	11/13/2008 0:00
10112936-PB-P-PID-0021	25474-000-M6-CN-00100	Piping & Instrument Diagram Lean Amine Piping &		
		Instrument Diagram Flash Feed Heaters	0	11/12/2008 0:00
10112936-PB-P-PID-0022	25474-000-M6-CN-00110	Piping & Instrument Diagram Lean Amine Piping &		
		Instrument Diagram Semi-Lean Amine Flash System	0	11/12/2008 0:00
10112936-PB-P-PID-0023	25474-000-M6-CN-00120	Piping & Instrument Diagram Lean Amine Piping &		
		Instrument Diagram Amine Stripper (Packed Section)	0	11/12/2008 0:00
10112936-PB-P-PID-0024	25474-000-M6-CN-00130	Piping & Instrument Diagram Lean Amine Piping &		
		Instrument Diagram Amine Stirpper (Trayed Section)	0	11/12/2008 0:00
10112936-PB-P-PID-0025	25474-000-M6-CN-00140	Piping & Instrument Diagram Lean Amine Piping &		
		Instrument Diagram Stripper Reflus Section	0	11/13/2008 0:00
10112936-PB-P-PID-0026	25474-000-M6-CN-00150	Piping & Instrument Diagram Lean Amine Piping &		
		Instrument Diagram Stripper Reboilers Sheet 1 of 2	0	11/13/2008 0:00
10112936-PB-P-PID-0027	25474-000-M6-CN-00160	Piping & Instrument Diagram Lean Amine Piping &		
		Instrument Diagram Stripper Reboilers Sheet 2 of 2	0	11/13/2008 0:00
10112936-PB-P-PID-0028	25474-000-M6-CN-00170	Piping & Instrument Diagram Lean Amine Pump	0	11/13/2008 0:00
10112936-PB-P-PID-0029	25474-000-M6-CN-00180	Piping & Instrument Diagram Amine Reclaimer	0	11/13/2008 0:00
10112936-PB-P-PID-0030	25474-000-M6-CN-00190	Piping & Instrument Diagram Chemical Feed Package	0	11/13/2008 0:00
10112936-PB-P-PID-0031	25474-000-M6-CY-00010	Piping & Instrument Diagram Lean Amine Piping &		
		Instrument Diagram Fresh & Lean Amine Storage	0	11/12/2008 0:00
10112936-PB-P-PID-0032	25474-000-M6-QG-00010	Piping & Instrument Diagram CO2 Compressor Suction Drum-		
		CO2 Product System	0	11/14/2008 0:00
10112936-PB-P-PID-0033	25474-000-M6-QG-00020	Piping & Instrument Diagram CO2 Compressor 1st Stage	0	11/14/2008 0:00
10112936-PB-P-PID-0034	25474-000-M6-QG-00030	Piping & Instrument Diagram CO2 Compressor 1st Stage		
		Steam Generator And Intercooler	0	11/14/2008 0:00
10112936-PB-P-PID-0035	25474-000-M6-QG-00040	Piping & Instrument Diagram CO2 Compressor 1st Stage		
		Interstage Knock-Out Drum	0	11/14/2008 0:00
10112936-PB-P-PID-0036	25474-000-M6-QG-00050	Piping & Instrument Diagram CO2 Compressor 2nd Stage	0	11/14/2008 0:00

### Sorted by Client Document Number

Client Document Number	Bechtel Document Number	Title	Revision	Date on Document
10112936-PB-P-PID-0037	25474-000-M6-QG-00060	Piping & Instrument Diagram CO2 Compressor 2nd Stage		
		Steam Generator And Intercooler	0	11/14/2008 0:00
10112936-PB-P-PID-0038	25474-000-M6-QG-00070	Piping & Instrument Diagram CO2 Compressor 2nd Stage		
		Interstage Knock-Out Drum	0	11/14/2008 0:00
10112936-PB-P-PID-0039	25474-000-M6-QG-00080	Piping & Instrument Diagram CO2 Drying Package	0	11/14/2008 0:00
10112936-PB-P-PID-0040	25474-000-M6-QG-00090	Piping & Instrument Diagram CO2 Compressor 3rd Stage	0	11/14/2008 0:00
10112936-PB-P-PID-0041	25474-000-M6-QG-00100	Piping & Instrument Diagram CO2 Compressor 3rd Stage		
		Steam Generator And Intercooler	0	11/14/2008 0:00
10112936-PB-P-PID-0042	25474-000-M6-QG-00110	Piping & Instrument Diagram CO2 Surge Drum & Product		
		Send Out Pump	0	11/14/2008 0:00
10112936-PB-P-PID-0043	25474-000-M6-WP-00010			
		Piping & Instrument Diagram Absorber Makeup Water Pump	0	11/13/2008 0:00
10112936-PB-P-PID-0044	25474-000-M6-AB-00001	LP Steam System	0	11/13/2008 0:00
10112936-PB-P-PID-0045	25474-000-M6-AB-00002	LP Steam System	0	11/13/2008 0:00
10112936-PB-P-PID-0046	25474-000-M6-AB-00003	HP Steam System	0	11/13/2008 0:00
10112936-PB-P-PID-0047	25474-000-M6-PA-00001	Compressed Air System	0	11/13/2008 0:00
10112936-PB-P-PID-0048	25474-000-M6-PA-00002	Piping & Instrument Diagram Compressed Air System	0	11/13/2008 0:00
10112936-PB-P-PID-0049	25474-000-M6-PF-00001	Piping & Instrument Diagram Fire Protection System	0	11/13/2008 0:00
10112936-PB-P-PID-0050	25474-000-M6-PG-00001	Piping & Instrument Diagram Nitrogen Gas System	0	11/13/2008 0:00
10112936-PB-P-PID-0051	25474-000-M6-PW-00001	Piping & Instrument Diagram Potable Water System	0	11/13/2008 0:00
10112936-PB-P-PID-0052	25474-000-M6-SC-00001	Piping & Instrument Diagram LP Condensate System	0	11/13/2008 0:00
10112936-PB-P-PID-0053	25474-000-M6-WR-00001	Piping & Instrument Diagram Raw Water System	0	11/13/2008 0:00
10112936-PB-P-PID-0054	25474-000-M6-WL-00001	Piping & Instrument Diagram Seawater Cooling System	0	11/13/2008 0:00
10112936-PB-P-PID-0055	25474-000-M6-WL-00002	Piping & Instrument Diagram Seawater Cooling System	0	11/13/2008 0:00
10112936-PB-P-PID-0056	25474-000-M6-WL-00003	Piping & Instrument Diagram Seawater Cooling System	0	11/13/2008 0:00
10112936-PB-P-PID-0057	25474-000-M6-XW-00001	Piping & Instrument Diagram Amine Waste System	0	11/13/2008 0:00
10112936-PB-P-PID-0058	25474-000-M6-XW-00002	Piping & Instrument Diagram Waste Water System	0	11/13/2008 0:00
10112936-PB-P-PID-0059	25474-000-M6-WD-00001			
		Piping & Instrument Diagram Demineralized Water System	0	11/13/2008 0:00
10112936-PB-P-PID-0060	25474-000-M6-SB-00001	Piping & Instrument Diagram Auxiliary Boiler System	0	11/13/2008 0:00
10112936-PB-P-TDO-0001	25474-000-M4C-CN-00001			
		Calculation Cover Sheet - Capture Simulation - Normal Case	1	11/14/2008 0:00
10112936-PB-P-TDO-0002	25474-000-M4C-CN-00002	Calculation Cover Sheet - Column Flooding Factors	0	10/10/2008 0:00
10112936-PB-P-TDO-0003	25474-000-M4C-CN-00003			
		Calculation Cover Sheet - CO2 Absorber sizing calculations	1	11/19/2008 0:00
10112936-PB-P-TDO-0004	25474-000-M4C-CN-00004	Calculation Cover Sheet - Stripper Sizing Calculations	1	11/19/2008 0:00
10112936-PB-P-TDO-0005	25474-000-M4C-CN-00005	Calculation Cover Sheet - Vessel Sizing	0	10/10/2008 0:00

Client Document Number	Bechtel Document Number	Title	Revision	Date on Document
10112936-PB-P-TDO-0006	25474-000-M4C-CN-00006	Calculation Cover Sheet - Dosing Rate For Degraded MEA		
		Neutralization	0	10/10/2008 0:00
10112936-PB-P-TDO-0007	25474-000-M5A-CN-00001	Effluent Production	0	10/10/2008 0:00
10112936-PB-P-TDO-0008	25474-000-30R-M84G-00001	Cooling Philosophy Study	1	11/11/2008 0:00
10112936-PB-P-TDO-0009	25474-000-M4C-CN-00007			
		Calculation Cover Sheet - Heat Exchanger Fouling Factors	0	10/10/2008 0:00
10112936-PB-P-TDO-0010	25474-000-M5C-CN-00002	Calculation - Process Line Sizing	0	11/14/2008 0:00
10112936-PB-P-TDO-0011	25474-000-H1-0000-00002	Amine Emissions Abatement	0	11/12/2008 0:00
10112936-PB-P-TDO-0012	25474-000-30R-M01G-00001	Hydraulic and Mechanical Study of the Amine Tower and		
		Stripper Column Design	0	11/12/2008 0:00
10112936-PB-P-TDO-0013	25474-000-30R-M01G-00002	Depressurization and Draining Philosophy	0	11/12/2008 0:00
10112936-PB-P-TDO-0014	25474-000-30R-M01G-00003	Energy Consumption Optimization	0	11/14/2008 0:00
10112936-PB-P-TDO-0015	25474-000-30R-M01G-00005	Reliability, Availability, Maintainability Analysis (RAM)	0	12/15/2008 0:00
10112936-PB-P-TED-0001	25474-001-30R-G01G-00003	Karsto - FEED Contractor Technologies and References	1	10/23/2008 0:00
10112936-PB-P-TED-0002	25474-000-3YD-M18G-00001	Process Description	1	11/14/2008 0:00
10112936-PB-P-TED-0003	25474-000-3YD-MYAG-00002	Utility System Description	0	11/14/2008 0:00
10112936-PB-Q-PPL-0001	25474-001-GQP-GAQ-00003	Karsto - Plan for Examination	1	10/24/2008 0:00
10112936-PB-R-DAS-0001	25474-000-3SD-MBPD-00001	Mechanical Data Sheet for Auxiliary Boiler	0	12/5/2008 0:00
10112936-PB-R-DAS-0002	25474-000-3SD-MPVW-00001	Mechanical Data Sheet for Seawater Cooling Pumo	0	12/5/2008 0:00
10112936-PB-R-DAS-0003	25474-000-3SD-MPCG-00001	Mechanical Data Sheet for Seawater Cooling Booster Pump	0	12/5/2008 0:00
10112936-PB-R-DAS-0004	25474-000-3SD-MPGC-00001	Mechanical Data Sheet for LP Condensate Return Pump	0	12/5/2008 0:00
10112936-PB-R-DAS-0005	25474-000-3SD-MCRA-00001	Mechanical Data Sheet for Air Compressor	0	12/5/2008 0:00
10112936-PB-R-DAS-0006	25474-000-3SD-MCRA-00002	Mechanical Data Sheet for Air Dryer	0	12/5/2008 0:00
10112936-PB-R-PAL-0001	25474-000-M0X-0000-00001	Mechanical Equipment List	1	12/7/2008 0:00
10112936-PB-R-TDO-0001	25474-000-30R-M01G-00004	Driver Selection Study	0	11/11/2008 0:00
10112936-PB-R-TDO-0002	25474-000-G07-GPX-00001	Equipment Vendor References	1	12/22/2008 0:00
10112936-PB-R-TDO-0003	25474-000-M0X-0000-00005	Main Equipment Outlines & Weights	0	11/21/2008 0:00
10112936-PB-S-HSE-0001	25474-000-U0Y-0000-00001	Health Design Philosophy	0	10/10/2008 0:00
10112936-PB-S-HSE-0002	25474-000-U6D-CN-00001	Material Safety Data Sheets for Main Chemicals	0	10/10/2008 0:00
10112936-PB-S-HSE-0003	25474-000-U4R-0000-00001	HAZID Report	0	10/23/2008 0:00
10112936-PB-S-HSE-0004	25474-000-U6D-0000-00001	Discharge and Emissions Data Forms	0	11/11/2008 0:00
10112936-PB-S-HSE-0005	25474-000-H1-0000-00001	Emission Dispersion Parameters	0	11/15/2008 0:00
10112936-PB-S-HSE-0006	25474-000-U1Y-0000-00001	Fire & Explosion Strategy	0	11/28/2008 0:00
10112936-PB-S-HSE-0007	25474-000-U0Y-0000-00002	Occupational Health Area Charts	1	12/4/2008 0:00
10112936-PB-S-HSE-0008	25474-000-U0Y-0000-00003	Concept Occupational Health Impact Assessment	0	11/21/2008 0:00
10112936-PB-S-HSE-0009	25474-000-U3R-0000-00001	Layout Safety Review	1	12/4/2008 0:00
10112936-PB-S-HSE-0010	25474-000-U5Y-0000-00001	Hazardous Area Classification Drawing (Preliminary)	0	11/30/2008 0:00

Sorted by Client Document Number

## Karsto CCC Plant FEED Study Documents List

Client Document Number	Bechtel Document Number	Title	Revision	Date on Document
10112936-PB-S-HSE-0011	25474-000-U2-0000-00001	Escape Route Drawing General Arrangement Plan		
		(Preliminary) Sheet 1 of 5	0	12/5/2008 0:00
10112936-PB-S-HSE-0012	25474-000-U0Y-0000-00004	Coarse Noise Evaluation	1	12/22/2008 0:00
10112936-PB-S-HSE-0013	25474-000-U4R-0000-00003	HazOp Report	0	12/5/2008 0:00
10112936-PB-S-HSE-0014	25474-000-U7Y-0000-00001	Contribution to Quantitative Risk Analysis	0	12/5/2008 0:00
10112936-PB-S-HSE-0015	25474-000-U2Y-0000-00001	Escape, Evacuation, and Rescue Strategy	0	12/5/2008 0:00
10112936-PB-S-HSE-0016	25474-000-U2-0000-00002	Escape Route Drawing General Arrangement Plan		
		(Preliminary) Sheet 2 of 5	0	12/5/2008 0:00
10112936-PB-S-HSE-0017	25474-000-U2-0000-00003	Escape Route Drawing General Arrangement Plan		
		(Preliminary) Sheet 3 of 5	0	12/5/2008 0:00
10112936-PB-S-HSE-0018	25474-000-U2-0000-00004	Escape Route Drawing General Arrangement Plan		
		(Preliminary) Sheet 4 of 5	0	12/5/2008 0:00
10112936-PB-S-HSE-0019	25474-000-U2-0000-00005	Escape Route Drawing General Arrangement Plan		
		(Preliminary) Sheet 5 of 5	1	12/11/2008 0:00
Total number = 276				

Client Document Number	Bechtel Document Number	Title	Client Status Code	Response Status Open/ Closed	Creation Date	Associated Client Document Number	Document Submitted for I-Information C - Comment A - Approval
10112936-S-FIPB-P-0034	25474-000-G27-GZC-00074	Owner's Engineer Document Review Form - Cooling Philosophy Study	Code 3	Closed	11/11/2008 9:46	10112936-PB-P-TDO-0008	А
10112936-S-FIPB-C-0203	25474-000-G27-GZC-00268	Owner's Engineer Document Review Form - Conceptual Plan Control Workshop Store Building	Code 3	Closed	12/9/2008 11:29	10112936-PB-C-PLN-0005	А
10112936-S-FIPB-E-0066	25474-000-G27-GZC-00106	Owner's Engineer Document Review Form -Main Single Line Diagram	Code 3	Closed	11/14/2008 14:01	10112936-PB-E-DGM-0001	А
10112936-S-FIPB-E-0117	25474-000-G27-GZC-00108	Owner's Engineer Document Review - Electrical Power System Design Philosophy	Code 3	Closed	11/19/2008 14:59	10112936-PB-E-TED-0001	А
10112936-S-FIPB-E-0132	25474-000-G27-GZC-00109	Owner's Engineer Document Review - Basic Architecture and Specification for Integrated Switchgear Protection Owner's Engineer Document Review Form - Main	Code 3	Closed	11/19/2008 14:59	10112936-PB-E-TED-0003	A
10112936-S-FIPB-G-0188	25474-000-G27-GZC-00243	Equipment Layout Flue Gas Blower	Code 3	Closed	12/4/2008 9:58	10112936PB-G-DRW-0002	A
10112936-S-FIPB-G-0208	25474-000-G27-GZC-00245	Owner's Engineer Document Review Form - Layout drawings of main equipment - Main Equipment Layout Stripper Area CO2 Compressor Building	Code 3	Closed	12/4/2008 9:58	10112936-PB-G-DRW-0003	A
10112936-S-FIPB-G-0183	25474-000-G27-GZC-00242	Equipment Layout Control Workshop Store Building Switchgear Building Tank Farm Owner's Engineer Document Review Form -	Code 3	Closed	12/4/2008 9:58	10112936-PB-G-DRW-0004	A
10112936-S-FIPB-N-0146	25474-000-G27-GZC-00199	Description of Design Philosophy and Acceptance Criteria for Structural Desing	Code 3	Closed	11/25/2008 8:45	10112936-PB-N-TED-0001	А
10112936-S-FIPB-Q-0003	25474-000-G27-GZC-00050	Karsto - Owner's Engineering Document Review Form - Plan for Examination	Code 2	Closed	10/1/2008 11:35	10112936-PB-A-PAM-0001	А
10112936-S-FIPB-A-0011	25474-000-G27-GZC-00046	Karsto - Owner's Engineering Document Form - Mobilization Plan	Code 2	Closed	10/1/2008 11:35	10112936-PB-A-PPL-0001	А
10112936-S-FIPB-A-0052	25474-000-G27-GZC-00086	Owner's Engineer Document Review Form - Comminication Control Procedure (Coordination Procedure)	Code 2	Closed	11/5/2008 10:20	10112936-PB-A-PPR-0002	A
10112936-S-FIPB-Q-0002	25474-000-G27-GZC-00049	Karsto - Owner's Enginnering Document Review Form - Quality Plan	Code 2	Closed	10/1/2008 11:35	10112936-PB-A-QAP-0001	А
10112936-S-FIPB-E-0171	25474-000-G27-GZC-00118	Owner's Engineer Document Review - Main Single Line Diagram	Code 2	Closed	11/21/2008 12:30	10112936-PB-E-DGM-0001	А
10112936-S-FIPB-E-0050	25474-000-G27-GZC-00085	Owner's Engineer Document Review Form - Design Basis	Code 2	Closed	10/28/2008 14:06	10112936-PB-E-TED-0002	А
10112936-S-FIPB-P-0026	25474-000-G27-GZC-00062	Owner's Engineering Document Review Form - Lean Amine Cooling 1/2	Code 2	Closed	10/22/2008 14:28	10112936-PB-P-FLD-0004 - 0005	A
10112936-S-FIPB-G-0189	25474-000-G27-GZC-00244	Arrangement Plan	Code 2	Closed	12/4/2008 9:58	10112936-PB-G-DRW-0001	А
10112936-S-FIPB-I-0119	25474-000-G27-GZC-00120	Owner's Engineer Document Review - Continuous Gas Monitoring System - CGMS	Code 2	Closed	11/21/2008 12:30	10112936-PB-I-DRW-0003	А
10112936-S-FIPB-I-0059	25474-000-G27-GZC-00119	Owner's Engineer Document Review - Safety and Automation (SAS) operating and control philosophy	Code 2	Closed	11/21/2008 12:30	10112936-PB-I-TDO-0001	А

			Client	Response Status Open/		Associated Client Document	Document Submitted for I-Information
Client Document Number	Bechtel Document Number	Title	Code	Closed	Creation Date	Number	A - Approval
10112936-S-FIPB-P-0021	25474-000-G27-G7C-00064	Flow Diagram	Code 2	Closed	10/22/2008 14.42	10112936-PB-P-FLD-0001	А
		Owner's Engineering Document Review Form -	00002		10/22/2000 11112		
10112936-S-FIPB-P-0025	25474-000-G27-GZC-00063	Blower & Quench Section	Code 2	Closed	10/22/2008 14:33	10112936-PB-P-FLD-0003	А
		Owner's Engineering Document Review Form - Lean					
10112936-S-FIPB-P-0028	25474-000-G27-GZC-00061	Amine Cooling 1/2	Code 2	Closed	10/22/2008 14:23	10112936-PB-P-FLD-0006	A
		Owner's Engineering Document Review Form - Lean					
10112936-S-FIPB-P-0029	25474-000-G27-GZC-00060	Amine Cooling 2/2	Code 2	Closed	10/22/2008 14:19	10112936-PB-P-FLD-0007	A
		Owner's Engineering Document Review Form -		<u>.</u>			
10112936-S-FIPB-P-0030	25474-000-G27-GZC-00059	Stripper	Code 2	Closed	10/22/2008 14:12	10112936-PB-P-FLD-0008	A
		Owner's Engineering Document Review Form - Fresh	0.1.0	Cleard	40/00/0000 44:07		
10112936-S-FIPB-P-0031	25474-000-G27-G2C-00058	& Lean Amine Storage	Code 2	Closed	10/22/2008 14:07	10112936-PB-P-FLD-0009	A
10112026 S EIDB D 0022	25474-000 C27 C7C 00057	Comprossion & Drving 1/2	Codo 2	Closed	10/22/2008 12:57	10112036 PB P ELD 0010	٨
10112930-3-FIFB-F-0032	23474-000-027-020-00057	Owner's Engineering Document Review Form	Code 2	Ciuseu	10/22/2006 13.37	10112930-FB-F-FLD-0010	A
10112936-S-EIPB-P-0033	25474-000-G27-G7C-00056	Compression & Drving 2/2	Code 2	Closed	10/22/2008 13:48	10112936-PB-P-FI D-0011	Δ
10112300 0111 01 0000	20414 000 021 020 00000	Karsto - Owner's Engineering Document Review	00002	Closed	10/22/2000 10.40		
10112936-S-FIPB-A-0008	25474-000-G27-GZC-00045	Form - Coordination Procedure	Code 2	Closed	10/1/2008 11:16	10112936-PB-Z-PPR-0002	А
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-C-0231	25474-000-G27-GZC-00270	Architectural descriptions and design reports	Code 2	Closed	12/9/2008 11:29	10112936-PB-C-DOC-0001	С
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-C-0017	25474-000-G27-GZC-00070	Defination of architectural design premises	Code 2	Closed	10/27/2008 16:07	10112936-PB-C-TED-0001	С
		Owner's Engineering Document Review Form -					
		Description of design philosophy and acceptance					
10112936-S-FIPB-C-0015	25474-000-G27-GZC-00069	criteria for civil works	Code 2	Closed	10/27/2008 15:34	10112936-PB-C-TED-0002	С
		Owner's Engineer Document Review - Description					
		and drawings of site preparation and leveling		<u>.</u>			
10112936-S-FIPB-C-0145	25474-000-G27-GZC-00191	requirements	Code 2	Closed	11/21/2008 15:30	10112936-PB-C-TED-0003	С
	05 474 000 007 070 00040	Owner's Engineer Document Review Form -	0.1.0	Cleard	40/5/0000 0.55		0
10112936-S-FIPB-C-0205	25474-000-G27-G2C-00248	Ductwork Foundation Plan	Code 2	Closed	12/5/2008 9:55	10112936-PB-C-TED-0006-7-8	U
		Plant Foundation Plan with typical sections and				10112036 PB C TED 0000 10 11	
10112036-S-FIPB-C-0212	25474-000-027-070-00249	details	Code 2	Closed	12/5/2008 0.55	-12	C
10112330-0-1 II D-0-0212	23474-000-027-020-00249	Owner's Engineer Document Review Form -		Ciused	12/3/2000 9.33	-12	U
		Arrangement of underground structural design					
10112936-S-FIPB-C-0222	25474-000-G27-GZC-00250	(caverns and tunels)	Code 2	Closed	12/5/2008 9:55	10112936-PB-C-TED-0014-15	С
		Karsto - Owner's Engineer Document Review - Risk					
10112936-S-FIPB-G-0005	25474-000-G27-GZC-00044	Management Plan	Code 2	Closed	9/30/2008 11:30	10112936-PB-G-DOC-0001	С
		Owner's Engineer Document Review Form - Cause					
10112936-S-FIPB-I-0220	25474-000-G27-GZC-00260	and Effect Diagrams	Code 2	Closed	12/5/2008 14:31	10112936-PB-I-DGM-0001-2	С
		Owner's Engineer Document Review - Narrative of					
		proposed SAS including system architecture drawing				10112936-PB-I-DRW-0001 and -	
10112936-S-FIPB-I-0162	25474-000-G27-GZC-00121	(SAS Topology)	Code 2	Closed	11/21/2008 12:30	0002	С
		Owner's Engineer Document Review Form - Central					
10112936-S-FIPB-I-0185	25474-000-G27-GZC-00257	Control Room Concetual Layour	Code 2	Closed	12/5/2008 14:31	10112936-PB-I-DRW-0004	С
		Owner's Engineer Document Review Form -	0.1.0	Cleard	40/5/0000 0 55		
10112936-S-FIPB-O-0211	25474-000-627-620-00254	Operation and Maintenance philosophy	Code 2	Closed	12/5/2008 9:55	10112936-PB-O-DOC-0003	C

Client Document Number	Bechtel Document Number	Title	Client Status Code	Response Status Open/ Closed	Creation Date	Associated Client Document Number	Document Submitted for I-Information C - Comment A - Approval
10112036-S-FIPB-0-0200	25474-000-027-070-00253	Owner's Engineer Document Review Form -	Code 2	Closed	12/5/2008 0.55	10112936-PB-O-DOC-0004	C
	23414 000 021 020 00205	Owner's Engineering Document Review Form - Heat	00002	010000	12/0/2000 3:00		Ŭ
10112936-S-FIPB-P-0051	25474-000-G27-GZC-00054	and Mass Balance Diagram	Code 2	Closed	10/22/2008 13:00	10112936-PB-P-HMB-0001 -0002	С
		Karsto - Owner's Engineering Document Review					
10112936-S-FIPB-P-0009	25474-000-G27-GZC-00048	Form - Technologies and References	Code 2	Closed	10/1/2008 11:35	10112936-PB-P-TED-0001	С
		Owner's Engineering Document Review Form -					
10112936-S-FIPB-P-0019	25474-000-G27-GZC-00065	Process Description	Code 2	Closed	10/22/2008 14:53	10112936-PB-P-TED-0001	С
		Owner's Engineering Document Review Form -			10/01/0000 10 00		0
10112936-S-FIPB-S-0016	25474-000-G27-G2C-00067	Health Design Philosophy	Code 2	Closed	10/24/2008 13:28	10112936-PB-S-HSE-0001	C
10112026 S EIPB S 0174	25474 000 627 676 00261	Owner's Engineer Document Review Form -	Codo 2	Closed	12/5/2008 14:21	10112036 PB S HSE 0007	C
10112930-3-11FB-3-0174	23474-000-027-020-00201	Owner's Engineer Document Review Form - Layout		Closed	12/3/2000 14.31	10112930-FB-3-H3E-0007	C
10112936-S-FIPB-S-0219	25474-000-G27-G7C-00262	Safety Review Report	Code 2	Closed	12/5/2008 14:31	10112936-PB-S-HSE-0009	С
			00002	0.0000	12/0/2000 1 1101		Ŭ
		Owner's Engineer Document Review Form - Noise					
10112936-S-FIPB-S-0175	25474-000-G27-GZC-00246	and vibration assessment (Coarse noise evaluation)	Code 2	Closed	12/4/2008 9:58	10112936-PB-S-HSE-0012	С
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-S-0123	25474-000-G27-GZC-00235	Emission Dispersion Parameters	Code 1	Closed	12/2/2008 17:07	10112936-PB-S-HSE-0005	С
		Owner's Engineer Document Review Form - CCS					
10112936-S-FIPB-P-0035	25474-000-G27-GZC-00075	Simulation Normal Case	Code 2	Closed	10/27/2008 18:17	10112936-PB-P-TDO-0001	
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-G-0053	25474-000-G27-GZC-00087	Mobilization Plan	Code 2	Closed	11/5/2008 10:20	10112936-PB-G-PPL-0001	
		Owner's Engineer Document Review Form - Vessel		Classed	40/00/0000 0.00		
10112936-S-FIPB-P-0036	25474-000-G27-G2C-00076	Data Sheet (Absorber)	Code 2	Closed	10/28/2008 9:06	10112936-PB-P-DAS-0001	1
10112026 S EIDB D 0027	25474 000 027 070 00077	Absorber Internale	Codo 2	Closed	10/20/2000 0.16	10112036 PB P DAS 0002	
10112936-S-FIPB-P-0037	25474-000-G27-G2C-00077	Absoluter Internals	Code 2	Closed	10/26/2006 9:16	10112930-FB-F-DA3-0002	· ·
10112036-S-FIPB-P-0038	25474-000-627-676-00078	Rich Amine heat Exchangers	Code 2	Closed	10/28/2008 10.44	10112036-PB-P-DAS-0003	1
10112330-0-1 II D-1 -0030	23474-000-027-020-00070	Owner's Engineer Document Review Form - Vessel		Ciosed	10/20/2000 10.44	10112330-1 D-1 -DAS-0003	
10112936-S-FIPB-P-0039	25474-000-G27-GZC-00079	Data Sheet (Stripper)	Code 2	Closed	10/28/2008 10:54	10112936-PB-P-DAS-0004	1
		Owner's Engineer Document Review Form - Stripper	00002	0.0000	10,20,2000 1010 1		
10112936-S-FIPB-P-0040	25474-000-G27-GZC-00080	Internals	Code 2	Closed	10/28/2008 10:59	10112936-PB-P-DAS-0005	1
		Owner's Engineering Document Review Form -					
10112936-S-FIPB-P-0041	25474-000-G27-GZC-00055	Compressor	Code 2	Closed	10/28/2008 11:29	10112936-PB-P-DAS-0006	I
10112936-S-FIPB-P-0042	25474-000-G27-GZC-00081	Owner's Engineer Document Review Form - Blowers	Code 2	Closed	10/28/2008 13:24	10112936-PB-P-DAS-0007	1
		Owner's Engineer Document Review Form - Flue					
10112936-S-FIPB-P-0043	25474-000-G27-GZC-00082	Gas Water Fogger System	Code 2	Closed	10/28/2008 13:32	10112936-PB-P-DAS-0008	I
		Owner's Engineer Document Review Form -					.
10112936-S-FIPB-P-0045	25474-000-G27-GZC-00083	Absorber Sizing Calculations	Code 2	Closed	10/28/2008 13:50	10112936-PB-P-1DO-0003	
	25 474 000 007 070 0000 4	Contractions Colouidations	Code O	Closed	10/00/0000 40 57		
10112936-S-FIPB-P-0046	25474-000-G27-G2C-00084	Sizing Calculations	Code 2	Closed	10/28/2008 13:57	10112936-PB-P-1DO-0004	
10112026 S EIDB D 0121	25474 000 627 676 00169	Vendor References	Codo 2	Closed	11/21/2008 12:20	10112936-PB-R-TDO-0002	
10112330-3-11F B-F-0131	23717-000-021-020-00108	Owner's Engineer Document Poviow Form		No action	11/21/2000 12.30		· ·
10112936-S-FIPB-A-0027	25474-000-627-676-00089	Description of Risk Management System	Code 1	required	11/6/2008 14.06	10112936-PB-A-GEA-0001	Δ
	0		1-000 .		1.76,2000 11.00		

Client Document Number	Bechtel Document Number	Title	Client Status Code	Response Status Open/ Closed	Creation Date	Associated Client Document	Document Submitted for I-Information C - Comment
		Karsto - Owner's Engineer Document Review - HSE	0000	No action	oroalion Balo		
10112936-S-FIPB-S-0013	25474-000-G27-GZC-00043	Plan	Code 1	required	10/9/2008 13:44	10112936-PB-A-HSE-0001	A
		Karsto - Owner's Engineering Document Review		No action			
10112936-S-FIFR-Q-0004	25474-000-G27-GZC-00051	Form - Plan for Quality Audits and Surveillance	Code 1	required	10/1/2008 11:35	10112936-PB-A-QAR-0001	A
	05474 000 007 070 00005	Owner's Engineer Document Review Form -		No action	10/0/0000 11 00		
10112936-S-FIPB-C-0200	25474-000-G27-G2C-00265	Conceptual Plan Flue Gas Blower Building	Code 1	required	12/9/2008 11:29	10112936-PB-C-PLN-0002	A
		Concentual Elevations Control Workshop Store		No action			
10112936-S-FIPB-C-0204	25474-000-G27-G7C-00269	Building	Code 1	required	12/9/2008 11.29	10112936-PB-C-PLN-0006	Δ
10112330-3-1 II B-8-0204	23474-000-027-020-00203	Owner's Engineer Document Review Form -	Code i	No action	12/3/2000 11.23	10112330-1 B-C-1 EN-0000	
10112936-S-FIPB-C-0159	25474-000-G27-GZC-00198	Defination of Architectural Design Premises	Code 1	required	11/25/2008 8:45	10112936-PB-C-TED-0001	А
		Owner's Engineer Document Review - Description of					
		design philosophy and acceptance criteria for civil		No action			
10112936-S-FIPB-C-0160	25474-000-G27-GZC-00192	works	Code 1	required	11/21/2008 15:30	10112936-PB-C-TED-0002	А
		Owner's Engineer Document Review Form - Main		No action			
10112936-S-FIPB-E-0214	25474-000-G27-GZC-00233	Single Line Diagram	Code 1	required	12/2/2008 16:38	10112936-PB-E-DGM-0001	А
		Owner's Engineer Document Review Form - DC and		No action			
10112936-S-FIPB-E-0215	25474-000-G27-GZC-00225	UPS Single Line Diagram	Code 1	required	12/2/2008 16:15	10112936-PB-E-DGM-0002	A
		Owner's Engineer Document Review Form - Basic					
		architecture and specification for integrated		No action			
10112936-S-FIPB-E-0217	25474-000-G27-GZC-00227	switchgear protection and control system	Code 1	required	12/2/2008 16:15	10112936-PB-E-TED-0003	A
		Owner's Engineer Document Review Form -Main		No action			
10112936-S-FIPB-G-0284	25474-000-G27-GZC-00324	Equipment Layout Flue Gas Blower	Code 1	required	12/23/2008 9:50	10112936-PB-G-DRW-0002	A
		Owner's Engineer Document Review Form - Layout		No option			
10112026 C FIDD C 0295	25474 000 007 070 00005	drawings of main equipment - Main Equipment	Code 1	No action	10/00/0000 0.50	10112026 DB C DBW 0002	^
10112936-S-FIPB-G-0285	25474-000-G27-G2C-00325	Cayout Supper Area -CO2	Code I	required	12/23/2008 9:50	10112936-PB-G-DRW-0003	A
		Equipment Layout Control Workshop Store Building		No action			
10112036-S-FIPB-C-0286	25474-000-627-676-00326	Switchgear Building Tank Farm	Code 1	required	12/23/2008 0.50	10112936-PB-G-DRW-0004	Δ
10112330-0-1 II D-0-0200	23474-000-027-020-00320	Owner's Engineer Document Review Form -	Code I	required	12/23/2000 9.30		
		Description to design philosophy and acceptance		No action			
10112936-S-FIPB-N-0213	25474-000-G27-GZC-00289	criteria for structural design	Code 1	required	12/11/2008 10:29	10112936-PB-N-TED-0001	А
		Owner's Engineer Document Review Form - Block		No action			
10112936-S-FIPB-P-0078	25474-000-G27-GZC-00210	Flow Diagram	Code 1	required	12/2/2008 10:42	10112936-PB-P-FLD-0001	А
		Owner's Engineering Document Review Form -		No action			
10112936-S-FIPB-P-0024	25474-000-G27-GZC-00066	Symbols & Legends	Code 1	required	10/24/2008 13:28	10112936-PB-P-FLD-0002	A
		Owner's Engineer Document Review - PFD Absorber		No action		10112936-PB-P-FLD-0004,	
10112936-S-FIPB-P-0150	25474-000-G27-GZC-00181	T101 and T102	Code 1	required	11/21/2008 12:30	10112936-PB-P-FLD-0005	A
		Owner's Engineer Document Review - PFD Lean		No action			
10112936-S-FIPB-P-0154	25474-000-G27-GZC-00184	Amine Cooling 2/2	Code 1	required	11/21/2008 12:30	10112936-PB-P-FLD-0007	A
				No action			
10112936-S-FIPB-P-0155	25474-000-G27-GZC-00185	Owner's Engineer Document Review - PFD Stripper	Code 1	required	11/21/2008 12:30	10112936-PB-P-FLD-0008	A
		Owner's Engineer Document Review - PFD Fresh &		No action			
10112936-S-FIPB-P-0156	25474-000-G27-GZC-00186	Lean Amine Storage	Code 1	required	11/21/2008 12:30	10112936-PB-P-FLD-0009	A
	05474 000 007 070 00107	Owner's Engineer Document Review - PFD	Code 4	NO action	44/04/0000 40.00		
10112936-S-FIPB-P-0157	25474-000-G27-G2C-00187	Compression & Drying 1/2	Code 1	required	11/21/2008 12:30	10112930-PB-P-FLD-0010	A

Client Document Number	Bechtel Document Number	Title	Client Status Code	Response Status Open/ Closed	Creation Date	Associated Client Document	Document Submitted for I-Information C - Comment
		Owner's Engineer Document Review - PFD	0000	No action	Croation Bato	Humbor	n npprovar
10112936-S-FIPB-P-0158	25474-000-G27-GZC-00188	Compression & Drying 2/2	Code 1	required	11/21/2008 12:30	10112936-PB-P-FLD-0011	Α
		Owner's Engineer Document Review - PFD Process		No action			
10112936-S-FIPB-P-0151	25474-000-G27-GZC-00182	Water System	Code 1	required	11/21/2008 12:30	10112936-PB-P-FLD-0012	A
		Owner's Engineer Document Review - Seawater		No action			
10112936-S-FIPB-P-0110	25474-000-G27-GZC-00163	Cooling System	Code 1	required	11/21/2008 12:30	10112936-PB-P-FLD-0013	A
		Owner's Engineer Document Review - LP		No action			
10112936-S-FIPB-P-0109	25474-000-G27-GZC-00162	Condensate Return System	Code 1	required	11/21/2008 12:30	10112936-PB-P-FLD-0014	A
		Owner's Engineer Document Review - P&ID Symbols	0.1.4	No action	44/04/0000 40.00		
10112936-S-FIPB-P-0114	25474-000-G27-G2C-00167	and Legends	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0001	A
	05474 000 007 070 00404	Owner's Engineer Document Review - P&ID Symbols	0.1.4	No action	44/04/0000 40:00		•
10112936-S-FIPB-P-0111	25474-000-G27-G2C-00164	and Legends	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0002	A
	05474 000 007 070 00405	Owner's Engineer Document Review - P&ID Symbols	0.1.4	No action	44/04/0000 40:00		•
10112936-S-FIPB-P-0112	25474-000-G27-G2C-00165	and Legends	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0003	A
		Owner's Engineer Document Review - P&ID Symbols		No action	44/04/0000 40.00		
10112936-S-FIPB-P-0103	25474-000-G27-G2C-00156	and Legends	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0004	A
	05474 000 007 070 00400	Owner's Engineer Document Review - P&ID Symbols	0.1.4	No action	44/04/0000 40.00		
10112936-S-FIPB-P-0107	25474-000-G27-GZC-00160	and Legends	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0005	A
		Owner's Engineer Document Review - P&ID		No action			
10112936-S-FIPB-P-0083	25474-000-G27-GZC-00137	Absorber 2 Rich Amine Pumps	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0010	A
		Owner's Engineer Document Review - P&ID Heat		No action		10112936-PB-P-PID-0015 through	
10112936-S-FIPB-P-0072	25474-000-G27-GZC-00127	Exchangers Sheet 1-4 of 4	Code 1	required	11/21/2008 12:30	-0018	A
		Owner's Engineer Document Review - P&ID Semi		No action			
10112936-S-FIPB-P-0081	25474-000-G27-GZC-00135	Lean Amine and Rich Amine Heat Exchanger	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0019	A
		Owner's Engineer Document Review - P&ID Side		No action			
10112936-S-FIPB-P-0080	25474-000-G27-G2C-00134	Stream Filters	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0020	A
		Owner's Engineer Document Review - P&ID Flash		No action			
10112936-S-FIPB-P-0073	25474-000-G27-GZC-00128	Feed Heaters	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0021	A
	05474 000 007 070 00400	Owner's Engineer Document Review - P&ID Semi-	0.1.4	No action	44/04/0000 40.00		
10112936-S-FIPB-P-0074	25474-000-G27-GZC-00129	Lean Amine Flash System	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0022	A
		Owner's Engineer Document Review - P&ID Stripper		No action			
10112936-S-FIPB-P-0084	25474-000-G27-GZC-00138	Reboiler	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0026, 0027	A
		Owner's Engineer Document Review - P&ID Lean	0.1.4	No action	44/04/0000 40.00		
10112936-S-FIPB-P-0086	25474-000-G27-GZC-00140		Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0028	A
		Owner's Engineer Document Review - P&ID CO2	0.1.4	No action	44/04/0000 40.00		
10112936-S-FIPB-P-0136	25474-000-G27-GZC-00172	Compressor 1st Stage-Interstage Knockout Drum	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0035	A
				N			
		Owner's Engineer Document Review - P&ID CO2		No action			
10112936-S-FIPB-P-0139	25474-000-G27-GZC-00175	Compressor 2nd stage Interstage Knock-Out Drum	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0038	A
		Owner's Engineer Document Review - P&ID		No action			
10112936-S-FIPB-P-0079	25474-000-G27-GZC-00133	Absorber Makeup Water Pump	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0043	A
		Owner's Engineer Document Review - P&ID LP		No action	44/04/0200 10		
10112936-S-FIPB-P-0105	25474-000-G27-GZC-00158	Steam System 2	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0045	A
		Owner's Engineer Document Review - P&ID		No action			
10112936-S-FIPB-P-0102	25474-000-G27-GZC-00155	Compressed Air System 1	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0047	A
		Owner's Engineer Document Review - P&ID Fire		No action	44/04/0200 10		
10112936-S-FIPB-P-0098	25474-000-G27-GZC-00151	Protection System	Code 1	required	11/21/2008 12:30	10112936-PB-P-PID-0049	A

Client Document Number	Bechtel Document Number	Title	Client Status Code	Response Status Open/ Closed	Creation Date	Associated Client Document Number	Document Submitted for I-Information C - Comment A - Approval
10112936-S-FIPB-P-0093	25474-000-G27-GZC-00146	Owner's Engineer Document Review - P&ID Auxiliary Boiler System	Code 1	No action required	11/21/2008 12:30	10112936-PB-P-PID-0060	А
10112936-S-FIPB-Q-0057	25474-000-G27-GZC-00092	Owner's Engineer Document Review Form - Plan for Examination	Code 1	No action required	11/6/2008 14:07	10112936-PB-Q-PPL-0001	A
10112936-S-FIPB-Q-0056	25474-000-G27-GZC-00091	Owner's Engineer Document Review Form - Project Quality Plan	Code 1	No action required	11/6/2008 14:07	10112936-PB-Q-QAP-0001	А
10112936-S-FIPB-S-0266	25474-000-G27-GZC-00342	Owner's Engineer Document Review Form -HAZOP (Hazard and Operability) report	Code 1	No action required	12/23/2008 9:50	10112936-PB-S-HSE-0013	А
10112936-S-FIPB-C-0232	25474-000-G27-GZC-00271	Architectural Analysis	Code 1	No action required	12/9/2008 11:29	10112936-PB-C-DOC-0002	с
10112936-S-FIPB-C-0182	25474-000-G27-GZC-00264	Durner s Engineer Document Review Form - Area plan for such defined Main area	Code 1	required	12/9/2008 11:29	10112936-PB-C-PLN-0007	с
10112936-S-FIPB-C-0193	25474-000-G27-GZC-00288	Owner's Engineer Document Review Form - Description and drawings of site preparation and leveling requirements	Code 1	No action required	12/11/2008 10:29	10112936-PB-C-TED-0003	С
10112936-S-FIPB-C-0225	25474-000-G27-GZC-00300	Owner's Engineer Document Review Form - Descriptions and drawings of drainage and underground pressurized piping	Code 1	No action required	12/16/2008 9:15	10112936-PB-C-TED-0004	С
10112026 S EIPB C 0252	25474 000 627 676 00272	Owner's Engineer Document Review Form - Description and Drawings of Structural Design Requirements for Buildings	Code 1	No action	12/0/2008 11:20	10112036-PB-C-TED-0016	C
10112936-S-FIPB-H-0118	25474-000-G27-GZC-00212	Owner's Engineer Document Review Form - HVAC Design and Control Philosophy	Code 1	No action required	12/9/2008 11:29	10112936-PB-H-TED-0001	c
10112936-S-FIPB-I-0287	25474-000-G27-GZC-00344	Owner's Engineer Document Review Form -Cause and Effect Diagrams	Code 1	No action required	1/9/2009 8:01	10112936-PB-I-DGM-0001-0002	с
10112936-S-FIPB-I-0288	25474-000-G27-GZC-00345	Owner's Engineer Document Review Form -Narrative of proposed SAS	Code 1	No action required	1/9/2009 8:01	10112936-PB-I-DRW-0002	С
10112936-S-FIPB-I-0190	25474-000-G27-GZC-00258	Owner's Engineer Document Review Form - Instrument Earthing Philosophy	Code 1	No action required	12/5/2008 14:31	10112936-PB-I-TDO-0002	с
10112936-S-FIPB-I-0173	25474-000-G27-GZC-00256	Owner's Engineer Document Review Form - Description of F&G Monitoring and Alarm System incl. block diagram	Code 1	No action required	12/5/2008 14:31	10112936-PB-I-TED-0001	С
10112936-S-FIPB-L-0207	25474-000-G27-GZC-00251	Owner's Engineer Document Review Form - Piping Arrangement - Overall Piping Plan	Code 1	No action required	12/5/2008 9:55	10112936-PB-L-DRW-0001-2-3-4- 5-6-7-8	С
10112936-S-FIPB-L-0251	25474-000-G27-GZC-00329	Owner's Engineer Document Review Form - LCC Pipe Design	Code 1	No action required	12/23/2008 9:50	10112936-PB-L-TED-0003	с
10112936-S-FIPB-N-0163	25474-000-G27-GZC-00252	Owner's Engineer Document Review Form - Typical drawings of outfitting structural steel (ladders, handrails, grating, platforms, connections)	Code 1	No action required	12/5/2008 9:55	10112936-PB-N-DRW-0001,-2,-3,- 4	С
10112936-S-FIPB-O-0293	25474-000-G27-GZC-00336	Owner's Engineer Document Review Form - Operation and Maintenance philosophy	Code 1	No action required	12/23/2008 9:50	10112936-PB-O-DOC-0003	с
10112936-S-FIPB-O-0294	25474-000-G27-GZC-00337	Owner's Engineer Document Review Form - Operating staff concept	Code 1	No action required	12/23/2008 9:50	10112936-PB-O-DOC-0004	с
10112936-S-FIPB-O-0258	25474-000-G27-GZC-00335	consumables	Code 1	required	12/23/2008 9:50	10112936-PB-O-DOC-0001	С

			Client Status	Response Status Open/		Associated Client Document	Document Submitted for I-Information C - Comment
Client Document Number	Bechtel Document Number	Title	Code	Closed	Creation Date	Number	A - Approval
10112936-S-FIPB-P-0126	25474-000-G27-GZC-00211	Emissions Abatement	Code 1	No action required	12/2/2008 12:56	10112936-PB-P-TDO-011	C
		Owner's Engineer Document Review Form - FEED		No action	12/2/2000 12:00		Ū.
10112936-S-FIPB-P-0055	25474-000-G27-GZC-00090	Contractor Technologies & References	Code 1	required	11/6/2008 14:07	10112936-PB-P-TED-0001	С
		Owner's Engineer Document Review Form - Driver		No action			
10112936-S-FIPB-R-0061	25474-000-G27-GZC-00094	Selection Study	Code 1	required	11/12/2008 10:35	10112936-PB-R-TDO-0001	С
		Owner's Engineering Document Review Form -		No action			_
10112936-S-FIPB-S-0018	25474-000-G27-GZC-00068	Material Safety Data Sheets for main chemicals	Code 1	required	10/24/2008 13:28	10112936-PB-S-HSE-0002	С
		Owner's Engineer Document Review Form -		No action	40/0/0000 47 07		0
10112936-S-FIPB-S-0122	25474-000-G27-G2C-00234	Discharge and Emissions Data Forms	Code 1	required	12/2/2008 17:07	10112936-PB-S-HSE-0004	C
10112026 S EIDB S 0280	25474 000 027 070 00212	Owner's Engineer Document Review Form -	Code 1	No action	12/10/2000 15:20	10112026 DB S HSE 0007	C
10112930-3-FIFB-3-0269	25474-000-027-020-00313	Owner's Engineer Document Review Form - Layout	Code I	No action	12/10/2000 15.20	10112930-FB-3-H3E-0007	C
10112936-S-FIPB-S-0290	25474-000-G27-G7C-00314	Safety Review Report	Code 1	required	12/18/2008 15:28	10112936-PB-S-HSE-0009	C
10112330 0111 0 0230		Owner's Engineer Document Review Form - Farthing	00001	No action	12/10/2000 10:20	101123001 8 8 1162 0003	0
10112936-S-FIPB-E-0242	25474-000-G27-GZC-00308	and lightning protection plans	Code 1	required	12/18/2008 15:28	10112936-PB-E-TDO-0011	1
		Owner's Engineer Document Review Form -Process		No action			
10112936-S-FIPB-P-0295	25474-000-G27-GZC-00339	Calculations (HX Fouling Factors)	Code 1	required	12/23/2008 9:50	10112936-PB-P-TDO-0009	I.
10112936-S-FIPB-P-0147	25474-000-G27-GZC-00110	Owner's Engineer Document Review - Cooling Philosophy Study	Code 2		11/19/2008 14:59	10112936-PB-B-TDO-0008	А
10112936-S-FIPB-C-0201	25474-000-G27-GZC-00266	Owner's Engineer Document Review Form - Conceptual Plan CO2 Compressor Builiding	Code 2		12/9/2008 11:29	10112936-PB-C-PLN-0003	А
10112936-S-FIPB-C-0202	25474-000-G27-GZC-00267	Owner's Engineer Document Review Form - Conceptual Plan Electrical Switchgear Building	Code 2		12/9/2008 11:29	10112936-PB-C-PLN-0004	А
10112936-S-FIPB-C-0292	25474-000-G27-GZC-00322	Owner's Engineer Document Review Form - Conceptual Plan Control Workshop Store Building	Code 2		12/23/2008 9:50	10112936-PB-C-PLN-0005	A
10112936-S-FIPB-E-0067	25474-000-G27-GZC-00104	UPS Single Line Diagram	Code 2		11/14/2008 14:01	10112936-PB-E-DGM-0002	А
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-E-0216	25474-000-G27-GZC-00226	Electrical Power System Design Philosophy	Code 2		12/2/2008 16:15	10112936-PB-E-TED-0001	А
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-E-0223	25474-000-G27-GZC-00241	Electrical Power System Design Philosophy	Code 2		12/4/2008 9:58	10112936-PB-E-TED-0001	A
	05 174 000 007 070 00001	Owner's Engineer Document Review Form - Process	O a d a O		40/0/0000 40:00		•
10112936-S-FIPB-P-0148	25474-000-G27-G2C-00231	Description	Code 2		12/2/2008 16:38	10112936-PB-E-TED-0002	A
10112026 S EIDB 1 0250	25474 000 627 676 00328	And Application of Valvos	Codo 2		12/22/2008 0.50	10112036 DB L TED 0002	^
10112930-3-1 IF B-E-0230	23474-000-027-020-00328	Owner's Engineer Document Review Form -	Coue 2		12/23/2000 9.30	10112330-FB-E-1ED-0002	~
10112936-S-FIPB-O-0253	25474-000-G27-GZC-00330	Mechanical testing and completion schedule	Code 2		12/23/2008 9:50	10112936-PB-O-DOC-0005	А
		Owner's Engineer Document Review Form - Cold	00002		12,20,2000 0100		
10112936-S-FIPB-O-0254	25474-000-G27-GZC-00331	commissioning schedule	Code 2		12/23/2008 9:50	10112936-PB-O-DOC-0006	А
		Owner's Engineer Document Review Form -Hot					
10112936-S-FIPB-O-0255	25474-000-G27-GZC-00332	commissioning schedule	Code 2		12/23/2008 9:50	10112936-PB-O-DOC-0007	A
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-O-0256	25474-000-G27-GZC-00333	Performance Guarantee Test procedure	Code 2		12/23/2008 9:50	10112936-PB-O-DOC-0008	A
10112936-S-FIPB-P-0104	25474-000-027-070-00157	Owner's Engineer Document Review - P&ID Flue	Code 2		11/21/2008 12.20	10112936-PB-P-DCM-0001	Δ
10112000 0111 0-1-0104	2011 - 000 021-020-00101	040 0301011	0000 Z	1	1721/2000 12.30	101120001 D1 D0IW-0001	~

			Client	Response Status Open/		Associated Client Document	Document Submitted for I-Information
Client Document Number	Bechtel Document Number	Title	Code	Closed	Creation Date	Number	A - Approval
10112936-S-FIPB-P-0108	25474-000-G27-G7C-00161	Owner's Engineer Document Review - P&ID Flue Gas System	Code 2		11/21/2008 12:30	10112936-PB-P-DGM-0002	Δ
		Owner's Engineer Document Review - PFD Blower &	00002		11/21/2000 12:00		~~~~~
10112936-S-FIPB-P-0149	25474-000-G27-GZC-00180	Quench Section	Code 2		11/21/2008 12:30	10112936-PB-P-FLD-0003	Α
		Owner's Engineer Document Review - PFD Lean					
10112936-S-FIPB-P-0153	25474-000-G27-GZC-00183	Amine Cooling 1/2	Code 2		11/21/2008 12:30	10112936-PB-P-FLD-0006	A
	05 474 000 007 070 00400	Owner's Engineer Document Review - Common to all			44/04/0000 40:00		•
10112936-S-FIPB-P-0172	25474-000-G27-G2C-00189	P&IDS Owner's Engineer Decument Review - R&D CO2	Code 2		11/21/2008 12:30	10112936-PB-P-PID 10112036 PB P PID 0006 and	A
10112936-S-FIPB-P-0062	25474-000-G27-G7C-00122	Absorber T-101 and T-102 Amine Section	Code 2		11/21/2008 12:30	0011	Δ
		Owner's Engineer Document Review - P&ID	00002		11/21/2000 12:00		~~~~~
		Wash_Water_Cooling_Section Absorbers T-101 and				10112936-PB-P-PID-0007 and	
10112936-S-FIPB-P-0063	25474-000-G27-GZC-00123	T-102	Code 2		11/21/2008 12:30	0012	A
		Owner's Engineer Document Review - P&ID				10112936-PB-P-PID-0008 and	
10112936-S-FIPB-P-0064	25474-000-G27-GZC-00124	Absorber_1_Wash_Water	Code 2		11/21/2008 12:30	0013	A
		Owner's Engineer Document Review - P&ID					
10112936-S-FIPB-P-0065	25474-000-G27-G2C-00125	Absorber 1 Rich Amine Pumps	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0009	A
10112036-S-FIPB-P-0071	25474-000-627-676-00126	Amine Cooling System	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0014	۵
10112330-5-111 D-1-0071	23474-000-027-020-00120	Owner's Engineer Document Review - P&ID Amine			11/21/2000 12:30		Λ
10112936-S-FIPB-P-0075	25474-000-G27-GZC-00130	Stripper Packed Section	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0023	А
		Owner's Engineer Document Review - P&ID Amine					
10112936-S-FIPB-P-0076	25474-000-G27-GZC-00131	Stripper Trayed Section	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0024	A
		Owner's Engineer Document Review - P&ID Stripper					
10112936-S-FIPB-P-0082	25474-000-G27-GZC-00136	Reflux Section	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0025	A
	05 474 000 007 070 00400	Owner's Engineer Document Review - P&ID Amine			44/04/0000 40:00		•
10112936-S-FIPB-P-0085	25474-000-G27-G2C-00139	Owner's Engineer Decument Poview - P&D	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0029	A
10112936-S-FIPB-P-0088	25474-000-G27-G7C-00141	Chemical Feed Package	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0030	Δ
		Owner's Engineer Document Review - P&ID Fresh &	00002		11/21/2000 12:00		~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
10112936-S-FIPB-P-0077	25474-000-G27-GZC-00132	Lean Amine Storage	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0031	А
		Owner's Engineer Document Review - P&ID CO2					
10112936-S-FIPB-P-0133	25474-000-G27-GZC-00169	Compress Suction Drum	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0032	A
		Owner's Engineer Document Review - P&ID CO2					
10112936-S-FIPB-P-0134	25474-000-G27-G2C-00170	Compressor-1st Stage	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0033	A
		Compressor 1st Stage-Steam Concrater and					
10112936-S-FIPB-P-0135	25474-000-G27-G7C-00171	Intercooler	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0034	А
		Owner's Engineer Document Review - P&ID CO2	00002		1.12.12000 12100		
10112936-S-FIPB-P-0137	25474-000-G27-GZC-00173	Compressor 2nd Stage	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0036	А
		Owner's Engineer Document Review - P&ID CO2	1				
		Compressor 2nd Stage-Steam Generator and					
10112936-S-FIPB-P-0138	25474-000-G27-GZC-00174	Intercooler	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0037	A
	05474 000 007 070 00170	Owner's Engineer Document Review - P&ID CO2	O de la O		44/04/0000 40 00		•
10112936-S-FIPB-P-0140	25474-000-G27-G2C-00176	Drying Package	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0039	A
10112936-S-FIPB-P-0141	25474-000-627-670-00177	Compressor 3rd Stage	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0040	Δ
	010 000 001 020 00111	I sempressed ord ordge	2000 2		11/21/2000 12:00		

Client Document Number	Bechtel Document Number	Title	Client Status Code	Response Status Open/ Closed	Creation Date	Associated Client Document Number	Document Submitted for I-Information C - Comment A - Approval
	25474 000 007 070 00479	Owner's Engineer Document Review - P&ID CO2	Codo 2		11/21/2008 12:20		٨
10112930-3-FIFB-F-0142	25474-000-027-020-00178	Owner's Engineer Document Review - P&ID Send			11/21/2006 12.30	10112930-FB-F-FID-0041	A
10112936-S-FIPB-P-0143	25474-000-G27-G7C-00179	Out Pump	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0042	А
		Owner's Engineer Document Review - P&ID LP	00002		1 1/2 1/2000 12:00		~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
10112936-S-FIPB-P-0106	25474-000-G27-GZC-00159	Steam System 1	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0044	А
		Owner's Engineer Document Review - P&ID HP					
10112936-S-FIPB-P-0113	25474-000-G27-GZC-00166	Steam System	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0046	А
		Owner's Engineer Document Review - P&ID					
10112936-S-FIPB-P-0095	25474-000-G27-GZC-00148	Compressed Air System 2	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0048	A
		Owner's Engineer Document Review - P&ID Nitrogen					
10112936-S-FIPB-P-0090	25474-000-G27-GZC-00143	Gas System	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0050	A
		Owner's Engineer Document Review - P&ID Potable					
10112936-S-FIPB-P-0101	25474-000-G27-GZC-00154	Water System	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0051	A
		Owner's Engineer Document Review - P&ID LP					
10112936-S-FIPB-P-0094	25474-000-G27-GZC-00147	Condensate Return	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0052	A
		Owner's Engineer Document Review - P&ID Raw					
10112936-S-FIPB-P-0099	25474-000-G27-GZC-00152	Water System	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0053	A
		Owner's Engineer Document Review - P&ID Sea			44/04/0000 40.00		
10112936-S-FIPB-P-0091	25474-000-G27-G2C-00144	Water Cooling System	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0054	A
10112026 S FIDB B 0006	25 474 000 007 070 001 40	Water Casling System	Codo 2		11/01/0000 10:00		
10112936-S-FIPB-P-0096	25474-000-627-620-00149	Water Cooling System	Code 2		11/21/2006 12:30	10112936-PB-P-PID-0055	A
10112036 S EIPB P 0002	25474 000 C27 C7C 00145	Water Cooling System 3	Codo 2		11/21/2008 12:30	10112026 PB P PID 0056	۸
10112930-3-1 IF B-F-0092	23474-000-027-020-00143	Owner's Engineer Document Review - P&D Amine			11/21/2000 12.30	10112330-FB-F-FID-0030	~
10112936-S-FIPB-P-0097	25474-000-G27-G7C-00150	Waste System	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0057	Δ
10112330-8-111 B-1 -0037	23474-000-027-020-00130	Owner's Engineer Document Review - P&ID Waste			11/21/2000 12:50	10112330-1 D-1 -1 1D-0037	~
10112936-S-FIPB-P-0089	25474-000-G27-G7C-00142	Water System	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0058	А
		Owner's Engineer Document Review - P&ID	00002		1.12.12000 12:00		
10112936-S-FIPB-P-0100	25474-000-G27-GZC-00153	Demineralized Water System	Code 2		11/21/2008 12:30	10112936-PB-P-PID-0059	А
		Owner's Engineer Document Review Form - HAZID					
10112936-S-FIPB-S-0058	25474-000-G27-GZC-00093	Report	Code 2		11/7/2008 9:39	10112936-PB-S-HSE-0003	А
		Owner's Engineer Document Review Form - Heat					
10112936-S-FIPB-P-0121	25474-000-G27-GZC-00215	and Mass Balance Diagrams	Code 2		12/2/2008 14:05	10112936-PB-P-HMB-0001-0002	С
		Owner's Engineer Document Review Form - Storage					
10112936-S-FIPB-P-0218	25474-000-G27-GZC-00214	Units and Transfer Systems	Code 2		12/2/2008 12:56	10112936-PB-P-LST-0002	С
		Owner's Engineer Document Review Form - Effluent					
10112936-S-FIPB-E-0023	25474-000-G27-GZC-00073	Production	Code 2		10/27/2008 17:14	10112936-PB-P-TDO-0007	С
		Owner's Engineer Document Review Form - Plant					
		area drawing including surrounding infrastructure and					
10112936-S-FIPB-C-0236	25474-000-G27-GZC-00302	security fencing	Code 2		12/16/2008 9:15	10112936-PB-C-DRW-0001	С
		Owner's Engineer Document Review Form - Site			10/10/0000		
10112936-S-FIPB-C-0237	25474-000-G27-GZC-00303	preparation and leveling drawings	Code 2		12/16/2008 9:15	10112936-PB-C-DRW-0002	С
	05474 000 007 070 00004	Owner's Engineer Document Review Form - Layout			40/40/0000 0 45		
10112936-S-FIPB-C-0238	25474-000-627-626-00304	arawings ito construction areas	Code 2		12/16/2008 9:15	TUTT2936-PB-C-DRW-0003	C
10112026 8 EIDB C 0224	25474 000 027 070 00000	Decliminary list of agginment and sining	Code 2		10/16/0000 0.45	10112026 PR C DAL 0001	6
10112930-3-FIPD-0-0224	23414-000-621-626-00299	Freiminary list of equipment and piping	Code 2		12/10/2006 9:15	10112930-PD-C-PAL-0001	U U

Client Document Number	Bechtel Document Number	Title	Client Status Code	Response Status Open/ Closed	Creation Date	Associated Client Document Number	Document Submitted for I-Information C - Comment A - Approval
10112936-S-FIPB-C-0144	25474-000-G27-GZC-00197	Owner's Engineer Document Review Form - Landscape Plan	Code 2		11/24/2008 14:39	10112936-PB-C-PLN-0001	С
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-C-0239	25474-000-G27-GZC-00305	Landscape plan	Code 2		12/16/2008 9:15	10112936-PB-C-PLN-0001	С
		Owner's Engineer Document Review Form -					
		Description and drawings of road, paving and terrain			10/10/0000 0 15		0
10112936-S-FIPB-C-0234	25474-000-G27-GZC-00301	surface requirements and design	Code 2		12/16/2008 9:15	10112936-PB-C-TED-0005	C
		Owner's Engineer Document Review Form -					
10112026 S EIDB C 0180	25474 000 627 676 00247	Site Subsurface Plan	Codo 2		12/5/2008 0.55	10112036 PB C TED 0013	C
10112930-3-11FB-C-0180	23474-000-027-020-00247	Owner's Engineer Document Review Form -	COUE 2		12/3/2000 9.33	10112930-FB-C-1ED-0013	C
10112936-S-FIPB-F-0241	25474-000-G27-GZC-00307	Electrical data sheets for equipment	Code 2		12/18/2008 15:28	10112936-PB-F-DAS-0001	С
		Owner's Engineer Document Review Form -	00002		12, 10, 2000 10,20		Ŭ
10112936-S-FIPB-E-0176	25474-000-G27-GZC-00219	Electrical Arrangement Drawings	Code 2		12/2/2008 15:50	10112936-PB-E-DRW-0001	С
		Owner's Engineer Document Review Form - Load					
10112936-S-FIPB-E-0194	25474-000-G27-GZC-00236	flow calculations (EDSA)	Code 2		12/3/2008 11:19	10112936-PB-E-TDO-0001	С
		Owner's Engineer Document Review Form - Short-					
10112936-S-FIPB-E-0195	25474-000-G27-GZC-00237	circuit calculations (EDSA)	Code 2		12/3/2008 11:19	10112936-PB-E-TDO-0002	С
		Owner's Engineer Document Review Form -					_
10112936-S-FIPB-E-0196	25474-000-G27-GZC-00238	Transient stability calculations (EDSA)	Code 2		12/3/2008 11:19	10112936-PB-E-TDO-0003	С
	05474 000 007 070 00000	Owner's Engineer Document Review Form -	0.1.0		40/0/0000 44-40		0
10112936-S-FIPB-E-0197	25474-000-G27-G2C-00239	Harmonic distortion study	Code 2		12/3/2008 11:19	10112936-PB-E-TDO-0004	ι L
10112036-S-FIPB-F-0108	25474-000-627-676-00223	Electrical load study (all voltage levels)	Code 2		12/2/2008 16:15	10112036-PB-F-TDO-0005	C
	23474 000 027 020 00223	Owner's Engineer Document Review Form -	00002		12/2/2000 10:10	10112936-PB-E-TDO-0007-8 -9 -	0
10112936-S-FIPB-E-0177	25474-000-G27-GZC-00220	Electrical Routing Plan Cable Ladder CCC Facilty	Code 2		12/2/2008 15:50	10	С
		Owner's Engineer Document Review Form -					
		Operating Philosophy and sizing of emergency diesel					
10112936-S-FIPB-E-0178	25474-000-G27-GZC-00221	generator	Code 2		12/2/2008 15:50	10112936-PB-E-TED-0004	С
10112936-S-FIPB-E-0179	25474-000-G27-GZC-00222	Owner's Engineer Document Review Form - Sizing reports and main design data for all electrical facilities within the CCC plant electrical systems	Code 2		12/2/2008 15:50	10112936-PB-E-TED-0005	с
		Owner's Engineer Document Review Form -					_
10112936-S-FIPB-E-0227	25474-000-G27-GZC-00293	Specification of main electrical equipment	Code 2		12/12/2008 11:39	10112936-PB-E-TSP-0001	С
	05 171 000 007 070 000 10	Owner's Engineer Document Review Form -Material	O de O		40/00/0000 44:00		0
10112936-S-FIPB-G-0243	25474-000-G27-G2C-00343	Take off (MTO) main components	Code 2		12/23/2008 14:39	10112936-PB-G-DOC-0002	C
10112936-S-FIPB-G-0244	25474-000-G27-GZC-00323	Owner's Engineer Document Review Form - 3D Model Composite Extraction End View and Elevation Owner's Engineer Document Review Form - HVAC	Code 2		12/23/2008 9:50	10112936-PB-G-DRW-0005,6	с
10112936-S-FIPB-H-0192	25474-000-G27-GZC-00273	System Design and Description	Code 2		12/9/2008 14:46	10112936-PB-H-TED-0002	С
		Owner's Engineer Document Review Form -	1				
10112936-S-FIPB-I-0210	25474-000-G27-GZC-00259	Telephone System Conceptual Block Diagram	Code 2		12/5/2008 14:31	10112936-PB-I-DRW-0007-8-9	С
10112936-S-FIPB-I-0235	25474-000-G27-GZC-00315	Owner's Engineer Document Review Form - Location plan of gas analysing and monitoring equipment	Code 2		12/19/2008 10:05	10112936-PB-I-PLN-0001	с

		7.1.	Client Status	Response Status Open/		Associated Client Document	Document Submitted for I-Information C - Comment
Client Document Number	Bechtel Document Number	I Itle	Code	Closed	Creation Date	Number	A - Approval
10112936-S-FIPB-M-0263	25474-000-G27-GZC-00275	Corrosion Evaluation For Main Systems	Code 2		12/9/2008 14:46	10112936-PB-M-TDO-0001	С
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-M-0262	25474-000-G27-GZC-00274	Durability Report	Code 2		12/9/2008 14:46	10112936-PB-M-TDO-0002	С
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-N-0223	25474-000-G27-GZC-00263	Identification and defination of foundation loads	Code 2		12/8/2008 9:05	10112936-PB-N-TDO-0002	C
10110000 C FIDD N 0000	05474 000 007 070 00070	Owner's Engineer Document Review Form -			40/0/0000 44.40	10110000 PD N TDO 0000	0
10112936-S-FIPB-N-0233	25474-000-G27-G2C-00276	Owner's Engineer Decument Review Form	Code 2		12/9/2008 14:46	10112936-PB-N-1DO-0002	U
10112036 S EIPB O 0120	25474 000 C27 C7C 00228	Constructibility Report	Codo 2		12/2/2008 16:38	10112036 PB O DOC 0001	C
10112930-3-1 IF B-O-0120	23474-000-027-020-00228	Owner's Engineer Document Review Form - Material			12/2/2000 10.30	10112930-FB-0-D00-0001	C
10112936-S-FIPB-O-0191	25474-000-G27-G7C-00232	Preservation and Storage Philosophy	Code 2		12/2/2008 16:38	10112936-PB-O-DOC-0002	C
		Owner's Engineer Document Review Form -	00002		12,2,2000 10.00		Ű
10112936-S-FIPB-O-0257	25474-000-G27-GZC-00334	Recommended Spare and wear Parts	Code 2		12/23/2008 9:50	10112936-PB-O-DOC-0009	С
							_
10112936-S-FIPB-P-0124	25474-000-G27-GZC-00229	Owner's Engineer Document Review Form - Line List	Code 2		12/2/2008 16:38	10112936-PB-P-LCL-0001	С
		Owner's Engineer Document Review Form - Utility					
10112936-S-FIPB-P-0125	25474-000-G27-GZC-00216	Consumption List	Code 2		12/2/2008 14:05	10112936-PB-P-LST-0001	С
		Owner's Engineer Document Review Form -					
		Hydraulic and Mechanical Study on CCC plant					
10112936-S-FIPB-P-0127	25474-000-G27-GZC-00212	Column Design	Code 2		12/2/2008 12:56	10112936-PB-P-TDO-0012	С
		Owner's Engineer Document Review Form - Energy					
10112936-S-FIPB-P-0129	25474-000-G27-GZC-00230	Consumption Optimization Study	Code 2		12/2/2008 16:38	10112936-PB-P-TDO-0014	С
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-P-0130	25474-000-G27-GZC-00213	Depressurization and Draining Philosophy	Code 2		12/2/2008 13:05	10112936-PB-P-TDO-013	С
		Owner's Engineer Document Review Form - Utility			40/0/0000 44.05		0
10112936-S-FIPB-P-0128	25474-000-G27-G2C-00217	Unit Descriptions	Code 2		12/2/2008 14:05	10112936-PB-P-TED-0003	C
		Owner's Engineer Desument Review Form				10112026 PB P DAS 0001 2 2 4	
10112036 S EIDB P 0250	25474 000 C27 C7C 00340	Equipment mechanical data sheets Auviliary Boiler	Codo 2		12/22/2008 0.50	10112930-FB-R-DA3-0001-2-3-4-	C
10112930-3-1 IF B-IC-0239	23474-000-027-020-00340	Owner's Engineer Document Review Form - Main			12/23/2000 9.30	5-6	C
10112936-S-FIPB-R-0265	25474-000-G27-G7C-00278	Equipment And Main Equipment Package List	Code 2		12/9/2008 14.46	10112936-PB-R-PAI -0001	C
		Owner's Engineer Document Review Form - Main	00002		12/0/2000 11:10		Ű
10112936-S-FIPB-R-0269	25474-000-G27-GZC-00341	Equipment And Main Equipment Package List	Code 2		12/23/2008 9:50	10112936-PB-R-PAL-0001	С
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-S-0260	25474-000-G27-GZC-00309	Contractor's Fire and Explosion Strategy (FES)	Code 2		12/18/2008 15:28	10112936-PB-S-HSE-0006	С
			1				
		Owner's Engineer Document Review Form -Concept					
10112936-S-FIPB-S-0181	25474-000-G27-GZC-00290	Occupational Health Impact Assessment	Code 2		12/11/2008 10:48	10112936-PB-S-HSE-0008	С
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-S-0261	25474-000-G27-GZC-00310	Hazardous Area Classification drawings	Code 2		12/18/2008 15:28	10112936-PB-S-HSE-0010	С
		Owner's Engineer Document Review Form -					
		Contractor's Escape Evacuation and Rescue				10112936-PB-S-HSE-0011-0015 -	
10112936-S-FIPB-S-0268	25474-000-G27-GZC-00312	Strategy (EERS)	Code 2		12/18/2008 15:28	0019	С
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-S-0267	25474-000-G27-GZC-00311	Contribution to Quantitative Risk Analysis (QRA)	Code 2		12/18/2008 15:28	10112936-PB-S-HSE-0014	C

			Client Status	Response Status Open/		Associated Client Document	Document Submitted for I-Information C - Comment
Client Document Number	Bechtel Document Number	Title	Code	Closed	Creation Date	Number	A - Approval
		Owner's Engineer Document Review Form -					
		Description of required infrastructure improvements					
10112936-S-FIPB-C-0240	25474-000-G27-GZC-00306	outside plant battery limits	Code 2		12/16/2008 9:15	10112936-PB-C-TED-0017	I
		Owner's Engineer Document Review Form -Electrical					
10112936-S-FIPB-E-0060	25474-000-G27-GZC-00105	Consumer List	Code 2		11/14/2008 14:01	10112936-PB-E-PAL-0001	1
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-E-0187	25474-000-G27-GZC-00240	Electrical Consumers List	Code 2		12/4/2008 9:58	10112936-PB-E-PAL-0001	1
		Owner's Engineer Document Review Form -					
10112936-S-FIPB-E-0226	25474-000-G27-GZC-00292	Electrical Consumers List	Code 2		12/12/2008 11:39	10112936-PB-E-PAL-0001	
		Owner's Engineer Document Review Form -					
		Electrical Location Plan Electrical Switchgear					
10112936-S-FIPB-E-0199	25474-000-G27-GZC-00224	Building	Code 2		12/2/2008 16:15	10112936-PB-E-TDO-0006	
		Owner's Engineer Document Review Form - Current					
10112936-S-FIPB-G-0054	25474-000-G27-GZC-00088	CDR List	Code 2		11/5/2008 10:20	10112936-PB-G-DAL-0001	
		Owner's Engineer Document Review Form - Utility					
10112936-S-FIPB-P-0291	25474-000-G27-GZC-00338	Data Sheet	Code 2		12/23/2008 9:50	10112936-PB-P-DAS-0013	
		Owner's Engineer Document Review Form - Main					
10112936-S-FIPB-R-0264	25474-000-G27-GZC-00277	Equpment Outlines And Weights	Code 2		12/9/2008 14:46	10112936-PB-R-TDO-0003	
Notes:		Total 9 Code 3 Reviews					
Code 1 - Approved (no action required)		Total 160 Code 2 Reviews	Total Code 2 in-progress = 107				
Code 2 - Approved with comment		TUIAI 74 GOUE T REVIEWS	-				

Total 243 Review Sheets

Code 3 - not Approved

Appendix A – CAPEX Cost Estimate
# **CAPEX Cost Estimate**

**CO₂ Capture Facility** 

Kårstø, Norway

#### **Bechtel Proprietary and Confidential**

© 2008 Bechtel Power Corporation. All rights reserved. Bechtel Confidential. Contains information that is confidential and proprietary to Bechtel and may not be used, reproduced or disclosed in any format without Bechtel's prior written permission. This document is prepared exclusively for Gassnova in connection with the preparation of the FEED study for the CO₂ Capture Facility at Karsto, Norway, and is not to be relied upon by others or used in connection with any other project.

———			<u> </u>						
								i	
0	125AN 04	Issued for approval		- Ch	Br	0	WZE		
Rev.	Date	Reason for	Revision	By	Check	Арр	🛞 Арр	Client	
0.23	-	6.	Job No. 25474						
E	E E	Jechiel		Document No.					
叫	P	² Ower	25474 - 000- G38-GAB-00001			0			
				PAGE 1 of 5					
312	GAS	SNOVA	Project No. 101129;	- Originator - C 36 - PB - G	Disc Code • Do i - CRE - O	oc Type - Se 1001	alal No.		

CO2 Kårstø-Gassnova

## Contents

Section	<u>Page</u>
1.0 General	3
2.0 CAPEX Estimate	3
3.0 CAPEX Cost Contingency and Risk analysis	5

#### Attachments

- 1) Capital Cost Estimate Summary Sheets
- 2) Summary of Contingency and Risk Analysis

Bechtel Proprietary and Confidential 25474 - 000-G38-GAB-00001

Kårstø FEED Study CAPEX Cost Estimate, Rev. 0 Page 2 of 5

#### **1.0** General

The estimate was prepared in accordance with the requirements of the following Contract Documents:

- Exhibit E1.1: Requirements for Cost Estimates and Capture Cost Calculation
- Exhibit E1.2: Cost Breakdown Structure

The Capital Cost Estimates (CAPEX) has been prepared to an accuracy of +/- 20% as required in the Contract documents. The Cost Breakdown Structure (CBS) described in document E1.2 was used.

A cost risk analysis was performed and details are provided in this documents.

The following sections provide additional information on the CAPEX and risk analysis

#### 2.0 CAPEX Estimate

#### 2.1 General

The Capital cost estimate (CAPEX) is provided in attachment number 1.

#### 2.2 Pricing basis

The estimate costs are based on 4th Quarter 2008 prices. Escalation through commercial operation is not included.

#### 2.3 Exchange rate

The currency exchange rate used for the estimate is 1 USD = 5.3 NOK, which is in accordance with the requirements of Exhibits E1.1 and E1.2

#### 2.4 Contingency

Contingency is not included in the Contractors Cost in attachment number 1. The Contingency analysis was undertaken as part of the risk analysis (see section 3.0).

#### 2.5 Qualifications and Assumptions

The following qualifications and assumptions apply to the CAPEX estimate:

- The site is clean, free of hazardous materials, level, and free of any obstructions above or below grade.
- The estimate is only for material within the plant B/L shown on the general arrangement drawing, except for the flue gas duct, electrical power tie-ins, seawater cooling pumps, and cooling water pipe.

Bechtel Proprietary and Confidential 25474 – 000-G38-GAB-00001

Kårstø FEED Study CAPEX Cost Estimate, Rev. 0 Page 3 of 5

- Since the site is an existing operating plant with a wharf, it is possible to receive shop-fabricated, large-diameter tanks and vessels. Access to the project site is possible without any modifications to the route.
- The existing stack can accept the modifications to support the CCC Plant flue duct and stack damper.
- The seawater pump structure accommodates the selected pumps, and the cooling water pipe connection design and routing can be accommodated.
- Construction power and water are to be provided by the Owner.
- Soils conditions allow for spread footing design.
- Adequate construction access is available on all sides of the proposed site except the west side.
- CCC Plant lighting and small power distribution are limited to the B/L.
- All pre-existing hazardous materials are to Owner's account.

#### 2.6 Exclusions

The following items are excluded from this cost estimate:

- Contingency (see section 3.0)
- Escalation
- Liquidated damages (LD) insurance
- Builders risk and marine cargo insurance
- Required payment securities
- Environmental wetland and endangered species protection is excluded.
- All construction and environmental permits (to be obtained by Owner)
- Camp costs
- Value-added taxes (VATs) and import duties, where applicable, which are a pass through
- Licensing or royalty fees associated with proprietary processes/ equipment/chemicals (none identified for base case)
- Capital spare parts
- Work associated with demolition at the site
- Furniture or laboratory equipment
- Duties, permits, and taxes
- Modifications to existing utilities, equipment, and facilities
- Onsite accommodations for craft housing are excluded

Bechtel Proprietary and Confidential 25474 – 000-G38-GAB-00001

Kårstø FEED Study CAPEX Cost Estimate, Rev. 0 Page 4 of 5

# 3.0 CAPEX Cost Contingency and Risk Analysis

#### 3.1 General

The Bechtel Risk Analysis Contingency (BecRAC) software was used for the contingency and risk analysis. The summary sheet of the results from the analysis IS provided in attachment 2.

The Contingency derived from the analysis was not included in the overall CAPEX estimate for the project.

**Bechtel Proprietary and Confidential** 25474 - 000-G38-GAB-00001 Kårstø FEED Study CAPEX Cost Estimate, Rev. 0 Page 5 of 5

# ATTACHMENT #1 SHT 10F3

# CO₂ KARSTO

# Estimate Summary Sheet



		TOTAL NOK
0 - A	Complete Project Cost	And And And And
1	Owner's Costs	by Gassnova
0 - B	Contractor's Costs	2,235,711,000
2	General (Indirect) Costs	438,227,000
2.1	Project Engineering (including Project Management, Documentation, other)	62,526,000
2.2	Construction Preliminaries	307,792,000
2.3	Mechanical Completion; Commissioning and Testing	62,609,000
2.4	Training	5,300,000
2.5	Guarantee tests	Included in 2.3
2,6	Spare Parts	Included in 2.3
3	Stack connection / modification incl. Engineering , Procurement, Construction and all ducting within the Naturkraft property	81,965,000
3.1	Flue gas plenum including support structure and foundation, reinforcement where necessary	13,716,000
3.2	Stack modifications including silencers, damper, measurement devices	3 395 000
3.3	Flue das transfer duct including insulation, measurement devices and support structure and	49,790,000
	foundation works	
3.4	Other	10,836,000
3.5	400 V power interface for new flue gas dampers including LV power cabeling with cable	4,228,000
	trays from outgoing terminal of existing 400 V CCPP switchgear and all required electrical systems to feed the required consumers	
4	Flue gas conditioning incl. Engineering, Procurement, Construction from Naturkraft	135,061,000
-	fence to Absorber inlet flange	
4.1	Flue gas cooler including all utilities	2,905,000
4.2	Flue gas fan including drives, all utilities	34,849,000
4,3	Piping and Vessels comprising: all process piping incl. valves and fittings all process	7,070,000
4.4	Pumps comprising: associated drives and utilities (e.g. Jubrication system)	Included in 4.1
4.4	Heat and sound insulation	5 080 000
4.6	Other (Ductwork)	84 248 000
4.0		04,240,000
5	CO2 Absorption incl. Engineering, Procurement, Construction from flange in flue gas conditioning & utility systems to flange towards Solvent Regeneration system	352,461,000
5.1	Absorber Tower	
5.1.1	Absorber tower	89,962,000
5.1.2	Internal packing Incl. distributon, collectors and associated equipment	60,866,000
5.1.3	Piping, tittings	83,731,000
5.1.4	Other All Hilling is heat evolvender, numer incl. drives	10,154,000
0.Z	All olimites i.e heat exchanger, pumps incl. drives	100,975,000
5.3 5.4	Other (License Fee)	0
6	Solvent Regeneration incl. Engineering, Procurement, Construction	177,280,000
6.1	Tanks and storage vessels comprising all utilities	4,169,000
6.2	Stripper, comprising all utilities	33,813,000
6.3	Reboiler, comprising all utilities	14,052,000
6.4	Overhead condenser, comprising all utilities	13,481,000

SHT 2 0 + 3

# CO₂ KARSTO

6.5 6.6 6.7

# **Estimate Summary Sheet**

Heat exchanger incl. all utilities Pumps and blowers incl. all utilities



U	~\
Γ	TOTAL NOK
Γ	25,954,000
	31,994,000
Г	53,559,000

6.7 6.8 6.9	All internal piping including valve and fittings Heat and sound insulation where applicable Other	53,559,000 258,000 0
7	CO2 Compressor and Conditioning incl. Engineering, Procurement,Construction from flange Solvent Regeneration system & utility system to flange of the CO2 pipeline to Transport Project	200,177,000
7.1	Multistage compression and conditioning package comprising all internal piping, valves and fittings	197,265,000
7.2	Metering package	1,696,000
7.3	All utility equipment	Included in 8.0
7.4	Heat and sound insulation	1.216.000
7.5	Other	0

Ρ.,	General utility system incl. Engineering, Procurement, Construction	1/1,240,000
8.1	Cooling water system	51,789,000
8.2	Process steam system	38,147,000
8.3	Condensate system	6,264,000
8.4	Sewage and waste water system	28,340,000
8.5	Compressed air and instrument air system	6.351,000
8.6	Reclaimer	7,973,000
8.7	Hazardous waste system	2.621.000
8.8	Fire fighting system	6,767,000
8.9	Other	22,988,000

9	Automation incl. Engineering, Procurement Documentation, Construction	98,005,000
9.1	Supply of Field Equipment in Flue Gas Conditioning Area	9,494,000
9.2	Supply of Field Equipment in CO2 Absorption Area	18,988,000
9.3	Supply of Field Equipment in Solvent Regeneration Area	9,494,000
9.4	Supply of Field Equipment in Compress. & Conditioning Area	9,494,000
9.5	Supply of Safety and Automation System (SAS)	9,284,000
9.6	Services for Field Equipment and SAS	26,643,000
9.7	Supply and Services of Plant Communication Systems	4.822.000
9.8	Supply and Services of Fire and Gas Monitoring and Alarm System	9,786,000

10	Civil structural work incl. Engineering, Procurement, Construction	222,804,000
10.1	Site preparation comprising: Levelling works, roads, parking areas, pavements, preparational works for cranes and tools, all installations for prefabrication and erection, utilities supply and installation, fencing and gates.	12,500,000
10.2	Foundations comprising Formworks, concrete works, piling if applicable and all internals	119,983,000
10.3	Supporting Steel Construction comprising all hangers and suspensions, all platforms and gratings	26,840,000
10.4	Trenches for cables and piping	7,170,000
10.5	Buildings (except control room building) comprising HVAC, sanitary installation and cladding	36,998,000
10.5.1	Control room building	19,313,000
10.5.2	Social rooms and offices	Included in 10.5

# CO₂ KARSTO

# Estimate Summary Sheet



10.5.3	Workshops and storage rooms	TOTAL NOK
10.5.4	Laboratory building	Included in 10.5
10.6	Other	0

	Main power supply, all distribution system and auxiliary system incl. Engineering, Procurement; Construction	358,492,000
11.01	Power Transformers Including tap changer, secondary cabling, protection, control, etc.	44,820,000
11.02	Medium Voltage Switchgears: including the complete secondary cabling, electrical protection and control, etc.	10,672,000
11.03	Low Voltage Switchgears: including the complete cabling, for protection, control, etc	4,109,000
11.04	DC equipment	6,023,000
11.05	Safe AC Equipment	0
11.06	Emergency Diesel Generator Set: including prime mover and all necessary auxiliary equipment like e.g. AVR, generator protection, etc	2,209,000
11.07	Cabling: including cable connecting, cable terminations, cable joints, etc	132,726,000
11.08	Earthing and Lightning Protection, EMC Requirements: Includes the earthing of the	8,600,000
	complete electrical equipment, all non electric metal structures, etc.; also includes the inner	
	and outer lightning protection of the whole CCC Plant and all EMC requirements. Note:	
	Earthing laid in concrete shall be included in the civil construction costs of the CCC Plant.	
11.09	Lighting and small power installations: the prices for lights, power sockets and domestic sockets shall include the respective portion of the lighting distributions and all necessary cabling, cable ducts, junction boxes, fixing materials, etc. necessary for their installation and connection to the related lighting distributions	26,712,000
11.10	Power factor compensation system: includes MV and / or LV compensation equipment, e. g. reactors, capacitors, electronic control, secondary cabling, electrical protection, etc. (refer to Exhibit E5.1, Section 1.6.1)	112,141,000
11.11	Accessories for Electrical Rooms: Includes all accessories as per Exhibit E5.1, Section 1.13.	6,018,000
11.12	Other	4,462,000

Notes:

A) Above given list shall be adapted and/or extended by the Contractor if necessary.

B) Bidder shall explain main cable types and quantities used in No. 11.7

C) Bidder shall explain power and domestic socket types given in No. 11.9.

.

# 1. Contingency and Risk

.

.

•	Kars	to CO2 Caplure	G   & C 	ASSNOV/ ompressic Norway 25474-UNI	4 In FEED Sludy-UNIQUE				
ESTIMATED COST:		<u></u>		· · · · · · · · · · · · · · · · · · ·	MANAGEMENT DECISIO	DN:	<b></b>	<u> </u>	
Est.Cost Excl.Contingency	5	422.000.000			Probability of Overrun		<u>50.0%</u>		
Accuracy Excl.Conlingency *	+	<u>15.4</u>		3.724	Contingency In %		4.3%		
Most Probable Cost	\$	439.957.000			Contingency In \$	\$	<u>18.158.000</u>		
					Estimate Accuracy Incl. Contingency *	+	11,1%	-	<u>80%</u>

BECHTEL POWER CORPORATION

Frederick, Maryland

Based on standard deviation



Appendix B – OPEX Cost Estimate

# **OPEX Cost Estimate**

**CO₂ Capture Facility** 

Kårstø, Norway

#### **Bechtel Proprietary and Confidential**

© 2008 Bechtel Power Corporation. All rights reserved. Bechtel Confidential. Contains information that is confidential and proprietary to Bechtel and may not be used, reproduced or disclosed in any format without Bechtel's prior written permission. This document is prepared exclusively for Gassnova in connection with the preparation of the FEED study for the CO₂ Capture Facility at Karsto, Norway, and is not to be relied upon by others or used in connection with any other project.

0	1250009	Issued for approval		ah?	In-	Kh.	we		
Rev.	Date	Reason for	Revision	By	Check	Арр	Арр	Client	
			Job No. 25474						
R	BEL B	echtel		Document No.			Rev.		
BECHTPower				25474 -	000- G38	-GAB-000	02	0	
	U	orporation		PAGE 1 of 4					
	GAS	SNOVA	Project No <b>101129</b> 3	Originator - D 6 PBG	iisc Code • D CRE C	loc Type - S 1002	eriał No.		

# Contents

Section	<b>Page</b>
1.0 General	3
2.0 OPEX Estimate	3
3.0 OPEX Sensitivity/risk analysis	4

#### Attachments

1) Operating Cost (OPEX) estimate

Bechtel Proprietary and Confidential 25474 – 000-G38-GAB-00002

## **1.0 General**

The estimate was prepared in accordance with the requirements of the following Contract Documents:

- Exhibit E1.1: Requirements for Cost Estimates and Capture Cost Calculation
- Exhibit E1.2: Cost Breakdown Structure

The Operating Expenditure (OPEX) Cost Estimates has been prepared to an accuracy of +/-20% as required in the Contract documents.

## 2.0 OPEX Estimate

#### 2.1 General

The OPEX estimate is provided in attachment number 1.

#### 2.2 Data used in developing OPEX

The following is a summary of the basis of the data used in the OPEX estimate:

- The average use time for utility consumption was estimated at 8105 hours per year. This includes allowances for CCPP outages and the 97% capacity factor for the CCC plant.
- 1: Utility Consumption:
  - o Usage rates are based on the base case open-art design
  - Unit prices were provided from Gassnova except for price of condensate which was estimated based on our past experience
- 2: Consumables
  - o Usage rates are based on the base case open-art design
  - o Unt prices were obtained from Bechtel pricing database
- 3: Staff
  - Staffing levels are as outlined in the Bechtel document submittal 10112936-PB-O-DOC-0004 (Operating Staff Concept)
- 4: Maintenance cost
  - This was estimated as a percentage of capital costs as is typical for a FEED estimate.

- 5: Spare and Wear Parts
  - This was estimated as a percentage of equipment costs, except for Absorber packing which was estimated separately based on input from packing suppliers.
- 6: Service cost to Gassco
  - o A cost of 8000,000 NOK/y was input per section 2.0 of Exhibit E1.1
- 7: Special Waste
  - Usage for activated carbon and reclaimer sludge is based on the base case open-art design. Unit price was based on vendor pricing data.
- 8: Service Agreement with Naturkraft
  - o Cost to be determined by Gassnova per clause E2.2 of Exhibit E1.2
- 9: Taxes
  - o Cost to be determined by Gassnova per clause E2.2 of Exhibit E1.2
- 10: Land leasing cost
  - o Cost to be determined by Gassnova per clause E2.2 of Exhibit E1.2
- 11: Other costs
  - Administartion cost of 10,000,000 NOK/y was input per section 2.0 of Exhibit E1.1

#### 3.0 OPEX Sensitivity/Risk Analysis

The data on the OPEX Sensitivity/risk analysis is included in the CO2 Capture Cost Calculation (document number: 10112936-PB-G-CRE-0003)

# Base Case: Open Art

2-14.

6

		Average		Annual
	Usage	Usage		Cost
	Rate	Time	Unit Price	(NOK 000s)
CULIN CONSTITUTION			We the second second second	A CAREER AND CO
Electricity	32.0 MW	8 105 h	450 NOK/MWh	116 714
LP Steam	165 t/h	8 105 b	96 NOK/t	128 185
HP Steam	12 t/h	486 h	340 NOK/	1 084
Natural Gas	708 ko/h	8 105 h	2.06 NOK/00	11.914
Cooling Water Consumption	17 340 m³/h	8 105 h	2.00 NOK/m	14.054
Condensate Consumption	12.0 th	8 105 5	15.00 NOK#	14,004
Utility Consumption	12.0 011	<u>0.100 II</u>	13.00 NORA	274,211
Gonsumables, Carlos	Here we a		a the second state	
MEA consumption				2,656
MEA lost through absorber	15.6 kg/h	8,105 h	14,310 NOK/t	1,807
MEA consumption from reclaimer	122.0 kg/h	485 1	14,310 NOK/I	849
Soda Ash Cost Consumption	35.0 kg/h	486 h	1.590 NOK/	27
Nitrogen Gas Cost Consumption	4.45 m³/h	8,105 h	5.30 NOK/m ³	191
Consumables Cost				2,874
Slaff	NEW XADAR	a sult		
Spec Workers	15 people	1 year	775 kNOK/y	11,625
Shift Leaders	5 people	1 year	950 kNOK/y	4,750
Secretaries	1 people	1 year	500 kNOK/y	500
Accounting	9 people	1 year	560 kNOK/y	5,040
Heads of CCC	1 people	<u>1 vear</u>	1,200 kNOK/y	1,200
Staff Cost				23,115
Maintenance cost				
Maintenance Cost	n/a	1 year	55,893 kNOK/y	55,893
5 Spare and wear parts	CHANNE -	at the	+ 1	-
Average Absorber Packing	n/a	1 year	1,749 kNOK/y	1,749
Spare and wear parts	<u>n/a</u>	<u>1 vear</u>	<u>11,925 kNOK/v</u>	<u>11,925</u>
"The absorber packing costs will not be the	same every year. See the i	financial model for the	estimated repacking sche	iule Jule
Service cost to GASSCO		1112		
Services from GASSCO	n/a	1 year	8,000 kNOK/y	8,000
7 Special waste	Contraction Con			1.87
Activated Carbon	29.8 kg/h	8,105 h	3,000 NOK/t	724
Reclaimer Sludge	<u>171.0 kg/h</u>	<u>486 h</u>	<u>3,000 NOK/t</u>	<u>249</u>
Waste Disposal				973
8 Service Agreement with Naturk	raft			
To be determined by Gassnova				0
9 Taxes				
by Gassnova				0
10 Land Leasing cost	1	15 C	· · · · · · · · · · · · · · · · · · ·	
by Gassnova				0
11 Other costs				
Administration	n/a	1 year	10,000 kNOK/y	10,000
Administration				
12 Total Operating Costs				

Appendix C – Capture Cost Calculation

# CO₂ Capture Cost Calculation

CO₂ Capture Facility

Kårstø, Norway

#### **Bechtel Proprietary and Confidential**

© 2008 Bechtel Power Corporation. All rights reserved. Bechtel Confidential. Contains information that is confidential and proprietary to Bechtel and may not be used, reproduced or disclosed in any format without Bechtel's prior written permission. This document is prepared exclusively for Gassnova in connection with the preparation of the FEED study for the CO₂ Capture Facility at Karsto, Norway, and is not to be relied upon by others or used in connection with any other project.

	T							
0	137411 09	Issued for information	n		Ron		U.D.C	
Rev.	Date	Reaso	n for Revision		Check	App	Арр	Client
	The second se			Job No.	25474			
ß		Bechtel		Docume	ent No.			Rev.
		Power Corporation		25474	- 000- G38	-GAB-000	03	0
						PAGE 1 of	4	- <b></b>
	GAS	SNOVA	Project Nc 101129	). «Originator - I 336 – PB – G	Disc Code - De	oc Type - Se 003	erial No.	

# Contents

Section	Page
1.0 General	3
2.0 CO ₂ Capture Cost Calculation	3

#### Attachments

1) CO₂ Capture Cost Calculation

# 1.0 General

The Capture Cost Calculation was not a required deliverable in the Exhibit A1 contract documents. However, we believe it would be useful to Gassnova and have therefore prepared the calculation and attached it to this document.

# 2.0 CO₂ Capture Cost Calculation

#### 2.1 General

The CO2 Capture Cost Calculation was undertaken using our own financial model. It uses a similar approach to the provisional calculation model provided by Gassnova as an attachment to Exhibit E1.1.

The calculation is undertaken for the base case open-art MEA design.

The output is provided in attachment 1.

#### 2.2 Information included and excluded from the model

The model calculates the CO2 capture cost (NOK/tCO2) based on data from the following cost estimates for the CO2 Capture Plant

- Capital cost (CAPEX). See document number 10112936-PB-G-CRE-0001
- Operating costs (OPEX). See document number 10112936-PB-G-CRE-0002

The following information is not included in the calculation:

- Gassnova's OPEX costs which were defined as 'By Gassnova' in Exhibit E1.2
- Capital cost contingency and all other items excluded from the CAPEX estimate
- Insurance
- Capital or operating costs for any work to be performed outside of the battery limit by Gassnova.

#### 2.3 Assumptions used in model

The following assumptions were used in creating the model

- Project Life time: 25 years
- We used the data provided in Exhibit E1.1 to determine the level of planned and unplanned outages for the Naturkraft CCPP. These vary year by year and this is reflected in the model. (for information the availability averages 95.4% over the 25 year period)

- We used a Capture plant on stream factor is 97% for the design case (100% load of power plant) relative to the CCPP availability
- One production year is equal to 8760 hours. Actual operation hours are then calculated using CCPP availability and CCC on stream factor for each year.
- Exchange rate used was NOK/USD: 5.3 (per Exhibit E1.1)
- Discount rate (NPV) is 8%
- For simplicity, the construction schedule was done on an annual basis. Because the NPV calculation is done on an annual basis, little is gained by splitting construction numbers in to a monthly level of detail.
- Changes in working capital are added to operating expenses to get a more accurate representation of cash flows. Working capital includes changes in operating cash and changes in accounts payable.

#### 2.4 Sensitivity Analysis

Sensitivity analysis were performed for the NPV unit cost (NOK/t) and the NPV of total cost.

The output is presented in terms of a 'tornado' chart with the higher impacts shown at the top of the chart.

The parameters listed in section 6 of Exhibit E1.1 were assessed along with other parameters identified by the Contractor.

#### 2.5 Description of model output sheets

The model output in contained in attachment number 1. The following data is contained in the output:

- Key Data and Results: These sheets show all model inputs and results. The inputs on the first page are all constant over time. The inputs on the second page are time-varying
- Project Financial Statement: These sheets show annual cash flows for each year
- OPEX summary. This shows the operating cost breakdowns for an average year. This information was also provided in the OPEX Cost Estimate document number: 10112936-PB-G-CRE-0002
- Technical Data Summary. These sheets show the non-financial model outputs
- Sensitivity Analysis. Sensitivity analysis in terms of unit cost and total cost

Karsto CO2 Capture Cost	t Calculation	$\bigcirc$
<ul> <li>Description of Model Outputs</li> <li>The Key Data &amp; Results sheets show all of the model inputhe second page are time-varying.</li> <li>The Technical Data Summary sheet shows the non-financi</li> <li>The OPEX Summary sheet shows operating cost breakdor</li> <li>The Project Financial Statement sheets show annual cash</li> <li>The Sensitivity Charts show the economic effect for change</li> </ul>	its and key financial metrics. The inputs on the first page are constant over time and the inputs ial model outputs. wn for an average year. I flows for each year. les in input variables.	LO SI
<ul> <li>Model Assumptions</li> <li>The model is done using real NOK and uses an 8% real di</li> <li>For simplicity, the construction schedule was done on an a splitting construction numbers into a monthly level of detail</li> <li>The model is based on both cost estimates provided by Be</li> <li>Changes in working capital are added to operating expension operating cash and changes in accounts payable.</li> </ul>	iscount rate (re exhibit E1.1). annual basis. Because the NPV calculation is done on an annual basis, little is gained by I before recombining them to annual numbers echtel and costs provided by Gassnova. ses to get a more accurate representation of cash flows. Working capital includes changes	
<b>Disclaimer</b> This report has been prepared by Bechtel Overseas Corporation for Gassnova so relied upon by any person other than Gassnova Neither the existence of this repo without the express prior written consent of Bechtel.	olely for (client's internal use and benefit with respect to the Karsto Project (the "Project"). This report is not intended to nor ma ort nor its contents may be distributed to, discussed with, summarized or otherwise disclosed to any person other than Gassno	lay it be Iova,
This report is preliminary and does not contain the amount of information which w conclusions and recommendations in this report are not meant to be used as the Any advice or opimions stated in this report reflect Bechhel's professional judgmen amend, supplement or withdraw any such advice or opinions.	kil be needed to satisfy the requirements of governmental authorities or funding institutions with respect to the Project. The basis for financial or menagement decisions or as part of any financial transaction. And are subject to the assumptions, limitations, qualifications and reservations described herein. Bechtet shall be entitled to	9
This report and its contents are valid only for the conditions reported herein and a attention that may materially change the report, or for any other reason. Bechtel ( Except where specifically stated otherwise in this report, the information containet otherwise examined by Bechtel to determine its accuracy or completeness.	is of the date hereof. Bechtal has no responsibility to update, correct or supplement this report, even if information cornes to its does not represent that any condition concerning the Project that is assumed in this report will be achieved. d herein was provided to Bechtel by Gassnova or third parties on behalf of Gassnova and has not been independently verified	its d or
Any model contained in, or used to prepare information in, this report uses genera assumptions or their accuracy or reasonableness. The results of the model shoul assumptions and methodologies and calculations incorporated in the model.	afized assumptions that have been derived from a variety of sources and Bechtel does not make any representation regerding Id not be taken as an indication of the viability or financeability of the Project. Users should perform their own due difgence as	g those as to the
Any use of or refance on this report or any information contained herein by any p disclaim all liability to any such person with respect to the use of or for kosses resu This report is integral and must be read in its entirety. This notice must accompar	erson other than Gassnova is at such person's sole risk and responsibility. Bechtel and all persons and parties acting on its be utting from the use of this report or any information contained in this report. ny every copy of this report.	behalf
1113/2008, 12:56 PM Karsto Model - 41619 - 473-x15	Model Description por 1 of 1	LI HOLE

0		25,845,091 tonne 8,766,039 tonne	1,868,773 NOK 0005 2,345,033 NOK 0005 194,818 NOK 0005 650,138 NOK 0005 84,282 NOK 0005 5,143,044 NOK 0005	25.16 NOKA 7.54 NOKA 7.54 NOKA 25.16 NOKA 25.16 NOKA 25.16 NOKA 25.15 NOKA 267.51 NOKA 267.51 NOKA 74.17 NOKA 74.17 NOKA 74.17 NOKA	St E Admin E O&M E Personnel E Consumables E Capital
	RESULTS	CO2 Captured CO2 captured NPV of CO2 Captured	<u>NPV of Capture Cost</u> Capilaf Consumables & Disposal Cost Personnel Costs Operation Maintenance & Repair Administration and Insurance Total	NPV 00 Cost Der tonne of Cost ca Capital Capital Consumables & Disposal Cost Personnel Costs Administration Maintenance & Repair Administration and Insurance Consumables & Disposal Cost Personnel Costs Operation Maintenance & Repair Administration and Insurance Total	Capture Co 22 22 22 22 22 22 22 22 22 22 22 22 22
		D NOK/MWh	5 NOKA 5 NOKA NOKA 0 NOKA 0 NOKA 0 NOKA 0 NOKA	r Salary e <u>NOK 0005</u> 950 560 1,200 1,200 0 NOK 0005 5 NOK 0005 3 NOK 0005 3 NOK 0005 3 NOK 0005	D NOK 000s 6 days 0 days 3 days 0 NOK/Eur
(D)		450.0	95.8 1.7 1.7 1.50 1.50 1.50 1.50 1.50 1.50 1.50	Number of People 5 5 5 5 6 1 1 1,920 39,752,8375	10,00 8,00 8,00 8,00
Karsto Key Data & Results	INPUTS	Consumable Price & Disposal Cost Electricity HP Steam	LP Steam Natural Gas Hot water Cooling Water Hazardous Waste Disposal MEA Soda AsF Nitrogen Gas Condensate	Personnel Cost Spec Workers Shift Leaders Secretaries Accounting Head of CCC Annual Spare Parts Usage Annual Spare Parts Usage Absorber & Stripper Packing Cost Maintenance	Administration Cost Insurance (percent of EPC) Working Capital Accounts Receivable Accounts Payable Operating Cash Operating Cash Exchange Rate (NOK/USD) Exchange Rate (NOK/EUR)
		NOK 000s NOK 000s	NOK 0005 NOK 0005 NOK 0005 NOK 0005 NOK 0005 NOK 0005 NOK 0005 NOX 0005	tonne/hr % % Mww Mww Mwm Mwm Mayhr	th tweek kg/m³ MJ/kg MJ/kg Kg/h kg/h kg/h
		438,227 81,965	135,061 352,461 177,280 200,177 171,240 98,005 222,804 2223,712 2235,712	149.53 95.4% 95.4% 97.0% 97.0% 165.0 0.213 0.213 0.213 0.213 0.213 39.000	12 5 708 0.8500 46.60 12.00 12.00 12.00 12.00 12.100 171.00 6.00%
Base C. Open Art	INPUTS	Capital Costs General Indirect Stack Connection	Flue Gas Condition CO2 Absorption Solvent Regeneration CO2 compression & Conditioning General Utifity Systems Automation Civil Work Main Power Supply Total Capital Cost	Engineering Data NGCC CO2 emissions from flue gas CO2 emissions from flue gas Average NGCC Availability Average NGCC Availability Average NGCC Capacity Factor CO2 Capture CO2 Capture CO3 CO2 Capture CO3 CO2 Capture CO3 CO3 CO3 CO3 CO3 CO3 CO3 CO3 CO3 CO3	Condensate Consumption Aux Boller Aux Boller Additional Fuel Consumption Natural Gas Density Natural Gas Heating Vatue (LHV) Reclaimer HP Steam Consumption MEA Consumption Soda Ash Consumption Studge Disposal Reclaimer run frequency (rel to CCC)

Use of this report is subject to certain restrictions set forth in the Important Notice located at the front of this report.

1/13/2009, 12:56 PM Karsto Model -F1F9 -V2s.xls

Key Data Results pg 1 of 2

	Art
_	pen
(	)
-	Cas
	Base

Karstد Key Data & Results

I ime Series Inputs							-		1 4 4 1 4 1			-				
-	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2015	2020	2021	2022	2023
Construction Draw Schedule EPC Draw Schedule	÷	15%	35%	20%		,e	÷	÷		ł	•	•	9	á	ä	•
Other Data NGCC Days of planned shutdown	1				•	1	21	1	7	37	1	4	1	21	1	•
NGCC Days of Unplanned shutdown		•		•	4	4	4	4	4	4	4	4	4	4	4	4
Repacking Cost (% of full replacement)	•		•		÷.,		•		2.5%	•	4		ā.	2.5%	4	•
	2024	2025	2026	2027	8202	2026	2030	2031	2032	2033	2034	2035	2036			
Construction Draw Schedule EPC Draw Schedule	•	Ŧ	ï	•	•		7	a.	4							
<u>Other Data</u> NGCC Days of planned shutdown	37	2	7	2	21	2	2	37	•	~	2	21	1			
NGCC Days of Unplanned shutdown	4	4	4	4	4	4	4	4	4	4	4	4	4			
Repacking Cost (% of full replacement)	•		100.0%	,	ł	2.5%	•	•	•	2.5%	•					



1/13/2009, 12:56 PM Karsto Model -F1F9 -v2s.xls

Key Data Results pg 2 of 2

		5
		4
		- Ua
		ā
	2	O
1		1
2		- 41
		ö
		- m
		- ŭ
		цц,

Technical Jata Summary

2015
2014
2013
2012
ant Unit
Const

2020

2018

2017

2016

# NGCC

NGCC Operating Hours NGCC Shirtdown hours (naamed + unplanned)	hours	8,496 264	8,496 264	8,160 600	8,496 264	8,496 264	7.776 984	8,496 264	8,496 264	8,496 264
NGCC other non-operating hours CO2 Emissions from NGCC	hours tonne	۔ 1,270,403	- 1,270,403	1,220,162	1,270,403	1,270,403	- 1,162,742	1,270,403	1,270,403	- 1,270,403
<u>Capture</u> Capture Plant Operating Hours	hours	8,241	8,241	7,915	8,241	8,241	7,543	8,241	8,241	8,241
CO2 Captured	tonne	1 051 145	1,051,145	1,009,574	1,051,145	1,051,145	962,064	1,051,145	1,051,145	1,051,145
Direct Electricity Consumption	MWh	263,716	263,716	253,286	263,716	263,716	241,367	263,716	263,716	263,716
HP Steam Consumption	tonne	5,934	5,934	5,699	5,934	5,934	5,431	5,934	5,934	5,934
LP Steam Consumption	tonne	1 359 785	1,359,785	1.306,008	1,359,785	1,359,785	1,244,549	1,359,785	1,359,785	1,359,785
Power Reduction from LP Steam Consumption	MWh	289,634	289,634	278,180	289,634	289,634	265,089	289,634	289,634	289,634
Hot Water Consumption	tonne		5	•	•	1	'	•	•	•
Cooling Water Consumption	ш² MM	142.90	142.90	137.25	142.90	142.90	130.79	142.90	142.90	142.90
Activated Carbon Disposal	tonne	245.27	245.27	235.57	245.27	245.27	224.49	245.27	245.27	245.27
MEA loss through absorber	tonne	128.40	128.40	123.32	128.40	128.40	117.52	128.40	128.40	128.40
Nitrogen Gas Consumption	ŗ.	36,690	36,690	35,239	36,690	36,690	33,581	36,690	36,690	36,690
Aux Boiler										
Aux Boiler Operating Hours	hours	8,241	8,241	7,915	8,241	8,241	7,543	8,241	8,241	8,241
Additional Fuel Consumption	tonne	5,835	5,835	5,604	5,835	5,835	5,340	5,835	5,835	5,835
Additional Fuel Consumption	ŗ,	6,864,368	6,864,368	6,592,896	6,864,368	6,864,368	6,282,642	6,864,368	6,864,368	6,864,368
Additional Fuel Consumption	MMBTU	257,709	257,709	247,517	257,709	257,709	235,869	257,709	257,709	257,709
Reclaimer										
Reclaimer run frequency (rel to CCC) 6.0%	%									
Reclaimer Operating Hours	hours	494	494	475	494	494	453	494	494	494
Reclaimer MEA Consumption	tonne	60	60	58	60	60	55	60	80	8
Soda Ash Consumption	tonne	11	17	17	17	17	16	17	17	17
Reclaimer Studge Disposal	tonne	85	85	81	85	85	11	85	88	85



1/13/2009, 12:56 PM Karsto Model -F1F9 -V2s.xts

Technical Data Summary pg 1 of 3

	Art
	Jen ,
E	ğ
P	-as-
	ase (
	ö

Technical Jata Summary

2029

2028

2025

2024

2023

Constant Unit

2021

NGCC

NGCC Operating Hours	hours	8,160	8,496	8,496	7,776	8,496	8,496	8,496	8,160	8,496
NGCC Shutdown hours (planned + unplanned)	hours	600	264	264	984	264	264	264	600	264
NGCC other non-operating hours	hours	•	'	•	'	•	•	'	'	•
CO2 Emissions from NGCC	tanne	1,220,162	1,270,403	1,270,403	1,162,742	1,270,403	1,270,403	1,270,403	1,220,162	1,270,403
and the first state of the stat										
Capture Crothing Deat Overation Hours		7 915	8.741	8 241	7 543	8.241	8.241	8.241	7.915	8,241
		1 000 574	1.051.145	1 051 145	067 064	1 051 145	1 051 145	1 051 145	1.009.574	1.051,145
COZ Capinieu		+Jr/200	011 100 I							212 000
Direct Electricity Consumption	ЧWW	253,286	263,716	263,716	241,367	263,716	263,716	263,716	092,562	263,/16
HP Steam Consumption	tonne	5,699	5,934	5,934	5,431	5,934	5,934	5,934	5,699	5,934
LP Steam Consumption	tonne	1,306,008	1,359,785	1,359,785	1,244,549	1,359,785	1,359,785	1,359,785	1,306,008	1,359,785
Power Reduction from LP Steam Consumption	HWM	278,180	289,634	289,634	265,089	289,634	289,634	289,634	278,180	289,634
Hot Water Consumption	tonne	•	'	,	•	•	'		•	'
Cooling Water Consumption	m² MM	137.25	142.90	142.90	130.79	142.90	142.90	142.90	137.25	142.90
Activated Carbon Disposal	tonne	235.57	245.27	245.27	224,49	245.27	245.27	245.27	235.57	245.27
MEA loss through absorber	tonne	123.32	128.40	128.40	117.52	128.40	128.40	128.40	123.32	128.40
Nitrogen Gas Consumption	۶щ	35,239	36,690	36,690	33,581	36,690	36,690	36,690	35,239	36,690
Aux Boiler										
Aux Boiler Operating Hours	hours	7,915	8,241	8,241	7,543	8,241	8,241	8,241	7,915	8,241
Additional Fuel Consumption	tonne	5,604	5,835	5,835	5,340	5,835	5,835	5,835	5,604	5,835
Additional Fuel Consumption	۳	6,592,896	6,864,368	6,864,368	6,282,642	6,864,368	6,864,368	6,864,368	6,592,896	6,864,368
Additional Fuel Consumption	MMBTU	247,517	257,709	257,709	235,869	257,709	257,709	257,709	247,517	257,709
Reclaimer Bodeimer and forencesses / red to CCC' 6 08/	6									
Dedaimer Oneration Marine Cool		A76	404	404	453	494	494	494	475	494
Reclaimer MEA Constitution	torne	85	60	5	55	60	60	09	58	90
Soda Ach Consumption	torna	12	42	1	16	17	17	17	17	17
Reciaimer Studge Disposal	torne	81	85	85	24	85	85	85	81	85



Technical Data Summary pg 2 of 3

1/13/2009, 12:56 PM Karsto Model -F1F9 -V2s.xts

	Art
	Open
(	Cas.
	Base

echnical Jata Summary

nary	
ata Sumi	
nical ut	
Tech	

2030

Constant Unit

2036

2035

# NGCC

NGCC Operating Hours	hours	8,496	7,776	8,496	8,496	8,496	8,160	8,496
NGCC Shutdown hours (planned + unplanned)	hours	264	984	264	264	264	600	264
NGCC other non-operating hours	hours		'		•	•	•	ı
CO2 Emissions from NGCC	tonne	1,270,403	1,162,742	1,270,403	1,270,403	1,270,403	1,220,162	1,270,403
Capture								
Capture Plant Operating Hours	hours	8,241	7,543	8,241	8,241	8,241	7,915	8,241
CO2 Captured	tonne	1 051 145	962,064	1,051,145	1,051,145	1,051,145	1,009,574	1,051,145
Direct Electricity Consumption	MWh	263,716	241,367	263,716	263,716	263,716	253,286	263,716
HP Steam Consumption	tonne	5,934	5,431	5,934	5,934	5,934	5,699	5,934
LP Steam Consumption	tonne	1,359,785	1,244,549	1,359,785	1,359,785	1,359,785	1,306,008	1,359,785
Power Reduction from LP Steam Consumption	MWh	289,634	265,089	289,634	289,634	289,634	278,180	289,634
Hot Water Consumption	tonne		•	•	•	•	•	•
Cooling Water Consumption	rn ^a MM	142.90	130.79	142.90	142.90	142.90	137.25	142.90
Activated Carbon Disposal	tonne	245.27	224.49	245.27	245.27	245.27	235.57	245.27
MEA loss through absorber	tonne	128.40	117.52	128.40	128.40	128.40	123.32	128.40
Nitrogen Gas Consumption	ŗ	36,690	33,581	36,690	36,690	36,690	35,239	36,690
<u>Aux Boller</u>								
Aux Boiler Operating Hours	pours	8,241	7,543	8,241	8,241	8,241	7,915	8,241
Additional Fuel Consumption	tonne	5,835	5,340	5,835	5,835	5,835	5,604	5,835
Additional Fuel Consumption	"" "	6,864,368	6,282,642	6,864,368	6,864,368	6,864,368	6,592,896	6,864,368
Additional Fuel Consumption	MMBTU	257,709	235,869	257,709	257,709	257,709	247,517	257,709
Reclaimer Reclaimer run frequency (rel to CCC) 6.0%	*							
Reclaimer Operating Hours	hours	494	453	494	494	494	475	494
Reclaimer MEA Consumption	tonne	60	55	60	60	60	58	60
Soda Ash Consumption	tonne	17	9	17	17	17	17	17
Reclaimer Studge Disposal	tonne	85	11	85	85	85	81	85



1/13/2009, 12.56 PM Karsto Model -F1F9 -V2s.xts

Technical Data Summary pg 3 of 3 Base Case: Open Art

.

#### Karsto OPEX Summary

	Usage Rate	Usage Time	Unit Price	Annual Cost (NOK 000s
Wtillty consumption	- Distantia - Distant			(11011 0000
Electricity	32.0 MW	8,105 h	450 NOK/MWh	118,714
LP Steam	165 t/h	8,105 h	96 NOKA	128,185
HP Steam	12 t/h	486 h	340 NOK/L	1.984
Natural Gas	708 kg/h	8,105 h	2.06 NOK/ka	11.814
Cooling Water Consumption	17,340 m³/h	8,105 h	0.10 NOK/m*	14.054
Condensate Consumption	12.0 Vh	8,105 h	15.00 NOK/t	1.459
Utility Consumption				274,211
Consumables	110000		the state of the s	110 - 5 - 5
MEA consumption			the state	2.655
MEA lost through absorber	15.6 kg/h	8,105 h	14 310 NOK/t	1.897
MEA consumption from reclaimer	122 0 kg/h	486 h	14 310 NOK/L	045
Soda Ash Cost Consumption	35.0 kg/h	486 h	1,590 NOK/t	27
Nitrogen Gas Cost Consumption	4.45 m³/h	8.105 h	5.30 NOK/m ³	191
Consumables Cost				2,874
Staff		- interior day	and the second	and the second second
Spec Workers	15 people	1 year	775 kNOK/y	11,625
Shift Leaders	5 people	1 year	950 kNOK/y	4.750
Secretaries	1 people	1 year	500 kNOK/y	500
Accounting	9 people	1 year	560 kNOK/v	5.040
Heads of CCC	1 people	<u>1 year</u>	1,200 kNOK/v	1.200
Staff Cost				23,115
Maintenance cost	In the state of the			Contraction of the
Maintenance Cost	n/a	1 vear	55 893 kNOKh	65 R07
			eolone with tay	00,000
Spare and wear parts	The second Miles			All Contraction
Epera Bade	11/8	i year	1,749 KNOK/Y	1,749
<u>Spare and were note</u>	<u>_n/a</u>	<u>1 Vear</u>	<u>11,925 kNOK/y</u>	<u>11,925</u>
"The absorber packing costs will not be the	same every year. See the l	financial model for the	estimated repacking scher	13,674 Jule
Service cost to GASSCO	All and the second second	Sector and		Service Collectores and
Services from GASSCO	n/a	1 year	B,000 kNOK/y	8,000
			4	
Special waste	and the second		The second secon	
Special waste	20 8 kath	8 405 L	2 000 NOVA	70.4
Special waste Activated Carbon Reclaimer Studge	29.8 kg/h	8,105 h	3,000 NOK/t	724
Special waste Activated Carbon Reclaimer Sludge Waste Disposal	29.8 kg/h 171,0 kg/h	8,105 h <u>486 h</u>	3,000 NOK/t 3,000 NOK/t	724 249 973
Special waste Activated Carbon <u>Reclaimer Studge</u> Waste Disposal	29.8 kg/h <u>171,0 kg/h</u>	8,105 h <u>486 h</u>	3,000 NOK/t <u>3,000 NOK/t</u>	724 <u>249</u> 973
Special waste Activated Carbon <u>Reclaimer Sludge</u> Waste Disposal Service Agreement with Näturk To be determined by Gassnova	29.8 kg/h <u>171.0 kg/h</u> iraft	8,105 h <u>486 h</u>	3,000 NOK/t <u>3,000 NOK/t</u>	724 <u>249</u> 973 0
/ Special waste Activated Carbon <u>Reclaimer Studge</u> Waste Disposal Service Agreement with Näturk To be determined by Gassnova	29.8 kg/h <u>171,0 kg/h</u> raft	8,105 h <u>486 h</u>	3,000 NOK/t <u>3,000 NOK/t</u>	724 <u>249</u> 973 0
Activated Carbon Activated Carbon <u>Reclaimer Studge</u> Waste Disposal <u>Service Agreement with Näturk</u> To be determined by Gassnova <u>Taxes</u> by Gassnova	29.8 kg/h <u>171,0 kg/h</u> raft	8,105 h <u>486 h</u>	3,000 NOK/t <u>3,000 NOK/t</u>	724 249 973 0
Activated Carbon <u>Reclaimer Studge</u> Waste Disposal <u>Service Agreement With Näturk</u> To be determined by Gassnova <u>Taxes</u> by Gassnova	29.8 kg/h <u>171,0 kg/h</u> iraft	8,105 h <u>486 h</u>	3,000 NOK/t <u>3,000 NOK/t</u>	724 <u>249</u> 973 0
Activated Carbon Activated Carbon <u>Reclaimer Studge</u> Waste Disposal <u>3 Service Agreement with Näturk</u> To be determined by Gassnova <u>9 Taxes</u> by Gassnova	29.8 kg/h <u>171,0 kg/h</u> rraft	8,105 h <u>486 h</u>	3,000 NOK/t <u>3,000 NOK/t</u>	724 <u>249</u> 973 0
VSpecial waste Activated Carbon <u>Reclaimer Studge</u> Waste Disposal Service Agreement with Naturk To be determined by Gassnova O Taxes by Gassnova	29.8 kg/h <u>171,0 kg/h</u> traft	8,105 h <u>486 h</u>	3,000 NOK/t <u>3,000 NOK/t</u>	724 <u>249</u> 973 0 0
Special waste     Activated Carbon <u>Reclaimer Studge</u> Waste Disposal     Service Agreement with Näturk     To be determined by Gassnova     Taxes     by Gassnova     Land Leasing cost     by Gassnova     10 Cher costs	29.8 kg/h <u>171,0 kg/h</u> rraft	8,105 h <u>486 h</u>	3,000 NOK/t 3,000 NOK/t	724 <u>249</u> 973 0 0 0
Special waste     Activated Carbon <u>Reclaimer Studge</u> Waste Disposal     Service Agreement with Naturk     To be determined by Gassnova     Taxes     by Gassnova     Io Land Leasing cost     by Gassnova     I Other costs     Administration	29.8 kg/h <u>171.0 kg/h</u> rraft n/a	8,105 h <u>486 h</u>	3,000 NOK/t 3.000 NOK/t 10,000 kNOK/y	724 249 973 0 0 0 0
Special waste         Activated Carbon         Reclaimer Sludge         Waste Disposal         Service Agreement with Naturk         To be determined by Gassnova         Taxes         by Gassnova         O Land Leasing cost         by Gassnova         1 Other costs         Administration         2 Total Operating Costs	29.8 kg/h <u>171,0 kg/h</u> raft n/a	8,105 h <u>486 h</u> 1 year	3,000 NOK/t 3,000 NOK/t 3,000 NOK/t 10,000 kNOK/y	724 <u>249</u> 973 0 0 0 0



	Art	
	Den	K 000s
(	ise:	oN ui sa
-	ase C.	All Value
	č	

# Karsto Canon Capture Proiect Financial Statements

			-			Superior						
	Total	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018
CAPITAL COST												
General Indirect	438,227	ı	65,734	153,379	219,114	•	ı	ı	•	•	•	1
Stack Connection	81,965	ı	12,295	28,688	40,983	'	•	•	•	ı	1	1
Flue Gas Condition	135,061	•	20,259	47,271	67,531	•	•	•	•	•	•	1
CO2 Absorption	352,461	•	52,869	123,361	176,231	•	٠	•	•	•	•	1
Solvent Receneration	177,280	ı	26,592	62,048	88,640	•	•	•	•	r	•	٠
CO2 Compression & Canditioning	200.177	•	30,027	70,062	100,089	•	•	•	ı	t	1	•
General Utility Systems	171.240	'	25,686	59,934	85,620	•	,	•	ı	•	r	•
Automation	98.005	,	14.701	34,302	49,003	1	•	•	•	ı	•	•
Chril Work	222,804	•	33.421	77,981	111.402	•	•	'	•	•	٠	•
Main Dawor Supply	358 AQ7	ı	53 774	125.472	179 246	'	٠	•	•	•	1	,
		I	1100	107 002	4 447 856	1	'	1		ı	•	•
Capital Costs	711'007'7	ſ	100,000	ne+(70 )	00011111	•	•	I	,			
OPERALING CUSI												
Consumables & Disposal Cost										020 077	270 007	
Direct Electricity Consumption	2,917,859	ı	ı	•	t	118,672	118,672	113,9/9	118,6/2	118,6/2	CL0'90L	118,0/2
HP Steam Consumption	49,604	•	r	•	ι	2,017	2,017	1,938	2,017	2,017	1,846	110'2
LP Steam Consumption	3,204,630	•	۱	1	•	130,335	130,335	125,181	130,335	130,335	119,290	130,335
Additional Fuel Consumption Cost	295,362	•	•	ı	•	12,013	12,013	11,538	12,013	12,013	10,995	12,013
Hot Water Consumption	•	ı		•	ı	•	•	•	'	ı	1	•
Cooling Water Consumption	351.359	ŀ	,	•	ł	14,290	14,290	13,725	14,290	14,290	13,079	14,290
Hazamone Waste Discosal	24 329	•	,	•	'	989	989	950	989	989	906	989
	56 404		4	ı	ı	2 701	2 701	2 594	2 7N1	2 701	2.472	2.701
Men dat detationing	101-100 743	1 1			1	28	280	26	280	28	25	28
Soua Asin Cost Consumption	110	•	•	•	ı	3					178	104
Nitrogen Gas Cost Consumption	4,/81	ı	ı	•	ŀ		4 A A A	301		401 407 F	1 250	1.483
Condensate Consumption	30,4/3	ı	•	1	,	1,403	20 <b>4</b> .1	C74.1	504°1	70#'T		
Total Consumables & Disposal	6,951,475	•	•	•	•	282,723	282,723	271,542	282,723	282,723	258,764	282,723
	100 000					11 076	11 676	11 CJE	11 E7E	11 675	11 675	11 B25
Spec workers	270'NR7	•	•	•	•	C70'II	070'11		040°			
Shift Leaders	118,750	•	•	•	•	4,750	4,750	4,750	0c/'4	100/ ⁴	4,700	4,73U
Secretaries	12,500	L	1	•	ŀ	200	500	0.09	500	000	1000	
Accounting	126,000	•	•	•	•	5,040	5,040	5,040	5,040	5,040	5,040	5,040
Heads of CCC	30,000	ŀ	1	•	•	1,200	1,200	1,200	1,200	1,200	1,200	1,200
Personnel	577,875	•	•	ı	ı	23,115	23,115	23,115	23,115	23,115	23,115	23,115
O2M												
Compaction GASSCO	200.000	•	0		•	8.000	8,000	8.000	8.000	8.000	8.000	8.000
CELVICS HULL CARGOLO	206 125	. 3	1.01	3		11 025	11 975	11,925	11,925	11.925	11.925	11.925
Aborber Darking	43 725	9				-	-	-	-	984	-	
	1 207 320			8		55 803	55 803	55 803	55 803	55,803	55,893	55,893
Maillictibilice Occurring Majoreneo and Danafa	070' 100' I		•	•	,			010 010	76 848	76 813	75 848	75 918
Орегацой макишлансе анд херан	1,945,170	•	•	•	•	010/07						
Administration & Insurance												
Administration	250,000	£.	n;	r	•	10,000	10,000	10,000	10,000	10,000	10,000	10,000
Insurance		•	•	•	•	ı	•	•	۱	•	•	•
Administration and insurance	250,000	•	×	•	•	10,000	10,000	10,000	10,000	10,000	10,000	10,000
T	0 740 630					227 525	301 666	100 47E	104 GEG	107 GEN	107 CO6	701 666
I otal Uperating Cost	* 12°'2LJ'A		1	,		321,000	000'LAC	200,410	000'100	200,200	000,100	201,000

1/13/2009 12:56 PM, MHM Karsto Model -F1F9 -V2s.xls

Project Financial Statements pg 1 of 6



	2018	(1,772)	389,884	•							
$\bigcirc$	2017	1,846	369,542								
	2016	(74)	392,576								
	2015	(827)	390,829	•							
	2014	827	381,302	ı							
	2013	•	391,656	•							
tapture tements	2012	(28,972)	362,684	•							
Con Con Con Standard	2011	•	1,117,856								
Karsto ( ^P roject Fir	2010	•	782,499	,							
Ľ	2009		335,357	ł							
	2008	٠	·	,							
	Total	•	11,954,232	5,143,044	13						
Base C: Open Art All Values in NOK 000s	MEE OADLI ELOM	<u>NET CASH FLOW</u> Increase in Net Working Capital	Net Cash Flow	NPV of Net Cash Flow							

Project Financial Statements pg 2 of 6

1/13/2009 12:56 PM, MHM Karsto Model -F1F9-v/25.xls

A
E

Project Financial Statements pg 3 of 6

1/13/2009 12:56 P.M. MHM Karsto Model -F1F9 -v2s.xts

(					C							(
Base Case: Open Art				Karsto (	Carpon (	Capture					/	)
	Total	2019	2020	2021	11811CIAL 01 2022	2023	2024	2025	2026	2027	2028	2029
CAPITAL COST					2							
General Indirect	438,227 81 065	• •			• = 2		•••			• •		••
State Commection Filie Gas Condition	135.061		•	•	ş I	1	1	•	•	ı	•	,
CO2 Absorption	352,461	•	•	•	•	•	ı	•	•	•	•	•
Solvent Regeneration	177,280	ı	ı	,	•	•	•	•	•	I	•	•
CO2 Compression & Conditioning	200,177	1	•	•		•	•	•	•		• •	• •
General Utility Systems	171,240	,	12	'	1	C)		•	• •		• •	
Automation Characteria	500,58 608 ccc	¢					• •		• •	• •		
CIVII VYGIK Main Power Stippiv	358,492			•		( <b>•</b>	•	,	•	•	ł	•
Capital Costs	2,235,712	§ •	ं •	•	•	•	•	•	•	ı	•	Ċ
<u>Consumations &amp; Disposal Cost</u> Direct Electricity Consumption	2,917,859	118,672	118,672	113,979	118,672	118,672	108,615	118,672	118,672	118,672	113,979	118,672
HP Steam Consumption	49,604	2,017	2,017	1,938	2,017	2,017	1,846	2,017	2,017	2,017	1,938	2,017
LP Steam Consumption	3,204,630	130,335	130,335	125,181	130,335	130,335	119,290	130,335	130,335	120,335	125,181 11 538	120,335
Additional Fuel Consumption Cast Hof Water Constitution	705'067	-		-		-	-	2 -			-	
Cooling Water Consumption	351,359	14,290	14,290	13,725	14,290	14,290	13,079	14,290	14,290	14,290	13,725	14,290
Hazardous Waste Disposal	24,329	989	989	950	989	888	906	989	989	989	950	989 201
MEA Cost Consumption	66,401	2,701	2,701	2,594	2,701	2,701	2,472	2,701	10/ 2	707,2	2,094 76	10/12
Soda Ash Cost Consumption	677	28	28	26	87	82	C7 7	201	104	104	187	104
Nitrogen Gas Cost Consumption	36.473	1 483	1 483	1475	184	1 483	1 358	1.483	1.483	1.483	1.425	1.483
Total Consumables & Disposal	6,951,475	282,723	282,723	271,542	282,723	282,723	258,764	282,723	282,723	282,723	271,542	282,723
Personnel												
Spec Workers	290,625	11,625	11,625	11,625	11,625	11,625	11,625	11,625	11,625	11,625	11,625	11,625
Shift Leaders	118,750	4,750	4,750	4,750	4,750	4,750	4,750	4,750 500	4,750 500	4,750 500	4,750 500	00/ 4
Secretaries Arrowinsting	12,500	200	000 S	200 5.040	5.040	5.040	5.040	5.040	5.040	5.040	5.040	5.040
Heads of CCC	30,000	1,200	1,200	1,200	1 200	1,200	1,200	1,200	1,200	1,200	1,200	1,200
Personnel	577,875	23,115	23,115	23,115	23,115	23,115	23,115	23,115	23,115	23,115	23,115	23,115
OSAM CAREFORD		000 a	000 0	000 8	000 8	000 8	NOD R		000 8	8 000	8.000	8.000
Spare Parts Usage	298,125	11,925	11,925	11,925	11,925	11,925	11,825	11,925	11,925	11,925	11,925	11,925
Absorber Packing	43,725	•	1	884	•	•	•		38,750			994 1000
Maintenance Operation Maintenance and Repair	1,397,320 1,939,170	55,893 75,818	55,893 7 <b>5,818</b>	55,893 76,812	55,893 75,818	55,893 7 <b>5,818</b>	55,893 75,818	55,893 75,818	55,893 1 <b>15,668</b>	55,818 75,818	75,816	55,883 76,812
<u>Administration &amp; Insurance</u> Administration	250,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000
insurance Administration and insurance	250,000	- 10,000	- 10,000	- 10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000
Total Operating Cost	9,718,520	391,666	391,656	381,469	391,656	391,656	367,6 <del>9</del> 6	391,656	431,406	391,656	380,475	392,650

Base Cas: Open Art All Values in NOK 000s			L	Karsto ( Project Fir	Coon C	apture atements						$\bigcirc$
	Total	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029
NET CASH FLOW Increase in Net Working Capital	٠		•	754	(754)	•	1,772	(1,772)	(2,940)	2,940	827	(106)
Net Cash Flow	11,954,232	391,656	391,656	382,222	390,902	391,656	369,469	389,884	428,466	394,596	381,302	391,749
NPV of Net Cash Flow	5,143,044	,	,	•		•		•	•	•	•	



Project Financial Statements pg 4 of 6

1/12/2009 12:56 PM, MHM Karsto Model -F1F9 -V25,xls

A		
4	B	

Project Financial Statements pg 5 of 6

1/13/2009 12:56 PM MHM Karsto Model -F1F9 -v2s.xls

Base Case: Open Art				Karsto	Carpon	Capture					
All Values in NOK 000s				Project Fi	inancial S	tatements					
	Total	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039
CAPITAL COST											
General Indirect	438,227		1	1		•			÷	ı	•
Stack Connection	81,965	•	•	•	*	•	•	i		•	•
Flue Gas Condition	130,651	1	•	•	•	•	•		•		•
COZ Absorption	352,461	•	•	•		•	•	•			•
Solvent Regeneration	177,280	•	1	•			•		•		•
CU2 Compression & Conditioning	1/1,002			•			•	•	•		•
General Utility Systems	171,240	•	•		¢		•		•		•
Automation	98,005	•	•	•	1		•			•	•
Civil Work	222,804	,	•	•		•	i,		è		i.
Main Power Supply	358,492	•	•	•	•		•	•			•
Capital Costs	2,235,712	•	•	•		•	•	•	•	•	•
OPERATING COST											
Consumations & UISPOSAL COST	2 017 A50	11R 672	108 615	118 G72	118 672	118 672	113 979	118 672	•	•	,
HP Steam Consumption	49.604	2.017	1,846	2.017	2.017	2,017	1.938	2,017	4	•	•
LP Steam Consumption	3,204,630	130,335	119,290	130,335	130,335	130,335	125,181	130,335	•		•
Additional Fuel Consumption Cost	295,362	12,013	10,995	12,013	12,013	12,013	11,538	12,013	•		•
Hot Water Consumption			•	'	•	,	•	1	•	•	•
Cooling Water Consumption	351,359	14,290	13,079	14,290	14,290	14,290	13,725	14,290	•	•	•
Hazardous Waste Disposal	24,329	989	906	689	989	989	950	989	ē,		•
MEA Cost Consumption	66,401	2,701	2,472	2,701	2,701	2,701	2,594	2,701	,	•	•
Soda Ash Cost Consumption	677	28	25	28	28	28	26	28	•	•	*
Nitrogen Gas Cost Consumption	4,781	194	178	194	194	194	187	194	•		•
Condensate Consumption	36,473	1,483	1,358	1,483	1,483	1,483	1,425	1,483	•	•	•
Total Consumables & Disposal	6,951,475	282,723	258,764	282,723	282,723	282,723	271,542	282,723	•	•	•
Personnel											
Spec Workers	290,625	11,625	11,625	11,625	11,625	11,625	11,625	11,625	ı		•
Shift Leaders	118,750	4,750	4,750	4,750	4,750	4,750	4,750	4,750	•	•	•
Secretaries	12,500	500	500	500	500	500	200	200	•	•	•
Accounting	126,000	5,040	5,040	5.040	5,040	5,040	5,040	5,040		•	•
Heads of CCC	30,000	1,200	1,200	1,200	1,200	1,200	1,200	1,200	•	•	•
rersonnel	G/9'//G	411,22	23,115	GLL'6Z	611,62	ett,82	ort,62	err,62	•	•	•
OSM						000 0	0000	0000			
	200 400		0,000	0,000	0,000 14	0,000	200	0'NUN		•	•
Spare Marks Usage Absorbs Daskins	C21,082	C78 1	076 11	076'11	C76'11	CZR'II	C7R'I I	C78'11			
Mainterrance	1 207 220	22 201	200 22	55 803		55 802	55 002	EE 802		•	
Maintanance Oneration Maintenance and Renair	1939.170	75,818	75 818	75 818	76 817	75 818	75,818	75,848			•
											I
<u>Administration &amp; Insurance</u> Administration	250.000	10.000	10.000	10.000	10.000	10.000	10.000	10.000			
Insurance	•	•	1	1		•	•	•		•	•
Administration and insurance	250,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	•	•	•
Total Oneration Cost	9 718 520	201 66G	767 696	201 656	207 GED	101 556	TRN A75	101 EKG			
Index Bitaminal Signal	211 10,044	2021122	222,102	0001100	006,000	201,000	011-000	20100			
	2039		•								
----------------------------------------------------	-------	---------------------------------------------------------	---------------	----------------------	----------------------------------------------	----------------------------------------------------					
	2038		ı	ı							
Karsto Con Capture Project Financial Statements	2037		ı	•							
	2036	28,145	419,801								
	2035	827	381,302								
	2034	74	391,729	•		of 6					
	2033	(74)	392,576	•		Statements pg 5					
	2032	(1,772)	389,884	•		Project Hinancial					
	2031	1,772	369,469	•							
	2030	74	391,729								
	Total	đ	11,954,232	5,143,044							
Base C:: Open Art All Values in NOK 000s		<u>NET CASH FLOW</u> Increase in Net Working Capital	Net Cash Flow	NPV of Net Cash Flow	11132008 1256 PM, MHM Michael 256 PM, AHM	Bitti Bitti A an an an an an an ann anns anns anns					



Sech horizontal bar represents the change in the total cost for a change in a specific input variable. For example, the electricity price row, which is labeled as 450 NOK/MWh (+/- 20%), shows the total cost when the electricity price is set to \$360, 450, and 540 NOK. Each bar is independent of other bars, therefore the base case total cost is the same for every variable. Because Capacity Factor and Reclaimer Use Frequency are already in units of percent, they are treated slightly differently. For example a 60% +/- 20% range would be treated as 40% to 80% instead of 48% to 72%.

*LP steam price is based on the power reduction factor and the electricity price.

** Reclaimer Usage Frequency refers how often the reclaimer must be run, and affect the use of HP steam, MEA, and soda ash:



The horizontal bar represents the change in the unit cost for a change in a specific input variable. For example, the electricity price row, which is labeled as NOK/MWh (+/- 20%), shows the unit cost when the electricity price is set to 360, 450, and 540 NOK. Each bar is independent of other bars, therefore the base case unit cost is the same for every variable. Because Capacity Factor and Reclaimer Use Frequency are already in units of percent, they are treated slightly differently. For example a 60% +/- 20% range would be treated as 40% to 80% instead of 46% to 72%.

*LP steam price is based on the power reduction factor and the electricity price

** Reclaimer Usage Frequency refers how often the reclaimer must be run, and affect the use of HP steam, MEA, and soda ash.